



Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. **PA0033294**
APS ID **1127214**
Authorization ID **1509179**

Applicant and Facility Information

| | | | |
|---------------------------|------------------------------------------------------------------------------|------------------|-------------------------------------------|
| Applicant Name | South Franklin Township | Facility Name | Franklin Manor STP |
| Applicant Address | 100 Municipal Road Washington, PA 15301-9000 | Facility Address | 70 Security Drive Washington, PA 15301 |
| Applicant Contact | Tyler Linick | Facility Contact | Same as Applicant |
| Applicant Phone | 724.225.4828 | Facility Phone | Same as Applicant |
| Client ID | 92076 | Site ID | 252733 |
| Ch 94 Load Status | | Municipality | South Franklin Township |
| Connection Status | | County | Washington |
| Date Application Received | November 26, 2024 | EPA Waived? | Yes |
| Date Application Accepted | | If No, Reason | |
| Purpose of Application | Application for a renewal of an NPDES permit for discharge of treated Sewage | | |

Summary of Review

Introduction

The Authority has applied for the renewal of NPDES Permit No. PA0033294, which was previously issued on May 20, 2020, and expired on May 31, 2025.

Facility Overview

WQM Permit No. 6384416 authorized construction of a STP and has an annual average design flow of 0.06 MGD. The design organic capacity of the STP is 145 lbs/day.

Secondary treatment is provided by an existing facility consisting of a bar screen, flow equalization, two aeration tanks, two final clarifiers, and aerated sludge holding tanks. UV is used for disinfection prior to discharge (Outfall 001) to UNT to Chartiers Creek, which is designated as a Warm Water Fishery (WWF) per 25 Pa. Chapter 93 Designated Use, located in State Watershed 20-F.

The renewal application does not list any industrial contributors to the sewer system.

Summary of Changes Since Last Permit Issuance

- Flow monitoring changed from 2/month to 1/week
- Effluent TRC limits removed
- UV monitoring added
- *E. Coli* monitoring added

| Approve | Deny | Signatures | Date |
|---------|------|---------------------------------------------------------------------|------------------|
| X | | William C. Mitchell, E.I.T. / Project Manager | October 30, 2025 |
| X | | Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineering Manager | October 31, 2025 |

Summary of Review

- Total Aluminum, Total Iron, and Total Manganese monitoring added

Sludge use and disposal description and location(s): All sludge is hauled to Hapchuk Incorporated. Application data indicates that the STP does not receive any hauled in waste.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Discharge, Receiving Waters and Water Supply Information | | | |
|----------------------------------------------------------|--------------------------------------------|------------------------------|----------------------------------------------|
| Outfall No. | 001 | Design Flow (MGD) | 0.06 |
| Latitude | 40° 6' 18.00" | Longitude | -80° 17' 36.00" |
| Quad Name | Prosperity | Quad Code | 1803 |
| Wastewater Description: | Sewage Effluent | | |
| Receiving Waters | Unnamed Tributary to Chartiers Creek (WWF) | Stream Code | 37159 |
| NHD Com ID | 99694836 | RMI | 0.05 |
| Drainage Area | 0.3 | Yield (cfs/mi ²) | 0.006 |
| Q ₇₋₁₀ Flow (cfs) | 0.0019 | Q ₇₋₁₀ Basis | USGS StreamStats Report |
| Elevation (ft) | 1106 | Slope (ft/ft) | 0.03479 |
| Watershed No. | 20-F | Chapter 93 Class. | WWF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | NONE | Exceptions to Criteria | NONE |
| Assessment Status | Not Assessed | | |
| Cause(s) of Impairment | | | |
| Source(s) of Impairment | | | |
| TMDL Status | Final, Final | Name | Chartiers Creek, & Chartiers Creek Watershed |
| Background/Ambient Data | Data Source | | |
| pH (SU) | | | |
| Temperature (°F) | | | |
| Hardness (mg/L) | | | |
| Other: | | | |
| Nearest Downstream Public Water Supply Intake | West View Water Authority – Neville Island | | |
| PWS Waters | Ohio River | Flow at Intake (cfs) | 4,730 |
| PWS RMI | 976.1 | Distance from Outfall (mi) | Over 25 Miles |

Changes Since Last Permit Issuance: UV replaces TRC for disinfection purposes.

Other Comments:

The discharge is to an UNT to Chartiers Creek, which flows into the Chartiers Creek Watershed that has an EPA Approved TMDL and is impaired by PCBs and Chlordane. No WLAs have been developed for this sewage discharge, as neither PCB nor Chlordane is typically found in sewage but instead found in legacy sediments. Monitoring for these pollutants will not be required at this time.

The discharge is to an UNT to Chartiers Creek, which flows into the Chartiers Creek Watershed that has a Final TMDL and is impaired by metals and pH. This sewage discharge is not expected to contribute to the stream impairment for which abandoned mine drainage is source of such impairment. No WLAs have been developed for this sewage discharge, and they are not expected to contribute to the stream impairment for these pollutants. 1/year Monitoring for total aluminum, total iron, and total manganese will be imposed on this sewage discharge and the results will be evaluated during the next renewal cycle to ensure that the discharge is not contributing to stream impairment.

| Treatment Facility Summary | | | | |
|----------------------------------------------------|----------------------------|----------------------|----------------------|------------------------------------------------|
| Treatment Facility Name: Franklin Manor STP | | | | |
| WQM Permit No. | | Issuance Date | | |
| 6384416 | | 05/23/1986 | | |
| 6384416 A-1 | | 6/5/1990 | | |
| 6384416 A-2 | | 3/8/2007 | | |
| 6384416 A-3 | | 9/23/2021 | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Activated Sludge | Ultraviolet | 0.06 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.06 | 145 | | Aerated Holding Tank | Pumped and hauled to an approved disposal site |

Changes Since Last Permit Issuance: UV replaces TRC for disinfection purposes.

Other Comments: N/A

Compliance History

DMR Data for Outfall 001 (from September 1, 2024 to August 31, 2025)

| Parameter | AUG-25 | JUL-25 | JUN-25 | MAY-25 | APR-25 | MAR-25 | FEB-25 | JAN-25 | DEC-24 | NOV-24 | OCT-24 | SEP-24 |
|------------------------------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.018 | 0.022 | 0.024 | 0.039 | 0.038 | 0.023 | 0.018 | 0.018 | 0.016 | 0.017 | 0.013 | 0.013 |
| pH (S.U.) Instantaneous Minimum | 7.0 | 7.0 | 6.9 | 6.9 | 6.9 | 7.0 | 6.9 | 6.9 | 6.9 | 7.0 | 6.9 | 6.9 |
| pH (S.U.) Daily Maximum | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.1 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 |
| DO (mg/L) Instantaneous Minimum | 6.2 | 6.3 | 6.2 | 6.6 | 6.5 | 6.2 | 5.8 | 5.6 | 5.4 | 5.9 | 5.6 | 6.0 |
| TRC (mg/L) Average Monthly | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 |
| TRC (mg/L) Instantaneous Maximum | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 | < 0.01 |
| CBOD5 (mg/L) Average Monthly | 3.6 | < 2.0 | 3.5 | 5.05 | 2.2 | 4.8 | < 2.0 | 2.3 | 2.0 | < 2.0 | 3.35 | 7.3 |
| CBOD5 (mg/L) Instantaneous Maximum | 4.1 | < 2.0 | 5.0 | 6.0 | 2.4 | 6.4 | 2.0 | 2.3 | 2.0 | < 2.0 | 4.4 | 10.0 |
| TSS (mg/L) Average Monthly | 6.0 | 5.5 | 6.0 | 5.5 | 5.5 | 17.0 | 14.5 | 13.5 | 9.0 | < 5.0 | 7.5 | < 5.0 |
| TSS (mg/L) Instantaneous Maximum | 7.0 | 6.0 | 7.0 | 6.0 | 6.0 | 22.0 | 21.0 | 22.0 | 9.0 | < 5.0 | 9.0 | < 5.0 |
| Fecal Coliform (No./100 ml) Geometric Mean | 11 | 3 | 2 | 12 | 92 | 2 | 11 | 13 | 2 | 2 | 2 | 2 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 121 | 8 | 2 | 151 | 186 | 2 | 124 | 173 | 2 | 2 | 2 | 2 |
| Total Nitrogen (mg/L) Daily Maximum | | | | | | | | | 29.98 | | | |
| Ammonia (mg/L) Average Monthly | 0.55 | 0.55 | 0.2 | 0.85 | 0.2 | 0.5 | 0.25 | 0.6 | 1.65 | 0.6 | 0.95 | 1.6 |

NPDES Permit Fact Sheet
Franklin Manor STP

NPDES Permit No. PA0033294

| | | | | | | | | | | | | |
|---------------------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Ammonia (mg/L) Instantaneous Maximum | 0.7 | 0.6 | 0.3 | 0.9 | 0.3 | 0.9 | 0.3 | 1.1 | 3.2 | 0.6 | 1.2 | 2.2 |
| Total Phosphorus (mg/L) Daily Maximum | | | | | | | | | 5.2 | | | |

Compliance History

Operations Compliance Check Summary Report

Facility: Franklin Manor STP

NPDES Permit No.: PA0033294

Compliance Review Period: 10/1/20-10/1/25

Inspection Summary:

| INSPECTED DATE | INSP TYPE | AGENCY | INSPECTION RESULT DESC |
|-----------------------|----------------------------|-------------------------------------|-------------------------------|
| 07/18/2025 | Chapter 94 Inspection | PA Dept of Environmental Protection | Administratively Closed |
| 07/15/2021 | Administrative/File Review | PA Dept of Environmental Protection | No Violations Noted |
| 07/15/2021 | Compliance Evaluation | PA Dept of Environmental Protection | No Violations Noted |

Violation Summary:

No violations noted during review period

Open Violations by Client ID:

No open violations for Client ID 92076

Enforcement Summary:

No enforcements executed during review period

Effluent Violation Summary:

| MON PD | PARAMETER | REPORTED VALUE | PERMIT LIMIT | UNIT | STAT BASE CODE |
|---------------|------------------|-----------------------|---------------------|-------------|-----------------------|
| Sep-24 | Ammonia-Nitrogen | 1.6 | 1.4 | mg/L | Average Monthly |
| Jun-23 | Fecal Coliform | 207 | 200 | No./100 ml | Geometric Mean |
| Jan-22 | Ammonia-Nitrogen | 5.1 | 2.8 | mg/L | Average Monthly |

Unauthorized Discharges:

No unauthorized discharges reported in eDMR during review period

Compliance Status: Facility is in general compliance with no open violations or pending enforcements.

Completed by: Amanda Illar **Completed date:** 10/1/25

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 6' 18.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .06
Longitude -80° 17' 36.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Comments: The discharge was evaluated using WQM 7.0 Version 1.1 (Attachments 2 & 3) to evaluate CBOD₅, Ammonia-Nitrogen, and Dissolved Oxygen. The modeling results show the above technology based effluent limitations are appropriate for CBOD₅, TSS, pH, and Fecal Coliform. Due to anti-backsliding, the previously permitted limit for CBOD₅ of 10 mg/L will be re-imposed, which was based upon regulations, guidance, and models that were valid at the time of permit issuance.

To determine applicability of standards associated with dry streams, application managers will generally consider the following:

1. If the stream flow (Q7-10) to wastewater flow (design flow) ratio is less than 3:1, proceed to paragraph 2, otherwise skip to the next section.
2. For new or expanding discharges, apply the more stringent treatment requirements in DEP's Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers (391-2000-014).
3. For existing discharges, if the more stringent treatment requirements cannot be achieved, do not apply the standards in DEP guidance (391-2000-014) unless the receiving stream is impaired, and the point source discharge contributes to the impairment. If this is the case, apply the more stringent treatment requirements and provide a schedule to meet final limitations not exceeding three years in the draft permit. Do not approve design flow increases without applying the more stringent treatment requirements where the discharge meets the criteria in the guidance for a dry stream.

DMR data confirms the existing facility cannot meet the more stringent treatment requirements discussed in DEP guidance (391-2000-014) and the receiving stream is not impaired. Do not approve design flow increases without applying the more stringent treatment requirements where the discharge meets the criteria in the guidance for a dry stream (Section I.C, SOP No. BCW-PMT-033, Establishing Effluent Limitations for Individual Sewage Permits).

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

| Parameter | Limit (mg/l) | SBC | Model |
|------------------------------------|--------------|-----------------|---------------------|
| Ammonia-Nitrogen Nov 1 - Apr 30 | 2.84 | Average Monthly | WQM 7.0 Version 1.1 |
| Ammonia-Nitrogen May 1 - Oct 31 | 1.92 | Average Monthly | WQM 7.0 Version 1.1 |
| Dissolved Oxygen | 5.0 | Inst Min | WQM 7.0 Version 1.1 |

Due to anti-backsliding, the previously permitted limits for ammonia-nitrogen (Nov 1 to Apr 30) of 2.8 mg/L and ammonia-nitrogen (May 1 to Oct 31) of 1.4 mg/L will be re-imposed. These limits were based upon regulations, guidance, and models that were valid at the time of permit issuance.

Best Professional Judgment (BPJ) Limitations

N/A

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (l) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The facility is not seeking to revise the previously permitted effluent limits.

Additional Considerations

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits (Document No. 386-0400-001).

Ultraviolet (UV) disinfection will replace the existing chlorine system and UV monitoring is required. Part A will contain, at a minimum, routine monitoring of UV transmittance (%) at the same monitoring frequency that would be used for TRC per Section I.A, Note 4, SOP No. BCW-PMT-033, Establishing Effluent Limitations for Individual Sewage Permits.

Sewage dischargers will include monitoring, at a minimum, for E. Coli, in new and reissued permits, with a monitoring frequency of 1/quarter for design flows ≥ 0.05 and < 1.0 MGD per 25 Pa. Code § 92a.061, and Section I.A, Note 12, SOP No. BCW-PMT-033, Establishing Effluent Limitations for Individual Sewage Permits.

Nutrient monitoring is required to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). The discharge is to waters not impaired for nutrients. A 1/year monitoring requirement for Total N & Total P has been added to the permit per 25 Pa. Code § 92a.061, and Section I.A, Note 7 & 8, SOP No. BCW-PMT-033, Establishing Effluent Limitations for Individual Sewage Permits.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|-----------------------------------------------|-------------------------------------|------------------|-----------------------|--------------------|---------|------------------|-------------------------------------------------|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | 1/week | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | 5.0 Inst Min | XXX | XXX | XXX | 1/day | Grab |
| CBOD5 | XXX | XXX | XXX | 10 | XXX | 20 | 2/month | Grab |
| TSS | XXX | XXX | XXX | 25 | XXX | 50 | 2/month | Grab |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 2/month | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/quarter | Grab |
| UV light transmittance (%) | XXX | XXX | Report | XXX | XXX | XXX | 1/day | Measured |
| Total Nitrogen | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Grab |
| Ammonia-Nitrogen Nov 1 - Apr 30 | XXX | XXX | XXX | 2.8 | XXX | 5.6 | 2/month | Grab |
| Ammonia-Nitrogen May 1 - Oct 31 | XXX | XXX | XXX | 1.4 | XXX | 2.8 | 2/month | Grab |
| Total Phosphorus | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Grab |

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------|-------------------------------------|----------------|-----------------------|-----------------|------------------|------------------|-------------------------------------------------|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Aluminum, Total | XXX | XXX | XXX | XXX | Report Daily Max | XXX | 1/year | Grab |
| Iron, Total | XXX | XXX | XXX | XXX | Report Daily Max | XXX | 1/year | Grab |
| Manganese, Total | XXX | XXX | XXX | XXX | Report Daily Max | XXX | 1/year | Grab |

Compliance Sampling Location: Outfall 001

Attachment 1 – USGS StreamStats


PA0033294 - StreamStats Report

Region ID: PA

Workspace ID: PA20251002182711662000

Clicked Point (Latitude, Longitude): 40.10517, -80.29291

Time: 2025-10-02 14:27:32 -0400



 [Collapse All](#)

► Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|-----------------------------------------|-------|--------------|
| DRNAREA | Area that drains to a point on a stream | 0.3 | square miles |
| ELEV | Mean Basin Elevation | 1247 | feet |

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|----------------------|-------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 0.3 | square miles | 2.26 | 1400 |
| ELEV | Mean Basin Elevation | 1247 | feet | 1050 | 2580 |

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

| Statistic | Value | Unit |
|-------------------------|---------|--------|
| 7 Day 2 Year Low Flow | 0.00736 | ft^3/s |
| 30 Day 2 Year Low Flow | 0.015 | ft^3/s |
| 7 Day 10 Year Low Flow | 0.0019 | ft^3/s |
| 30 Day 10 Year Low Flow | 0.00448 | ft^3/s |
| 90 Day 10 Year Low Flow | 0.00979 | ft^3/s |

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.3

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Attachment 2 – WQM 7.0 v.1.1 Summer Period

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 20F | 37159 | Trib 37159 to Chartiers Creek | 0.050 | 1106.00 | 0.30 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | pH | Stream Temp (°C) | pH |
|--------------|---------------|--------------------|----------------------|-------------------------|-----------------------|----------|-------------------|-------------------|------------------------|------|---------------------|------|
| Q7-10 | 0.006 | 0.00 | 0.00 | 0.000 | 0.000 | 10.0 | 0.00 | 0.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | | |
|------------------|--|---------------|--------------------------|---------------------------|------------------------|--------------------|----------------|---------|
| Name | | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| Franklin Manor | | PA0033294 | 0.0600 | 0.0000 | 0.0000 | 0.000 | 20.00 | 7.00 |
| Parameter Data | | | | | | | | |
| Parameter Name | | | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | |
| CBOD5 | | | 25.00 | 2.00 | 0.00 | 1.50 | | |
| Dissolved Oxygen | | | 3.00 | 8.38 | 0.00 | 0.00 | | |
| NH3-N | | | 25.00 | 0.00 | 0.00 | 0.70 | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | | RMI | Elevation | Drainage Area | Slope | PWS Withdrawal | Apply FC |
|-----------------------|------------------|-------------------------------|-----------------------------|------------------------------|---------------------------|-----------------------|-------------------|------------------------|-------------------------------------|
| | | | | (ft) | (sq mi) | (ft/ft) | (mgd) | | |
| 20F | 37159 | Trib 37159 to Chartiers Creek | | 0.001 | 1097.00 | 0.31 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |
| Stream Data | | | | | | | | | |
| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio (ft) | Rch Width (ft) | Tributary Temp (°C) | Stream Temp (°C) |
| Q7-10 | 0.006 | 0.00 | 0.00 | 0.000 | 0.000 | 10.0 | 0.00 | 0.00 | 25.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | 7.00 | 0.00 |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | 0.00 |
| Discharge Data | | | | | | | | | |
| | Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH | |
| | | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 | |
| Parameter Data | | | | | | | | | |
| | Parameter Name | | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | | |
| | CBOD5 | | 25.00 | 2.00 | 0.00 | 1.50 | | | |
| | Dissolved Oxygen | | 3.00 | 8.24 | 0.00 | 0.00 | | | |
| | NH3-N | | 25.00 | 0.00 | 0.00 | 0.70 | | | |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | | | | | | |
|--------------------|-------------|--------------------|-----------------|-------------------------------|-------------|-------|-------|-----------|----------|-----------------|---------------|-------------|
| 20F | | 37159 | | Trib 37159 to Chartiers Creek | | | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
| | (cfs) | (cfs) | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | |
| Q7-10 Flow | | | | | | | | | | | | |
| 0.050 | 0.00 | 0.00 | 0.00 | .0928 | 0.03479 | .362 | 3.04 | 8.39 | 0.09 | 0.035 | 20.10 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 0.050 | 0.00 | 0.00 | 0.00 | .0928 | 0.03479 | NA | NA | NA | 0.09 | 0.035 | 20.06 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 0.050 | 0.00 | 0.00 | 0.00 | .0928 | 0.03479 | NA | NA | NA | 0.09 | 0.035 | 20.13 | 7.00 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 5 | | |

WQM 7.0 Wasteload Allocations

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
|------------------|--------------------|-------------------------------|
| 20F | 37159 | Trib 37159 to Chartiers Creek |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 0.050 | Franklin Manor | 16.67 | 16.89 | 16.67 | 16.89 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 0.050 | Franklin Manor | 1.87 | 1.92 | 1.87 | 1.92 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | CBOD5 | | NH3-N | | Dissolved Oxygen | | Critical Reach | Percent Reduction |
|------|----------------|-----------------|-----------------|-----------------|-----------------|------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 0.05 | Franklin Manor | 25 | 25 | 1.92 | 1.92 | 5 | 5 | 0 | 0 |

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|-----------------|----------------|
| 20F | 37159 | Trib 37159 to Chartiers Creek | | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> | | |
| 0.050 | 0.060 | 20.100 | 7.000 | | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> | | |
| 3.041 | 0.362 | 8.389 | 0.086 | | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> | | |
| 24.54 | 1.497 | 1.88 | 0.705 | | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> | | |
| 5.067 | 27.461 | Owens | 5 | | |
| <u>Reach Travel Time (days)</u> | | <u>Subreach</u> | <u>Results</u> | | |
| 0.035 | | TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) |
| | | 0.003 | 24.41 | 1.88 | 5.24 |
| | | 0.007 | 24.29 | 1.87 | 5.39 |
| | | 0.010 | 24.16 | 1.87 | 5.53 |
| | | 0.014 | 24.03 | 1.87 | 5.66 |
| | | 0.017 | 23.91 | 1.86 | 5.78 |
| | | 0.021 | 23.78 | 1.86 | 5.89 |
| | | 0.024 | 23.66 | 1.85 | 5.98 |
| | | 0.028 | 23.53 | 1.85 | 6.08 |
| | | 0.031 | 23.41 | 1.84 | 6.16 |
| | | 0.035 | 23.29 | 1.84 | 6.24 |

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|------------------|--------------------|-------------------------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 20F | 37159 | Trib 37159 to Chartiers Creek | | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 0.050 | Franklin Manor | PA0033294 | 0.060 | CBOD5 | 25 | | |
| | | | | NH3-N | 1.92 | 3.84 | |
| | | | | Dissolved Oxygen | | | 5 |

Attachment 3 – WQM 7.0 v.1.1 Winter Period

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 20F | 37159 | Trib 37159 to Chartiers Creek | 0.050 | 1106.00 | 0.30 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | pH | Stream Temp (°C) | pH |
|--------------|---------------|--------------------|----------------------|-------------------------|-----------------------|----------|-------------------|-------------------|------------------------|------|---------------------|------|
| Q7-10 | 0.013 | 0.00 | 0.00 | 0.000 | 0.000 | 10.0 | 0.00 | 0.00 | 5.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|------------------|--|------------------|--------------------------|---------------------------|------------------------|----------------|----------------|
| Name | | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) |
| Franklin Manor | | PA0033294 | 0.0600 | 0.0000 | 0.0000 | 0.000 | 15.00 |
| Parameter Data | | | | | | | |
| Parameter Name | | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | |
| CBOD5 | | 25.00 | 2.00 | 0.00 | 1.50 | | |
| Dissolved Oxygen | | 3.00 | 12.80 | 0.00 | 0.00 | | |
| NH3-N | | 25.00 | 0.00 | 0.00 | 0.70 | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 20F | 37159 | Trib 37159 to Chartiers Creek | 0.001 | 1097.00 | 0.31 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | Stream pH | Temp (°C) | pH |
|--------------|--------|-----------|-------------|----------------------|--------------------|----------|----------------|----------------|---------------------|-----------|-----------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.013 | 0.00 | 0.00 | 0.000 | 0.000 | 10.0 | 0.00 | 0.00 | 5.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|------------------|---------------|--------------------------|---------------------------|------------------------|--------------------|----------------|---------|
| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |
| Parameter Data | | | | | | | |
| Parameter Name | | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | |
| CBOD5 | | 25.00 | 2.00 | 0.00 | 1.50 | | |
| Dissolved Oxygen | | 3.00 | 8.24 | 0.00 | 0.00 | | |
| NH3-N | | 25.00 | 0.00 | 0.00 | 0.70 | | |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | | <u>Stream Code</u> | | | <u>Stream Name</u> | | | | | | |
|--------------------|-------------|----------|--------------------|--------------------|-------------|-------------------------------|-------|-----------|----------|-----------------|---------------|-------------|
| 20F | | | 37159 | | | Trib 37159 to Chartiers Creek | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
| | (cfs) | (cfs) | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | |
| Q7-10 Flow | | | | | | | | | | | | |
| 0.050 | 0.00 | 0.00 | 0.00 | .0928 | 0.03479 | .364 | 3.06 | 8.4 | 0.09 | 0.034 | 14.61 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 0.050 | 0.00 | 0.00 | 0.00 | .0928 | 0.03479 | NA | NA | NA | 0.09 | 0.035 | 14.75 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 0.050 | 0.01 | 0.00 | 0.01 | .0928 | 0.03479 | NA | NA | NA | 0.09 | 0.034 | 14.48 | 7.00 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 5 | | |

WQM 7.0 Wasteload Allocations

| SWP Basin | Stream Code | Stream Name |
|-----------|-------------|-------------------------------|
| 20F | 37159 | Trib 37159 to Chartiers Creek |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-----|----------------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| | 0.050 Franklin Manor | 24.1 | 24.73 | 24.1 | 24.73 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-----|----------------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| | 0.050 Franklin Manor | 2.69 | 2.84 | 2.69 | 2.84 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|-----|---------------------|-----------------|-----------------|-----------------|-----------------|-------------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| | 0.05 Franklin Manor | 25 | 25 | 2.84 | 2.84 | 5 | 5 | 0 | 0 |

WQM 7.0 D.O. Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|-------------|
| 20F | 37159 | Trib 37159 to Chartiers Creek | | |
| <hr/> | | | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> | |
| 0.050 | 0.060 | 14.609 | 7.000 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> | |
| 3.056 | 0.364 | 8.402 | 0.087 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> | |
| 24.10 | 1.495 | 2.73 | 0.462 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> | |
| 5.305 | 24.129 | Owens | 5 | |
| <u>Reach Travel Time (days)</u> | Subreach Results | | | |
| 0.034 | TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) |
| | 0.003 | 24.00 | 2.73 | 5.54 |
| | 0.007 | 23.91 | 2.72 | 5.75 |
| | 0.010 | 23.81 | 2.72 | 5.95 |
| | 0.014 | 23.72 | 2.72 | 6.13 |
| | 0.017 | 23.62 | 2.71 | 6.30 |
| | 0.021 | 23.53 | 2.71 | 6.45 |
| | 0.024 | 23.43 | 2.70 | 6.59 |
| | 0.028 | 23.34 | 2.70 | 6.73 |
| | 0.031 | 23.24 | 2.69 | 6.85 |
| | 0.034 | 23.15 | 2.69 | 6.96 |

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|------------------|--------------------|-------------------------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 20F | 37159 | Trib 37159 to Chartiers Creek | | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 0.050 | Franklin Manor | PA0033294 | 0.060 | CBOD5 | 25 | | |
| | | | | NH3-N | 2.84 | 5.68 | |
| | | | | Dissolved Oxygen | | | 5 |