

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0033588  
 APS ID 1009305  
 Authorization ID 1301689

**Applicant and Facility Information**

Applicant Name	<u>Country Estates MHP, LLC</u>	Facility Name	<u>Country Estates MHP</u>
Applicant Address	<u>378 Red Bank Road</u> <u>Mifflinburg, PA 17844</u>	Facility Address	<u>1011 South Lake Road</u> <u>Mercer, PA 16137</u>
Applicant Contact	<u>James Bender, Owner</u>	Facility Contact	<u>Marvin McAfoose, STP Operator</u>
Applicant Phone	<u>(570) 412-6039</u>	Facility Phone	<u>(724) 699-4070</u>
Client ID	<u>287851</u>	Site ID	<u>247520</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Jefferson Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Mercer County</u>
Date Application Received	<u>January 2, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 14, 2020</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater.</u>		

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.  
 A Part II Water Quality Management permit is not required at this time.  
 The applicant should be able to continue to meet the limits of this permit, which will continue to protect the uses of the receiving stream.

**I. OTHER REQUIREMENTS:**

- A. Stormwater into Sewers
- B. Right of Way
- C. Solids Handling
- D. Effluent Chlorine Optimization and Minimization
- E. Little or No Assimilative Capacity or Dilution

**SPECIAL CONDITIONS:**

- II. Solids Management

There are 4 open violations in efacts associated with the subject Client ID (287851) as of 11/17/2020 (see Attachment 4).

Approve	Deny	Signatures	Date
X		Stephen A. McCauley	11/17/2020
		Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	
X		Justin C. Dickey	12/7/2020
		Justin C. Dickey, P.E. / Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.015</u>
Latitude	<u>41° 15' 9.00"</u>	Longitude	<u>-80° 16' 40.00"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to the Lackawannock Creek (TSF)</u>	Stream Code	<u>N/A</u>
NHD Com ID	<u>130025760</u>	RMI	<u>N/A</u>
Drainage Area	<u>1.51 (point of first use)</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.151</u>	Q <sub>7-10</sub> Basis	<u>calculated</u>
Elevation (ft)	<u>1029</u>	Slope (ft/ft)	<u>0.01755</u>
Watershed No.	<u>20-A</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Aqua Pennsylvania, Inc. - Shenango Valley</u>		
PWS Waters	<u>Shenango River</u>	Flow at Intake (cfs)	<u>97.0</u>
PWS RMI	<u>30.0</u>	Distance from Outfall (mi)	<u>19.0</u>

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.015 MGD of treated sewage from a non-Municipal STP in Jefferson Township, Mercer County.

Treatment permitted under WQM Permit 4373402 consists of: A manual bar screen, a comminutor, three 15,000 gallon aeration tanks in series, alum chemical addition for phosphorus control, a 3,000 gallon sludge holding tank, a 1,567 gallon

clarifier, an approximately 1,600 gallon settling/dosing tank, a 7,200 square foot (200' x 36') sand filter and a 8,208 square foot (228' x 36') sand filter in parallel, tablet chlorine disinfection with a 3,275 gallon contact tank, and an effluent cascade aerator.

1. **Streamflow:** Shenango River near Girard, Pa. (USGS Stream Gage 04213075):

Drainage Area: 4.45 sq. mi. (USGS StreamStats)  
Q<sub>7-10</sub>: 0.3 cfs (USGS StreamStats)  
Yieldrate: 0.1 cfsm (calculated)

Unnamed Tributary to the Lackawannock Creek @ Outfall 001 (first point of use):

Drainage Area: 0.38 sq. mi. (USGS StreamStats)  
Yieldrate: 0.1 cfsm (from above)  
Q<sub>7-10</sub>: 0.038 cfs (calculated)

% of stream allocated: 100% Basis: No nearby discharges

2. **Wasteflow:**

Permitted discharge: 0.015 MGD = 0.023 cfs

Runoff flow period: 24 hours Basis: Runoff flow for a non-Municipal STP using sand filtration)

There is less than 3 parts stream flow (Q<sub>7-10</sub>) to 1 part effluent (design flow). In accordance with the SOP, since this is an existing discharge, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were evaluated for this facility. Based on eDMR data, the treatment requirements are not attainable with the treatment technology in place so the requirements will not be implemented in this NPDES Permit renewal.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. **Parameters:**

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, Phosphorus, Total Nitrogen, NH<sub>3</sub>-N, CBOD<sub>5</sub>, Dissolved Oxygen, and Total Residual Chlorine. NH<sub>3</sub>-N, CBOD<sub>5</sub>, and Dissolved Oxygen were evaluated using WQM 7.0 at the discharge point.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits. The measurement frequency was changed from 1/week to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

b. Total Suspended Solids

Limits set as 30 mg/l as a monthly average and 60 mg/l as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits. The technology-based limits are less restrictive than the limits that are set in the previous permit. The more restrictive limits set in the previous renewal are retained since, based on eDMR data, the limits are attainable.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)  
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)  
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits.

d. Phosphorus

- Limit necessary due to:
- Discharge to lake, pond, or impoundment
  - Discharge to stream

Basis: N/A

- Limit not necessary

Basis: The previous monitoring for Total Phosphorus will remain in accordance with the SOP, based on Chapter 92a.61.

e. Total Nitrogen

The previous monitoring for Total Nitrogen will remain in accordance with the SOP, based on Chapter 92a.61.

f. Ammonia-Nitrogen (NH<sub>3</sub>-N)

Median discharge pH to be used: 7.1 Standard Units (S.U.)

Basis: eDMR data

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: (default value used in the absence of data)

Stream Temperature: 25°C (default value used for TSF modeling)

Background NH<sub>3</sub>-N concentration: 0.0 mg/l

Basis: Default value.

Calculated NH<sub>3</sub>-N Summer limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Calculated NH<sub>3</sub>-N Winter limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated summer limits above (see Attachment 2). The winter limits are calculated as three times the summer limits, but since the technology-based limits are more protective, they will be used. The calculated limits are less restrictive than the limits that are set in the previous permit. The more restrictive limits set in the previous renewal are retained since, based on eDMR data, the limits are attainable.

g. CBOD<sub>5</sub>

Median discharge pH to be used: 7.1 Standard Units (S.U.)

Basis: eDMR data

Discharge temperature: 25°C (default value used in the absence of data)  
Median stream pH to be used: 7.0 Standard Units (S.U.)  
Basis: (default value used in the absence of data)  
Stream Temperature: 25°C (default value used for TSF modeling)  
Background CBOD<sub>5</sub> concentration: 2.0 mg/l  
Basis: Default value  
CBOD<sub>5</sub> Summer limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)  
CBOD<sub>5</sub> Winter limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated summer limits above (see Attachment 2), which are the same as the previous NPDES Permit. The winter limits are calculated as three times the summer limits, but since the technology-based limits are more protective, they will be used. The calculated limits are less restrictive than the limits that are set in the previous permit. The more restrictive limits set in the previous renewal are retained since, based on eDMR data, the limits are attainable.

h. Dissolved Oxygen (DO)

- 4.0 mg/l - minimum desired in effluent to protect all aquatic life
- 5.0 mg/l - desired in effluent for CWF, WWF, or TSF
- 6.0 mg/l - minimum required due to discharge falling under guidance document 391-2000-014
- 8.0 mg/l - required due to discharge going to a naturally reproducing salmonid stream

Discussion: The Dissolved Oxygen minimum of 4.0 mg/l will be retained with this renewal. The technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 2) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61. The measurement frequency was changed from 1/week to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

i. Total Residual Chlorine (TRC)

- No limit necessary
- TRC limits: 0.5 mg/l (monthly average)  
1.2 mg/l (instantaneous maximum)

Basis: The TRC limits above are technology-based using the TRC Calc Spreadsheet (see Attachment 1) at the first point of use on the receiving stream. The TRC limits are the same as in the previous renewal and will be retained. The measurement frequency was changed from 1/week to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

j. Anti-Backsliding

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

**Attachment List:**

Attachment 1 - TRC\_Calc Spreadsheet

Attachment 2 - WQ Modeling Printouts - Perennial Reach

Attachment 3 - WQ Modeling Printouts - Dry Reach

Attachment 4 - WMS Open Violations by Client

If viewing this electronically, please refer to the following PDF to view the above Attachments:



Adobe Acrobat  
Document

**Compliance History**

**DMR Data for Outfall 001 (from October 1, 2019 to September 30, 2020)**

Parameter	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20	DEC-19	NOV-19	OCT-19
Flow (MGD) Average Monthly	0.002	0.005	0.001	0.002	0.0038	0.002	0.004	0.003	0.003	0.001	0.002	0.002
Flow (MGD) Daily Maximum	0.003	0.006	0.001	0.002	0.0059	0.002	0.004	0.003	0.004	0.002	0.002	0.002
pH (S.U.) Minimum	7.38	6.36	7.18	7.27	7.07	7.25	6.2	6.4	6.9	7.27	7.29	7.27
pH (S.U.) Maximum	7.67	7.20	7.48	7.47	7.37	7.62	7.9	8.1	8.0	7.32	7.34	7.34
DO (mg/L) Minimum	4.08	4.12	4.60	4.29	4.39	4.45	5.1	7.1	8.1	5.20	5.10	4.95
TRC (mg/L) Average Monthly	0.42	0.35	0.37	0.27	0.30	0.33	0.26	0.08	0.17	0.45	0.41	0.45
TRC (mg/L) Instantaneous Maximum	1.08	0.59	0.80	0.99	0.74	1.0	0.41	0.12	0.21	0.52	0.50	0.57
CBOD5 (mg/L) Average Monthly	2.6	2.0	2.1	2.5	2.6	2.25	2.25	2.4	2.2	2.4	2.4	2.4
TSS (mg/L) Average Monthly	2.0	2.0	3	5.0	6.5	9.5	4.5	2.5	2	2.0	2.0	2.0
Fecal Coliform (CFU/100 ml) Geometric Mean	1	1	1	7	8	1	1	1	1	1.41	1	8
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	1	1	1	47	71	1	1	1	1	2	1	66
Total Nitrogen (mg/L) Average Monthly	E	6.83	13.8	1.34	14.5	8.43	E	10.1	12.7	13.5	13.0	7.56
Ammonia (mg/L) Average Monthly	0.11	0.56	10.63	4.1	6.9	7.44	1.5	0.17	0.08	0.19	0.16	0.24
Total Phosphorus (mg/L) Average Monthly	E	0.30	4.32	3.31	1.63	1.45	E	0.52	1.21	1.02	0.79	0.91

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.2	1/day	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite

Compliance Sampling Location: at Outfall 001, after disinfection.



Flow is monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limit is technology-based on Chapter 92a.48. The limits for CBOD<sub>5</sub>, Total Suspended Solids, Dissolved Oxygen, and Fecal Coliform are technology based on Chapter 92a.47. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. Monitoring for Total Nitrogen and Total Phosphorus is based on Chapter 92a.61.

<b>TRC EVALUATION</b>				
Input appropriate values in A3:A9 and D3:D9				
0.151	= Q stream (cfs) (First point of use)	0.5	= CV Daily	
0.015	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)	0	=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 2.095		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.781		5.1d
		WLA_cfc = 2.035		
		LTAMULT_cfc = 0.581		
		LTA_cfc = 1.183		
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635		
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	$wla\_afc \cdot LTAMULT\_afc$			
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$			
LTA_cfc	$wla\_cfc \cdot LTAMULT\_cfc$			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$			
AVG MON LIMIT	$MIN(BAT\_BPJ, MIN(LTA\_afc, LTA\_cfc) \cdot AML\_MULT)$			
INST MAX LIMIT	$1.5 \cdot ((av\_mon\_limit / AML\_MULT) / LTAMULT\_afc)$			

**WQM 7.0 Effluent Limits** (Perennial Reach)

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20A	36067	LACKAWANNOCK CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.340	Perennial Reach	PA0033588b	0.015	CBOD5	5.88		
				NH3-N	6.42	12.84	
				Dissolved Oxygen			2

Inputs equal outputs so all three inputs into Dry Reach model are protective.

## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20A	36067	LACKAWANNOCK CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
0.340	0.015	25.000		7.012
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
5.678	0.383	14.833		0.080
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.52	0.393	0.86		1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
7.411	26.608	Owens		5
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.259	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>
	(days)	(mg/L)	(mg/L)	(mg/L)
	0.026	2.48	0.83	7.54
	0.052	2.45	0.81	7.54
	0.078	2.42	0.79	7.54
	0.104	2.39	0.77	7.54
	0.130	2.36	0.75	7.54
	0.156	2.33	0.73	7.54
	0.181	2.30	0.71	7.54
	0.207	2.27	0.69	7.54
	0.233	2.24	0.67	7.54
	0.259	2.21	0.66	7.54

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	36067	LACKAWANNOCK CREEK	<b>0.340</b>	1029.00	1.51	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Tributary pH	Stream Temp (°C)	Stream pH
	<b>Q7-10</b>	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	25.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing		Permitted Design		Reserve Factor	Disc Temp (°C)	Disc pH
		Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)			
Perennial Reach	PA0033588b	0.0150	0.0000	0.0000	0.0000	0.000	25.00	7.10

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	5.88	2.00	0.00	1.50
Dissolved Oxygen	2.00	8.24	0.00	0.00
NH3-N	6.42	0.00	0.00	0.70

(Input from Dry Reach)

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	36067	LACKAWANNOCK CREEK	<b>0.000</b>	997.00	3.99	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Tributary pH	Stream Temp (°C)	Stream pH
	<b>Q7-10</b>	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	25.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Permitted Design			Reserve Factor	Disc Temp (°C)	Disc pH
		Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)			
		0.0000	0.0000	0.0000	0.000	0.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20A	36067	LACKAWANNOCK CREEK

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.340	Perennial Reach	6.68	12.84	6.68	12.84	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.340	Perennial Reach	1.33	6.42	1.33	6.42	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.34	Perennial Reach	5.88	5.88	6.42	6.42	2	2	0	0



## WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20A		36067				LACKAWANNOCK CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
0.340	0.15	0.00	0.15	.0232	0.01783	.383	5.68	14.83	0.08	0.259	25.00	7.01
<b>Q1-10 Flow</b>												
0.340	0.10	0.00	0.10	.0232	0.01783	NA	NA	NA	0.06	0.320	25.00	7.02
<b>Q30-10 Flow</b>												
0.340	0.21	0.00	0.21	.0232	0.01783	NA	NA	NA	0.09	0.223	25.00	7.01

**WQM 7.0 D.O. Simulation** (Dry Reach)

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20A	36067	LACKAWANNOCK CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
0.770	0.015	25.000		7.035
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
2.375	0.372	6.393		0.069
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
10.72	1.260	9.48		1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
2.758	25.531	Owens		NA
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.379	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.038	10.10	9.12	2.00
	0.076	9.51	8.77	2.00
	0.114	8.95	8.43	2.00
	0.152	8.43	8.11	2.00
	0.189	7.94	7.80	2.00
	0.227	7.48	7.50	2.00
	0.265	7.04	7.22	2.00
	0.303	6.63	6.94	2.00
	0.341	6.24	6.67	2.00
	0.379	5.88	6.42	2.00

(Input into perennial reach)

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	36067	LACKAWANNOCK CREEK	<b>0.770</b>	1242.00	0.38	0.00000	0.00	<input type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Tributary pH	Stream Temp (°C)	Stream pH
	<b>Q7-10</b>	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	25.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Permitted Design			Reserve Factor	Disc Temp (°C)	Disc pH
		Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)			
Dry Reach	PA0033588a	0.0150	0.0000	0.0000	0.000	25.00	7.10

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	2.00	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	36067	LACKAWANNOCK CREEK	<b>0.340</b>	1029.00	1.51	0.00000	0.00	<input type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
<b>Q7-10</b>	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	25.00	7.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Permitted Design			Reserve Factor	Disc Temp	Disc pH
		Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)		(°C)	
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Simulation	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	2		

## WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>			<u>Stream Name</u>							
20A		36067			LACKAWANNOCK CREEK							
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
0.770	0.04	0.00	0.04	NA	0.09382	.372	2.37	6.39	0.07	0.379	25.00	7.04
<b>Q1-10 Flow</b>												
0.770	0.02	0.00	0.00	NA	0.09382	NA	NA	NA	0.00	0.000	0.00	0.00
<b>Q30-10 Flow</b>												
0.770	0.05	0.00	0.00	NA	0.09382	NA	NA	NA	0.00	0.000	0.00	0.00



**WATER MANAGEMENT SYSTEM  
OPEN VIOLATIONS BY CLIENT**

Client ID: 287851

Client: All

Open Violations: 4

CLIENT ID	CLIENT	PF ID	FACILITY	PF KIND	PF STATUS	INSP PROGRAM	PROGRAM SPECIFIC ID
287851	COUNTRY ESTATES MHP LLC	253591	COUNTRY ESTATES MHP	Sewage Non-Publicly Owned (Non-Muni)	Active	WPC NPDES	PA0033588
287851	COUNTRY ESTATES MHP LLC	253591	COUNTRY ESTATES MHP	Sewage Non-Publicly Owned (Non-Muni)	Active	WPC NPDES	PA0033588
287851	COUNTRY ESTATES MHP LLC	253591	COUNTRY ESTATES MHP	Sewage Non-Publicly Owned (Non-Muni)	Active	WPC NPDES	PA0033588
287851	COUNTRY ESTATES MHP LLC	253591	COUNTRY ESTATES MHP	Sewage Non-Publicly Owned (Non-Muni)	Active	WPC NPDES	PA0033588

INSP ID	VIOLATION ID	INSPECTION CATEGORY	VIOLATION DATE	VIOLATION CODE	VIOLATION	PF INSPECTOR	INSP REGION
2794489	831608	PF	10/25/2018	92A.44	NPDES - Violation of effluent limits in Part A of permit	PUDLICK, DAN	NWRO
2934877	862556	PF	09/19/2019	92A.44	NPDES - Violation of effluent limits in Part A of permit	PUDLICK, DAN	NWRO
2968349	870512	PF	12/10/2019	CSL611	CSL - Failure to comply with terms and conditions of a WQM permit	PUDLICK, DAN	NWRO
2968349	870513	PF	12/10/2019	92A.41(A)5	NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance	PUDLICK, DAN	NWRO