

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0033928  
 APS ID 1041530  
 Authorization ID 1358943

**Applicant and Facility Information**

Applicant Name	<u>PA 2018 Town &amp; Country, LLC</u>	Facility Name	<u>PA 2018 Town &amp; Country, LLC</u>
Applicant Address	<u>1400 Belleville Street</u> <u>Richmond, VA 23230-4629</u>	Facility Address	<u>60 Town and Country Lane</u> <u>Troy, PA 16947-8855</u>
Applicant Contact	<u>Matt Foster</u>	Facility Contact	<u>Patrick Crowley</u>
Applicant Phone	<u>(804) 747-7207</u>	Facility Phone	<u>(570) 429-0731</u>
Client ID	<u>346776</u>	Site ID	<u>237138</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Troy Township</u>
Connection Status	<u>N/A</u>	County	<u>Bradford</u>
Date Application Received	<u>June 17, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>July 1, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit</u>		

**Summary of Review**

The subject facility is a sewage treatment plant serving a mobile home park is Troy Township, Bradford County.

Sludge use and disposal description and location(s): The facility's sludge is disposed by landfill. Per the application, 0.5 tons of sludge were disposed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	November 22, 2021
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	November 23, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.024</u>
Latitude	<u>41° 47' 59.25"</u>	Longitude	<u>-76° 48' 58.90"</u>
Quad Name	<u>Troy, PA</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to West Branch Sugar Creek (TSF)</u>	Stream Code	<u>30781 (UNT) 30779 (POFU)</u>
NHD Com ID	<u>66401549</u>	RMI	<u>0.83 (UNT) 1.02 (POFU)</u>
Drainage Area	<u>3.79 (POFU)</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0082</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.0019 (UNT) 0.031 (POFU)</u>	Q <sub>7-10</sub> Basis	<u>USGS Gage #01516500, Corey Ck near Mainsburg</u>
Elevation (ft)	<u>1312 (UNT) 1219 (POFU)</u>	Slope (ft/ft)	<u>0.212 (UNT)</u>
Watershed No.	<u>4-C</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	<u>None</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Nearest Downstream Public Water Supply Intake	<u>Danville Municipal Water Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>1,120</u>
PWS RMI	<u>138.06</u>	Distance from Outfall (mi)	<u>&gt;100</u>

Changes Since Last Permit Issuance: The above stream and drainage characteristics were mostly determined for the previous review and remain adequate.

Other Comments:

Discharge is to an intermittent stream. A point of first use (POFU) determination was performed by the Department in 2016 for the previous review. This survey found the POFU to be at the confluence of the UNT to West Branch Sugar Creek (30781) with West Branch Sugar Creek (30779) affirming a previous Department determination in 1990.

No downstream water supply is expected to be affected by the discharge with the limitations and monitoring proposed.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Town & Country Estates				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
0872403		Original – 3/16/72		
		T-1 – 3/28/02		
		T-2 – 3/22/19		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Activated Sludge	Hypochlorite	0.024
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.024	67.7	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: WQM and NPDES permits were transferred in 2019.

Other Comments: The treatment, as permitted by WQM Permit No. 0872403 T-2, consists of comminutor, bypass bar screen, aeration tank, settling tank, two intermittent sand filters, hypochlorite disinfection, chlorine contact tank, and aerated sludge holding tank.

Compliance History

DMR Data for Outfall 001 (from October 1, 2020 to September 30, 2021)

Parameter	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20
Flow (MGD) Average Monthly	0.014	0.017	0.013	0.014	0.013	0.015	0.016	0.019	0.018	0.017	0.0145	0.014
pH (S.U.) Instantaneous Minimum	7.1	7.0	7.2	7.2	7.1	7.0	6.8	7.0	7.2	7.1	7.2	7.2
pH (S.U.) Instantaneous Maximum	7.8	7.6	7.8	7.6	7.6	7.8	7.8	7.8	7.8	7.9	7.8	7.9
DO (mg/L) Instantaneous Minimum	6.2	6.0	6.0	6.1	6.0	6.5	7.4	8.3	7.7	8.5	5.9	6.7
TRC (mg/L) Average Monthly	0.4	0.4	0.3	0.4	0.3	0.4	0.4	0.4	0.4	0.4	0.4	0.3
TRC (mg/L) Instantaneous Maximum	0.6	0.6	0.5	0.6	0.5	0.5	0.5	0.6	0.5	0.6	0.6	0.5
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 4.0	< 3.0	< 3.0	< 3.0	< 3.0
CBOD5 (mg/L) Instantaneous Maximum	< 3.0	< 3.0	< 3.0	< 3.0	3.0	< 3.0	< 3.0	4.5	< 3.0	< 3.0	< 3.0	< 3.0
TSS (mg/L) Average Monthly	< 2.0	< 3.0	< 2.0	< 5.0	8.0	< 5.0	4.0	< 2.0	< 2.0	< 1.6	< 4.0	3.0
TSS (mg/L) Instantaneous Maximum	2.0	< 3.0	2.8	8.4	8.4	8.8	7.0	1.6	< 2.0	< 1.6	5.6	3.6
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 98	< 1	182	27	176	7	< 10	1	< 8	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	2	< 1	> 2420	1	205	116	387	14	49	1	64	1
Ammonia (mg/L) Average Quarterly	< 0.25			< 0.69			< 0.10			0.29		

**Compliance History, Cont'd**

Effluent Violations for Outfall 001, from: November 1, 2020 To: September 30, 2021

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
DO	11/30/20	Inst Min	5.9	mg/L	6.0	mg/L
Fecal Coliform	07/31/21	IMAX	> 2420	No./100 ml	1000	No./100 ml

**Compliance History, Cont'd**

<b>Summary of Inspections:</b>	The facility has been inspected approximately annually by the Department over the past permit term. The most recent inspection on June 10, 2020 noted eDMR effluent violations.
<b>Other Comments:</b>	A query in WMS found no open violations in eFACTS for PA 2018 Town & Country, LLC.

**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Weir
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5 Nov 1 - Apr 30	XXX	XXX	XXX	20.0	XXX	40.0	2/month	Grab
CBOD5 May 1 - Oct 31	XXX	XXX	XXX	10.0	XXX	20.0	2/month	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Ammonia	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.024</u>
<b>Latitude</b> <u>41° 47' 59.00"</u>	<b>Longitude</b> <u>-76° 48' 59.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable and included in the existing permit except for more stringent existing limits for TSS and CBOD<sub>5</sub> as discussed below. Due to the addition of e. coli bacteria criteria to Chapter 93 of the Department's regulations and consistent with current Department policy, monitoring for e. coli will now be included in the permit.

**Water Quality-Based Limitations**

**Discharge to Dry or Intermittent Stream**

The existing limitations for CBOD<sub>5</sub>, TSS, and DO were based on a prior version of the Department's *Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales and Storm Sewers* guidance document (391-2000-014). The current version of the guidance prescribes additional and more stringent limitations for new or expanded discharges that include a TN limit of 5 mg/L and TP limit of 0.5 mg/L. These additional limitations will not be required at this time for this existing discharge.

**CBOD<sub>5</sub>, NH<sub>3</sub>-N & DO**

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. WQM7.0 modeling was performed (see Attachment B) for the discharge to the unnamed tributary and West Branch Sugar Creek and indicated that the existing limits should be adequate to protect the receiving stream. Due to the discharge scenario the modeling was performed in two reaches. The first reach modelled the DO in the intermittent Unnamed Tributary. The second reach used the output from the first reach as a discharge at the POFU to West Branch Sugar Creek and found the existing limitations to be adequate.

A discharge ammonia-nitrogen concentration of 1.0 mg/L was input into the model due to the consistent NH<sub>3</sub>-N levels seen in the discharge. A review of the NH<sub>3</sub>-N levels for the past permit term found a maximum reported concentration of <0.97 mg/L.

**Total Residual Chlorine**

The Department typically uses a modeling spreadsheet to analyze the toxicity of a discharge's Total Residual Chlorine (TRC) in a receiving stream accounting for available dilution. However, no modeling was performed at this time due to the

significant distance from the point of discharge to the POFU (0.83 Miles) which would provide chlorine removal and the discharge will typically infiltrate before reaching the POFU during low-flow conditions anyways.

**Toxics Management**

No further "Reasonable Potential Analysis" was conducted for this minor sewage treatment facility with no industrial wastes to determine additional parameters as candidates for limitations or monitoring.

**Chesapeake Bay/Nutrient Requirements**

According to the Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, this facility is considered a Phase 5 Chesapeake Bay sewage discharger, and as such requires no nutrient loading limits. Per a review of the facility eDMR data for the past four years the Total Nitrogen has averaged 15.4 mg/L and the Total Phosphorus has averaged 2.06 mg/L. Due to the intermittent stream discharge, the existing annual monitoring will remain.

**Best Professional Judgment (BPJ) Limitations**

Comments: No additional BPJ limits are necessary at this time beyond the water quality and technology-based limits noted above.

**Anti-Backsliding**

Consistent with the anti-backsliding provisions of the Clean Water Act and 40 CFR 122.44(l), no proposed limits have been made less stringent in the attached draft permit.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Weir
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5 Nov 1 - Apr 30	XXX	XXX	XXX	20.0	XXX	40.0	2/month	Grab
CBOD5 May 1 - Oct 31	XXX	XXX	XXX	10.0	XXX	20.0	2/month	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Ammonia	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
e. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab


Compliance Sampling Location: Outfall 001

Other Comments: The monitoring above is unchanged from the existing permit except for the inclusion of e. Coli monitoring as noted above. While not consistent with the Department's typical requirements of twice per months for WWTP discharges of this size the existing quarterly monitoring for NH<sub>3</sub>-N will remain due to the consistent low ammonia levels seen in the discharge.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 3/24/21
<input type="checkbox"/>	Other: [redacted]

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model – Run 1 @UNT and Run 2 @West Branch Sugar Creek



Run #1 – Discharge into Unnamed Tributary

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04C	30781 Trib	30781 to W Br S Br Sugar Cr	<b>0.083</b>	1312.00	0.23	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
<b>Q7-10</b>	0.008	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Town&Country	PA0033928	0.0240	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	10.00	2.00	0.00	1.50
Dissolved Oxygen	6.00	8.24	0.00	0.00
NH3-N	1.00	0.00	0.00	0.70

Permit No. PA0033928

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04C	30781	Trib 30781 to W Br S Br Sugar Cr	0.000	1219.00	0.50	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.008	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Simulation	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Permit No. PA0033928

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
04C		30781		Trib 30781 to W Br S Br Sugar Cr								
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
0.083	0.00	0.00	0.00	NA	0.21247	.414	1.46	3.53	0.06	0.079	24.76	7.00
<b>Q1-10 Flow</b>												
0.083	0.00	0.00	0.00	NA	0.21247	NA	NA	NA	0.00	0.000	0.00	0.00
<b>Q30-10 Flow</b>												
0.083	0.00	0.00	0.00	NA	0.21247	NA	NA	NA	0.00	0.000	0.00	0.00

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
04C		30781		Trib 30781 to W Br S Br Sugar Cr			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>		<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>		
0.083	0.024		24.758		7.000		
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>		<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>		
1.463	0.414		3.534		0.064		
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>		<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>		
9.61	1.484		0.95		1.010		
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>		<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>		
6.108	19.779		Owens		5		
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>						
0.079	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>			
	0.008	9.47	0.94	6.22			
	0.016	9.34	0.94	6.31			
	0.024	9.20	0.93	6.39			
	0.031	9.07	0.92	6.47			
	0.039	8.94	0.91	6.54			
	0.047	8.81	0.91	6.60			
	0.055	8.68	0.90	6.65			
	0.063	8.56	0.89	6.70			
	0.071	8.44	0.89	6.75			
	0.079	8.31	0.88	6.79			

Subreach results above from Run #1 inputted as discharge into West Branch Sugar Creek for Run #2

**Permit No. PA0033928**

Run #2 – Discharge into West Branch Sugar Creek

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04C	30779	WEST BRANCH SOUTH BRANCH S	1.020	1219.00	3.79	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.008	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Town&Country2	PA0033928-2	0.0240	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	8.31	2.00	0.00	1.50
Dissolved Oxygen	6.79	8.24	0.00	0.00
NH3-N	0.88	0.00	0.00	0.70

Permit No. PA0033928

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04C	30779	WEST BRANCH SOUTH BRANCH S	0.100	1092.00	28.90	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.008	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
04C	30779	WEST BRANCH SOUTH BRANCH SUGAR CR.										
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
1.020	0.03	0.00	0.03	.0371	0.02614	.342	4.98	14.55	0.04	1.407	22.72	7.00
<b>Q1-10 Flow</b>												
1.020	0.02	0.00	0.02	.0371	0.02614	NA	NA	NA	0.04	1.555	23.26	7.00
<b>Q30-10 Flow</b>												
1.020	0.04	0.00	0.04	.0371	0.02614	NA	NA	NA	0.04	1.292	22.34	7.00

Permit No. PA0033928

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	E MPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
04C	30779	WEST BRANCH SOUTH BRANCH SUGAR CR.

#### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.020	Town&Country 2	12.8	1.76	12.8	1.76	0	0

#### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.020	Town&Country 2	1.62	.88	1.62	.88	0	0

#### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.02	Town&Country 2	8.31	8.31	.88	.88	6.79	6.79	0	0

Permit No. PA0033928

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
04C	30779	WEST BRANCH SOUTH BRANCH SUGAR CR.	
<hr/>			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
1.020	0.024	22.722	7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
4.984	0.342	14.553	0.040
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
5.43	0.627	0.48	0.863
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
7.452	19.437	Owens	6
<u>Reach Travel Time (days)</u>			
1.407			
<b>Subreach Results</b>			
	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>
	(days)	(mg/L)	(mg/L)
	<u>D.O.</u>		
	(mg/L)		
	0.141	4.92	0.42
	0.281	4.45	0.38
	0.422	4.03	0.33
	0.563	3.64	0.29
	0.703	3.30	0.26
	0.844	2.98	0.23
	0.985	2.70	0.20
	1.125	2.44	0.18
	1.266	2.21	0.16
	1.407	2.00	0.14
		7.84	

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
04C	30779	WEST BRANCH SOUTH BRANCH SUGAR CR.	
<hr/>			
<u>RMI</u>	<u>Name</u>	<u>Permit Number</u>	<u>Disc Flow (mgd)</u>
1.020	Town&Country 2	PA0033928-2	0.024
			<u>Parameter</u>
			<u>E ff. Limit 30-day Ave. (mg/L)</u>
			<u>E ff. Limit Maximum (mg/L)</u>
			<u>E ff. Limit Minimum (mg/L)</u>
			CBOD5
			8.31
			NH3-N
			0.88
			1.76
			Dissolved Oxygen
			6.79