



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

**PA0034185**

APS ID

**1139575**

Authorization ID

**1530966**

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<b>PWF1 High Meadows LLC</b>	Facility Name	<b>High Meadows MHP STP</b>
Applicant Address	4751 Kendor Drive	Facility Address	219 Leewood Drive
	New Kensington, PA 15068-9506		Lower Burrell, PA 15068-9508
Applicant Contact	Dennis Steck	Facility Contact	Dennis Steck
Applicant Phone	(419) 892-4800	Facility Phone	(419) 892-4800
Client ID	387406	Site ID	244136
Ch 94 Load Status	Not Overloaded	Municipality	Allegheny Township
Connection Status		County	Westmoreland
Date Application Received	June 16, 2025	EPA Waived?	Yes
Date Application Accepted		If No, Reason	
Purpose of Application	Renewal of authorization for treated sewage discharge		

**Summary of Review**

The applicant has applied for a renewal of NPDES Permit No. PA0034185, which was previously issued by the Department on 12/4/2019. That permit expired on 12/30/2024.

The receiving stream, the Tributary 42546 to Allegheny River, is classified as a Warm Water Fishery (WWF) located in the Lower Allegheny River State Watershed No.18-A.



WQM Permit No. 6569433 A-2 was issued on 05/24/2004. The treatment plant is rated at an annual average design flow of 0.026 MGD and designed to serve 106 housing units. The treatment process consists of flow equalization, primary settling, Rotating Biological Contactors (RBCs), final clarification, and ultraviolet disinfection.

On February 3, 2020, a Point of First Surface Water Use (POFU) survey in the vicinity of the STP outfall was conducted by Jamie Detweiler and Richard Spear, the Aquatic Biologists of Clean Water Program. The study identified that Tributary 42546 to Allegheny River is capable of supporting an Aquatic Life Use as defined in 25 Pennsylvania Code §93.9q, where water quality standards must be met.

The client has 3 open violations by client ID. Additionally, there are significant effluent violations for Ammonia-Nitrogen, CBOD5, and TSS in the DMR reports.

Act 14 notifications were provided on May 5, 2025

**Public Participation**

Approve	Return	Deny	Signatures	Date
x			 Sam Mahsoob, EIT / Environmental Engineering Trainee	9/3/2025
x			 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineer Manager	9/18/2025

### Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.026
Latitude	40° 37' 24"	Longitude	-79° 41' 41"
Quad Name	New Kensington East	Quad ID	40079E6
Wastewater Description:	Sewage Effluent		

Receiving Waters	Unnamed Tributary to Allegheny River (WWF)	Stream Code	42546
NHD Com ID	123972443	RMI	0.96
Drainage Area	0.0435	Yield (cfs/mi <sup>2</sup> )	0.00377
Q <sub>7-10</sub> Flow (cfs)	0.000164	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	1030.25	Slope (ft/ft)	0.03247
Watershed No.	18-A	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	<b>None</b>	Name	<b>None</b>

Background/Ambient Data	Data Source
pH (SU)	
Temperature (°F)	
Hardness (mg/L)	
Other:	

Nearest Downstream Public Water Supply Intake	PWS ID: 5020108	
PWS Waters	System Name: HARRISON TWP WATER AUTH	
PWS RMI	Flow at Intake (cfs)	2070
	Distance from Outfall (mi)	1.5

Treatment Facility Summary				
<b>Treatment Facility Name:</b> High Meadows MHP STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
6569433		12/09/1969		
6569433 A-2		05/24/2004		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	RBC	UV	0.026
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.026	79.14	Not Overloaded	Holding Tank	Allegheny Valley Joint Sewer Authority

**Compliance History**

**A compliance check was requested.**

Compliance History

DMR Data for Outfall 001 (from May 1, 2024 to April 30, 2025)

Parameter	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24
Flow (MGD) Average Monthly	0.018	0.014	0.019	0.011	0.011	0.009	0.007	0.00911 3	0.00662 7	0.00637	0.00827 5	0.01660
pH (S.U.) Instantaneous Minimum	7.2	7.3	7.2	7.2	7.2	7.1	7.1	7.03	7.5	7.6	7.6	7.6
pH (S.U.) Instantaneous Maximum	7.3	7.3	7.4	7.3	7.3	7.3	7.8	7.7	7.7	7.7	7.8	7.8
DO (mg/L) Instantaneous Minimum	5.2	5.4	5.2	5.1	5.2	5.2	5.3	5.1	5.0	5.0	5.1	5.1
TRC (mg/L) Average Monthly	0.01	0.01	0.01	0.01	0.01	0.01	0.01	< 0.001	< 0.001	< 0.001	0.001	0.001
TRC (mg/L) Instantaneous Maximum	0.01	0.01	0.01	0.01	0.01	0.01	0.01	< 0.001	< 0.001	< 0.001	0.001	0.001
CBOD5 (mg/L) Average Monthly	37.0	18.3	26.5	16.6	7.3	11	12	6.85	6.8	4.7	8.5	11.85
CBOD5 (mg/L) Instantaneous Maximum	57.1	19.3	32.2	23.6	10.2	12	17	7.6	7.0	6.4	8.9	14.2
TSS (mg/L) Average Monthly	17.5	8.5	22	7.5	6	7	12	5.5	3	3.5	32.33	10
TSS (mg/L) Instantaneous Maximum	26.0	10.0	26	10	10	8	18	8	3	4	74	18
Fecal Coliform (No./100 ml) Geometric Mean	389	48	180	511	43	116	47	16.61	< 1	22.5	286.59	40.69
Fecal Coliform (No./100 ml) Instantaneous Maximum	1011	54	2420	1046	140	387	2420	276	< 1	25	871	69
UV Transmittance (%) Daily Minimum	66	54	51	48	38	39	32					
Total Nitrogen (mg/L) Daily Maximum					25.1							

Ammonia (mg/L) Average Monthly	23.2	14.6	17.4	15.0	15.7	16.6	9.0	10.25	11.825	23.4	20.27	17.75
Ammonia (mg/L) Instantaneous Maximum	31.9	17.3	25.2	26.9	16.3	19.0	10.2	10.6	16.9	25.1	27.4	25.5
Total Phosphorus (mg/L) Daily Maximum					4.4							

### Compliance History

#### Effluent Violations for Outfall 001, from: June 1, 2024 To: April 30, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
CBOD5	02/28/25	Avg Mo	26.5	mg/L	25	mg/L
CBOD5	04/30/25	Avg Mo	37.0	mg/L	25	mg/L
CBOD5	04/30/25	IMAX	57.1	mg/L	50	mg/L
TSS	06/30/24	Avg Mo	32.33	mg/L	30	mg/L
TSS	06/30/24	IMAX	74	mg/L	60	mg/L
Fecal Coliform	06/30/24	Geo Mean	286.59	No./100 ml	200	No./100 ml
Ammonia	12/31/24	Avg Mo	15.7	mg/L	3.0	mg/L
Ammonia	02/28/25	Avg Mo	17.4	mg/L	3.0	mg/L
Ammonia	03/31/25	Avg Mo	14.6	mg/L	3.0	mg/L
Ammonia	10/31/24	Avg Mo	9.0	mg/L	2.0	mg/L
Ammonia	04/30/25	Avg Mo	23.2	mg/L	3.0	mg/L
Ammonia	11/30/24	Avg Mo	16.6	mg/L	3.0	mg/L
Ammonia	01/31/25	Avg Mo	15.0	mg/L	3.0	mg/L
Ammonia	02/28/25	IMAX	25.2	mg/L	6.0	mg/L

**NPDES Permit Fact Sheet**  
**High Meadows MHP STP**

**NPDES Permit No. PA0034185**

Ammonia	10/31/24	IMAX	10.2	mg/L	4.0	mg/L
Ammonia	04/30/25	IMAX	31.9	mg/L	6.0	mg/L
Ammonia	03/31/25	IMAX	17.3	mg/L	6.0	mg/L
Ammonia	12/31/24	IMAX	16.3	mg/L	6.0	mg/L
Ammonia	11/30/24	IMAX	19.0	mg/L	6.0	mg/L
Ammonia	01/31/25	IMAX	26.9	mg/L	6.0	mg/L

**Development of Effluent Limitations**

**Outfall No.** 001  
**Latitude** 40° 37' 24.00"  
**Wastewater Description:** Sewage Effluent

**Design Flow (MGD)** .026  
**Longitude** -79° 41' 41.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/L)	SBC	Federal Regulation	State Regulation
Flow	Report	Average Monthly	-	§§ 92a.27, 92a.61
Flow	Report	Max Daily	-	§§ 92a.27, 92a.61
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Total Nitrogen	Report	Average Monthly	-	92a.61(7)
Total Phosphorus	Report	Average Monthly	-	92a.61(8)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
E. Coli (No./100 ml)	-	Report		93a.61(11)(12)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Total Residual Chlorine	1.6	IMAX	-	92a.47-48(3)(4)
Ammonia-Nitrogen	25	Average Monthly	-	BPJ (5)
Ammonia-Nitrogen	50	IMAX	-	BPJ (5)
Dissolved Oxygen	4.0	IMIN	-	BPJ (6)

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (See Attachments 3, 4, & 5):

Parameter	Limit (mg/l)	SBC	Model
Ammonia-Nitrogen (May 1 to Oct 31)	1.4	Average Monthly	WQM 7.0
Ammonia-Nitrogen (May 1 to Oct 31)	2.8	IMAX	WQM 7.0
Ammonia-Nitrogen (Nov 1 to Apr 30)	1.98	Average Monthly	WQM 7.0
Ammonia-Nitrogen (Nov 1 to Apr 30)	3.96	IMAX	WQM 7.0
Dissolved Oxygen	6	Minimum	WQM 7.0

Comments: Stricter limits will be imposed for Dissolved Oxygen and Ammonia-Nitrogen in the summer and winter. In looking at the DMR data, it appears that the permittee will not be able to immediately comply with these limits. Therefore, a three-year compliance schedule has been implemented for NH<sub>3</sub>-N and DO.

### Additional Considerations

#### Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation. Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

*(40 CFR 122.44 (l)(2) Establishing limitations, standards, and other permit conditions., 40 CFR Ch. I (7-1-21 Edition))*

No permits limits have been made less stringent in the renewal draft permit.

#### E. Coli

Sewage discharges will include monitoring, at a minimum, for E. Coli, in new and reissued permits, with a monitoring frequency of 1/month for design flows  $\geq 1$  MGD, 1/quarter for design flows  $\geq 0.05$  and  $< 1$  MGD, 1/year for design flows of 0.002 – 0.05 MGD.

*(Note 12 SOP-Establishing Effluent Limitations for Individual Sewage Permits Final November 9, 2012, Revised February 5, 2024, Version 2.0. and 25 PA Code 92a.61(b).)*

#### Effluent Multipliers

Section 2.C of the Permit Writers Manual contains the procedure for converting average monthly effluent limitations to average weekly, maximum daily, and instantaneous maximum effluent limitations. The average monthly limit is multiplied according to the following chart:

Discharge Solution	Parameters	Average Weekly	Maximum Daily	Instantaneous Maximum Multiplier
Sewage	All	1.5		2.0
Industrial	All		2.0	2.5*

*(Department Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits, Updated June 28, 2023 (Document No. 362-0400-001))*

### Rounding Off

Section 5 C.2. of the Permit Writers Manual contains general guidelines for rounding conventional and toxic pollutants, with instructions to round down to the nearest decimal place indicated.

<u>General Magnitude</u>	<u>Conventional Pollutants</u>	<u>Toxic Pollutants</u>
<0.01	to nearest 0.001	to nearest 0.001
0.01 - 0.1	to nearest 0.01	to nearest 0.01
0.1 - 1.0	to nearest 0.1	to nearest 0.01
1.0 - 10.0	to nearest 0.5	to nearest 0.01
10.0 - 60.0	to nearest 1.0	to nearest 0.01
60.0 or greater	to nearest 5.0	to nearest 0.10

*(Department Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits, Updated June 28, 2023 (Document No. 362-0400-001))*

### Ultraviolet Disinfection

Ultraviolet (UV) disinfection is used. Routine monitoring of UV intensity is at the same monitoring frequency that is used for TRC.

*(Section I.A, Note 4, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9 and 25 PA Code 92a.61(b).)*

### Nutrient Monitoring

Nutrient monitoring is required by the SOP for Effluent Limitations for Individual Sewage Permits. Monitoring is included to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). The receiving stream is not listed as impaired for nutrients, therefore at the discretion of the application manager, a monitoring frequency less than the equivalent of conventional pollutants in Table 6-3 of the Permit Writer's Manual has been selected.

*(Section I.A, Note 7 & 8, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9 and 25 PA Code 92a.61(b).)*

Table 6-3 – Self-Monitoring Requirements for SEWAGE Discharges

Plant Design Flow (MGD)	Flow Monitoring	C-BOD <sub>5</sub> or BOD <sub>5</sub>	Suspended Solids	pH	Fecal Coliform	Chlorine Residual	NH <sub>3</sub> -N	Phosphorus	DO	Toxics
Single Residence (Individual Permit)	2/year by estimate	2/year*	2/year*	1/month*	2/year*	1/month*	2/year*	2/year*	2/year*	N/A
.0005 to .002	weekly, using average pump rate or weir (a)	1/month*	1/month*	daily*	1/month*	daily*	1/month*	1/month*	daily*	N/A
.002 to .01	weekly, using average pump rate or weir (a)	2/month*	2/month*	daily*	2/month*	daily*	2/month*	2/month*	daily*	N/A
<b>0.01 to 0.1</b>	<b>weekly, using average pump rate or weir (a)</b>	<b>2/month*</b>	<b>2/month*</b>	<b>daily*</b>	<b>2/month*</b>	<b>daily*</b>	<b>2/month*</b>	<b>2/month*</b>	<b>Daily*</b>	<b>1/week*</b>
0.1 to 1.0	meter	1/week**	1/week**	daily*	1/week*	daily*	1/week**	1/week**	daily*	1/week****
1.0 to 5.0	meter	2/week***	2/week***	daily*	2/week*	daily*	2/week***	2/week***	daily*	1/week****
5.0 to 25.0	meter	daily***	daily***	daily*	daily*	1/shift*	daily***	daily***	daily*	1/week****
over 25.0	meter	daily***	daily***	1/shift*	daily*	1/shift*	1/shift***	1/shift***	1/shift*	1/week****

\* Grab sample-these should be most representative of the effluent and are to be taken at a time when the normal daily maximum flow would reach the sampling point.

\*\* 8-hour composite sample.

\*\*\* 24-hour composite sample.

\*\*\*\* Same sample type as for Industrial Process Wastewater (See Table 6-4).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Max Daily	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
UV Transmittance (%)	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Recorded
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through End of Interim Period 1.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	3.0	XXX	6.0	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	2.0	XXX	4.0	2/month	Grab

Compliance Sampling Location: Outfall 001

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: End of Interim Period 1 through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	1.98	XXX	3.96	1/day	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	1.4	XXX	2.8	1/day	Grab

Compliance Sampling Location: Outfall 001

# Attachment 1

## USGS StreamStats

### Upstream


### StreamStats Report - US

Region ID: PA

Workspace ID: PA20250624145136926000

Clicked Point (Latitude, Longitude): 40.62250, -79.69431

Time: 2025-06-24 10:52:00 -0400



[Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.0435	square miles
ELEV	Mean Basin Elevation	1106	feet

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.0435	square miles	2.26	1400
ELEV	Mean Basin Elevation	1106	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.000738	ft^3/s
30 Day 2 Year Low Flow	0.00164	ft^3/s
7 Day 10 Year Low Flow	0.000164	ft^3/s
30 Day 10 Year Low Flow	0.000442	ft^3/s

Statistic	Value	Unit
90 Day 10 Year Low Flow	0.00103	ft^3/s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


# Attachment 2

## USGS StreamStats

### Downstream

## StreamStats Report - Downstream

**Region ID:** PA  
**Workspace ID:** PA20250624145631410000  
**Clicked Point (Latitude, Longitude):** 40.61832, -79.69974  
**Time:** 2025-06-24 10:56:56 -0400



 Collapse All

## ➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.24	square miles
ELEV	Mean Basin Elevation	1088	feet

» Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.24	square miles	2.26	1400
ELEV	Mean Basin Elevation	1088	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.00509	ft^3/s
30 Day 2 Year Low Flow	0.0104	ft^3/s
7 Day 10 Year Low Flow	0.00134	ft^3/s
30 Day 10 Year Low Flow	0.00316	ft^3/s
90 Day 10 Year Low Flow	0.00678	ft^3/s

*Low-Flow Statistics Citations*

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

# Attachment 3

## WQM 7.0 Model -

## Summer

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
18A	42546 Trib 42546 to Allegheny River				0.960	1030.25	0.04	0.00000	0.00	<input checked="" type="checkbox"/>		
<b>Stream Data</b>												
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)		
<b>Q7-10</b> 0.004 0.00 0.00 0.000 0.000 0.0 0.00 0.00 25.00 7.00 0.00 0.00 <b>Q1-10</b> 0.00 0.00 0.000 0.000 <b>Q30-10</b> 0.00 0.00 0.000 0.000												
<b>Discharge Data</b>												
				Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)		
				Outfall 001	PA0034185	0.0260	0.0260	0.0260	0.000	20.00 7.50		
<b>Parameter Data</b>												
					Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
					CBOD5	25.00	2.00	0.00	1.50			
					Dissolved Oxygen	4.00	8.24	0.00	0.00			
					NH3-N	25.00	0.00	0.00	0.70			

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A		42546 Trib 42546 to Allegheny River			0.580	965.31	0.24	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10 0.006 0.00 0.00 0.000 0.000 0.0 0.00 0.00 25.00 7.00 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000										
<b>Discharge Data</b>										
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
0.0000 0.0000 0.0000 0.000 25.00 7.00										
<b>Parameter Data</b>										
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5 Dissolved Oxygen NH3-N				25.00	2.00	0.00	1.50			
3.00 25.00				8.24	0.00	0.00				
				0.00	0.00	0.70				

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5.5		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
18A			42546			Trib 42546 to Allegheny River							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
0.960	0.00	0.00	0.00	.0402	0.03237	.35	1.42	4.07	0.08	0.287	20.02	7.50	
<b>Q1-10 Flow</b>													
0.960	0.00	0.00	0.00	.0402	0.03237	NA	NA	NA	0.08	0.287	20.01	7.50	
<b>Q30-10 Flow</b>													
0.960	0.00	0.00	0.00	.0402	0.03237	NA	NA	NA	0.08	0.286	20.03	7.49	

## WQM 7.0 Wasteload Allocations

SWP Basin		Stream Code		Stream Name						
18A		42546		Trib 42546 to Allegheny River						
NH3-N Acute Allocations										
RMI	Discharge Name		Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
0.960	Outfall 001		9.26	9.28	9.26	9.28	0	0		
NH3-N Chronic Allocations										
RMI	Discharge Name		Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
0.960	Outfall 001		1.4	1.4	1.4	1.4	0	0		
Dissolved Oxygen Allocations										
RMI	Discharge Name		CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
			Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.96	Outfall 001		25	25	1.4	1.4	6	6	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>				
		18A	42546	Trib 42546 to Allegheny River		
<u>RMI</u>			<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		
0.960			0.026	20.020		
<u>Reach Width (ft)</u>			<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		
1.423			0.350	4.065		
<u>Reach CBOD5 (mg/L)</u>			<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		
24.91			1.499	1.40		
<u>Reach DO (mg/L)</u>			<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		
6.009			28.105	Owens		
<u>Reach Travel Time (days)</u>				<u>Reach DO Goal (mg/L)</u>		
0.287				5.5		
			<b>Subreach Results</b>			
			TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
			0.029	23.86	1.37	6.59
			0.057	22.85	1.34	6.89
			0.086	21.89	1.32	7.07
			0.115	20.97	1.29	7.20
			0.143	20.09	1.27	7.29
			0.172	19.24	1.24	7.38
			0.201	18.43	1.22	7.45
			0.229	17.66	1.19	7.52
			0.258	16.91	1.17	7.59
			0.287	16.20	1.14	7.65

**WQM 7.0 Effluent Limits**

<b>SWP Basin</b>		<b>Stream Code</b>	<b>Stream Name</b>				
<b>18A</b>	<b>42546</b>	<b>Trib 42546 to Allegheny River</b>					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Efl. Limit 30-day Ave. (mg/L)	Efl. Limit Maximum (mg/L)	Efl. Limit Minimum (mg/L)
0.960	Outfall 001	PA0034185	0.026	CBOD5	25		
				NH3-N	1.4	2.8	
				Dissolved Oxygen			6

# Attachment 4

## WQM 7.0 Model -

## Winter

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42546 Trib 42546 to Allegheny River				0.960	1030.25	0.04	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
<b>Q7-10</b> 0.008 0.00 0.00 0.000 0.000 0.0 0.00 0.00 5.00 7.00 0.00 0.00 <b>Q1-10</b> 0.00 0.00 0.000 0.000 <b>Q30-10</b> 0.00 0.00 0.000 0.000										
<b>Discharge Data</b>										
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
		Outfall 001	PA0034185	0.0260	0.0260	0.0260	0.000	15.00	7.50	
<b>Parameter Data</b>										
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
				CBOD5	25.00	2.00	0.00	1.50		
				Dissolved Oxygen	4.00	12.54	0.00	0.00		
				NH3-N	25.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A		42546 Trib 42546 to Allegheny River			0.580	965.31	0.24	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10 0.011 0.00 0.00 0.000 0.000 0.0 0.00 0.00 5.00 7.00 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000										
<b>Discharge Data</b>										
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
0.0000 0.0000 0.0000 0.000 25.00 7.00										
<b>Parameter Data</b>										
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
				25.00	2.00	0.00	1.50			
				3.00	8.24	0.00	0.00			
				25.00	0.00	0.00	0.70			

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5.5		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
18A			42546			Trib 42546 to Allegheny River							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
0.960	0.00	0.00	0.00	.0402	0.03237	.35	1.42	4.07	0.08	0.286	14.92	7.49	
<b>Q1-10 Flow</b>													
0.960	0.00	0.00	0.00	.0402	0.03237	NA	NA	NA	0.08	0.286	14.95	7.50	
<b>Q30-10 Flow</b>													
0.960	0.00	0.00	0.00	.0402	0.03237	NA	NA	NA	0.08	0.285	14.89	7.49	

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
18A	42546	Trib 42546 to Allegheny River					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.960	Outfall 001	13.38	13.45	13.38	13.45	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.960	Outfall 001	1.95	1.98	1.95	1.98	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
0.96	Outfall 001	25	25	1.98	1.98	6	6
						0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18A	42546	Trib 42546 to Allegheny River		
<u>RMI</u> 0.960	<u>Total Discharge Flow (mgd)</u> 0.026	<u>Analysis Temperature (°C)</u> 14.919	<u>Analysis pH</u> 7.492	
<u>Reach Width (ft)</u> 1.425	<u>Reach Depth (ft)</u> 0.350	<u>Reach WDRatio</u> 4.066	<u>Reach Velocity (fps)</u> 0.081	
<u>Reach CBOD5 (mg/L)</u> 24.81	<u>Reach Kc (1/days)</u> 1.499	<u>Reach NH3-N (mg/L)</u> 1.96	<u>Reach Kn (1/days)</u> 0.473	
<u>Reach DO (mg/L)</u> 6.053	<u>Reach Kr (1/days)</u> 24.904	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 5.5	
<u>Reach Travel Time (days)</u> 0.286	<b>Subreach Results</b>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.029	23.99	1.93	7.15
	0.057	23.19	1.91	7.72
	0.086	22.41	1.88	8.03
	0.114	21.66	1.86	8.21
	0.143	20.94	1.83	8.33
	0.172	20.24	1.81	8.41
	0.200	19.57	1.78	8.48
	0.229	18.92	1.76	8.54
	0.257	18.28	1.74	8.59
	0.286	17.67	1.71	8.64

**WQM 7.0 Effluent Limits**

<b>SWP Basin</b>		<b>Stream Code</b>	<b>Stream Name</b>				
<b>18A</b>	<b>42546</b>	<b>Trib 42546 to Allegheny River</b>					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.960	Outfall 001	PA0034185	0.026	CBOD5	25		
				NH3-N	1.98	3.96	
				Dissolved Oxygen			6