

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0034193

APS ID

1103901

Authorization ID

1467580

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

Applicant Name	<u>Lake View CC</u>	Facility Name	<u>Lake View CC</u>
Applicant Address	<u>8351 Route 89</u>	Facility Address	<u>8351 Route 89 Box 468</u>
	<u>North East, PA 16428-5233</u>		<u>North East, PA 16428</u>
Applicant Contact	<u>Gordon Seliga</u>	Facility Contact	<u>Gorden Saliga</u>
Applicant Phone	<u>(814) 725-5554</u>	Facility Phone	<u>(814) 725-5554</u>
Client ID	<u>252118</u>	Site ID	<u>450775</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>North East Township</u>
Connection Status		County	<u>Erie</u>
Date Application Received	<u>December 26, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>NPDES renewal of an existing treated sewage discharge.</u>		

Summary of Review

This is an existing sewage treatment facility serving a golf course with a restaurant.

Existing treatment consists of: two (2) each, 550 gallon sludge holding tanks, associated piping and submersible pump in the existing aeration tank; a new erosion tablet chlorinator at the influent end of the CCT and a new sodium bisulfate, erosion tablet de-chlorinator on the CCT effluent pipe.

Annual monitoring for E. Coli has been added.

There are currently no open violations for this client as of 9/17/2025.

The EPA Waiver is in effect.

Act 14 – Proof of Notification was submitted and received.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	September 17, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	September 29, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	.01
Latitude	42° 10' 49.58"	Longitude	-79° 49' 14.99"
Quad Name	North East	Quad Code	42079B7
Wastewater Description: Sewage Effluent			
Receiving Waters	Sixteenmile Creek (CWF, MF)	Stream Code	63798
NHD Com ID	123924564	RMI	0.7900
Drainage Area	3.32	Yield (cfs/mi ²)	0.05
Q ₇₋₁₀ Flow (cfs)	0.166	Q ₇₋₁₀ Basis	Streamstats
Elevation (ft)	1153	Slope (ft/ft)	---
Watershed No.	15-A	Chapter 93 Class.	CWF, MF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Background/Ambient Data			
pH (SU)	7.0	Data Source	
Temperature (°F)	20	Default	
Hardness (mg/L)	100	Default	
Other:			
Nearest Downstream Public Water Supply Intake			
PWS Waters	Lake Erie	Flow at Intake (cfs)	N/A
PWS RMI	N/A	Distance from Outfall (mi)	7.5

Changes Since Last Permit Issuance: None.

Other Comments: None.

Treatment Facility Summary				
Treatment Facility Name: Lake View Cc				
WQM Permit No.		Issuance Date		
368-S-037		9 September 1968		
368-S-037 A1		6 May 2010		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Hypochlorite	0.01
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.01	20	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: None.

Other Comments:

368-S-037 is for comminution, aeration (now with submersible pump discharging to new sludge holding tanks), settling (with return to aeration), and chlorination. Design is for 200 people, 200-mg/L TSS and 20-PPD BOD. Approval and issuance date as on the application is 9 September 1968. Applicant was Lakeview Developments, Inc.

368-S-037 A-1 for two 550-gallon aerated sludge holding tanks, sodium bisulfate de-chlorination and chlorinator replacement. The chlorinator is at the chlorine contact tank influent end and de-chlorinator is at the chlorine contact tank effluent end. Design is by August Maas of Hill Engineers.

Development of Effluent Limitations

Outfall No. 001
Latitude 42° 10' 50.70"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .01
Longitude -79° 49' 16.10"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report	IMAX	-	92a.61

Comments: Existing TRC limits were corroborated using the Department's TRC spreadsheet. Monitoring for E. Coli has been added in accordance with Chapter 92 regulations.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
CBOD ₅	25	Average Monthly	WQM 7.0, v1.1b
NH ₃ -N (May 1 – Oct 31)	6.0	Average Monthly	WQM 7.0, v1.1b
NH ₃ -N (Nov 1 – Apr 31)	18.0	Average Monthly	WQM 7.0, v1.1b
Dissolved Oxygen	4.0	Minimum	WQM 7.0, v1.1b

Comments: CBOD5, NH3-N and Dissolved Oxygen limits calculated from WQM modeling are consistent with the existing permit limits for these parameters.

Best Professional Judgment (BPJ) Limitations

Comments: N/A

Anti-Backsliding

N/A

Proposed Effluent Limitations and Monitoring Requirements


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	3/week	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	3/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.5	3/week	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	18.0	XXX	36.0	2/month	Grab
Ammonia May 1 - Oct 31	Report	XXX	XXX	6.0	XXX	12.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: None.





TRC Spreadsheet - Lake View CC

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.166 = Q stream (cfs)			0.5 = CV Daily		
0.01 = Q discharge (MGD)			0.5 = CV Hourly		
30 = no. samples			1 = AFC_Partial Mix Factor		
0.3 = Chlorine Demand of Stream			1 = CFC_Partial Mix Factor		
0 = Chlorine Demand of Discharge			15 = AFC_Criteria Compliance Time (min)		
0.5 = BAT/BPJ Value			720 = CFC_Criteria Compliance Time (min)		
0 = % Factor of Safety (FOS)			=Decay Coefficient (K)		
Source	Reference	AFC Calculations	Reference	CFC Calculations	
TRC	1.3.2.iii	WLA_afc = 3.442	1.3.2.iii	WLA_cfc = 3.348	
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
PENTOXSD TRG	5.1b	LTA_afc = 1.283	5.1d	LTA_cfc = 1.946	
Effluent Limit Calculations					
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc		(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)			
LTAMULT_afc		EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)			
LTA_afc		wla_afc*LTAMULT_afc			
WLA_cfc		(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)			
LTAMULT_cfc		EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)			
LTA_cfc		wla_cfc*LTAMULT_cfc			
AML_MULT		EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))			
AVG_MON_LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)			
INST_MAX_LIMIT		1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)			

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
15	63798	Trib 63798 to Sixteenmile Creek

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.750	Lake View CC	9.24	12	9.24	12	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.750	Lake View CC	1.87	6	1.87	6	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.75	Lake View CC	25	25	6	6	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
15	63798	Trib 63798 to Sixteenmile Creek		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.750	0.010	20.426	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
6.051	0.409	14.778	0.073	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
3.96	0.631	0.51	0.723	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.881	19.841	Owens	5	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.626	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.063	3.80	0.49	8.18
	0.125	3.65	0.47	8.18
	0.188	3.51	0.45	8.18
	0.250	3.37	0.43	8.18
	0.313	3.24	0.41	8.18
	0.376	3.11	0.39	8.18
	0.438	2.99	0.37	8.18
	0.501	2.87	0.36	8.18
	0.563	2.76	0.34	8.18
	0.626	2.65	0.33	8.18

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
15	63798	Trib 63798 to Sixteenmile Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.750	Lake View CC	PA0034193	0.010	CBOD5	25		
				NH3-N	6	12	
				Dissolved Oxygen			4

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC			
				(ft)	(sq mi)	(ft/ft)	(mgd)					
15		63798 Trib	63798 to Sixteenmile Creek	0.750	1153.00	3.32	0.00000	0.00	<input checked="" type="checkbox"/>			
Stream Data												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	pH	pH
Q7-10	0.050	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
Discharge Data												
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
	Lake View CC	PA0034193	0.0100	0.0100	0.0100	0.000	25.00	7.00				
Parameter Data												
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)							
	CBOD5	25.00	2.00	0.00	1.50							
	Dissolved Oxygen	4.00	8.24	0.00	0.00							
	NH3-N	6.00	0.00	0.00	0.70							

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC			
				(ft)	(sq mi)	(ft/ft)	(mgd)					
15		63798 Trib	63798 to Sixteenmile Creek	0.000	1007.00	3.62	0.00000	0.00	<input checked="" type="checkbox"/>			
Stream Data												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	pH	pH
Q7-10	0.050	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
Discharge Data												
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
			0.0000	0.0000	0.0000	0.000	25.00	7.00				
Parameter Data												
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)							
	CBOD5	25.00	2.00	0.00	1.50							
	Dissolved Oxygen	3.00	8.24	0.00	0.00							
	NH3-N	25.00	0.00	0.00	0.70							

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
15		63798		Trib 63798 to Sixteenmile Creek								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
0.750	0.17	0.00	0.17	.0155	0.03687	.409	6.05	14.78	0.07	0.626	20.43	7.00
Q1-10 Flow												
0.750	0.11	0.00	0.11	.0155	0.03687	NA	NA	NA	0.06	0.783	20.64	7.00
Q30-10 Flow												
0.750	0.23	0.00	0.23	.0155	0.03687	NA	NA	NA	0.09	0.534	20.32	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		