

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0034568  
 APS ID 1066333  
 Authorization ID 1401202

**Applicant and Facility Information**

Applicant Name	<u>Harbor Mobile Home Village &amp; Terrace Sales, Inc.</u>	Facility Name	<u>Harbor Terrace MHP</u>
Applicant Address	<u>203 Independence Lane New Castle, PA 16101-2883</u>	Facility Address	<u>State Route 422 New Castle, PA 16101-2883</u>
Applicant Contact	<u>William Cunningham, Owner (billcunningham724@yahoo.com)</u>	Facility Contact	<u>William Cunningham, Owner (billcunningham724@yahoo.com)</u>
Applicant Phone	<u>(724) 658-1000</u>	Facility Phone	<u>(724) 658-1000</u>
Client ID	<u>325698</u>	Site ID	<u>239472</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Union Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lawrence</u>
Date Application Received	<u>June 27, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of an existing NPDES Permit for an existing discharge of treated sanitary wastewater from a non-municipal sewer system.</u>		

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.  
 A Part II Water Quality Management permit is not required at this time.  
 The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into Sewers
- B. Right of Way
- C. Solids Handling
- D. Public Sewerage Availability
- E. Effluent Chlorine Optimization and Minimization

SPECIAL CONDITIONS:

- II. Solids Management

There are no open violations in effects associated with the subject Client ID (325698) as of 5/8/2023. [5/16/2023 CWY](#)

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	5/8/2023
X		Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager	5/16/2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0125</u>
Latitude	<u>41° 02' 09.00"</u>	Longitude	<u>-80° 24' 52.00"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to the Shenango River (WWF)</u>	Stream Code	<u>N/A</u>
NHD Com ID	<u>130025491</u>	RMI	<u>0.64</u>
Drainage Area	<u>3.3</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.053</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.1749</u>	Q <sub>7-10</sub> Basis	<u>calculated</u>
Elevation (ft)	<u>838</u>	Slope (ft/ft)	<u>0.005031</u>
Watershed No.	<u>20-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Impaired*</u>		
Cause(s) of Impairment	<u>Nutrients</u>		
Source(s) of Impairment	<u>Package Plants or Other Permitted Small Flow Discharges</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Pennsylvania American Water Company - New Castle</u>		
PWS Waters	<u>Shenango River</u>	Flow at Intake (cfs)	<u>16.2</u>
PWS RMI	<u>5.1</u>	Distance from Outfall (mi)	<u>5.0</u>

\* The aquatic life use of the receiving stream is impaired due to Nutrients from Package Plants or Other Permitted Small Flow Discharges. The Devites MHP, the Twilight MHP, and the Zoccoli MHP are all upstream of this site. It is believed the impairment to the stream is from sources upstream, especially since all three upstream MHPs have had compliance issues. Since the receiving stream is impaired due to Nutrients, the monitoring for Total Nitrogen and Total Phosphorus will remain unchanged.

Sludge use and disposal description and location(s): All sludge is hauled by the Pullium Sanitary Service to the Mahoning Township WWTP (NPDES No. PA0240095) and is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any

person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.0125 MGD of treated sewage from an existing non-municipal STP in Union Township, Lawrence County.

Treatment permitted under Water Quality Management (WQM) Permit No. 3772402 consists of the following: A comminutor with manually cleaned bypass screen, a 14,800 gallon aeration tank, a 2,486 gallon settling tank, and tablet chlorination with a 1,000 gallon contact tank.

**1. Streamflow:**

Unnamed Tributary to the Shenango River @ Outfall 001:

Drainage Area:	<u>3.3</u>	sq. mi.	(USGS StreamStats)
Yieldrate:	<u>0.053</u>	cfs	from 1/30/2006 WQPR
% of stream allocated:	<u>100%</u>	Basis:	No nearby discharges
Q <sub>7-10</sub> :	<u>0.1749</u>	cfs	(USGS StreamStats)

**2. Wasteflow:**

Maximum discharge: 0.0125 MGD = 0.0193 cfs

Runoff flow period: 16 hours Basis: Runoff flow for MHPs

24 hour flow: 0.0125 MGD x 24/16 = 0.01875 MGD = 0.029 cfs

The calculated stream flow (Q<sub>7-10</sub>) is greater than 3 times the permitted discharge flow. In accordance with the SOP, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were not evaluated for this facility.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

**3. Parameters:**

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH<sub>3</sub>-N, CBOD<sub>5</sub>, Dissolved Oxygen, and Total Residual Chlorine.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)  
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)  
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows between 0.002 MGD and 0.05 MGD.

e. Phosphorus

Chapter 96.5 does not apply. The previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61. The monitoring frequency will not be reduced from 1/quarter since the receiving stream is impaired for nutrients, per the SOP.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61. The monitoring frequency will not be reduced from 1/quarter since the receiving stream is impaired for nutrients, per the SOP.

g. Ammonia-Nitrogen (NH<sub>3</sub>-N)

Median discharge pH to be used: 7.2 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background NH<sub>3</sub>-N concentration: 0.1 mg/l

Basis: Default value

Calculated NH<sub>3</sub>-N Summer limits: 12.4 mg/l (monthly average)  
24.8 mg/l (instantaneous maximum)

Calculated NH<sub>3</sub>-N Winter limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 1). The winter limits are calculated as three times the summer limits, but since the technology-based limits would govern, they will be used. The calculated limits are less stringent than the current limits. Since the current limits are being attained, the previous, more restrictive limits will be retained.

h. CBOD<sub>5</sub>

Median discharge pH to be used: 7.2 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background CBOD<sub>5</sub> concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD<sub>5</sub> limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the limits above (see Attachment 1). The calculated limits are the same as the previous permit and will be retained.

i. Dissolved Oxygen (DO)

The Dissolved Oxygen minimum of 4.0 mg/l will be retained with this renewal. The technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

j. Disinfection

Ultraviolet (UV) light

Basis: N/A

TRC limits: 0.5 mg/l (monthly average)

1.6 mg/l (instantaneous maximum)

Basis: The TRC limits above were calculated using the Department's TRC Calculation Spreadsheet (see Attachment 2). The limits are the same as in the previous NPDES Permit and will be retained.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

4. **Reasonable Potential Analysis for Receiving Stream:**

A Reasonable Potential Analysis was not performed in accordance with State practices for Outfall 001 using the Department's Toxics Management Spreadsheet since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

**5. Reasonable Potential for Downstream Public Water Supply (PWS):**

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). Since no relevant sampling was provided, mass-balance calculations were not performed.

Nearest Downstream potable water supply (PWS): Pennsylvania American Water Company - New Castle

Distance downstream from the point of discharge: 5.0 miles (approximate)

Result: No limits or monitoring are necessary as there is significant dilution available.

**6. Anti-Backsliding:**

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

**7. Attachment List:**

Attachment 1 - WQ Modeling Printouts

Attachment 2 - TRC Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from April 1, 2022 to March 31, 2023)

Parameter	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22
Flow (MGD) Average Monthly	0.0095	0.0095	0.0095	0.0095	0.0095	0.0095	0.0095	0.0095	0.0095	0.0095	0.0095	0.0095
pH (S.U.) Instantaneous Minimum	7.0	6.84	6.49	6.72	7.11	7.58	7.47	6.74	6.71	6.79	7.12	7.16
pH (S.U.) Instantaneous Maximum	7.43	7.53	7.48	7.98	7.94	8.16	8.20	8.05	7.13	7.76	7.69	7.88
DO (mg/L) Instantaneous Minimum	6.09	5.04	5.69	6.06	5.02	5.01	4.51	3.24	4.51	4.77	5.19	4.65
TRC (mg/L) Average Monthly	0.4	0.4	0.50	0.30	0.30	0.30	0.40	0.1	0.4	0.36	0.3	0.30
TRC (mg/L) Instantaneous Maximum	0.6	0.5	0.50	0.47	0.51	0.44	0.46	0.46	0.46	0.51	0.5	0.49
CBOD5 (mg/L) Average Monthly	6.9	4.0	8.25	5.1	8.6	4.0	4.0	9.9	4.0	4.0	4.0	4.0
TSS (mg/L) Average Monthly	14	11.3	7.50	13.3	11.5	9.0	9.3	7.3	8.25	5.25	5.0	9.5
Fecal Coliform (No./100 ml) Geometric Mean	17	10	2.83	40	2	1.0	5.0	49	2.45	1.0	2.0	4.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	93	105	8.0	816	3	2	15	58	6.0	1	5.0	10
Total Nitrogen (mg/L) Average Quarterly	7.52			23.21			< 1.25			3		
Ammonia (mg/L) Average Monthly	0.30	0.30	0.30	6.0	1.0	1.25	0.30	10	0.30	0.30	0.30	3
Total Phosphorus (mg/L) Average Quarterly	0.959			2.97			4.32			1.0		

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	9.5	XXX	19	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite

Compliance Sampling Location: at Outfall 001, after disinfection.



Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The limits for Total Residual Chlorine (TRC) are technology based on Chapter 92a.47. The limits for CBOD<sub>5</sub>, Total Suspended Solids (TSS), and Fecal Coliforms are technology-based on Chapter 92a.47. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61.

Attachment 1

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
20A		35482		SHENANGO RIVER			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.640	Harbor Terrace	PA0034568	0.019	CBOD5	25		
				NH3-N	12.49	24.98	
				Dissolved Oxygen			4

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
20A	35482	SHENANGO RIVER	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
0.640	0.019	25.000	7.023
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
7.744	0.397	19.514	0.066
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
5.27	0.813	1.78	1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
7.036	21.936	Owens	5
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>		
0.589	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.059	4.96	1.67
	0.118	4.67	1.57
	0.177	4.40	1.48
	0.236	4.14	1.39
	0.295	3.90	1.31
	0.354	3.67	1.24
	0.413	3.46	1.16
	0.472	3.25	1.09
	0.531	3.06	1.03
	0.589	2.88	0.97

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	0.640	838.00	3.30	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.053	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Harbor Terrace	PA0034568	0.0188	0.0000	0.0000	0.000	25.00	7.20

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	0.000	821.00	4.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.053	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20A	35482	SHENANGO RIVER

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.640	Harbor Terrace	10.74	50	10.74	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.640	Harbor Terrace	1.36	12.49	1.36	12.49	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.64	Harbor Terrace	25	25	12.49	12.49	4	4	0	0

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20A		35482				SHENANGO RIVER						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
0.640	0.17	0.00	0.17	.029	0.00503	.397	7.74	19.51	0.07	0.589	25.00	7.02
<b>Q1-10 Flow</b>												
0.640	0.11	0.00	0.11	.029	0.00503	NA	NA	NA	0.05	0.725	25.00	7.03
<b>Q30-10 Flow</b>												
0.640	0.24	0.00	0.24	.029	0.00503	NA	NA	NA	0.08	0.507	25.00	7.02



Attachment 2

<b>TRC EVALUATION</b>					
Input appropriate values in A3:A9 and D3:D9					
0.1749	= Q stream (cfs)			0.5	= CV Daily
0.01875	= Q discharge (MGD)			0.5	= CV Hourly
30	= no. samples			1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream			1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge			15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value			720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)			0	= Decay Coefficient (K)
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 1.942		1.3.2.iii	WLA_cfc = 1.886
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.724		5.1d	LTA_cfc = 1.097
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e(-k*AFC\_tc)) + [(AFC\_Yc*Qs*.019/Qd*e(-k*AFC\_tc))... \\ ...+ Xd + (AFC\_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$				
LTA_afc	wla_afc*LTAMULT_afc				
WLA_cfc	$(.011/e(-k*CFC\_tc)) + [(CFC\_Yc*Qs*.011/Qd*e(-k*CFC\_tc))... \\ ...+ Xd + (CFC\_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no\_samples+1))-2.326*LN(cvd^2/no\_samples+1)^0.5)$				
LTA_cfc	wla_cfc*LTAMULT_cfc				
AML_MULT	$EXP(2.326*LN((cvd^2/no\_samples+1)^0.5)-0.5*LN(cvd^2/no\_samples+1))$				
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)				