

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0035653

APS ID

763592

Authorization ID

1497065

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

Applicant Name	PA DOT	Facility Name	PA DOT I70 Site 3 Rest Area
Applicant Address	400 North Street, 6th Floor Harrisburg, PA 17120	Facility Address	Interstate I70 Eb Brush Creek Twp Fulton Co, PA 17563
Applicant Contact	Nicholaus Sahd	Facility Contact	Dennis Clark
Applicant Phone	(717) 951-8685	Facility Phone	(717) 485-3816
Client ID	134834	Site ID	456184
Ch 94 Load Status	Not Overloaded	Municipality	Brush Creek Township
Connection Status		County	Fulton
Date Application Received	August 27, 2024	EPA Waived?	Yes
Date Application Accepted	August 29, 2024	If No, Reason	
Purpose of Application	NPDES permit renewal.		

Summary of Review

PA Department of Transportation Rest Area Site 3 wastewater treatment plant has applied to the Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit No. PA0035653. The permit was issued on February 24, 2020, and became effective on March 1, 2020. The Department received the NPDES renewal permit application on August 29, 2024. The existing permit expiration date was February 28, 2025.

The permit authorized discharge of treated sewage from the existing wastewater treatment plant (WWTP) located in Brush Creek Township, Fulton County to Unnamed Tributary to Brush Creek.

This facility has a current hydraulic design capacity flow and average annual design flow of 0.0065 MGD.

The original WQM Part II 2991402 was issued on February 26, 1992.

Sludge use and disposal description and location(s): N/A because sludge hauling by Smith's Septic & Kline's Septic Services.

Changes from the previous permit: The E. Coli monitoring and report requirements will add to the proposed permit.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	January 31, 2025
X		Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager	February 4, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	0.0065
Latitude	39° 55' 22.40"	Longitude	-78° 14' 8.34"
Quad Name	Breezewood	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to Brush Creek (HQ-CWF)	Stream Code	14178
NHD Com ID	65849449	RMI	0.34
Drainage Area	0.84 mi. ²	Yield (cfs/mi ²)	See comments below
Q ₇₋₁₀ Flow (cfs)	See comments below	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	1240	Slope (ft/ft)	
Watershed No.	11-C	Chapter 93 Class.	HQ-CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	Saxton Borough Municipal Authority, Bedford County		
PWS Waters	Raystown Branch Juniata River	Flow at Intake (cfs)	
PWS RMI	42.5 miles	Distance from Outfall (mi)	Approximate 52 miles

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Unnamed Tributary (14334) to Brush Creek (14178) at RMI 0.34 mile. A drainage area upstream of the discharge is estimated to be 0.84 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

There are no nearby stream gages with low flow data that have extensive or recent periods of record. Since USGS PA StreamStats estimated the drainage area that is below the minimum value allowed by USGS's regression equations, the USGS gage station No. 01565000 on Juniata River watershed located in Mifflin Borough will be used to calculate the Q₇₋₁₀ at the point of discharge using a low flow yield method. The Q₇₋₁₀ here is 336 cfs and the drainage area is 2,840 mi.² which results in a Q₇₋₁₀ low flow yield of 0.12 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned} \text{Low Flow Yield} &= Q_{7-10\text{gage}} / \text{Drainage Area}_{\text{gage}} = 336 \text{ cfs} / 2840 \text{ mi.}^2 = 0.12 \text{ cfs/mi.}^2 \\ Q_{7-10\text{discharge}} &= 0.12 \text{ cfs/mi.}^2 * \text{Drainage Area}_{\text{discharge}} = 0.12 \text{ cfs/mi.}^2 * 0.84 \text{ mi.}^2 = 0.10 \text{ cfs} \\ Q_{30-10} &= 1.36 * Q_{7-10\text{discharge}} = 1.36 * 0.1 \text{ cfs} = 0.136 \text{ cfs} \\ Q_{1-10} &= 0.64 * Q_{7-10\text{discharge}} = 0.64 * 0.1 \text{ cfs} = 0.064 \text{ cfs} \end{aligned}$$

Unnamed Tributary 14178 to Brush Creek

Under 25 Pa Code § 93.9n, the unnamed tributary to Brush Creek is designated as High Quality-Cold Water Fishes (HQ-CWF). However, the discharge has existed since 1970 and does not require compliance in HQ requirements until an expansion or upgrade would be requested.

Potable Water Supply Intake

The nearest downstream public water supply intake is the Saxton Borough Municipal Authority intake on the Raystown Branch Juniata River, Bedford County approximately 52 miles from the point of discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: PA DOT - Rest Area 3 - I-70				
WQM Permit No.	Issuance Date			
2991402	2/26/1992			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0065		Not Overloaded	Aerobic Digestion	Combination of methods

Changes Since Last Permit Issuance:

Other Comments:

The treatment process is as follows: Comminutor (1) - Bar Screen (1) – Equalization Tank (1) – Splitter Box (1) - Aeration Tanks (2) – Clarifiers (2) - Dosing Tank (1) – Sand Filters (4) - Chlorine Contact Tank (1) – Post Aeration Tank (1) – Sludge Holding Tank (1) - Discharge (Outfall to Unnamed Tributary to Brush Creek).

Magnesium hydroxide is used for alkalinity supplementation and sodium hypochlorite is used for disinfection. A sludge holding tank is used for solids storage.

Compliance History	
Summary of DMRs:	DMRs reported last 12 months are summarized in the next page.
Summary of Inspections:	9/26/2024: Mr. Clark, DEP Water Quality Specialist, conducted a compliance evaluation inspection. The effluent looks clear and field test results were within the permit limits. The facility needs to repair the composite sampler or start taking composite samples by hand. Effluent samples can be composited by hand by combining four different grab samples, taken every two hours, over an eight-hour period. The four individual grab times need to be recorded in the operations logbook. There was violation noted during the inspection such as failure to monitor pollutants as required by the NPDES permit (not collecting 8-hour composite sample).
Other Comments:	There are currently 5 open violations associated with the permittee or the facility. <ul style="list-style-type: none"> - 6/22/2022: three violations codes: 92A.41(A)8, 271.918, & 92A.41(A)12B. - 8/17/2023: one violation code 92A.44. - 9/26/2024: one violation code 92A.61(C).

Other Comments: [REDACTED]

Compliance History

DMR Data for Outfall 001 (from December 1, 2023 to November 30, 2024)

Parameter	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23
Flow (MGD) Average Monthly	0.01460	0.00164 6	0.00219 4	0.00198 5	0.00116 2	0.00234 9	0.00197 2	0.00087 2	0.00139 0	0.00154 4	0.00135 0	0.00095 2
Flow (MGD) Daily Maximum	0.00358	0.00394	0.00344	0.00915	0.00236	0.00465	0.00338	0.00139	0.00230	0.00227	0.00327	0.00214
pH (S.U.) Daily Minimum	6.2	7.1	6.9	7.2	7.1	7.2	7.3	7.2	7.1	7.3	7.1	7.5
pH (S.U.) Instantaneous Maximum	8.1	7.9	7.8	7.8	7.8	8.0	7.8	8.1	7.6	7.8	7.5	7.9
DO (mg/L) Daily Minimum	8.6	8.6	7.8	4.9	5.2	7.8	9.7	8.4	9.4	10.2	9.6	8.8
TRC (mg/L) Average Monthly	0.23	0.23	0.23	0.23	0.25	0.16	0.23	0.23	0.23	0.23	0.23	0.23
TRC (mg/L) Instantaneous Maximum	0.35	0.26	0.40	0.43	0.51	0.28	0.26	0.26	0.27	0.29	0.26	0.26
CBOD5 (mg/L) Average Monthly	< 5.5	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
TSS (mg/L) Average Monthly	2.2	6.8	< 1.6	< 3.4	< 2.8	< 1.6	2.4	< 2.4	4.6	< 3.2	< 1.6	< 3.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1	3	< 1	< 1	< 2	1773	< 5	< 3	< 1	< 1	26	328
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	6	< 1	< 1	< 4	2420	21	9	< 1	< 1	689	579
Total Nitrogen (lbs/day) Total Annual												< 0.405
Total Nitrogen (mg/L) Annual Average												< 41.59
Ammonia (mg/L) Average Monthly	< 0.56	0.68	< 0.10	< 0.21	< 0.71	< 0.10	< 0.10	< 0.27	< 0.16	< 0.10	< 0.10	< 0.10
Total Phosphorus (lbs/day) Total Annual												0.023

NPDES Permit Fact Sheet
PA DOT I70 Site 3 Rest Area

NPDES Permit No. PA0035653

Total Phosphorus (mg/L) Annual Average												2.34
--	--	--	--	--	--	--	--	--	--	--	--	------

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)			Instant. Maximum	Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum			
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.23	XXX	0.74	1/day	Grab
CBOD ₅	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	21	XXX	42	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	7.0	XXX	14	2/month	8-Hr Composite
Total Nitrogen	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Phosphorus	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 55' 22.40"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.0065
Longitude -78° 14' 8.34"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: [REDACTED]

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃-N calculations were first based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached computer model of the stream:

- Discharge pH = 7.0 (Default)
- Discharge Temperature = 25°C (Default)
- Stream pH = 7.0 (Default)
- Stream Temperature = 20°C (Default)
- Background NH₃-N = 0 (Default)

Analysis Results WQM 7.0

RMI	Discharge Name	Permit Number	Disc Flow (mgd)																
0.34	PA DOT Rest 3	PA0035653	0.0065																
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Effluent Limit 30 Day Average (mg/L)</th> <th>Effluent Limit Maximum (mg/L)</th> <th>Effluent Limit Minimum (mg/L)</th> </tr> </thead> <tbody> <tr> <td>CBOD5</td> <td>25</td> <td></td> <td></td> </tr> <tr> <td>NH3-N</td> <td>25</td> <td>50</td> <td></td> </tr> <tr> <td>Dissolved Oxygen</td> <td></td> <td></td> <td>5</td> </tr> </tbody> </table>				Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)	CBOD5	25			NH3-N	25	50		Dissolved Oxygen			5
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)																
CBOD5	25																		
NH3-N	25	50																	
Dissolved Oxygen			5																
Record: 14 < 1 of 1 > No Filter Search																			
Print		< Back																	
Next >		Archive																	
Cancel																			

The printout of the WQM 7.0 output indicates that at a discharge of 0.0065 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 25.0 mg/L NH₃-N as a monthly average and 50.0 mg/L NH₃-N instantaneous maximum are necessary to protect the aquatic life from toxicity effects. Winter limit is 3 times the summer limit. Therefore, the existing summer limits 7.0 mg/L AML & 14.0 mg/L IMAX are more stringent and will remain in the proposed permit.

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

Only the minimum treatment requirements of secondary treatment will be necessary to protect water quality. The existing limits of 25.0 mg/L average monthly and 50.0 mg/L instantaneous maximum will remain in the renewal permit. Past DMRs and inspection reports show that the facility has been consistently achieving concentrations under these limits.

Dissolved Oxygen (D.O.):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

Total Suspended Solids (TSS):

The existing limits of 30.0 mg/L average monthly and 60.0 mg/L instantaneous maximum will remain in the renewal permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Past DMRs and inspection reports show that the facility has been consistently achieving concentrations under these limits.

pH:

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa. Code § 95.2(2).

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Chesapeake Bay Strategy:

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases I, II, and III) dischargers will receive annual loading caps based on their design flow on August 29, 2005, and concentrations of 6 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase IV (0.2 - 0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly and Phase V (below 0.2 MGD) will monitor during current permit renewal once a year. However, any facility in Phases IV and V that undergoes expansion is subjected to cap load right away. This plant is classified as a phase V, will be required to monitor and report TP and TN once a year.

Toxic:

This is a minor sewage facility receiving domestic wastewater only and the current application does not require sampling of toxic pollutants (or heavy metals) for those facilities with design flows less than 0.1 MGD. Therefore, no reasonable potential analysis for toxic pollutants has been performed for this permit renewal.

Total Residual Chlorine (TRC):

Based on the attached TRC Excel Spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), indicated a monthly average limit of 0.5 mg/L and an instantaneous maximum limit of 1.64 mg/L. Therefore, the existing limits 0.23 mg/L AML & 0.74 mg/L IMAX were more stringent and will remain in the proposed permit. Based on the DMRs from the past year, the facility has been consistently achieving this limit.

TRC EVALUATION

Input appropriate values in A3:A9 and D3:D9

0.1	= Q stream (cfs)	0.5	= CV Daily
0.0065	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)

Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 3.191	1.3.2.iii	WLA_cfc = 3.104
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 1.189	5.1d	LTA_cfc = 1.804

Source	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.231	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635	

WLA_afc $(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$

LTAMULT_afc $EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$

LTA_afc $wla_afc*LTAMULT_afc$

WLA_cfc $(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$

LTAMULT_cfc $EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$

LTA_cfc $wla_cfc*LTAMULT_cfc$

AML_MULT $EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$

AVG_MON_LIMIT $MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$

INST_MAX_LIMIT $1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$

Additional Consideration

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the proposed permit per 40 CFR § 122.44(i)(1)(ii).

Monitoring Frequency and Sample Type

The facility currently is required to collect daily effluent grab samples for D.O., TRC, and pH; bi-monthly effluent 8-hr composite samples of CBOD₅, TSS, and ammonia-nitrogen; bi-monthly effluent grab samples of fecal coliform, annually effluent 8-hr composite samples of TP; and annually effluent calculation samples of TN. Based on the best professional judgement of the author, the existing monitoring frequencies are sufficient and necessary. Therefore, the renewal permit monitoring frequencies will remain the same as those specified in the existing permit.

Antidegradation (93.4)

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No Exceptional Value Waters are impacted by this discharge.

303d Listed Streams

This discharge is not located on a 303d listed stream segment.

Class A Wild Trout Fisheries


No Class A Wild Trout Fisheries are impacted by this discharge.

Anti-Backsliding

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as existing permit requirements in accordance with 40 CFR §122.44(l)(1).

- Discharge pH	=	7	(Default)
- Discharge Temperature	=	25°C	(Default)
- Stream pH	=	7.0	(Default)
- Stream Temperature	=	20°C	(Default)
- Background NH ₃ -N	=	0	(Default)

1. Outfall 001 on Unnamed Trib (14334) to Brush Creek (14178)
 - a. Elevation: 1240 ft
 - b. RMI: 0.34 mile
 - c. Drainage Area: 0.84 mi.²
 - d. Low Flow Yield: 0.12 cfs/mi.²
 - e. Discharge Flow: 0.0065 MGD
2.
 - a. Elevation: 1170 ft
 - b. RMI: 0.10 mile
 - c. Drainage Area: 0.93 mi.²
 - d. Low Flow Yield: 0.12 cfs/mi.²
 - e. Discharge Flow: 0.000 MGD.



NPDES Permit Fact Sheet

PA DOT I70 Site 3 Rest Area

NPDES Permit No. PA0035653

USGS StreamStats

SELECT A STATE / REGION Pennsylvania

IDENTIFY A STUDY AREA Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- ✓ Basin Characteristics Report
- ✓ Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Parameter Code Parameter Description Value Unit

CARBON	Percentage of area of carbonate rock	18.67	percent
DRNAREA	Area that drains to a point on a stream	2840	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.5	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.94	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	2840	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4
STRDEN	Stream Density	1.94	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	18.67	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	504	ft ³ /s
30 Day 2 Year Low Flow	609	ft ³ /s
7 Day 10 Year Low Flow	336	ft ³ /s
30 Day 10 Year Low Flow	407	ft ³ /s
90 Day 10 Year Low Flow	521	ft ³ /s

USGS StreamStats

SELECT A STATE / REGION Pennsylvania

IDENTIFY A STUDY AREA Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- ✓ Basin Characteristics Report
- ✓ Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Parameter Code Parameter Description Value Unit

CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	0.84	square miles
PRECIP	Mean Annual Precipitation	40	inches
ROCKDEP	Depth to rock	4.5	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.26	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.84	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	40	inches	35	50.4
STRDEN	Stream Density	1.26	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0832	ft ³ /s
30 Day 2 Year Low Flow	0.117	ft ³ /s
7 Day 10 Year Low Flow	0.0338	ft ³ /s
30 Day 10 Year Low Flow	0.0476	ft ³ /s
90 Day 10 Year Low Flow	0.0835	ft ³ /s

NPDES Permit Fact Sheet

PA DOT I70 Site 3 Rest Area

NPDES Permit No. PA0035653

USGS StreamStats

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Zoom Level: 15 Map Scale: 1:18,000,000 Lat: 39.9021, Lon: -77.0300 R

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	0.93	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.66	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.93	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4
STRDEN	Stream Density	1.66	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.4	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.063	ft³/s
30 Day 2 Year Low Flow	0.0912	ft³/s
7 Day 10 Year Low Flow	0.0243	ft³/s
30 Day 10 Year Low Flow	0.0352	ft³/s
90 Day 10 Year Low Flow	0.0635	ft³/s



Batch Processor
Report
About
Help

Layers

Base Maps

Application Layers

National Layers

PA Map Layers

Analysis Results WQM 7.0

Hydrodynamics **NH3-N Allocations** **D.O. Allocations** **D.O. Simulation** **Effluent Limitations**

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.34	PA DOT Rest 3	PA0035653	0.0065

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	25	50	
Dissolved Oxygen			5

Record: 1 of 1

Print **< Back** **Next >** **Archive** **Cancel**

NPDES Permit Fact Sheet
PA DOT I70 Site 3 Rest Area

NPDES Permit No. PA0035653

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name
11C	14178	BRUSH CREEK

RM#	Name	Permit Number	Disch. Flow (mgd)	Parameter	EM Limit 30-day Ave. (mg/L)	EM Limit Maximum (mg/L)	EM Limit Minimum (mg/L)
0.340	PA DOT Site 3	PA0035653	0.007	CBOD5	25	50	
				NH3-N	25	50	
				Dissolved Oxygen	5		

Thursday, January 30, 2025 Version 1.1 Page 1 of 1

rpt_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name
11C	14178	BRUSH CREEK

NH3-N Allocations						
RM#	Discharge Name	Baseline Criterion (mg/L)	WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach Percent Reduction
0.340 PA DOT Site 3		15.85	00	15.85	50	0 0

NH3-N Chronic Allocations						
RM#	Discharge Name	Baseline Criterion (mg/L)	WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach Percent Reduction
0.340 PA DOT Site 3		1.85	25	1.85	25	0 0

Dissolved Oxygen Allocations						
RM#	Discharge Name	Baseline Criterion (mg/L)	WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach Percent Reduction
0.340 PA DOT Site 3		25	25	25	25	5 0 0

Thursday, January 30, 2025 Version 1.1 Page 1 of 1

Page: 1 No Filter

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name
11C	14178	BRUSH CREEK

RM#	Total Discharge Flow (mgd)	Atmos. Temperature (°C)	Atmos. RH%
0.340	0.007	26.456	7.000
Reach Wdth (ft)	Reach Depth (ft)	Reach Wdth (ft)	Reach Velocity (fps)
3724	0.360	9.726	
Reach CBOD5 (mg/L)	Reach Kc (1/day)	Reach NH3-N (mg/L)	Reach Kn (1/day)
4.09	0.779	2.27	0.725
Reach DO (mg/L)	Reach Kt (1/day)	N/A	Reach DO Goal (mg/L)
7.949	0.169		5
Reach Tavel Time (days)			

Subreach Results				
Time	CBOD5	NH3-N	D.O.	
(mg/L)	(mg/L)	(mg/L)	(mg/L)	
0.019	4.03	2.24	8.17	
0.036	3.97	2.21	8.17	
0.057	3.91	2.18	8.17	
0.075	3.84	2.15	8.17	
0.092	3.79	2.12	8.17	
0.113	3.73	2.09	8.17	
0.132	3.68	2.06	8.17	
0.151	3.62	2.03	8.17	
0.170	3.57	2.01	8.17	
0.189	3.52	1.98	8.17	

Thursday, January 30, 2025 Version 1.1 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameters	Value	Notes
WLA Method	DMRR	Use Inputted Q1-10 and Q30-10 Flows
Q140-QT40 Ratio	0.61	Use Inputted W/L Ratio
Q30-10-QT40 Ratio	1.36	Use Inputted Reach Travel Times
D.O. Saturation	90.0%	Temperature Adjust If
D.O. Goal	5	Use Balanced Technology

Thursday, January 30, 2025 Version 1.1 Page 1 of 1

Page: 1 No Filter

NPDES Permit Fact Sheet
PA DOT I70 Site 3 Rest Area

NPDES Permit No. PA0035653

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin		Stream Code		Stream Name								
11C	14170			BRUSH CREEK								
Run	Streams	PWS	Net	Dis-	Reach	Depth	Width	W.D.	Velocity	Reach	Acute	Analys
	Flow	With	Stream	Analys	Slope	(ft)	(ft)	Ratio	(fps)	Time	Temp	ph
	(cfs)	(cfs)	(cfs)	(ft)	(ft)	(ft)	(ft)		(ft/s)	(days)	(°C)	

Q7-10 Flow
0.340 0.10 0.00 0.10 .0101 0.02534 .363 3.72 9.73 0.08 0.169 20.45 7.00

Q1-10 Flow
0.340 0.06 0.00 0.06 .0101 0.02534 NA NA 0.06 0.256 20.67 7.00

Q30-10 Flow
0.340 0.14 0.00 0.14 .0101 0.02534 NA NA 0.09 0.161 20.34 7.00

rptGeneral

Input Data WQM 7.0

SWP Basin		Stream Code		Stream Name						Run	Elevation	Drainage	Slope	PWS	Apply
11C	14170			BRUSH CREEK						340	130.00	0.64	0.00000	0.00	<input checked="" type="checkbox"/>
Design	LFY	Trib	Stream	Run	Rich	Rich	W.D.	Rich	Depth	Temp	Tributary	Temp	Temp	Withdrawal	Appl. PC
Cond.	(cfs)	Flow	Flow	Time	Velocity	Width	Ratio	Velocity	(ft)	(°C)	pH	(°C)	(°C)	(mgd)	
	(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)		(ft/s)	(ft)	(°C)					

Q7-10 0.120 0.00 0.00 0.000 0.000 0.0 0.00 0.000 0.0 0.00 20.00 7.00 0.00 0.00

Q1-10 0.00 0.00 0.00 0.000 0.000 0.0 0.00 0.000 0.0 0.00 20.00 7.00 0.00 0.00

Q30-10 0.00 0.00 0.00 0.000 0.000 0.0 0.00 0.000 0.0 0.00 20.00 7.00 0.00 0.00

Discharge Data

Name	Permit Number	Existing	Permitted	Design	Design	Revere	Disc	Disc
		Disc	Disc	Disc	Disc	Factor	Temp	pH
		(mgd)	(mgd)	(mgd)	(mgd)		(°C)	
PA DOT Site 3	PA0035653	0.0000	0.0000	0.0000	0.0000	0.0000	25.00	7.00

Parameter Data

Parameter Name	Disc	Trib	Stream	Rate
	Conc.	Conc.	Conc.	Coef.
	(mg/L)	(mg/L)	(mg/L)	(1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NO3-N	25.00	0.00	0.00	0.70

Thursday, January 30, 2025

Version 1.1

Page 1 of 1

Thursday, January 30, 2025

Version 1.1

Page 1 of 2

rptGeneral

Input Data WQM 7.0

SWP Basin		Stream Code		Stream Name						Run	Elevation	Drainage	Slope	PWS	Apply
11C	14170			BRUSH CREEK						110	170.00	0.93	0.00000	0.00	<input checked="" type="checkbox"/>
Design	LFY	Trib	Stream	Run	Rich	Rich	W.D.	Rich	Depth	Temp	Tributary	Temp	Temp	Withdrawal	Appl. PC
Cond.	(cfs)	Flow	Flow	Time	Velocity	Width	Ratio	Velocity	(ft)	(°C)	pH	(°C)	(°C)	(mgd)	
	(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)		(ft/s)	(ft)	(°C)					

Q7-10 0.120 0.00 0.00 0.000 0.000 0.0 0.00 0.000 0.0 0.00 20.00 7.00 0.00 0.00

Q1-10 0.00 0.00 0.00 0.000 0.000 0.0 0.00 0.000 0.0 0.00 20.00 7.00 0.00 0.00

Q30-10 0.00 0.00 0.00 0.000 0.000 0.0 0.00 0.000 0.0 0.00 20.00 7.00 0.00 0.00

Discharge Data

Name	Permit Number	Existing	Permitted	Design	Design	Revere	Disc	Disc
		Disc	Disc	Disc	Disc	Factor	Temp	pH
		(mgd)	(mgd)	(mgd)	(mgd)		(°C)	
PA DOT Site 3	PA0035653	0.0000	0.0000	0.0000	0.0000	0.0000	25.00	7.00

Parameter Data

Parameter Name	Disc	Trib	Stream	Rate
	Conc.	Conc.	Conc.	Coef.
	(mg/L)	(mg/L)	(mg/L)	(1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NO3-N	25.00	0.00	0.00	0.70

Thursday, January 30, 2025

Version 1.1

Page 2 of 2

Page: 14 2 No Filter

13

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.23	XXX	0.74	1/day	Grab
CBOD ₅	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	21.0	XXX	42.0	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	7.0	XXX	14.0	2/month	8-Hr Composite
Total Nitrogen	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Phosphorus	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Compliance Sampling Location: 

Other Comments: 

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]