



Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0036889
APS ID 5082
Authorization ID 1493992

Applicant and Facility Information

Applicant Name	Reading Township Municipal Authority Adams County	Facility Name	Reading Township Adams County STP
Applicant Address	843 W Middle Street Hanover, PA 17331-5011	Facility Address	1010 N Browns Dam Road New Oxford, PA 17350-8705
Applicant Contact	Gary Bullock	Facility Contact	Ryan Swope
Applicant Phone	(717) 259-9998	Facility Phone	(717) 880-5738
Client ID	43791	Site ID	251152
Ch 94 Load Status	Not Overloaded	Municipality	Reading Township
Connection Status	No Limitations	County	Adams
Date Application Received	<u>July 30, 2024</u>	EPA Waived?	Yes
Date Application Accepted	<u>August 1, 2024</u>	If No, Reason	
Purpose of Application	NPDES permit renewal.		

Summary of Review

Keller Engineers, on behalf of the Reading Township Municipal Authority (Authority/Permittee), applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. The permit was reissued on January 28, 2020, and became effective on February 1, 2020. The permit expires on January 31, 2025.

The average annual design flow is 0.33 MGD, hydraulic design capacity of 0.42 MGD, and the organic loading capacity is 788 lbs BOD₅/day. The renewal application indicated the STP receives its 100% from the Reading Township.

The WQM Part II permit No. 0198401 was issued on 5/22/1998. The WQM Part II permit No. 0108404 pump station was issued on 1/16/2009. The WQM Part II permit No. 0111402 pump station was issued on 7/22/2011.

Sludge use and disposal description and location(s): N/A because sludge hauled by Peck's Septic Service.

Changes from the previous permit: E. Coli monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	December 19, 2024
X		Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager	January 27, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.33
Latitude	39° 55' 49.91"	Longitude	-77° 2' 22.48"
Quad Name	Hampton	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Conewago Creek (WWF)	Stream Code	08303
NHD Com ID	57471023	RMI	46.36 miles
Drainage Area	199 mi. ²	Yield (cfs/mi ²)	0.07
Q ₇₋₁₀ Flow (cfs)	14.0	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	418.63	Slope (ft/ft)	
Watershed No.	7-F	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Wrightsville Borough Municipal Authority, York County		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	28.52 miles	Distance from Outfall (mi)	Approximate 59.0 miles

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Conewago Creek at RMI 46.36 miles. A drainage area upstream of the discharge is estimated to be 199 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>. The Q7-10 is 14.0 cfs, then the low flow yield is 0.07 cfs/mi.²(14.0 cfs/199 mi.²).

Conewago Creek

Under 25 Pa. Code § 93.9o, the Conewago Creek is designated as Warm Water Fishes (WWF).

Potable Water Supply Intake

The nearest downstream public water supply intake is the Wrightsville Borough Municipal Authority, York County intake on the Susquehanna River, approximately 59.0 miles from the point of discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Reading Township STP				
WQM Permit No.		Issuance Date		
0198401		5/22/1998		
0108404		1/16/2009		
0111402		7/22/2011		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	Chlorine With Dechlorination	0.33
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.42	788	Not Overloaded		

Changes Since Last Permit Issuance:

Other Comments:

The WWTP train after construction will be as follows:

Heliscreen/Bar Screen (1) → SBR Tanks (2) → Chlorine Contact Tank (1) → De-chlorination → Discharge to Conewago Creek

Chemical used:

Sodium Aluminate is used for phosphorus removal at a rate of 9.0 gpd.

Industrial/Commercial Users:

The application lists a number of commercial/industrial users contributing wastewater to the existing sewer system.

Biosolids:

The total sewage sludge/biosolids production within the facility for the previous year was 25.42 dry tons.

Compliance History	
Summary of DMRs:	A summary of past 12-month DMR data is presented on the next page.
Summary of Inspections:	8/16/21: Mr. Bettinger, DEP WQS, conducted a compliance evaluation inspection. There were no violations noted during inspection. The field test results were within permit limits.
Other Comments:	There are currently no open violations associated with the permittee or the facility.

Other Comments: 

NPDES Permit Fact Sheet
Reading Township Adams County STP

NPDES Permit No. PA0036889

The table below summarizes the influent/effluent testing results submitted along with the application.

<i>Influent Testing Results</i>			<i>Effluent Testing Results</i>		
Parameter	Min/Max Value	Average Value	Parameter	Min/Max Value	Average Value
BOD ₅ (mg/L)	116/282 mg/L	192 mg/L	pH (minimum)	6.76 S.U.	
BOD ₅ (lbs/day)	115/384 lbs/day	181 lbs/day	pH (maximum)	8.57 S.U.	
TSS (mg/L)	114/290 mg/L	188 mg/L	D.O (minimum)	5.63 mg/L	6.92 mg/L
TSS (lbs/day)	110/315 lbs/day	178 lbs/day	TRC	0.01/0.48 mg/L	0.2 mg/L
TN (mg/L)	<56.8 mg/L	<56.8 mg/L	Fecal Coliform	2,420 No./100mL	
TN (lbs/day)	<31.26 lbs/day	<31.26 lbs/day	CBOD ₅	2.4/4.2 mg/L	2.43 mg/L
TP (mg/L)	6.0 mg/L	6.0 mg/L	TSS	1/9 mg/L	1.89 mg/L
TP (lbs/day)	3.3 lbs/day	3.3 lbs/day	NH ₃ -N	0.1/6.6 mg/L	0.6 mg/L
NH ₃ -N (mg/L)	34 mg/L	34 mg/L	TN	3.9/23.9 mg/L	12.96 mg/L
NH ₃ -N (lbs/day)	18.71 lbs/day	18.71 lbs/day	TP	0.12/2.4 mg/L	0.97 mg/L
TDS (mg/L)	578 mg/L	578 mg/L	Temp	50/75 F	63 F
TDS (lbs/day)	318.15 lbs/day	318.15 lbs/day	TKN	0.5/9.0 mg/L	1.36 mg/L
TKN	mg/L	mg/L	NO ₂ -N + NO ₃ -N	2.7/23.4 mg/L	11.6 mg/L
NO ₂ -N + NO ₃ -N	mg/L	mg/L	TDS	624 mg/L	624 mg/L
			Chloride	170 mg/L	170 mg/L
			Bromide	<0.2 mg/L	<0.2 mg/L
			Sulfate	86 mg/L	86 mg/L
			Oil and Grease	<5.0 mg/L	<5.0 mg/L
			Total Copper	0.006 mg/L	0.006 mg/L
			Total Lead	<0.001 mg/L	<0.001 mg/L
			Total Zinc	0.016 mg/L	0.016 mg/L

Compliance History

DMR Data for Outfall 001 (from November 1, 2023 to October 31, 2024)

Parameter	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23
Flow (MGD) Average Monthly	0.0952	0.0896	0.1752	0.0743	0.1176	0.1391	0.2305	0.2393	0.2102	0.2860	0.2308	0.1121
Flow (MGD) Daily Maximum	0.2632	0.1848	0.8738	0.1795	0.5758	0.2998	0.9825	0.6906	0.4275	0.8101	0.6956	0.4777
pH (S.U.) Daily Minimum	6.47	6.62	6.6	6.84	6.94	7.11	7.06	7.05	6.91	6.89	6.83	6.88
pH (S.U.) Instantaneous Maximum	6.94	7.27	7.13	7.29	7.51	7.41	7.58	7.68	7.59	7.52	7.47	7.44
DO (mg/L) Daily Minimum	6.16	5.91	5.81	5.67	6.01	6.42	7.20	7.67	8.81	7.33	6.92	6.12
TRC (mg/L) Average Monthly	0.22	0.22	0.20	0.22	0.21	0.22	0.23	0.22	0.23	0.21	0.19	0.20
TRC (mg/L) Instantaneous Maximum	0.36	0.35	0.30	0.35	0.32	0.54	0.36	0.32	0.40	0.48	0.48	0.30
CBOD5 (lbs/day) Average Monthly	< 2	< 2	< 3	< 1	< 3	< 3	< 4.0	< 3.85	3.96	6.80	< 4.34	3.20
CBOD5 (lbs/day) Weekly Average	4	< 3	< 7	2	< 7	< 5	< 7	5.09	4.94	16.21	< 6.36	10.36
CBOD5 (mg/L) Average Monthly	< 2	< 3	< 2	< 2	< 2	< 3	< 2	< 2.53	2.64	2.45	< 2.4	2.52
CBOD5 (mg/L) Weekly Average	3	3	2	3	< 2	3	3.0	2.90	3.20	2.60	< 2.4	2.80
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	187	165	167	150	309	179	197	198.75	157.49	269.58	253.40	384.38
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	237	276	196	227	643	219	237	235.32	166.87	506.72	516.84	1354.57
BOD5 (mg/L) Raw Sewage Influent Average Monthly	264	265	199	274	253	202	135	135.50	108.80	115.50	132.50	281.60
TSS (lbs/day) Average Monthly	1	2	1	1	2	2	3	4.33	2.85	4.69	2.55	1.23
TSS (lbs/day) Raw Sewage Influent Average Monthly	169	145	194	150	353	189	157	186.65	195.24	262.17	219.95	291.19

NPDES Permit Fact Sheet

NPDES Permit No. PA0036889

Reading Township Adams County STP

TSS (lbs/day) Raw Sewage Influent Daily Maximum	205	212	357	173	873	242	193	206.72	245.01	405.37	487.68	956.16
TSS (lbs/day) Weekly Average	2	4	3	1	3	6	6	6.89	5.92	6.76	3.46	3.98
TSS (mg/L) Average Monthly	2	2	1	2	2	2	2	3.0	1.80	2.25	1.50	1.00
TSS (mg/L) Raw Sewage Influent Average Monthly	242	244	197	277	256	205	122	132.00	134.40	121.00	114.00	234.40
TSS (mg/L) Weekly Average	4	3	1	3	2	3	2	6.0	3.00	4.00	2.00	1.00
Fecal Coliform (No./100 ml) Geometric Mean	< 6	< 3	< 1	< 14	< 14	< 5	16	10.86	3.99	23.24	12.57	9.50
Fecal Coliform (No./100 ml) Instantaneous Maximum	63	6	4	> 2420	> 2420	28	157	579.00	23.00	75.00	21.00	2420
Nitrate-Nitrite (lbs/day) Average Monthly	< 9	< 6	< 10	< 4	< 12	< 10	< 9	10.45	11.83	25.41	18.78	6.58
Nitrate-Nitrite (lbs/day) Daily Maximum	< 11	< 9	< 21	5	< 29	< 17	< 10	14.03	13.80	65.64	35.52	14.74
Nitrate-Nitrite (mg/L) Average Monthly	< 13.9	< 9	< 8.5	< 8.02	< 9.1	< 10.1	< 6.7	6.81	7.95	8.81	9.80	8.64
Nitrate-Nitrite (lbs) Total Monthly	< 293	< 167	< 300	< 137	< 362	< 310	< 282	324.08	343.03	787.81	582.25	197.32
Total Nitrogen (lbs/day) Average Monthly	< 10	< 6	< 10	< 5	< 13	< 11	< 13	17.04	17.80	29.30	19.69	8.93
Total Nitrogen (lbs/day) Daily Maximum	< 12	< 10	< 22	< 5	< 30	< 18	16	21.24	21.07	68.91	36.84	23.90
Total Nitrogen (mg/L) Average Monthly	< 14.44	< 9.66	< 9	< 8.67	< 9.6	< 10.81	< 8.97	11.51	11.97	10.68	10.30	10.14
Total Nitrogen (lbs) Total Monthly	< 307	< 180	< 319	< 148	< 383	< 330	< 401	528.36	516.16	908.23	610.29	267.77
Total Nitrogen (lbs) Total Annual		4867.15										
Ammonia (lbs/day) Average Monthly	< 0.08	< 0.07	< 0.1	< 0.06	< 0.1	< 0.1	3	4.96	4.76	2.37	0.25	1.39
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.12	1.79	3.45	3.22	1.29	0.13	0.93
Ammonia (mg/L) Instantaneous Maximum	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	0.19	2.9	5.0	4.2	3.5	0.17	2.1

NPDES Permit Fact Sheet

NPDES Permit No. PA0036889

Reading Township Adams County STP

Ammonia (lbs)	< 3	< 2	< 4	< 2	< 4	< 4	95	153.84	138.10	73.45	7.78	41.82
Total Monthly												
Ammonia (lbs)		528.30										
Total Annual												
TKN (lbs/day)												
Average Monthly	< 0.4	< 0.4	< 0.6	< 0.4	< 0.7	< 0.7	< 4	6.59	5.97	3.88	< 0.90	2.35
TKN (lbs/day)												
Daily Maximum	< 0.7	< 0.7	< 1	0.6	< 1	< 0.9	6	7.46	8.07	9.34	< 1.33	9.16
TKN (mg/L)												
Average Monthly	< 0.56	< 0.71	< 0.5	< 0.7	< 0.55	< 0.69	< 2.3	4.70	4.02	1.88	< 0.50	1.50
TKN (lbs)												
Total Monthly	< 13	< 13	< 19	< 11	< 20	< 20	< 119	204.28	173.13	120.42	28.04	70.45
Total Phosphorus (lbs/day)												
Average Monthly	1.0	0.9	1.0	0.9	2.0	1.0	1.0	0.94	0.83	1.97	0.58	1.01
Total Phosphorus (mg/L)												
Average Monthly	1.6	1.3	1.14	1.7	1.5	1.27	0.81	0.64	0.56	0.68	0.28	0.97
Total Phosphorus (mg/L)												
Instantaneous Maximum	1.9	1.4	1.2	1.8	1.9	1.7	1.4	1.1	0.74	0.82	0.58	1.3
Total Phosphorus (lbs)												
Total Monthly	38	26	40	29	53	37	33	29.07	23.98	61.06	17.92	30.19
Total Phosphorus (lbs)												
Total Annual		401.86										

Existing Effluent Limitations and Monitoring Requirements

Outfall 001.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.23	XXX	0.75	1/day	Grab
CBOD ₅	68	110 Wkly Avg	XXX	25	40	50	1/week	8-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	82	123 Wkly Avg	XXX	30	45	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Ammonia May 1 - Oct 31	19	XXX	XXX	7.0	XXX	14	1/week	8-Hr Composite
Ammonia Nov 1 - Apr 30	58	XXX	XXX	21	XXX	42	1/week	8-Hr Composite
Total Phosphorus	5.5	XXX	XXX	2.0	XXX	4.0	1/week	8-Hr Composite

NPDES Permit Fact Sheet

Reading Township Adams County STP

Chesapeake Bay requirement: Outfall 001, Continued

NPDES Permit No. PA0036889

Parameter	Effluent Limitations					Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)			Minimum Measurement Frequency	Required Sample Type
	Monthly	Annual	Minimum	Average Monthly	Instant. Maximum		
Ammonia—N	Report	Report	XXX	Report	XXX	1/week	8-Hr Composite
Kjeldahl—N	Report	XXX	XXX	Report	XXX	1/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	1/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	1/week	8-Hr Composite

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 55' 49.91"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.33
Longitude -77° 2' 22.48"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: [redacted]

Water Quality-Based Limitations

NH₃N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

- * Discharge pH = 7.0 (Default)
- * Discharge Temperature = 25°C (Default)
- * Stream pH = 7.0 (Default)
- * Stream Temperature = 20°C (Default)
- * Background NH₃-N = 0 mg/L (Default)

Analysis Results WQM 7.0

Hydrodynamics		NH ₃ -N Allocations		D.O. Allocations		D.O. Simulation		Effluent Limitations		
RMI	Discharge Name	Permit Number Disc Flow (mgd)								
46.36	Reading Twp	PA0036889 0.3300								
		Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)					
		CBOD ₅	25	50	5					
		NH ₃ -N	25	50	5					
		Dissolved Oxygen								
Record: 1 of 1 < Back Next > No Filter Search										
Print		< Back		Next >		Archive		Cancel		

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 25.0 mg/L as a monthly average and 50.0 mg/L instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects at the point of discharge. Therefore, the existing summer limits of 7.0 mg/L monthly average & 14.0 mg/L IMAX are more stringent and will remain in the proposed permit. The existing winter average monthly limit of 21.0 mg/L & IMAX limit of 42.0 mg/L will remain in place. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

Summer average monthly mass limit: 7.0 mg/L x 0.33 MGD x 8.34 = 19.265 (19.0) lbs/day
Winter average monthly mass limit: 21.0 mg/L x 0.33 MGD x 8.34 = 57.796 (58.0) lbs/day

Dissolved Oxygen (D.O.):

The minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BCW-PMT-033, version 2.0 revised February 5, 2024, and has been applied to other point source dischargers throughout the state.

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. Therefore, the existing summer permit 25.0 mg/L as AML, 40.0 mg/L as weekly average limit (AWL), & 50.0 mg/L as IMAX will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has typically been achieving concentrations below this limit. Mass limits are calculated as follows:

Summer Average monthly mass limit: 25.0 mg/L x 0.33 MGD x 8.34 = 68.80 (68.0) lbs/day
Summer Average weekly mass limit: 40.0 mg/L x 0.33 MGD x 8.34 = 110.09 (110.0) lbs/day

These values are rounded down to 68.0 lbs/day and 110.0 lbs/day, respectively. The minimum monitoring frequency will remain the same as 1/week.

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

Total Suspended Solids (TSS):

The existing technology-based limits of 30.0 mg/L average monthly, 45.0 mg/L weekly average, and 60.0 mg/L IMAX will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

Average monthly mass limit: 30.0 mg/L x 0.33 MGD x 8.34 = 82.57 (82.0) lbs/day
Average weekly mass limit: 45.0 mg/L x 0.33 MGD x 8.34 = 123.85 (123.0) lbs/day

The average monthly and weekly average mass loadings will be rounded down to 82.0 lbs/day and 123.0 lbs/day, respectively. The minimum monitoring frequency will remain the same as 1/week.

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/quarter will be included in the permit to be consistent with the recommendation from this SOP.

Raw Sewage Influent Monitoring:

As a result of negotiation with EPA, influent monitoring of TSS and BOD₅ are required for any POTWs; therefore, influent sampling of BOD₅ and TSS will remain in the proposed permit. A 24-hr composite sample type will be required to be consistent with the proposed sampling frequency for TSS and BOD₅ in the effluent.

Reading Township Adams County STP

Total Phosphorus:

The existing permit average monthly TP concentration of 2.0 mg/L, and 4.0 mg/L IMAX will remain in the proposed permit. Mass average monthly is calculated and also in the proposed permit.

Average monthly mass limit: 2.0 mg/L x 0.33 MGD x 8.34 = 5.504 (5.5) lbs/day

Stormwater:

There is no known stormwater outfall associated with this facility.

Total Residual Chlorine (TRC):

The attached computer printout utilizes the equations and calculations as presented in the Department's May 1, 2003 Implementation Guidance for TRC (ID No. 391-2000-015) for developing chlorine limitations. The attached printout indicates that a water quality limit of 0.5 mg/L monthly average and 1.6 mg/L IMAX would be needed to prevent toxicity concerns. Therefore, the existing TRC limit of 0.23 mg/L monthly average and 0.75 mg/L IMAX are more stringent and will remain in the proposed permit.

TRC EVALUATION									
Input appropriate values in A3:A9 and D3:D9									
14 = Q stream (cfs)				0.5 = CV Daily					
0.33 = Q discharge (MGD)				0.5 = CV Hourly					
30 = no. samples				1 = AFC_Partial Mix Factor					
0.3 = Chlorine Demand of Stream				1 = CFC_Partial Mix Factor					
0 = Chlorine Demand of Discharge				15 = AFC_Criteria Compliance Time (min)					
0.5 = BAT/BPJ Value				720 = CFC_Criteria Compliance Time (min)					
0 = % Factor of Safety (FOS)				=Decay Coefficient (K)					
Source	Reference	AFC Calculations			Reference	CFC Calculations			
TRC	1.3.2.iii	WLA_afc = 8.767			1.3.2.iii	WLA_cfc = 8.540			
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373			5.1c	LTAMULT_cfc = 0.581			
PENTOXSD TRG	5.1b	LTA_afc= 3.267			5.1d	LTA_cfc = 4.965			
Effluent Limit Calculations									
PENTOXSD TRG	5.1f	AML MULT = 1.231							
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500				BAT/BPJ			
		INST MAX LIMIT (mg/l) = 1.635							
WLA_afc		(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)							
LTAMULT_afc		wla_afc*LTAMULT_afc							
LTA_afc									
WLA_cfc		(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)							
LTAMULT_cfc		wla_cfc*LTAMULT_cfc							
LTA_cfc									
AML MULT		EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))							
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)							
INST MAX LIMIT		1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)							

Chesapeake Bay Requirement:

According to the Pennsylvania's Chesapeake Bay Tributary Strategy, this facility is categorized as a phase 4 facility, non-significant point source sewage discharges design annual average daily flow greater than or equal to 0.2 MGD but less than 0.4 MGD. The permittee has already performed two (2) year nutrient monitoring as required by the Strategy. However, the Department's new Supplement to Phase II Watershed Implementation Plan indicates that any renewed or amended permits for phase 4 facilities that do not increase in design flow will contain monitoring and reporting for Total Nitrogen and Total Phosphorus throughout the permit term at a frequency no less than monthly. Accordingly, monitoring requirements for nutrients will remain in the proposed permit.

Toxic:

DEP's current permit renewal application for minor sewage facilities requires sampling of Total Copper, Total Lead, and Total Zinc for facilities with a design flow greater than or equal to 0.1 MGD. The application reported non-detect sample results for these pollutants. Previously, a routine monitoring requirement were developed for Total Copper, Total Lead, Total Zinc and Osmotic Pressure. As none of these parameters has been considered pollutants of concern based on the review of DMR data, DEP removed this requirement during the last permit renewal. Consequently, DEP determined that there is no toxic pollutant of concern for this facility at this time.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Total Dissolved Solids

TDS and its associated solids including Bromide, Chloride, and Sulfate have become statewide pollutants of concern. The requirement to monitor these pollutants must be considered under the criteria specified in 25 Pa. Code § 95.10 and the following January 23, 2014 DEP Central Office Directive:

For point source discharges and upon issuance or reissuance of an individual NPDES permit:

-Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.

-Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.

CTA reported maximum concentrations of 624.0 mg/L for TDS and < 0.2 mg/L for Bromide. Accordingly, the requirement to monitor for these pollutants is not necessary.

WETT:

Minor facilities and facilities without a formal EPA approved pretreatment program are exempted from WETT.

Antidegradation Requirements:

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Anti-backsliding Requirements:

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as those specified in the existing permit.

WQM 7.0:

The following data were used in the attached computer model (WQM 7.0) of the stream:

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	25°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	20°C	(Default)
*	Background NH ₃ -N	=	0 mg/L	(Default)

Node 1: Outfall 001 Conewago Creek (08303)


Elevation:	418.63 ft (USGS National Map Viewer)
Drainage Area:	199.0 mi ² (USGS PA StreamStats)
River Mile Index:	46.36 (PA DEP eMapPA)
Low Flow Yield:	0.07 cfs/mi ²
Discharge Flow:	0.33 MGD

Node 2: At confluence with Unnamed Tributary 08800

Elevation:	415.79 ft (USGS National Map Viewer)
Drainage Area:	200.0 mi ² (USGS PA StreamStats)
River Mile Index:	44.50 (PA DEP eMapPA)
Low Flow Yield:	0.07 cfs/mi ²
Discharge Flow:	0.0 MGD

NPDES Permit Fact Sheet
Reading Township Adams County STP

NPDES Permit No. PA0036889



USGS StreamStats

SELECT A STATE / REGION Pennsylvania

IDENTIFY A STUDY AREA Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button.

Show Basin Characteristics

Select available reports to display:

- ✓ Basin Characteristics Report
- ✓ Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	3.5022	degrees
DRNAREA	Area that drains to a point on a stream	199	square miles
ROCKDEP	Depth to rock	4.7	feet
URBAN	Percentage of basin with urban development	3.6419	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]


Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	199	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	3.5022	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.7	feet	4.13	5.21
URBAN	Percent Urban	3.6419	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct (other - see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	28.9	ft^3/s	46	46
30 Day 2 Year Low Flow	39.2	ft^3/s	38	38
7 Day 10 Year Low Flow	14	ft^3/s	51	51
30 Day 10 Year Low Flow	19	ft^3/s	46	46
90 Day 10 Year Low Flow	32.2	ft^3/s	41	41



Low-Flow Statistics Citations



NPDES Permit Fact Sheet

Reading Township Adams County STP

NPDES Permit No. PA0036889



NPDES Permit Fact Sheet
Reading Township Adams County STP

NPDES Permit No. PA0036889

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	CONEWAGO CREEK					
RM#	Name	Permit Number	Disch. Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
46360	Reading Twp	PA0036889	0.330	CBOD5	25	25	50
				NH3N			
				Dissolved Oxygen		5	

Wednesday, December 18, 2024 Version 1.1 Page 1 of 1

rpt_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	CONEWAGO CREEK					
NH3-N Acute Allocations				NH3-N Chronic Allocations			
RM#	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
46360	Reading Twp	16.36	50	16.36	50	0	0
NH3-N Chronic Allocations				Dissolved Oxygen Allocations			
RM#	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
46360	Reading Twp	1.87	25	1.87	25	0	0

Wednesday, December 18, 2024 Version 1.1 Page 1 of 1

Page: 1 No Filter

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	CONEWAGO CREEK			
RM#	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH		
46360	0.330	20.177	7.000		
Reach Depth (ft)	0.868	Reach Kt (1/day)	Reach Velocity (ft/s)		
Reach CBOD5 (mg/L)	0.363	Reach NH3-N (mg/L)	Reach Kt (1/day)		
Reach DO (mg/L)	0.437	Reach Kt (1/day)	Reach DO Goal (mg/L)		
Reach Travel Time (days)	0.492	TrayTime CBOD5 (days)	D.O. (mg/L)		
		0.009 2.76 0.05 7.04			
		0.009 2.71 0.02 7.76			
		0.118 2.66 0.00 7.59			
		0.197 2.62 0.77 7.43			
		0.287 2.57 0.57 7.28			
		0.386 2.52 0.37 7.14			
		0.315 2.48 0.09 7.00			
		0.391 2.44 0.07 6.88			
		0.413 2.39 0.05 6.76			
		0.492 2.35 0.02 6.65			

Wednesday, December 18, 2024 Version 1.1 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameter	Value	Notes
WLA Method	EMPR	Use Inputted W/LA Ratio
Q1-10Q-740 Ratio	0.64	Use Inputted Reach Travel Times
Q30-10Q-10 Ratio	1.36	Temperature Adjust %
D.O. Saturation	90.00%	Use Balanced Technology
D.O. Goal	5	

Wednesday, December 18, 2024 Version 1.1 Page 1 of 1

Page: 1 No Filter

NPDES Permit Fact Sheet
Reading Township Adams County STP

NPDES Permit No. PA0036889

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin		Stream Code		Stream Name										
SWP	Basin	Code	Stream	Depth	Width	WD	Velocity	Rich	Trav.	Analysis	Analysis			
Stream	Flow	Flow	With	Strm	Disc.	Step	Time	Width	Time	Temp	pH			
(ft/s)	(ft/s)	(ft/s)	(ft/s)	(ft)	(ft)	(ft)	(sec)	(ft)	(sec)	(°C)				
Q7-10 F b/w	46,360	13.83	0.00	13.9	.510	5.00	0.029	.899	0.61	77.47	0.23	0.492	20.18	7.00
Q1-10 F b/w	46,360	8.82	0.00	8.82	.510	5.00	0.029	NA	NA	NA	0.18	0.625	20.27	7.00
Q30-10 Flow	46,360	18.94	0.00	18.9	.510	5.00	0.029	NA	NA	NA	0.27	0.417	20.13	7.00

rptGeneral

Input Data WQM 7.0

SWP Basin		Stream Code		Stream Name									
SWP	Basin	Code	Stream	RMB	Elevation	Drainage	Slope	PWS	Withdrawal	Apply			
Stream	Flow	Flow	With	Strm	Disc.	Area	(ft)	(ft)	(m3/s)	FC			
(ft/s)	(ft/s)	(ft/s)	(ft/s)	(ft)	(ft)	(sq mi)	(ft)	(ft)	(m3/s)				
OTF	8003			CONEWAGO CREEK			46.360	41.603	199.00	0.000000	0.00		

Stream Data

Design Cond.	LFY	Trib. Flow	Strm Flow	Rich Flow	Trav. Time	WD Ratio	Rich Velocity	Rich Width	Rich Depth	Turbidity	Temp	Stream pH
(ft/sec)	(ft/sec)	(ft/sec)	(ft/sec)	(ft)	(sec)	(ft)	(ft/sec)	(ft)	(ft)	(°C)	(°C)	
Q7-10	0.070	0.00	0.00	0.0000	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00
Q1-10	0.00	0.00	0.00	0.0000	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00
Q30-10	0.00	0.00	0.00	0.0000	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00

Discharge Data

Name	Permit Number	Existing Disc. Flow (m3/s)	Permitted Disc. Flow (m3/s)	Design Disc. Flow (m3/s)	Reserve Factor	Disc. Temp (°C)	Disc. pH
		(mg/L)	(mg/L)	(mg/L)			
Reading Twp	PA0036889	0.0000	0.0000	0.0000	0.0000	25.00	7.00

Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Rate Coef. (1/day)
	(mg/L)	(mg/L)	(mg/L)	
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Wednesday, December 18, 2014

Version 1.1

Page 1 of 1

rptGeneral

Input Data WQM 7.0

SWP Basin		Stream Code		Stream Name									
SWP	Basin	Code	Stream	RMB	Elevation	Drainage	Slope	PWS	Withdrawal	Apply			
Stream	Flow	Flow	With	Strm	Disc.	Area	(ft)	(ft)	(m3/s)	FC			
(ft/s)	(ft/s)	(ft/s)	(ft/s)	(ft)	(ft)	(sq mi)	(ft)	(ft)	(m3/s)				
OTF	8003			CONEWAGO CREEK			44.360	41.579	200.00	0.000000	0.00		

Stream Data

Design Cond.	LFY	Trib. Flow	Strm Flow	Rich Flow	Trav. Time	WD Ratio	Rich Velocity	Rich Width	Rich Depth	Turbidity	Temp	Stream pH
(ft/sec)	(ft/sec)	(ft/sec)	(ft/sec)	(ft)	(sec)	(ft)	(ft/sec)	(ft)	(ft)	(°C)	(°C)	
Q7-10	0.070	0.00	0.00	0.0000	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00
Q1-10	0.00	0.00	0.00	0.0000	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00
Q30-10	0.00	0.00	0.00	0.0000	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00

Discharge Data

Name	Permit Number	Existing Disc. Flow (m3/s)	Permitted Disc. Flow (m3/s)	Design Disc. Flow (m3/s)	Reserve Factor	Disc. Temp (°C)	Disc. pH
		(mg/L)	(mg/L)	(mg/L)			
Reading Twp	PA0036889	0.0000	0.0000	0.0000	0.0000	25.00	7.00

Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Rate Coef. (1/day)
	(mg/L)	(mg/L)	(mg/L)	
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Wednesday, December 18, 2014

Version 1.1

Page 2 of 2

Page: 1 2 No Filter

17

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.23	XXX	0.75	1/day	Grab
CBOD ₅	68.0	110.0	XXX	25.0	40.0	50.0	1/week	8-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	82.0	123.0	XXX	30.0	45.0	60.0	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Ammonia Nov 1 - Apr 30	58.0	XXX	XXX	21.0	XXX	42.0	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	19.0	XXX	XXX	7.0	XXX	14.0	1/week	8-Hr Composite
Total Phosphorus	5.5	XXX	XXX	2.0	XXX	4.0	1/week	8-Hr Composite

Compliance Sampling Location:

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite

Compliance Sampling Location: 

Other Comments: 

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]