

Application Type
 Facility Type
 Major / Minor

Renewal
Municipal
Minor
**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

 Application No. PA0036994
 APS ID 1048726
 Authorization ID 1371184
Applicant and Facility Information

Applicant Name	<u>Pleasantville Borough</u>	Facility Name	<u>Pleasantville Borough STP</u>
Applicant Address	<u>114 West State Street</u> <u>Pleasantville, PA 16341</u>	Facility Address	<u>South Main Street</u> <u>Pleasantville, PA 16341</u>
Applicant Contact	<u>Harvey Long</u>	Facility Contact	<u>Mike Guzzi</u>
Applicant Phone	<u>(814) 589-7432</u>	Facility Phone	<u>(814) 589-5321</u>
Client ID	<u>23973</u>	Site ID	<u>261190</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Pleasantville Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Venango</u>
Date Application Received	<u>October 1, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 1, 2021</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of NPDES permit.</u>		

Summary of Review

The applicant is requesting the renewal of an NPDES permit to discharge up to 0.4 MGD of treated sewage into Tributary 54760 of West Pithole Creek, a Cold-Water Fish (CWF) receiving stream in State Water Plan Basin 16-E (Oil Creek). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use. This discharge is not expected to affect public water supplies.

Apart from Ammonia-Nitrogen, all limitations and monitoring requirements from the previously issued permit (effective April 1, 2017) are carried over in this renewal and summarized at the end of the fact sheet. WQM 7.0 (see WQM Modeling section) recommended a slightly more stringent summertime monthly average limitation of 1.6 mg/L for Ammonia-N (previously 2.0 mg/L). It appears the permittee can meet the new limitations after review of eEDMR data, therefore, the limitations will come into effect on the permit effective date. The standard 3x wintertime multiplier and 2x IMAX multiplier is applied for Ammonia-Nitrogen.

Limits for CBOD₅, TSS, and D.O. were previously derived from an older version of the Department's "Dry Streams and Swales Manual" due to the effluent dominated nature of the receiving stream. Cap loads for Total Nitrogen and Total Phosphorus were included in the NPDES permit when the WWTP was upgraded to a hydraulic design capacity of 0.4 MGD and are carried over in this renewal.

The permit renewal application indicates the facility utilizes ultraviolet (UV) radiation for disinfection with chlorine as a backup. eEDMR data shows chlorine is regularly used at the WWTP, therefore, the previously established daily monitoring requirements are carried over in this renewal. The following Part C template special condition is added to the permit for UV system monitoring and replaces the UV Part C condition from the previously issued permit:

The permittee shall report operation of the ultraviolet (UV) disinfection system on a daily basis using the Daily Effluent Monitoring Form (3800-FM-BCW0435) and the parameter named "UV Functional" The permittee shall report values of "1" for

Approve	Deny	Signatures	Date
X		 Brian Burden, E.I.T. / Project Manager	December 9, 2024
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	December 12, 2024

Summary of Review

Yes (i.e., the UV system is functional) and “*< 1*” for No (i.e., the UV system is not functional). The UV system shall be considered functional when all components that are necessary for disinfection to achieve effluent limitations in Part A of this permit are operating properly.

DEP’s Toxics Management Spreadsheet was not utilized during this renewal since no sample results for toxic pollutants are available in the renewal application or eDMR. There are no commercial or industrial users in the sewage collection system. Sample results were provided with the renewal application for the public water supply sensitive pollutants (TDS, Bromide, Chloride and Sulfate). Since the nearest downstream public water supply intake is approximately 64 miles downstream on the Allegheny River, there was no need to model the discharge with the water supply intake as the second modeling point due to the large dilatation available.

Monitoring frequencies for all parameters with limitations are consistent with the recommended frequencies found in Table 6-3 of DEP’s Technical Guidance for the Development and Specification of Effluent Limitations (Document No. 362-0400-001).

The most recently submitted Chapter 94 report for 2023 doesn’t show any current or projected hydraulic/organic overloads at the WWTP.

As per current DEP guidance, quarterly monitoring/reporting requirements are included in the renewed permit for E. Coli. Template Part C special conditions are carried over in this renewal.

Sludge use and disposal description and location(s): Sludge from the facility is hauled to the Seneca Landfill via Tri County Industries.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP’s discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.4
Latitude	41° 35' 19"	Longitude	-79° 35' 3"
Quad Name	Pleasantville	Quad Code	0609
Wastewater Description:	Sewage Effluent		
Receiving Waters	Tributary 54760 to West Pithole Creek (CWF)	Stream Code	54760
NHD Com ID	100473587	RMI	1.14
Drainage Area	0.65 mi ²	Yield (cfs/mi ²)	0.1
Q ₇₋₁₀ Flow (cfs)	0.065	Q ₇₋₁₀ Basis	Gage 03020500
Elevation (ft)	1579	Slope (ft/ft)	0.0086
Watershed No.	16-E	Chapter 93 Class.	CWF
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Impaired		
Cause(s) of Impairment	Nutrients		
Source(s) of Impairment	Municipal Point Source Discharges		
TMDL Status	N/A	Name	N/A
Background/Ambient Data		Data Source	
pH (SU)	-	-	
Temperature (°F)	-	-	
Hardness (mg/L)	-	-	
Other:	-	-	
Nearest Downstream Public Water Supply Intake		Aqua Pennsylvania Emlenton	
PWS Waters	Allegheny River	Flow at Intake	542 cfs - StreamStats (6390 mi ² D.A.)
PWS RMI	90.5	Distance from Outfall	~64 miles

Treatment Facility Summary				
Treatment Facility Name: Pleasantville Borough - STP				
WQM Permit No.	Issuance Date			
6188404 A-2	April 8, 2014			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	Ultraviolet - Chlorination/Dechlorination Backup	0.4
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.4	600	Not Overloaded	Aerobic Digestion	Landfill

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	0.4	
Latitude	41° 35' 19"	Longitude	-79° 35' 3"	
Wastewater Description:	Sewage Effluent			

Technology-Based & BPJ Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	10.0	Average Monthly	-	BPJ
	15.0	Average Weekly		
	20.0	IMAX		
Total Suspended Solids	10.0	Average Monthly	-	BPJ
	15.0	Average Weekly		
	20.0	IMAX		
Dissolved Oxygen	6.0	Minimum	-	BPJ
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
	10,000 / 100 ml	IMAX	-	92a.47(a)(5)

Comment: Mass-based limitations are included in the permit for CBOD₅ and TSS.

Water Quality-Based Limitations

The following concentration limitations (except TN & TP) were determined through water quality modeling:

Parameter	Limit (mg/l)	SBC	Model
Total Residual Chlorine	0.024	Average Monthly	2017 TRC Calculation Spreadsheet
	0.08	IMAX	
Ammonia-Nitrogen (5/1 – 10/31)	1.6	Average Monthly	2024 WQM 7.0
	3.2	IMAX	
Ammonia-Nitrogen (11/1 – 4/30)	4.8	Average Monthly	Cap Loads established for 0.4 MGD WWTP upgrade
	9.6	IMAX	
Total Nitrogen	12.0 lbs/day	Average Monthly	Cap Loads established for 0.4 MGD WWTP upgrade
Total Phosphorus	1.5 lbs/day	Average Monthly	

Comment: Mass-based limitations are included in the permit for Ammonia-Nitrogen.

Monitoring Requirements

The following monitoring requirements have been established:

Parameter	SBC	Model / Basis
Flow (MGD)	Average Monthly	Standard requirement
	Daily Maximum	
Influent BOD ₅	Average Monthly	Standard requirement for POTWs
	Average Monthly	
E. Coli	IMAX	2024 DEP Guidance / § 92a.61

Comments: Mass-based monitoring requirements are included in the permit for influent BOD₅ and influent TSS.

Anti-Backsliding

No limitations were removed from the permit or made less stringent.

Watershed Information

@ Outfall 001 on Tributary 54760 to West Pithole Creek

RMI = 1.14

Clicked Point (Latitude, Longitude): 41.58792, -79.58470

Time: 2024-11-25 08:38:53 -0500




DRNAREA

Area that drains to a point on a stream

0.65 square miles

Elevation: 1579 ft

Elevation profile




@ confluence with West Pithole Creek

RMI = 0


Clicked Point (Latitude, Longitude): 41.57690, -79.59640

Time: 2024-11-25 09:15:57 -0500



DRNAREA Area that drains to a point on a stream 2.87 square miles

Elevation: 1527 ft



Reference Stream Gage

USGS Station Number	03020500	
Station Name	Oil Creek at Rouseville, Pa.	
Station Type	Gaging Station, continuous record	
Latitude	41.48173	
Longitude	-79.69533	
NWIS Latitude	41.4817261	
NWIS Longitude	-79.6953304	
Is regulated?	false	
Agency	United States Geological Survey	
NWIS Discharge Period of Record	10/01/1932 - 11/24/2024	
Drainage Area	300	square miles
	7 Day 10 Year Low F low	cubic feet per second

Low Flow Yield = $30.1 \text{ cfs} / 300 \text{ mi}^2 = 0.1 \text{ cfs/mi}^2$
 $Q_{7-10} \text{ at Outfall 001} = 0.65 \text{ mi}^2 \times 0.1 \text{ cfs/mi}^2 = 0.065 \text{ cfs}$

WQM Modeling

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54760	Trib 54760 to West Pithole Creek	1.140	1579.00	0.65	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.000	0.000								
Q30-10		0.00	0.000	0.000								

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Pleasantville	PA0036994	0.4000	0.4000	0.4000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		10.00	2.00	0.00	1.50		
Dissolved Oxygen		6.00	8.24	0.00	0.00		
NH3-N		2.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54760	Trib 54760 to West Pithole Creek			0.010	1527.00	2.87	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
Discharge Data										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
			0.0000	0.0000	0.0000	0.000	25.00	7.00		
Parameter Data										
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5		25.00	2.00	0.00	1.50				
	Dissolved Oxygen		3.00	8.24	0.00	0.00				
	NH3-N		25.00	0.00	0.00	0.70				

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
16E	54760	Trib 54760 to West Pithole Creek										
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow	1.140	0.06	0.00	0.06	.6188	0.00872	.484	7.22	14.9	0.20	0.353	24.52
Q1-10 Flow	1.140	0.04	0.00	0.04	.6188	0.00872	NA	NA	NA	0.19	0.360	24.69
Q30-10 Flow	1.140	0.09	0.00	0.09	.6188	0.00872	NA	NA	NA	0.20	0.347	24.38

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name				
		16E	54760	Trib 54760 to West Pithole Creek		

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.140 Pleasantville		6.92	4	6.92	4	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.140 Pleasantville		1.4	1.6	1.4	1.6	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.14 Pleasantville		10	10	1.6	1.6	6	6	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
16E	54760	Trib 54760 to West Pithole Creek			
RMI		Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH	
1.140		0.400	24.525	7.000	
Reach Width (ft)		Reach Depth (ft)	Reach WDRatio	Reach Velocity (fps)	
7.219		0.484	14.902	0.196	
Reach CBOD5 (mg/L)		Reach Kc (1/days)	Reach NH3-N (mg/L)	Reach Kn (1/days)	
9.24		1.457	1.45	0.992	
Reach DO (mg/L)		Reach Kr (1/days)	Kr Equation	Reach DO Goal (mg/L)	
6.213		30.933	Owens	5	
Reach Travel Time (days)		<u>Subreach Results</u>			
0.353		TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
		0.035	8.67	1.40	7.04
		0.071	8.14	1.35	7.36
		0.106	7.64	1.30	7.50
		0.141	7.17	1.26	7.58
		0.177	6.73	1.22	7.60
		0.212	6.32	1.17	7.60
		0.247	5.93	1.13	7.60
		0.283	5.57	1.09	7.60
		0.318	5.22	1.06	7.60
		0.353	4.90	1.02	7.60

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
16E	54760	Trib 54760 to West Pithole Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.140	Pleasantville	PA0036994	0.400	CBOD5	10		
				NH3-N	1.6	3.2	
				Dissolved Oxygen			6

TRC Calculation

TRC EVALUATION							
Input appropriate values in A3:A9 and D3:D9							
0.065 = Q stream (cfs)			0.5 = CV Daily				
0.4 = Q discharge (MGD)			0.5 = CV Hourly				
30 = no. samples			1 = AFC_Partial Mix Factor				
0.3 = Chlorine Demand of Stream			1 = CFC_Partial Mix Factor				
0 = Chlorine Demand of Discharge			15 = AFC_Criteria Compliance Time (min)				
0.5 = BAT/BPJ Value			720 = CFC_Criteria Compliance Time (min)				
0 = % Factor of Safety (FOS)			=Decay Coefficient (K)				
Source	Reference	AFC Calculations		Reference	CFC Calculations		
TRC	1.3.2.iii	WLA_afc = 0.053		1.3.2.iii	WLA_cfc = 0.044		
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581		
PENTOXSD TRG	5.1b	LTA_afc = 0.020		5.1d	LTA_cfc = 0.025		
Effluent Limit Calculations							
PENTOXSD TRG	5.1f	AML MULT = 1.231		AVG MON LIMIT (mg/l) = 0.024			
PENTOXSD TRG	5.1g	INST MAX LIMIT (mg/l) = 0.079		AFC			
WLA_afc		$(.019/e(-k^*AFC_tc)) + [(AFC_Yc^*Qs^*.019/Qd^*e(-k^*AFC_tc))...\\...+ Xd + (AFC_Yc^*Qs^*Xs/Qd)]^*(1-FOS/100)$					
LTAMULT_afc		$\text{EXP}((0.5^*\text{LN}(cvh^2+1))-2.326^*\text{LN}(cvh^2+1)^{0.5})$					
LTA_afc		$wla_afc^*LTAMULT_afc$					
WLA_cfc		$(.011/e(-k^*CFC_tc)) + [(CFC_Yc^*Qs^*.011/Qd^*e(-k^*CFC_tc))...\\...+ Xd + (CFC_Yc^*Qs^*Xs/Qd)]^*(1-FOS/100)$					
LTAMULT_cfc		$\text{EXP}((0.5^*\text{LN}(cvd^2/no_samples+1))-2.326^*\text{LN}(cvd^2/no_samples+1)^{0.5})$					
LTA_cfc		$wla_cfc^*LTAMULT_cfc$					
AML MULT		$\text{EXP}(2.326^*\text{LN}((cvd^2/no_samples+1)^{0.5})-0.5^*\text{LN}(cvd^2/no_samples+1))$					
AVG MON LIMIT		$\text{MIN}(\text{BAT_BPJ}, \text{MIN}(\text{LTA_afc}, \text{LTA_cfc})^*\text{AML_MULT})$					
INST MAX LIMIT		$1.5^*((\text{av_mon_limit}/\text{AML_MULT})/\text{LTAMULT_afc})$					