

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0037052
APS ID 605167
Authorization ID 1352649

Applicant and Facility Information

Applicant Name	<u>Pen Argyl Municipal Authority</u>	Facility Name	<u>Pen Argyl Wastewater Treatment Plant</u>
Applicant Address	<u>11 North Robinson Avenue, POB 128</u> <u>Pen Argyl, PA 18072-1452</u>	Facility Address	<u>249 South Main Street</u> <u>Pen Argyl, PA 18072-9520</u>
Applicant Contact	<u>John Cuono, Authority Chairman</u>	Facility Contact	<u>Jeffrey Markovitz, WWTP Operator</u>
Applicant Phone	<u>(610) 863-4119</u>	Facility Phone	<u>(610) 863-5422</u>
Client ID	<u>62404</u>	Site ID	<u>255664</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Pen Argyl Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Northampton</u>
Date Application Received	<u>April 30, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 11, 2021</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of NPDES permit for discharge of treated sewage.</u>		

Summary of Review

The applicant is requesting the renewal of an NPDES permit to discharge up to 0.95 MGD of treated sewage into Waltz Creek, a Cold-Water Fishery, Migratory Fish (CWF, MF) receiving stream in State Water Plan Basin 1-F (Jacoby – Bushkill Creeks). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use. This stream segment is designated as a naturally reproducing trout stream as per PA Fish & Boat Commission. This discharge is not expected to affect public water supplies.

The renewal application and the previous permit lists the receiving stream as Waltz Creek. It appears the discharge is really to an Unnamed Tributary to Waltz Creek. This Unnamed Tributary does not appear on eMAP PA but does appear on USGS StreamStats. The DRBC Docket, the Waltz Creek TMDL, and the Water Quality Pollution Report dated August 4, 2011 all list the receiving stream as an Unnamed Tributary to Waltz Creek. However, the Water Quality Pollution Report indicates that the point of first use is considered to be at the point of discharge along Waltz Creek. The wording on this NPDES Permit renewal will continue to list the receiving stream as Waltz Creek since the modeling is based at the point where the Unnamed Tributary meets Waltz Creek,

Limitations for pH, CBOD₅, Total Suspended Solids (TSS), and Fecal Coliform are technology-based and carried over from the previous permit.

Limitations for Ammonia Nitrogen are water quality-based and carried over from the previous permit. WQM 7.0 did not recommend stricter limits.

A final Total Maximum Daily Load (TMDL) exists for Waltz Creek. The Total Copper, Total Lead, and Total Zinc limits are carried over from the previous permit and are derived from the Waste Load Allocations (WLAs) specified in the Waltz Creek TMDL dated August 9, 2004.

Approve	Deny	Signatures	Date
X		/s/ Allison Seyfried / Environmental Engineering Specialist	April 12, 2022
X		/s/ Amy M. Bellanca, P.E. / Environmental Engineer Manager	May 13, 2022

Summary of Review

WQM 7.0 modeling recommends a stricter limit for Dissolved Oxygen (DO) of 7.0 mg/L due to the stream being designated as a naturally reproducing trout stream. eDMR data from March 1, 2021 to February 28, 2022 (included on pages 4-6 of this Fact Sheet) indicates that the facility is consistently above 7.0 mg/L (and typically even over 8.0 mg/L). Therefore, the new DO limitations will become effective at the permit effective date.

Weekly influent monitoring requirements for TSS has been carried over from the previous permit. The latest DRBC Docket No. D-1975-028 CP-5 requires the addition of monitoring/reporting for 85% minimum CBOD₅ Percent Removal at the same monitoring frequency as CBOD₅. The weekly influent monitoring for BOD₅ has been changed to influent monitoring of CBOD₅ to better determine the removal percentages. The DRBC Docket requirement of 1,000 mg/L average quarterly limit for Total Dissolved Solids was also carried over from the previous permit.

The annual monitoring and reporting for Total Nitrogen, Total Phosphorous, Total Kjeldahl Nitrogen, and Nitrate-Nitrite as N has been maintained in this permit.

The Total Residual Chlorine (TRC) Calculation Spreadsheet recommends stricter limitations than the previous permit. The permittee will be required to meet the new water quality-based limits for TRC starting four years after the effective date of the permit (see Part C.III.). TRC limitations from the previously issued permit are in effect for the first three years after the permit effective date. The WWTP utilizes ultraviolet light for disinfection. Therefore, these limits are only applicable in the event the facility uses chlorine for cleaning purposes or as a back-up disinfection option (see requirements under Part C.I.D).

Sewage discharges now require monitoring and reporting for E. Coli. A monitoring frequency of 1/month for design flows \geq 1 MGD, 1/quarter for design flows \geq 0.05 and $<$ 1 MGD, 1/year for design flows of 0.002 – 0.05 MGD will be utilized.

For this permit renewal, all monitoring frequencies for parameters with limitations are consistent with the Department's *Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits* (document no. 362-0400-001).

There are no representative stream gages in the vicinity of the outfall and the drainage area at Outfall 001 is too small for USGS StreamStats to estimate accurate low flow values. Therefore, the default Low Flow Yield (LFY) of 0.1 cfs/mi² was used to model the discharge. For modeling inputs, RMI values were obtained using the "PA Historic Streams" feature of eMapPA, drainage areas were delineated using USGS's StreamStats Interactive Map, and elevations were obtained using the elevation profile feature of StreamStats.

The existing permit expired on October 31, 2021 and the application for renewal was received on time.

A Water Management System Inspection query indicated a Compliance Evaluation was performed on January 27, 2022.

There are currently no open violations for this client that warrant withholding issuance of this permit.

Sludge use and disposal description and location(s): As per the permittee's NPDES Renewal Application, sludge is hauled to the Grand Central Sanitary Landfill by Allstate Septic Systems, LLP.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.95
Latitude	40° 51' 29.24"	Longitude	-75° 14' 58.64"
Quad Name	Bangor	Quad Code	1244
Wastewater Description: Sewage Effluent			
Receiving Waters	Waltz Creek (CWF, MF)	Stream Code	63243
NHD Com ID	26066412	RMI	4.086
Drainage Area	2.56 mi ²	Yield (cfs/mi ²)	0.10
Q ₇₋₁₀ Flow (cfs)	0.256	Q ₇₋₁₀ Basis	State-wide default
Elevation (ft)	622.4	Slope (ft/ft)	-
Watershed No.	1-F	Chapter 93 Class.	CWF, MF
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Impaired		
Cause(s) of Impairment	FLOW REGIME MODIFICATION, FLOW REGIME MODIFICATION, HABITAT ALTERATIONS, SILTATION		
Source(s) of Impairment	EROSION FROM DERELICT LAND (BARREN LAND), EROSION FROM DERELICT LAND (BARREN LAND), URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS		
TMDL Status	Final	Name	Waltz Creek TMDL
Nearest Downstream Public Water Supply Intake	Easton Area Water Authority		
PWS Waters	Delaware River	Flow at Intake (cfs)	-
PWS RMI	110.4	Distance from Outfall (mi)	~ 14

Treatment Facility Summary				
Treatment Facility Name: Pen Argyl Municipal Authority WWTP				
WQM Permit No.	Issuance Date			
4806405	6/11/207			
4815401	10/13/2015			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Activated Sludge	Ultraviolet	0.554
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.95	1,596	Not Overloaded	Primary aerobic digester, secondary aerobic digestors, reed beds, sludge dewatering centrifuge	Hauled

Compliance History

DMR Data for Outfall 001 (from March 1, 2021 to February 28, 2022)

Parameter	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21
Flow (MGD) Average Monthly	0.586	0.350	0.389	0.557	0.571	1.002	0.559	0.388	0.406	0.45	0.679	0.741
Flow (MGD) Daily Maximum	1.327	0.462	0.455	0.746	1.294	1.843	1.92	0.437	0.443	0.534	1.014	1.085
pH (S.U.) Minimum	6.9	6.9	6.8	6.9	6.8	6.8	6.9	7.1	6.9	7.0	7.0	6.9
pH (S.U.) Instantaneous Maximum	7.3	7.3	7.2	7.2	7.0	7.1	7.2	7.3	7.4	7.3	7.2	7.2
DO (mg/L) Minimum	8.9	8.5	8.6	8.3	8.2	8.2	7.9	7.2	7.6	8.4	8.3	8.7
TRC (mg/L) Average Monthly	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG
TRC (mg/L) Instantaneous Maximum	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG
CBOD5 (lbs/day) Average Monthly	15	7.1	9	16	< 10	< 17	< 11	< 7	< 8	< 8	< 12	< 13
CBOD5 (lbs/day) Weekly Average	32	8.3	15	35	< 12	< 25	< 14	< 7	< 8	< 9	< 13	< 17
CBOD5 (mg/L) Average Monthly	3.2	2.2	2.6	3.3	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2
CBOD5 (mg/L) Weekly Average	5.0	2.7	5.1	7.2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	837	908	781	998	894	978	1083	933	928	820	888	852
BOD5 (lbs/day) Raw Sewage Influent Weekly Average	10.85	984	1146	1043	1146	1520	3008	1311	1308	1220	1399	1455
BOD5 (mg/L) Raw Sewage Influent Average Monthly	225	319	238	217	220	146	157	297	279	232	163	149
BOD5 (mg/L) Raw Sewage Influent Weekly Average	390	355	302	242	332	187	193	397	415	374	223	268

**NPDES Permit Fact Sheet
Pen Argyl Municipal Authority**

NPDES Permit No. PA0037052

TSS (lbs/day) Average Monthly	19	< 12	< 14	< 17	< 18	< 33	< 21	< 13	< 14	16	< 22	< 24
TSS (lbs/day) Raw Sewage Influent Average Monthly	864	1383	1144	2373	1954	1807	1560	1164	1298	1086	1679	1701
TSS (lbs/day) Raw Sewage Influent Weekly Average	1069	1907	1734	4576	4895	2131	4938	1440	1882	1683	2340	3192
TSS (lbs/day) Weekly Average	32	< 13	< 16	< 19	< 23	< 50	< 28	< 14	< 15	18	< 26	< 34
TSS (mg/L) Average Monthly	4.5	< 4	< 4	< 4	< 4	< 4	< 4	< 4	< 4	4.1	< 4	< 4
TSS (mg/L) Raw Sewage Influent Average Monthly	232	488	349	512	443	282	201	372	388	306	318	305
TSS (mg/L) Raw Sewage Influent Weekly Average	385	693	457	978	1050	404	284	436	597	516	478	588
TSS (mg/L) Weekly Average	6.0	< 4	< 4	< 4	< 4	< 4	< 4	< 4	< 4	4.4	< 4	< 4
Total Dissolved Solids (mg/L) Average Monthly			326			316			264			278
Fecal Coliform (CFU/100 ml) Geometric Mean	1	1	< 3	< 1	< 3	3	< 4	< 2	< 2	1	< 1	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	1	1	43	< 1	12	7	23	2	2	1	< 1	< 1
Nitrate-Nitrite (lbs/day) Annual Average			16									
Nitrate-Nitrite (mg/L) Annual Average			3.2									
Total Nitrogen (lbs/day) Annual Average			19.5									
Total Nitrogen (mg/L) Annual Average			3.8									
Ammonia (lbs/day) Average Monthly	1.5	< 0.3	< 0.4	< 0.5	< 0.5	< 0.9	< 0.6	< 0.4	< 0.4	< 0.5	< 0.6	1.0
Ammonia (mg/L) Average Monthly	0.4	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	0.14

**NPDES Permit Fact Sheet
Pen Argyl Municipal Authority**

NPDES Permit No. PA0037052

TKN (lbs/day) Annual Average			4.7									
TKN (mg/L) Annual Average			0.8									
Total Phosphorus (lbs/day) Annual Average			6.0									
Total Phosphorus (mg/L) Annual Average			1.3									
Total Copper (lbs/day) Average Monthly	0.027	0.023	0.027	0.024	0.033	0.099	0.033	0.027	0.028	0.040	0.050	0.042
Total Copper (lbs/day) Daily Maximum	0.027	0.023	0.027	0.024	0.033	0.099	0.040	0.027	0.028	0.040	0.050	0.042
Total Copper (mg/L) Average Monthly	0.010	0.008	0.007	0.005	0.007	0.008	0.008	0.008	0.008	0.009	0.008	0.007
Total Copper (mg/L) Daily Maximum	0.010	0.008	0.007	0.005	0.007	0.008	0.008	0.008	0.008	0.009	0.008	0.007
Total Lead (lbs/day) Average Monthly	< 0.0027	< 0.0029	< 0.0039	< 0.0049	< 0.0047	< 0.0124	< 0.0041	< 0.0033	< 0.0035	< 0.0005	< 0.0062	< 0.0060
Total Lead (lbs/day) Daily Maximum	< 0.0027	0.0029	< 0.0039	< 0.0049	< 0.0047	< 0.0124	< 0.0051	< 0.0033	< 0.0035	< 0.0005	< 0.0062	< 0.0060
Total Lead (mg/L) Average Monthly	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0005	< 0.0010	< 0.0010
Total Lead (mg/L) Daily Maximum	< 0.00100	< 0.00100	< 0.00100	< 0.00100	< 0.00100	< 0.00100	< 0.00100	< 0.00100	< 0.00100	< 0.00050	< 0.00100	< 0.00100
Total Zinc (lbs/day) Average Monthly	0.32	0.23	0.24	0.17	0.18	0.61	0.22	0.23	0.22	0.32	0.30	0.29
Total Zinc (lbs/day) Daily Maximum	0.32	0.23	0.24	0.17	0.18	0.61	0.23	0.23	0.22	0.32	0.30	0.29
Total Zinc (mg/L) Average Monthly	0.118	0.078	0.062	0.034	0.039	0.049	0.058	0.068	0.062	0.073	0.047	0.049
Total Zinc (mg/L) Daily Maximum	0.118	0.078	0.062	0.034	0.039	0.049	0.067	0.068	0.062	0.073	0.047	0.049

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.95</u>
Latitude <u>40° 51' 53.00"</u>	Longitude <u>-75° 14' 44.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25.0	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40.0	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
	50.0	IMAX	-	-
Total Suspended Solids	30.0	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45.0	Average Weekly	133.102(b)(2)	92a.47(a)(2)
	60.0	IMAX	-	-
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
E. Coli	Report	IMAX	-	92a.61

Water Quality-Based Limitations

The following limitations were determined through water quality modeling:

Parameter	Limit (mg/l)	SBC	Model
Dissolved Oxygen	7.0	Minimum	WQM 7.0
Total Residual Chlorine	0.03	Average Monthly	TRC Calculation Spreadsheet
	0.11	IMAX	
Ammonia-Nitrogen Nov 1 - Apr 30	4.5	Average Monthly	Previous Permit
	9.0	IMAX	
Ammonia-Nitrogen May 1 - Oct 31	1.5	Average Monthly	DRBC Docket
	3.0	IMAX	
Total Dissolved Solids	1,000	Average Quarterly	DRBC Docket
	2,000	IMAX	
CBOD ₅ Minimum % Removal (%)	85	Minimum Monthly Average	Waltz Creek TMDL
Copper, Total	0.016	Monthly Average	
	0.025	Daily Max	
Lead, Total	0.0059	Monthly Average	
	0.00929	Daily Max	
Zinc, Total	0.135	Monthly Average	
	0.204	Daily Max	
CBOD ₅ – Raw Sewage Influent	Report	Monthly Average	POTW Requirement and DRBC Docket
Total Suspended Solids – Raw Sewage Influent	Report	Monthly Average	POTW Requirement

Anti-Backsliding

No limitations were made less stringent.

Modeling


At point of first use on Waltz Creek:

RMI	Elevation (ft)	Drainage Area (mi ²)	Q ₇₋₁₀ Flow (cfs)
4.086	622.4	2.56	0.925

$$\text{Low Flow Yield using StreamStats} = \frac{0.925 \text{ ft}^3/\text{sec}}{2.56 \text{ mi}^2} = 0.361 \frac{\text{ft}^3/\text{sec}}{\text{mi}^2}$$

StreamStats Report

Region ID: PA
 Workspace ID: PA20210818151238494000
 Clicked Point (Latitude, Longitude): 40.85735, -75.24830
 Time: 2021-08-18 11:12:57 -0400



Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	2.56	square miles
Statistic		Value	Unit
7 Day 2 Year Low Flow		1.87	ft ³ /s
30 Day 2 Year Low Flow		2.33	ft ³ /s
7 Day 10 Year Low Flow		0.925	ft ³ /s

Using the state-wide Low-Flow Yield (LFY) of 0.1 cfs/mi²:


$$\frac{0.1 \text{ ft}^3/\text{sec}}{\text{mi}^2} \times 2.56 \text{ mi}^2 = \frac{0.256 \text{ ft}^3}{\text{sec}}$$

At confluence with Unnamed Tributary to Waltz Creek:

RMI	Elevation (ft)	Drainage Area (mi ²)	Q ₇₋₁₀ Flow (cfs)
4.086	622.4	2.56	0.925

StreamStats Report

Region ID: PA
 Workspace ID: PA20210818153429692000
 Clicked Point (Latitude, Longitude): 40.84584, -75.23726
 Time: 2021-08-18 11:34:48 -0400



WQM 7.0 Effluent Limits

SWP Basin		Stream Code		Stream Name			
01F		63243		WALTZ CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
4.086	Pen Argyl Boro	pa0037052	0.950	CBOD5	25		
				NH3-N	2.93	5.86	
				Dissolved Oxygen			7

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.256	= Q stream (cfs)		0.5	= CV Daily	
0.95	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA afc = 0.075		1.3.2.iii	WLA cfc = 0.065
PENTOXSD TRG	5.1a	LTAMULT afc = 0.373		5.1c	LTAMULT cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc= 0.028		5.1d	LTA_cfc = 0.038
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.034		AFC	
		INST MAX LIMIT (mg/l) = 0.112			



DRBC Docket
 1975-028 CP-5 Pen A



WaltzCreekTMDL.p
 df



WQ Protection
 Report.pdf