

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0038164
APS ID 807232
Authorization ID 1372950

Applicant and Facility Information

Applicant Name	<u>Confluence Borough Municipal Authority</u>	Facility Name	<u>Confluence Borough STP</u>
Applicant Address	<u>PO Box 6 711 Logan Place Confluence, PA 15424-0006</u>	Facility Address	<u>2847 Drake Town Road Confluence, PA 15424</u>
Applicant Contact	<u>Mark Waszczak</u>	Facility Contact	<u>Mark Waszczak</u>
Applicant Phone	<u>(814) 395-5512</u>	Facility Phone	<u>(814) 395-5512</u>
Client ID	<u>133984</u>	Site ID	<u>250268</u>
Ch 94 Load Status	<u>Existing Hydraulic Overload</u>	Municipality	<u>Confluence Borough</u>
Connection Status	<u>Dept. Imposed Connection Prohibitions</u>	County	<u>Somerset</u>
Date Application Received	<u>October 5, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

The PA Department of Environmental Protection (PADEP/Department) received an NPDES permit renewal application from CME Engineering on behalf of Confluence Borough Municipal Authority (permittee) on October 5, 2021 for permittee's Confluence Borough STP (facility). The facility is a minor STP with an average annual design flow of 0.137 MGD. The treated effluent is discharged into Youghiogheny River (HQ-CWF) through Outfall 001 in state watershed 19-E. The existing permit will expire on March 31, 2022. The terms and conditions are administratively extended since the renewal application was not received at least 180 days of permit expiration date. Renewal NPDES permit applications under Clean Water program are not covered by PADEP's PDG per 021-2100-001.


This fact sheet is developed in accordance with 40 CFR §124.56.

Changes in this renewal: Quarterly E. Coli monitoring is added, and minimum DO limit is changed to 5.0 mg/l.

Sludge use and disposal description and location(s): Hauled off-site.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
√		Reza H. Chowdhury, E.I.T. / Project Manager 	November 16, 2021
X		Pravin Patel Pravin C. Patel, P.E. / Environmental Engineer Manager	11/17/2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.137
Latitude	39° 49' 2"	Longitude	-79° 21' 54.31"
Quad Name	Confluence	Quad Code	2011
Wastewater Description: Sewage Effluent			
Receiving Waters	Youghiogheny River (HQ-CWF)	Stream Code	37456
NHD Com ID	69922129	RMI	73.5
Drainage Area	1,029 mi ²	Yield (cfs/mi ²)	0.275
Q ₇₋₁₀ Flow (cfs)	283	Q ₇₋₁₀ Basis	Please see below
Elevation (ft)	1310.33	Slope (ft/ft)	
Watershed No.	19-E	Chapter 93 Class.	HQ-CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	MERCURY		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status	N/A	Name	
Background/Ambient Data		Data Source	
pH (SU)	7.0		Median Jul-Sep, 1999-2019, WQN0709
Temperature (°C)	17.2		Median Jul-Sep, 1999-2019, WQN0709
Hardness (mg/L)	30		Median Jul-Sep, 1999-2019, WQN0709
Other:			
Nearest Downstream Public Water Supply Intake		Indian Creek Valley Water Department	
PWS Waters	Youghiogheny River	Flow at Intake (cfs)	
PWS RMI	62.85	Distance from Outfall (mi)	10.65

Changes Since Last Permit Issuance: Confluence Borough MA completed a Sewer Improvement Project to handle SSOs.

Other Comments:

Streamflow:

USGS's web based watershed delineation tool StreamStats (accessible at <https://streamstats.usgs.gov/ss/>, accessed on November 2, 2021) was utilized to determine the drainage area and low flow statistics of the receiving stream at discharge point. The drainage area was found to be 1,029 mi². Data from the nearby StreamGage 03081000 was also considered. This gage is located in Youghiogheny River below Confluence, PA. Q₇₋₁₀, Q₁₋₁₀, and Q₃₀₋₁₀ values at this gage are 283 cfs, 240 cfs, and 358 cfs respectively for the reporting years of 1942-2008. The drainage area was found to be 1,029 mi². These values were obtained from the latest USGS streamflow report ⁽¹⁾.

$$\begin{aligned}
 Q_{7-10} \text{ runoff rate} &= 283 \text{ cfs}/1029 \text{ mi}^2 = 0.275 \text{ cfs/mi}^2 \\
 Q_{7-10} &= 0.275 \text{ cfs/mi}^2 * 1029 \text{ mi}^2 = 283 \text{ cfs} \\
 Q_{1-10}/Q_{7-10} &= 240 \text{ cfs}/283 \text{ cfs} = 0.848 \\
 Q_{30-10}/Q_{7-10} &= 358 \text{ cfs}/283 \text{ cfs} = 1.27
 \end{aligned}$$

(1) Stuckey, M.H., Roland, M.A., 2011, Selected streamflow statistics for streamgage locations in and near Pennsylvania: U.S. Geological Survey Scientific Investigations Report 2011-1070, PP 31, PP 45.

DEP's SOP (BPMP SM-PMT-033, revised March 24, 2021) section II.B.4 states that where a facility is eligible for technology-based limits of CBOD₅ exceeding 25 mg/l, application managers will evaluate a WQBEL for CBOD₅ as follows:

- a. Model the discharge using Toxics Management Spreadsheet (TMS)
- b. Multiply the acute partial mix factor by the Q₇₋₁₀ of the receiving waters
- c. Run the WQM 7.0 model using the adjusted Q₇₋₁₀ and apply the WQBEL in the permit, if less than the technology-based limits
- d. Establish the average monthly concentration limit for TSS at the same concentration as for CBOD₅ using BPJ, if the CBOD₅ limit is a WQBEL

The attached TMS model suggested a PMFa of 5.8%. A partial mixing factor, according to DEP's technical guidance (391-2000-011), is used to describe the fractional portion of the stream that mixes with the discharge at the criteria compliance times. The partial mix factor is a value between 0 and 1; 1 presenting complete mixing and less than 1 represents there is incomplete mixing between the discharge and the stream. Therefore, the revised Q₇₋₁₀ will be **283 * 0.058 or 16.41 cfs**.

PWS Intake:

The nearest downstream public water supply is Indian Creek Valley Water Dept, on Youghiogheny River at RMI 62.85. Its approximately 10.65 miles downstream of Outfall 001.

Wastewater Characteristics:

A median pH of 6.74 from daily DMR during dry months July through September for the year 2021, discharge temperature of 14.03°C (application data), and a default discharge hardness of 100 mg/l will be used for modeling, if needed.

Background data:

The nearby WQN station is WQN0709 on Youghiogheny River at Confluence. The stream pH, Temperature, and Hardness for dry months (July-September) for the period 1999-2018 was calculated to be 7.0 S.U, 17.2°C, and 30 mg/l, respectively.

303d Listed Streams:

The Youghiogheny River is impaired for Fish Consumption due to Mercury from unknown sources. No TMDL is prepared/proposed for this river segment and the discharge is believed not to add to its existing impairment.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The receiving streams are designated as High-Quality Cold-Water Fishes (HQ-CWF). This is a renewal application; therefore, an anti-degradation analysis is not performed.

Treatment Facility Summary				
Treatment Facility Name: Confluence Borough STP				
WQM Permit No.	Issuance Date			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.137
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.137	28.5	Existing Hydraulic Overload		

Other Comments:

Treatment Plant Description

Confluence Borough STP is a 0.137 MGD minor sewage facility located in Confluence Borough, Somerset County which discharges treated sewage through Outfall 001 into Youghiogheny Creek in state watershed 19-E. This is an extended aeration treatment system with chlorine-dechlorination. The application indicated the following treatment train: *Influent enters the distribution box which separates the influent to two identical treatment systems. The process is aeration tank, primary clarifier, secondary clarifier, then effluent to the chlorine contact tank and dechlorination tablet feeder. The effluent is discharged to the outfall. Solids are pumped to the sludge tank.* The facility receives 80% of its flow from Confluence borough and 20% from Henry Clay Township. The sewer system is now 100% separated.

Summary of Inspection:

07/30/2021: RTPT conducted to review the progress of the COA the Department issued. New blowers, new building ventilation and new electronics have been installed inside the STP control building. Composite sampler was installed, and flow proportioned.

05/03/2021: RTPT conducted in response to a bypass reported by the operator. They initiated the bypass due to influent PS pumps malfunctioning. A portable pump was installed temporarily. Since the permittee will be separating their system in approximately two months and the wet well will be eliminated, the malfunctioning pumps will not be replaced, and the portable pumps will be kept at site until separation.

04/02/2019: CEI conducted. Violations noted including DMR effluent violation, SSO bypass, and Ch. 94 hydraulic overload condition. Several recommendations were made including purchase of a refrigerated composite sampler for effluent sampling, separate logbook for maintenance and daily operations, and to submit a WQM permit amendment application to install de-chlorination.

Compliance History

DMR Data for Outfall 001 (from September 1, 2020 to August 31, 2021)

Parameter	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20
Flow (MGD) Average Monthly	0.048	0.078	0.139	0.215	0.094	0.206	0.133	0.193	0.134	0.100	0.073	0.077
Flow (MGD) Daily Maximum	0.070	0.177	0.354	0.774	0.210	0.507	0.273	0.434	0.219	0.198	0.327	0.223
pH (S.U.) Minimum	6.21	6.50	6.24	6.15	6.58	6.70	6.59	6.51	6.04	6.03	6.03	6.45
pH (S.U.) Maximum	8.28	7.07	7.17	7.97	8.74	8.00	7.58	7.97	7.92	7.88	6.91	7.52
DO (mg/L) Minimum	5.75	5.65	6.09	6.41	6.39	6.88	6.40	8.22	4.80	4.55	6.33	6.61
TRC (mg/L) Average Monthly	0.14	0.28	0.53	0.51	0.50	0.48	0.06	0.33	0.77	0.78	0.47	0.41
TRC (mg/L) Instantaneous Maximum	0.68	0.99	1.00	0.98	0.89	0.84	0.57	0.83	1.04	1.29	0.96	0.97
CBOD5 (lbs/day) Average Monthly	2.35	3.05	3.72	3.72	1.72	4.73	6.47	12.00	7.91	2.60	1.69	3.21
CBOD5 (lbs/day) Weekly Average	3.84	3.83	5.70	8.74	2.00	12.68	11.77	15.33	24.94	7.25	2.00	5.78
CBOD5 (mg/L) Average Monthly	5.86	5.28	3.29	3.50	3.0	3.00	5.25	11.25	6.22	3.36	3.23	4.57
CBOD5 (mg/L) Weekly Average	9.22	6.13	4.43	4.99	3.0	3.00	6.92	16.20	16.90	3.86	3.91	8.78
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	130.01	156.33	262.33	281.18	111.61	207.27	148.65	216.77	131.76	124.04	50.75	72.65
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	146.87	199.93	389.90	467.62	193.90	285.48	240.86	282.33	234.17	277.46	65.85	148.85
BOD5 (mg/L) Raw Sewage Influent Average Monthly	368.0	279.5	231.80	275.25	195.75	239.30	195.75	226.30	239.00	161.70	99.78	103.52
BOD5 (mg/L) Raw Sewage Influent Daily Maximum	452.0	393.0	324.00	364.00	347.00	391.00	380.00	312.00	288.00	323.00	141.00	184.00
TSS (lbs/day) Average Monthly	2.32	4.58	5.51	2.84	2.06	30.64	16.41	7.83	3.63	5.15	2.80	5.48
TSS (lbs/day) Raw Sewage Influent Average Monthly	59.42	91.77	181.19	175.03	66.12	127.58	62.09	133.09	67.07	40.07	24.89	59.82

**NPDES Permit Fact Sheet
Confluence Borough STP**

NPDES Permit No. PA0038164

TSS (lbs/day) Raw Sewage Influent Daily Maximum	92.86	120.10	277.61	297.74	101.41	143.61	144.52	227.73	154.99	58.05	31.76	118.11
TSS (lbs/day) Weekly Average	3.34	7.76	8.38	4.14	3.03	123.47	48.32	10.37	9.45	12.25	4.33	16.60
TSS (mg/L) Average Monthly	6.20	7.90	5.12	3.80	3.70	10.96	11.20	7.70	3.04	7.90	5.40	8.08
TSS (mg/L) Raw Sewage Influent Average Monthly	159.0	163.00	182.60	165.77	113.00	111.00	85.38	143.30	72.4	56.50	48.25	84.20
TSS (mg/L) Raw Sewage Influent Daily Maximum	210.0	202.00	272.00	264.00	152.00	194.00	228.00	246.00	184.00	80.00	68.00	146.00
TSS (mg/L) Weekly Average	10.00	12.40	9.20	5.60	5.60	29.20	28.40	11.20	6.40	20.40	8.80	25.20
Fecal Coliform (CFU/100 ml) Geometric Mean	34.86	125.22	66.56	10.74	5.05	40.43	203.53	416.12	82.06	17.87	163.92	634.64
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	2419.60	2419.60	1011.20	770.10	209.80	2419.00	1230.40	18416	9678.00	980.40	1553.0 0	39726
Total Nitrogen (mg/L) Daily Maximum									0.54			
Ammonia (mg/L) Average Monthly	13.41	9.84	3.43	0.26	0.45	0.58	0.70	9.95	1.53	0.17	0.70	3.56
Ammonia (mg/L) Weekly Average	28.20	12.08	7.19	0.52	0.69	1.34	2.15	15.72	6.97	0.36	2.51	14.04
Total Phosphorus (mg/L) Daily Maximum									3.40			

Compliance History

Effluent Violations for Outfall 001, from: October 1, 2020 To: August 31, 2021

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Flow	05/31/21	Avg Mo	0.215	MGD	.137	MGD
Flow	03/31/21	Avg Mo	0.206	MGD	0.137	MGD
Flow	06/30/21	Avg Mo	0.139	MGD	.137	MGD
Flow	01/31/21	Avg Mo	0.193	MGD	0.137	MGD
TRC	06/30/21	Avg Mo	0.53	mg/L	.5	mg/L

TRC	05/31/21	Avg Mo	0.51	mg/L	.5	mg/L
TRC	11/30/20	Avg Mo	0.78	mg/L	0.5	mg/L
TRC	12/31/20	Avg Mo	0.77	mg/L	0.5	mg/L
TSS	03/31/21	Wkly Avg	123.47	lbs/day	51.4	lbs/day
Fecal Coliform	07/31/21	IMAX	2419.60	CFU/100 ml	1000	CFU/100 ml
Fecal Coliform	08/31/21	IMAX	2419.60	CFU/100 ml	1000	CFU/100 ml
Fecal Coliform	01/31/21	IMAX	18416	CFU/100 ml	10000	CFU/100 ml
Fecal Coliform	06/30/21	IMAX	1011.20	CFU/100 ml	1000	CFU/100 ml

Other Comments: A COA was entered in between the permittee and the Department to address the non-compliance.

Existing Effluent Limitations and Monitoring Requirements

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	0.137	Report	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
Dissolved Oxygen	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	28.5	42.8 Wkly Avg	XXX	25	38	50	1/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Total Suspended Solids	34.3	51.4 Wkly Avg	XXX	30	45	60	1/week	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	Report	XXX	1/week	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	24-Hr Composite
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	24-Hr Composite

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.137</u>
Latitude <u>39° 49' 2.00"</u>	Longitude <u>-79° 21' 54.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

WQM 7.0:

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate effluent limits for CBOD₅, NH₃-N and DO. The model simulates two basic processes. In the NH₃-N module, the model simulates the mixing and degradation of NH₃-N in the stream and compares calculated instream NH₃-N concentrations to NH₃-N water quality criteria. In the D.O. module, the model simulates the mixing and consumption of D.O. in the stream due to the degradation of CBOD₅ and NH₃-N and compares calculated instream D.O. concentrations to D.O. water quality criteria. Since WQM 7.0 assumes immediate and complete mix between the discharge and stream flow, Q₇₋₁₀ was adjusted, as shown on page 3, to examine allowable wasteload allocations under appropriate mixing conditions. The model was utilized for this permit renewal by using adjusted Q₇₋₁₀ and historic background water quality levels of the river. The following data were used in the attached computer model of the stream:

- Discharge pH 6.74 (median Jul-Sep, 2021, eDMR data)
- Discharge Temperature 14.03°C (Application data)
- Discharge Hardness 100 mg/l (Default)
- Stream pH 7.0 (WQN0709, Median Jul-Sep, 1999-2018)
- Stream Temperature 17.2°C (WQN0709, Median Jul-Sep, 1999-2018)
- Stream Hardness 30 mg/l (WQN0709, Median Jul-Sep, 1999-2018)

The following nodes were considered in modeling:

Node 1: Outfall 001 at Youghiogheny River (37456)
 Elevation: 1311.25 ft (USGS National Map viewer, 11/02/2021)
 Drainage Area: 1029 mi² (StreamStat Version 3.0, 11/02/2021)
 River Mile Index: 73.5 (PA DEP eMapPA)
 Low Flow Yield: 0.275 cfs/mi²
 Discharge Flow: 0.137 MGD

Node 2: At confluence with 38573 at Youghiogheny River (37456)
 Elevation: 1307.4 ft (USGS National Map viewer, 11/02/2021)
 Drainage Area: 1030 mi² (StreamStat Version 3.0, 11/02/2021)

River Mile Index: 72.10 (PA DEP eMapPA)
Low Flow Yield: 0.275 cfs/mi²
Discharge Flow: 0.0 MGD

NH₃-N:

WQM 7.0 suggested NH₃-N limit of 25.0 mg/l as monthly average and 50.0 mg/l as IMAX limit are necessary to protect water quality standards. Per BCW-PMT-033, if WQM modeling results for summer indicates that an average monthly limit of 25 mg/l is acceptable, the application manager will generally establish a year-round monitoring requirement for ammonia-nitrogen, at a minimum. The current permit has monitoring requirement that is consistent with SOP's guidance and will be carried over.

CBOD₅:

The WQM 7.0 model suggests a monthly average CBOD₅ limit of 25 mg/l. The average monthly and average weekly mass loadings were calculated as 28.5 lbs/day and 42.8 lbs/day respectively. These limits are the same as in the existing permit and will be carried over.

Dissolved Oxygen (DO):

The existing permit has a minimum DO of 4.0 mg/l. Per Pa Code 25 Ch.93.7, a minimum DO of 5.0 is required for CWF. This is also supported by WQM 7.0 output. A review of the past 12 months DMR data indicated that the facility is meeting at least 5.0 mg/l DO concentration 83% of the time. A schedule may be provided to meet the final DO limit.

Toxics:

Minor facilities are not required to provide Total Copper, Total Lead, and Total Zinc effluent data if there are no industrial or commercial contributors. The permit application indicated there is no commercial/industrial contributor to the treatment plant.

TDS and its constituents:

TMS suggests no RP for TDS and its constituents. Therefore, no monitoring or limits requirement will be placed in the permit.

Additional Considerations

Fecal Coliform:

The recent coliform guidance in 25 Pa. code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml. These are existing limits that will be carried over.

E. Coli:

DEP's SOP titled "Establishing Effluent Limitations for Individual Sewage Permits (BCW-PMT-033, revised March 24, 2021) recommends quarterly E. Coli monitoring for all sewage dischargers with design flows ≥ 0.05 MGD and < 1.0 MGD. This requirement will be applied from this permit term.

pH:

The TBEL for pH is above 6.0 and below 9.0 S.U. (40 CFR §133.102(c) and Pa Code 25 § 95.2(1)) which are existing limits and will be carried over.

Total Suspended Solids (TSS):

There is no water quality criterion for TSS. The existing limits of 30 mg/L average monthly, 45 mg/l average weekly, and 60 mg/L instantaneous maximum will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment, 25 Pa. Code § 92a.47 and 40CFR 133.102(b). The mass based average monthly and weekly average limits are calculated to be 34.3 lbs./day and 51.4 lbs./day respectively. These are all existing limits that will be carried over.

Total Residual Chlorine (TRC):

The attached computer printout utilizes the equation and calculations as presented in the Department's 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID#391-2000-015) for developing chlorine limitations. The attached printout indicates that a water quality limit of 0.5 mg/l would be needed to prevent toxicity concerns at the

discharge point for Outfall 002. The Instantaneous Maximum (IMAX) limit is 1.6 mg/l. These are the existing permit limit that will be carried over.

Flow and Influent BOD₅ and TSS Monitoring Requirement:

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii). Influent BOD₅ and TSS monitoring requirements are established in the permit per the requirements set in Pa Code 25 Chapter 94.

Best Professional Judgement (BPJ):

Total Phosphorus:

PADEP's SOP BCW-PMT-033 suggests monitoring requirement, at a minimum, for facilities with design flow greater than 2,000 GPD. This requirement is applied for all facilities meeting the flow criteria. This is an existing parameter with monitoring requirement that will be carried over.

Total Nitrogen:

PADEP's SOP BCW-PMT-033 suggests monitoring requirement, at a minimum, for facilities with design flow greater than 2,000 GPD. This requirement is applied for all facilities meeting the flow criteria. This is an existing parameter with monitoring requirement that will be carried over.

Monitoring Frequency and Sample Types:

Otherwise specified above, the monitoring frequency and sample type of compliance monitoring for existing parameters are recommended by DEP's SOP and Permit Writers Manual and/or on a case-by-case basis using best professional judgment (BPJ).

Anti-Backsliding

The proposed limits are at least as stringent as are in existing permit, unless otherwise stated; therefore, anti-backsliding is not applicable.

Proposed Effluent Limitations and Monitoring Requirements


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	0.137	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	28.5	42.8	XXX	25	38	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
TSS	34.3	51.4	XXX	30.0	45.0	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	Report Avg Qrtly	Report Daily Max	XXX	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	24-Hr Composite
Ammonia	XXX	XXX	XXX	Report	Report	XXX	1/week	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	24-Hr Composite

Compliance Sampling Location: At Outfall 001


Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [redacted]



Location Map

Confluence Borough Municipal Authority

NPDES PERMIT RENEWAL



CME


ENGINEERING
 CME ENGINEERING LP
 165 E. Union Street, Somerset, PA 15501
 Phone: 814-443-3344 Fax: 724-672-4801

Document Path: W:\C\m\0129 Confluence Borough Man Auth00 (S) NPDES Renewal\2021 NPDES Permit Appl\CADD\Live\Location Map.mxd

Permit No. PA0038164

PA0038164 at DP

Region ID: PA
Workspace ID: PA20211103014903852000
Clicked Point (Latitude, Longitude): 39.81722, -79.36547
Time: 2021-11-02 21:49:25 -0400



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	1030	square miles
ELEV	Mean Basin Elevation	2370	feet

Low-Flow Statistics Parameters [99.9 Percent (1030 square miles) Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1030	square miles	2.26	1400
ELEV	Mean Basin Elevation	2370	feet	1050	2580

Low-Flow Statistics Flow Report [99.9 Percent (1030 square miles) Low Flow Region 4]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	134	ft ³ /s	43	43
30 Day 2 Year Low Flow	195	ft ³ /s	38	38
7 Day 10 Year Low Flow	62.6	ft ³ /s	66	66
30 Day 10 Year Low Flow	84.7	ft ³ /s	54	54
90 Day 10 Year Low Flow	144	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

PA0038164 at Node 2

Region ID: PA

Workspace ID: PA20211103020018565000

Clicked Point (Latitude, Longitude): 39.82762, -79.37644

Time: 2021-11-02 22:00:40 -0400



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	1030	square miles
ELEV	Mean Basin Elevation	2367	feet

Low-Flow Statistics Parameters [99.9 Percent (1030 square miles) Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1030	square miles	2.26	1400
ELEV	Mean Basin Elevation	2367	feet	1050	2580

Low-Flow Statistics Flow Report [99.9 Percent (1030 square miles) Low Flow Region 4]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	134	ft ³ /s	43	43
30 Day 2 Year Low Flow	195	ft ³ /s	38	38
7 Day 10 Year Low Flow	62.6	ft ³ /s	66	66
30 Day 10 Year Low Flow	84.7	ft ³ /s	54	54
90 Day 10 Year Low Flow	144	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Permit No. PA0038164

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19D	37456	YOUGHIOGHENY RIVER	73.500	1311.25	1029.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.275	16.41	0.00	0.000	0.000	0.0	0.00	0.00	17.20	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Confluence Boro	PA0038164	0.1370	0.1370	0.1370	0.000	14.00	6.74

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Permit No. PA0038164

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19D	37456	YOUGHIOGHENY RIVER	72.100	1307.40	1030.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.275	0.00	0.00	0.000	0.000	0.0	0.00	0.00	17.20	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

Permit No. PA0038164

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
19D		37456				YOUGHIOGHENY RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
73.500	16.41	0.00	16.41	.2119	0.00052	1.023	89.98	87.95	0.18	0.474	17.16	7.00
Q1-10 Flow												
73.500	13.92	0.00	13.92	.2119	0.00052	NA	NA	NA	0.16	0.519	17.15	6.99
Q30-10 Flow												
73.500	20.84	0.00	20.84	.2119	0.00052	NA	NA	NA	0.21	0.415	17.17	7.00

Permit No. PA0038164

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.848	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.27	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Permit No. PA0038164

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19D	37456	YOUGHIOGHENY RIVER

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
73.500	Confluence Boro	11.97	50	11.97	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
73.500	Confluence Boro	2.37	25	2.37	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
73.50	Confluence Boro	25	25	25	25	5	5	0	0

Permit No. PA0038164

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19D	37456	YOUGHIOGHENY RIVER		
<u>RMi</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
73.500	0.137	17.159	6.995	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
89.956	1.023	87.948	0.181	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.29	0.160	0.32	0.563	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.202	0.600	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.474	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.047	2.28	0.31	8.18
	0.095	2.26	0.30	8.17
	0.142	2.25	0.29	8.15
	0.189	2.23	0.29	8.14
	0.237	2.22	0.28	8.12
	0.284	2.20	0.27	8.11
	0.332	2.19	0.26	8.10
	0.379	2.17	0.26	8.09
	0.426	2.16	0.25	8.08
	0.474	2.15	0.24	8.08

Permit No. PA0038164

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
19D		37456	YOUGHIOGHENY RIVER				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
73.500	Confluence Boro	PA0038164	0.137	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5

TRC_CALC

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
16.41	= Q stream (cfs)		0.5	= CV Daily	
0.137	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 24.719		1.3.2.iii	WLA_cfc = 24.091
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 9.211		5.1d	LTA_cfc = 14.005
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)]^{(1-FOS/100)}$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)]^{(1-FOS/100)}$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				



Discharge Information

Instructions Discharge Stream

Facility: Confluence Borough STP NPDES Permit No.: PA0038164 Outfall No.: 001
 Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Treated Wastewater

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.137	100	6.74						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1											
Total Dissolved Solids (PWS)	mg/L	478									
Chloride (PWS)	mg/L										
Bromide	mg/L	< 0.2									
Sulfate (PWS)	mg/L	25.4									
Fluoride (PWS)	mg/L										
Group 2											
Total Aluminum	µg/L										
Total Antimony	µg/L										
Total Arsenic	µg/L										
Total Barium	µg/L										
Total Beryllium	µg/L										
Total Boron	µg/L										
Total Cadmium	µg/L										
Total Chromium (III)	µg/L										
Hexavalent Chromium	µg/L										
Total Cobalt	µg/L										
Total Copper	µg/L										
Free Cyanide	µg/L										
Total Cyanide	µg/L										
Dissolved Iron	µg/L										
Total Iron	µg/L										
Total Lead	µg/L										
Total Manganese	µg/L										
Total Mercury	µg/L										
Total Nickel	µg/L										
Total Phenols (Phenolics) (PWS)	µg/L										
Total Selenium	µg/L										
Total Silver	µg/L										
Total Thallium	µg/L										
Total Zinc	µg/L										
Total Molybdenum	µg/L										
Acrolein	µg/L	<									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	<									
Benzene	µg/L	<									
Bromoform	µg/L	<									



Stream / Surface Water Information

Confluence Borough STP, NPDES Permit No. PA0038164, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: Youghiogheny River

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	037456	73.5	1310.33	1029			Yes
End of Reach 1	037456	72.1	1307.43	1030			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	73.5	0.275										30	7		
End of Reach 1	72.1	0.275										30	7		

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	73.5														
End of Reach 1	72.1														



Model Results

Confluence Borough STP, NPDES Permit No. PA0038164, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/l)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/l)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	

THH

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/l)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	

CRL

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/l)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: **4**

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable