



Application Type Amendment,
Major
Facility Type Sewage
Major / Minor Major

**NPDES PERMIT FACT SHEET
ADDENDUM**

Application No. PA0038415 A-1
APS ID 275687
Authorization ID 1526586

Applicant and Facility Information

Applicant Name	<u>East Pennsboro Township</u>	Facility Name	<u>East Pennsboro Township STP</u>
Applicant Address	<u>98 S Enola Drive</u> <u>Enola, PA 17025-2704</u>	Facility Address	<u>21 Dulles Drive E</u> <u>Camp Hill, PA 17011-1108</u>
Applicant Contact	<u>John Pietropaoli</u>	Facility Contact	<u>Andrew Kirkessner</u>
Applicant Phone	<u>(717) 732-0711</u>	Facility Phone	<u>(717) 732-1815</u>
Client ID	<u>85946</u>	Site ID	<u>251354</u>
SIC Code	<u>4952</u>	Municipality	<u>East Pennsboro Township</u>
SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>	County	<u>Cumberland</u>
Application Received Date	<u>05/08/2025</u>	EPA Waived?	<u>No</u>
Application Accepted Date	<u>05/12/2025</u>	If No, Reason	<u>Major CB Discharge</u>
Purpose of Application	<u>NPDES Permit Amendment</u>		

Internal Review and Recommendations

East Pennsboro Township (Township) has applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of its NPDES permit amendment.

The Township has proposed to replace the existing gaseous chlorine disinfection system with a new UV disinfection system. No other changes are proposed. The permit will be amended to include an UV transmittance output monitoring requirement. According to the application, the completion of construction will take about 12 months from the receipt of all permits.

Based on the review, it is recommended that the permit be amended to include interim (existing TRC requirement) and final (UV transmittance monitoring requirement) requirements in the permit. All other existing permit requirements will remain unchanged. Since this is a major change being made to the permit, a draft permit will be issued for public comments for 30 days. The final permit will be issued concurrently with the WQM permit amendment.

Approve	Return	Deny	Signatures	Date
X			<i>Jinsu Kim</i> Jinsu Kim / Environmental Engineering Specialist	May 12, 2025
X			<i>Daniel W. Martin</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	May 19, 2025