

Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. **PA0038482**
APS ID **1104396**
Authorization ID **1468506**

Applicant and Facility Information

Applicant Name	<u>Fox Township Sewer Authority</u>	Facility Name	<u>Fox Township STP</u>
Applicant Address	<u>116 Irishtown Road PO Box 186</u>	Facility Address	<u>129 Gahr Road</u>
Applicant Contact	<u>Kersey, PA 15846-2608</u>	Facility Contact	<u>Kersey, PA 15846</u>
Applicant Phone	<u>(814) 885-6552</u>	Facility Phone	<u>(814) 885-6156</u>
Client ID	<u>112577</u>	Site ID	<u>271118</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Fox Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Elk</u>
Date Application Received	<u>December 29, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 19, 2024</u>	If No, Reason	<u> </u>
Purpose of Application	<u>Renewal of existing NPDES Permit</u>		

Summary of Review

The Fox Township Sewer Authority (FTSA) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of a NPDES permit for the Fox Township Sewer Authority STP. The permit was originally issued on June 27, 2019, with an effective date of July 1, 2019. The permit expired on June 30, 2024, but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Sludge use and disposal description and location(s): Noble Environmental's Greentree Landfill

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
x		Aaron Baar Aaron Baar / Project Manager	June 8, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	June 9, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	.4
Latitude	41° 21' 55.53"	Longitude	-78° 36' 52.21"
Quad Name	0817	Quad Code	Kersey
Wastewater Description: Sewage Effluent			

Receiving Waters	Unnamed Tributary to Daguscahonda Run (CWF)	Stream Code	50483
NHD Com ID	102666327	RMI	0.43
Drainage Area	1.09 sq. mi.	Yield (cfs/mi ²)	0.0562
Q ₇₋₁₀ Flow (cfs)	0.0613	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	1875.85	Slope (ft/ft)	
Watershed No.	17-A	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	METALS		
Source(s) of Impairment	ACID MINE DRAINAGE		
TMDL Status	Final	Name	Daguscahonda Run Watershed TMDL

Background/Ambient Data	Data Source
pH (SU)	Assumed, default value
Temperature (°F)	CWF, default value
Hardness (mg/L)	Assumed, default value
Other: Ammonia (mg/L)	Assumed, default value

Nearest Downstream Public Water Supply Intake	PA American Water Company - Clarion
PWS Waters	Clarion River
PWS RMI	33.3
	Flow at Intake (cfs) 90.7
	Distance from Outfall (mi) ~71

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001*	Design Flow (MGD)	.4
Latitude	41° 25' 16.4"	Longitude	-78° 38' 39.6"
Quad Name	0817	Quad Code	Kersey
Wastewater Description:	Sewage Effluent		
Receiving Waters	Elk Creek (CWF)	Stream Code	50459
NHD Com ID	102665559	RMI	6.92
Drainage Area	47.1 sq. mi.	Yield (cfs/mi ²)	0.146921
Q ₇₋₁₀ Flow (cfs)	3.37	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	1471.32	Slope (ft/ft)	
Watershed No.	17-A	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Final	Name	Elk Creek TMDL (Elk County) 50459
Background/Ambient Data			
pH (SU)	7.0	Data Source	Assumed, default value
Temperature (°F)	20		CWF, default value
Hardness (mg/L)	100		Assumed, default value
Other: Ammonia (mg/L)	0.1		Assumed, default value
Nearest Downstream Public Water Supply Intake			
PWS Waters	Clarion River	PA American Water Company - Clarion	
PWS RMI	33.3	Flow at Intake (cfs)	90.7
		Distance from Outfall (mi)	~70.5

Comments

For modelling purposes, Elk Creek is considered to be the receiving water in this Protection Report while Daguscahonda Run is considered to be the outfall (001*) with a Q₇₋₁₀ flow of 0.4 mgd – see the Water Quality-Based Limitations Section below for a more in-depth description of the modelling for this draft permit.

Drainage Area

The discharge (001*) is to Elk Creek at RMI 6.92. A drainage area upstream of the discharge is determined to be 47.1 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, Elk Creek below the Daguscahonda Run watershed has a Q₇₋₁₀ of 3.37 cfs and a Q₃₀₋₁₀ of 4.36 cfs. This information was used to obtain a Low Flow Yield (LFY), and a chronic Q₃₀₋₁₀:Q₇₋₁₀ ratio for the discharge point as follows (Guidance No. 391-2000-023).

$$\begin{aligned}
 Q_{7-10} &= 3.37 \text{ cfs} \\
 Q_{30-10} &= 4.36 \text{ cfs} \\
 Q_{30-10}:Q_{7-10} &= 4.36 \text{ cfs} / 3.37 \text{ cfs} = 1.2938 \\
 \text{LFY} &= 3.37 \text{ cfs}/47.1 \text{ mi}^2 = 0.0715 \text{ cfs}/\text{mi}^2
 \end{aligned}$$

For WQM modelling purposes, the default acute (Q₁₋₁₀) exposure stream value of 0.64 cfs was utilized in the absence of other information.

Elk Creek

25 Pa Code §93.9 classifies the receiving water, Elk Creek, with a Cold-Water Fishery (CWF) Existing Use designation. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The discharge is in a stream segment listed as not fully attaining uses.

Local Watershed Total Maximum Daily Loads (TMDLs)

According to PA's 2024 integrated water quality monitoring and assessment report, UNT to Daguscahonda Run in the vicinity of the point of discharge is currently assessed for aquatic life and fish consumption. The assessment found aquatic life in the waterway to be impaired due to acid mine drainage and fish consumption to be impaired due to the atmospheric deposition of mercury. The aquatic life evaluation is listed as Category 4a in the 2024 integrated report, indicating that the water is impaired for one or more uses not needing a TMDL because a TMDL has been completed. The fish consumption evaluation is listed as Category 5 in the 2024 Integrated Report, indicating that the water may be impaired for one or more uses by a pollutant that requires the development of a TMDL.

According to PA's 2024 integrated water quality monitoring and assessment report, Elk Creek in the vicinity of the point of discharge is currently assessed for aquatic life and fish consumption. The assessment found aquatic life in the waterway is supported but that fish consumption to be impaired due to the atmospheric deposition of mercury. The aquatic life evaluation is listed as Category 2 in the 2024 integrated report, indicating that the water is meeting some but not all uses. The assessment status of the remaining uses may be unknown because data are insufficient to assess the water, or it may be impaired. The fish consumption evaluation is listed as Category 5 in the 2024 Integrated Report, indicating that the water may be impaired for one or more uses by a pollutant that requires the development of a TMDL.

Both the existing Elk Creek TMDL (EPA Approved June 20, 2006) and the Daguscahonda Run Watershed TMDL (EPA Approved March 28, 2005) have been taken into consideration during this review.

Public Water Supply Intake

The nearest downstream public water supply intake is the PA American Water Company - Clarion intake, located on the Clarion River approximately 71 miles from the point of discharge. Considering the nature of the discharge and distance, the discharge is not expected to impact the water supply.

Class A Wild Trout Streams

The receiving stream is not a Class A Wild Trout stream; therefore, no Class A Wild Trout Fishery is impacted by this discharge.

Treatment Facility Summary				
Treatment Facility Name: Fox Township STP				
WQM Permit No.		Issuance Date		
2402401 A-1		July 22, 2010		
2402401		November 26, 2002		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Aerated Lagoon	Gas Chlorine	0.4
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.4	734.0	Not Overloaded	Aerobic Digestion	Landfill

FTSA owns and operates the wastewater treatment facility located at 129 Gahr Road (Fox Township, Elk County); the facility only serves Fox Township. The application states that the facility does not accept any industrial wastewater, only sanitary wastewater from 735 residential customers and an identified number of commercial/industrial users connected to the system. With an annual average design flow and hydraulic design capacity of 0.04 MGD, the treatment process, as described in the application, is configured as follows:

Raw Influent Screening → Oxidation Ditch → Secondary Clarification → Chlorine Contact Tank → Outfall 001

The facility utilizes soda ash for pH adjustment and an unidentified polymer to condition the sludge for dewatering. Solids handling is facilitated by a belt filter press.

Compliance History	
Summary of DMRs:	DMR results for the past year are presented below.
Summary of Inspections:	<p>Since the last renewal of the facility's NPDES permit, the following inspections have been logged:</p> <p>March 13, 2024: An Incidence Inspection was conducted by Melanie Lewis. A wastewater release from a Wal-Mart parking lot manhole, on March 8, 2024 was discussed. No violations were noted.</p> <p>December 14, 2022: A CEI was conducted by Alan Poyer. No new violations were noted, but the following unresolved violations were listed:</p> <ol style="list-style-type: none">1. 25 Pa. Code 92a.41(a)(10): Failure to utilize approved analytical methods. % solids for reporting sludge disposal on sludge/biosolids form should be determined periodically through laboratory testing. An acceptable form is method 2540 in Standard Methods for the Examination of Water and Wastewater, 18th edition. Authority was conducting onsite analysis without laboratory accreditation. Mr Zimmerman stated beginning in January 2023 % solid testing will be done by DEP certified lab.2. 25 Pa. Code 92a.41(a)(12): Failure to submit monitoring reports or properly complete monitoring reports. Operator is currently using a in-house spreadsheet. Mr. Zimmerman states he will begin using the Department's permit required Influent process control form starting in January 2023.3. 25 Pa. Code 92a.41(a)(12): Failure to submit a required DMR supplemental report. Influent is reported currently on effluent form will begin using Influent form in Jan. 23.4. 25 Pa. Code 92a.61(f)(1): Failure to properly document monitoring activities and results. Operator will begin completing/submitting Influent supplemental forms beginning January 2023.5. 25 Pa. Code 92a.61(f)(1): Failure to properly document monitoring activities and results. Operator is reporting max CBOD 5 and TSS values instead of weekly average for loading in October 2022 DMR . Mr. Zimmerman states he will do revision in EDMR to correct reporting issue. <p>Various recommendations were noted.</p>

Other Comments: As of June 8, 2025, there are no open violations associated with this facility.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	83.4	133	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	100	150	XXX	30.0	45.0	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	Report	1/month	24-Hr Composite
Ammonia May 1 - Oct 31	60.0	XXX	XXX	18.0	XXX	36	1/month	24-Hr Composite
Total Phosphorus	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Aluminum	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	Report	1/year	24-Hr Composite
Total Copper	0.20	XXX	XXX	0.06	XXX	0.15	1/month	24-Hr Composite
Total Iron	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	Report	1/year	24-Hr Composite
Total Manganese	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	Report	1/year	24-Hr Composite

Compliance Sampling Location: Outfall 001

Compliance History

DMR Data for Outfall 001 (from May 1, 2024 to April 30, 2025)

Parameter	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24
Flow (MGD) Average Monthly	0.212	0.240	0.221	0.183	0.201	0.149	0.129	0.128	0.167	0.142	0.152	0.171
Flow (MGD) Weekly Average	0.250	0.328	0.310	0.230	0.228	0.172	0.144	0.136	0.217	0.167	0.180	0.189
pH (S.U.) Instantaneous Minimum	7.0	6.8	6.7	6.9	6.7	6.6	6.6	6.6	6.8	6.7	6.6	6.6
pH (S.U.) Instantaneous Maximum	7.3	7.2	7.1	7.2	7.1	7.2	7.2	7.3	7.0	7.1	7.1	7.0
DO (mg/L) Instantaneous Minimum	7.0	7.3	7.4	7.1	6.7	6.0	5.6	5.4	5.4	5.2	5.6	6.4
TRC (mg/L) Average Monthly	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
TRC (mg/L) Instantaneous Maximum	0.5	0.5	0.5	0.4	0.5	0.5	0.3	0.3	0.4	0.5	0.4	0.51
CBOD5 (lbs/day) Average Monthly	3.2	4.7	3.9	0.5	4.1	2.9	2.3	2.1	2.8	3.0	4.0	3.1
CBOD5 (lbs/day) Weekly Average	3.9	8.1	6.1	5.4	4.2	3.4	3.1	2.2	3.7	4.0	4.9	3.8
CBOD5 (mg/L) Average Monthly	2.0	2.5	2.3	2.0	2.4	2.5	2.2	2.0	2.0	2.6	3.0	2.3
CBOD5 (mg/L) Weekly Average	2.0	4.0	3.0	3.0	3.0	3.0	3.0	2.0	2.0	3.0	4.0	3.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	208	227	231	198	227	247	275	211	214	134	143	247
BOD5 (mg/L) Raw Sewage Influent Average Monthly	145	128	137	156	137	211	268	204	150	116	107	181
TSS (lbs/day) Average Monthly	5	8	6	4	7	4	3	3	4	3.0	4.0	4.0

NPDES Permit Fact Sheet
Fox Township STP

NPDES Permit No. PA0038482

TSS (lbs/day) Raw Sewage Influent Average Monthly	230	257	320	216	285	362	274	207	244	286	364	338
TSS (lbs/day) Weekly Average	6	14	10	11	8	5	3	3	6	4.0	4.0	5.0
TSS (mg/L) Average Monthly	3.0	4.0	3.5	3.0	4.2	3.0	3.0	3.0	3.0	3.0	3.0	3.0
TSS (mg/L) Raw Sewage Influent Average Monthly	162	140	185	175	172	318	265	198	172	258	270	239
TSS (mg/L) Weekly Average	3.0	7.0	5.0	6.0	4.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
Fecal Coliform (No./100 ml) Geometric Mean	1.6	3	8.9	2.0	1.6	2.9	11	14.1	1.4	3.5	4.0	7.90
Fecal Coliform (No./100 ml) Instantaneous Maximum	4	12	31	4	5	15	1986	111	4.0	17	16	28
Total Nitrogen (lbs/day) Average Quarterly		12.57			11.4			8.80			10.7	
Total Nitrogen (mg/L) Average Quarterly		6.18			7.36			9.02			8.45	
Ammonia (lbs/day) Average Monthly	10.5	1.4	1.4	8.9	5.1	1.1	0.5	0.5	0.7	0.6	1.0	1.2
Ammonia (mg/L) Average Monthly	6.6	0.8	0.8	7.0	3.0	0.9	0.5	0.5	0.5	0.5	0.8	0.9
Ammonia (mg/L) Instantaneous Maximum	8.94	1.4	1.12	9.53	6.74	1.92						
Total Phosphorus (lbs/day) Average Quarterly		2.82			6.67			3.61			8.01	
Total Phosphorus (mg/L) Average Quarterly		1.39			4.3			3.7			6.32	
Total Aluminum (lbs/day) Annual Average					0.02							
Total Aluminum (mg/L) Annual Average					0.013							

NPDES Permit Fact Sheet
Fox Township STP

NPDES Permit No. PA0038482

Total Aluminum (mg/L) Instantaneous Maximum					0.013							
Total Copper (lbs/day) Average Monthly	0.009	0.01	0.01	0.007	0.01	0.03	0.02	0.02	0.02	0.01	0.01	0.01
Total Copper (mg/L) Average Monthly	0.006	0.006	0.007	0.006	0.009	0.03	0.02	0.02	0.01	0.01	0.01	0.01
Total Iron (lbs/day) Annual Average					0.488							
Total Iron (mg/L) Annual Average					0.315							
Total Iron (mg/L) Instantaneous Maximum					0.315							
Total Manganese (lbs/day) Annual Average					0.11							
Total Manganese (mg/L) Annual Average					0.072							
Total Manganese (mg/L) Instantaneous Maximum					0.072							

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	.4	
Latitude	41° 21' 54.00"	Longitude	-78° 36' 53.00"	
Wastewater Description:	Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

Water Quality-Based Limitations

Comments

The receiving water, UNT to Daguscahonda Run, is affected by Abandoned Mine Drainage (AMD). In accordance with § 95.5 of the PA Code, sewage wastes discharged to waters polluted by abandoned coal mine drainage are required to receive secondary treatment. Secondary treatment, per § 92a.47, includes:

1. Monthly average discharge limitation for BOD₅ and TSS may not exceed 30 milligrams per liter. If CBOD₅ is specified instead of BOD₅ the limitation may not exceed 25 milligrams per liter.
2. Weekly average discharge limitation for BOD₅ and TSS may not exceed 45 milligrams per liter for POTW facilities. If CBOD₅ is specified instead of BOD₅ the limitation may not exceed 40 milligrams per liter.
3. On a concentration basis, the monthly average percent removal of BOD₅ or CBOD₅, and TSS, must be at least 85% for POTW facilities.
4. From May through September, a monthly average discharge limitation for fecal coliform of 200/100 mL as a geometric mean and an instantaneous maximum effluent limitation not greater than 1,000/100 mL.
5. From October through April, a monthly average discharge limitation for fecal coliform of 2,000/100 mL as a geometric mean and an instantaneous maximum effluent limitation not greater than 10,000/100 mL.
6. Provision for the disposal or beneficial use of sludge in accordance with applicable Department regulations.
7. Compliance with § 95.2(1) and (2) (relating to effluent standards for industrial waste).
8. Compliance with § 92a.48 (b) (relating to industrial waste permit) if chlorine is used.

Previous renewals of this permit have analyzed the impact of the discharge from the Fox Township STP on Elk Creek immediately downstream from the confluence of Elk Creek and Daguscahonda Run. The entirety of the Daguscahonda Run watershed is currently impaired for aquatic life. Elk Creek immediately below the confluence with Daguscahonda Run is the first water downstream of the Fox Township STP that has been determined to be attaining uses and supporting aquatic life. Therefore, in accordance with previous renewals of this permit, discharge limits for the Fox Township STP have been developed to be protective of aquatic life in Elk Creek downstream of the confluence with Daguscahonda Run.

In accordance with previous renewals, the flow rate from the Daguscahonda Run watershed into Elk Creek has been assumed in this Protection Report to only be comprised of Fox Township STP effluent at the treatment plant's design flow rate of 0.4 mgd.

As stated previously, for modelling purposes Elk Creek is considered to be the receiving water in this Protection Report while Daguscahonda Run is considered to be the outfall (001*) with a Q7-10 flow of 0.4 mgd – see below for a description of the modelling for this draft permit.

CBOD5, NH3-N and Dissolved Oxygen (DO)

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD5, NH3-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. The model was utilized using data derived by USGS StreamStats and past permits.

Modelling was conducted in two phases. Phase 1 entailed an evaluation of the decay of BOD5, Ammonia and DO between RMI 0.43 and 0.001 of UNT Daguscahonda at existing discharge limits. Phase 2 took the model results from Phase 1, attributed the resulting loading to the discharge of Daguscahonda Run into Elk Creek, and the model was re-run the model with Elk Creek as the receiving water and Daguscahonda Run as a pseudo-outfall into Elk Creek.

The model output indicated that no change was recommended to CBOD5, Ammonia or DO at the pseudo-outfall. In accordance with previous permits, this conclusion demonstrates that current discharges from the Fox Township STP are still protective of water quality in Elk Creek.

See attached for model inputs and outputs.

Toxics

A reasonable potential (RP) analysis was done for Total Copper, Total Lead and Total Zinc using the sampling results provided with the application. Additionally, a RP analysis was also completed for Total Aluminum, Total Iron and Total Manganese since these parameters have existing monitoring requirements due to the presence of AMD. The Department's Toxics Management Spreadsheet (Version 1.4) was used to perform the RP analysis for these parameters at a pH of 6.8 and a discharge hardness of 100 mg/L. The sample sizes for all analyzed parameters were less than 10, so the maximum reported effluent concentration was utilized in the analysis. The analysis indicates that monitoring requirements for Total Copper and Total Zinc are appropriate.

<input checked="" type="checkbox"/> CRL	CCT (min):	14.416	PMF:	1	Analysis Hardness (mg/l):	N/A	Analysis pH:	N/A
Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL Basis	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	Report	Report	Report	Report	Report	mg/L	0.046	AFC	Discharge Conc > 10% WQBEL (no RP)
Total Zinc	Report	Report	Report	Report	Report	mg/L	0.36	AFC	Discharge Conc > 10% WQBEL (no RP)

In conformity with the Department's SOP for Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants in NPDES Permits for Existing Dischargers (SOP No. BCW-PMT-037), the Department proposes to establish monitoring requirements in the draft permit for Total Zinc due to effluent concentrations exceeding 10% of the WQBEL (i.e., RP is demonstrated). In conformity with the Department's *Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits* (PA Doc No. 362-0400-001), Table 6-3 (plant design flow = 0.4 mgd.), weekly monitoring of Total Zinc is proposed.

Due to anti-backsliding provisions, the existing discharge limit for Total Copper and the existing monitoring requirements for Total Aluminum, Total Iron and Total Manganese will remain unchanged from the previous renewal of this permit.

The full TMS report is presented at the end of this report.

E. Coli Monitoring

In conformity with the Department's *Establishing Effluent Limitations for Individual Sewage Permits* (SOP No. BCW-PMT-033) and as authorized by § 92a.61 of the PA Code, quarterly E. Coli monitoring has been proposed in this permit. The collection method will be via grab sample.

Best Professional Judgment (BPJ) Limitations

Total Residual Chlorine

Since chlorine is used for disinfection, Total Residual Chlorine (TRC) effluent levels must be regulated in accordance with 25 Pa Code §92a.48(b). DEP's TRC_CALC worksheet is utilized to determine if the existing BAT TBEL is still appropriate. The worksheet indicates that the existing limits of 0.5 mg/L (average monthly) and 1.6 mg/L (IMAX) are still protective of water quality.

The Department's TRC_CALC worksheet is presented at the end of this report.

Total Phosphorus & Total Nitrogen

DEP's SOP no. BPNPSM-PMT-033 (Establishing Effluent Limitations for Individual Sewage Permits) recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, routine monitoring for Total Phosphorus and Total Nitrogen are recommended to be continued in this permit. Sampling frequency for TP and TN is currently required 1/quarter.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Monitoring Frequency and Sample Type

The existing permit currently has monthly concentration and mass discharge limits for Ammonia and Total Copper. The Department's Guidance Document 362-0400-001 (Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits, Table 6.3) recommends sampling these parameters 1/week. The draft permit proposes changing the sampling frequency of both Ammonia and Total Copper to 1/week.

The existing permit requires the permittee to collect 24-hour composite samples of Ammonia (Nov 1- Apr 30), Total Aluminum, Total Iron and Total Manganese, but requires the reporting of instantaneous maximum sampling results. Instantaneous maximum sampling results which would only be appropriate for grab samples. This permit proposes the removal of the instantaneous maximum reporting requirement since there is no associated sampling requirement for these parameters. This change constitutes permissible backsliding on the grounds that the reporting requirement was imposed erroneously. The same number of samples are required to be collected and the limits for these parameters remain unchanged.

Unless discussed otherwise above, the permit's monitoring frequency and sample type for all parameters will remain unchanged from the last permit renewal.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Anti-backsliding Requirement

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal unless noted otherwise above. This approach is in accordance with 40 CFR §122.44(l)(1).

Annual Fees

An annual fee clause is continued in the permit in accordance with 25 Pa. Code § 92a.62. The facility covered by the permit is classified in the Minor Sewage Facility ≥ 0.05 and < 1 MGD fee category, which has an annual fee of \$1,000.

Mass Loading Limitations

Unless stated otherwise in this fact sheet, mass loading effluent limits are calculated based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	83.4	133	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	100	150	XXX	30.0	45.0	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	Report	1/week	24-Hr Composite
Ammonia May 1 - Oct 31	60.0	XXX	XXX	18.0	XXX	36	1/week	24-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Aluminum	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Copper	0.20	XXX	XXX	0.06	XXX	0.15	1/week	24-Hr Composite
Total Iron	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Manganese	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Zinc	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite

Compliance Sampling Location: Outfall 001

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]



Outfall 001


StreamStats Report

Region ID: PA

Workspace ID: PA20250524170523171000

Clicked Point (Latitude, Longitude): 41.36541, -78.61447

Time: 2025-05-24 13:05:42 -0400



+/- Collapse All

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	1.09	square miles
ELEV	Mean Basin Elevation	1960	feet
PRECIP	Mean Annual Precipitation	45	inches

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1.09	square miles	2.33	1720
ELEV	Mean Basin Elevation	1960	feet	898	2700
PRECIP	Mean Annual Precipitation	45	inches	38.7	47.9

Low-Flow Statistics Disclaimers [Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.145	ft ³ /s
30 Day 2 Year Low Flow	0.214	ft ³ /s
7 Day 10 Year Low Flow	0.0613	ft ³ /s
30 Day 10 Year Low Flow	0.0851	ft ³ /s
90 Day 10 Year Low Flow	0.127	ft ³ /s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Outfall 001 Downstream Reach


StreamStats Report

Region ID: PA

Workspace ID: PA20250524170723509000

Clicked Point (Latitude, Longitude): 41.36845, -78.62072

Time: 2025-05-24 13:07:42 -0400



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	1.27	square miles
ELEV	Mean Basin Elevation	1952	feet
PRECIP	Mean Annual Precipitation	45	inches

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1.27	square miles	2.33	1720
ELEV	Mean Basin Elevation	1952	feet	898	2700
PRECIP	Mean Annual Precipitation	45	inches	38.7	47.9

Low-Flow Statistics Disclaimers [Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.169	ft ³ /s
30 Day 2 Year Low Flow	0.249	ft ³ /s
7 Day 10 Year Low Flow	0.0721	ft ³ /s
30 Day 10 Year Low Flow	0.0997	ft ³ /s
90 Day 10 Year Low Flow	0.148	ft ³ /s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

NPDES Permit Fact Sheet
Fox Township STP

NPDES Permit No. PA0038482

DMR Metals



Region: NWRO
County: All
Municipality: All
Permit #: PA0038482
Pollutant: All

PERMIT	AUTH ID	PF NAME	PF ID	CLIENT ID	MONITORING START DATE	MONITORING END DATE	REPORT FREQUENCY	DUE DATE	DMR VERSION	DMR RECEIVED DATE	REPORT STATUS	DMR VERSION 1 LATE IND	OUTFALL	DISCHARGE	REPORTING LOCATION	PARAMETER CODE	PARAMETER	LOAD 1 SEC		LOAD 2 SEC		LOAD 3 SEC	
																		CODE 1 VALUE	CODE 1 LIMIT	CODE 2 VALUE	CODE 2 LIMIT	CODE 3 VALUE	CODE 3 LIMIT
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2020	12/31/2020	Annually	01/26/2021	1	01/27/2020	Submitted	No	001	Yes	Final Effluent	01105	Aluminum, Total	Annual Average	mg/L	0.02	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2020	12/31/2020	Annually	01/26/2021	2	01/15/2021	Submitted	No	001	Yes	Final Effluent	01105	Aluminum, Total	Annual Average	mg/L	0.05	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2021	12/31/2021	Annually	01/26/2022	1	01/05/2022	Submitted	No	001	Yes	Final Effluent	01105	Aluminum, Total	Annual Average	mg/L	0.018	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2022	12/31/2022	Annually	01/26/2023	1	01/16/2023	Submitted	No	001	Yes	Final Effluent	01105	Aluminum, Total	Annual Average	mg/L	0.016	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2023	12/31/2023	Annually	01/26/2024	1	01/11/2024	Submitted	No	001	Yes	Final Effluent	01105	Aluminum, Total	Annual Average	mg/L	0.022	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2024	12/31/2024	Annually	01/26/2025	1	01/09/2025	Submitted	No	001	Yes	Final Effluent	01105	Aluminum, Total	Annual Average	mg/L	0.013	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2025	12/31/2025	Annually	01/26/2026	1	01/27/2026	Submitted	No	001	Yes	Final Effluent	01045	Iron, Total	Annual Average	mg/L	0.119	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2026	12/31/2026	Annually	01/26/2027	1	01/15/2027	Submitted	No	001	Yes	Final Effluent	01045	Iron, Total	Annual Average	mg/L	0.008	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2027	12/31/2027	Annually	01/26/2028	1	01/05/2028	Submitted	No	001	Yes	Final Effluent	01045	Iron, Total	Annual Average	mg/L	0.034	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2028	12/31/2028	Annually	01/26/2029	1	01/16/2029	Submitted	No	001	Yes	Final Effluent	01045	Iron, Total	Annual Average	mg/L	0.095	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2029	12/31/2029	Annually	01/26/2030	1	01/11/2030	Submitted	No	001	Yes	Final Effluent	01045	Iron, Total	Annual Average	mg/L	0.07	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2030	12/31/2030	Annually	01/26/2031	1	01/09/2031	Submitted	No	001	Yes	Final Effluent	01045	Iron, Total	Annual Average	mg/L	0.315	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2031	12/31/2031	Annually	01/26/2032	1	01/27/2032	Submitted	No	001	Yes	Final Effluent	01055	Manganese, Total	Annual Average	mg/L	0.092	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2032	12/31/2032	Annually	01/26/2033	1	01/15/2033	Submitted	No	001	Yes	Final Effluent	01055	Manganese, Total	Annual Average	mg/L	0.03	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2033	12/31/2033	Annually	01/26/2034	1	01/11/2034	Submitted	No	001	Yes	Final Effluent	01055	Manganese, Total	Annual Average	mg/L	0.027	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2034	12/31/2034	Annually	01/26/2035	1	01/09/2035	Submitted	No	001	Yes	Final Effluent	01055	Manganese, Total	Annual Average	mg/L	0.029	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2035	12/31/2035	Annually	01/26/2036	1	01/07/2036	Submitted	No	001	Yes	Final Effluent	01055	Manganese, Total	Annual Average	mg/L	0.051	Monitor and Report	Annual Average	
PA0038482	1210495	FOX TWP STP	293892	112577	01/01/2036	12/31/2036	Annually	01/26/2037	1	01/05/2037	Submitted	No	001	Yes	Final Effluent	01055	Manganese, Total	Annual Average	mg/L	0.072	Monitor and Report	Annual Average	

DMR pH

Apr-25	Mar-25	Feb-25	Jan-25	Dec-24	Nov-24	Oct-24	Sep-24	Aug-24	Jul-24	Jun-24	May-24
7.3	5.01187E-08	6.8	1.58489E-07	7.1	7.94E-08	7.0	1E-07	6.9	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.58E-07	6.9	1E-07
7.2	6.30597E-08	6.8	1.58489E-07	6.8	1.58E-07	6.9	1E-07	6.8	1.58E-07	6.7	1E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.7	2E-07	7.0	1E-07	6.9	1.26E-07	6.8	1.58E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	6.9	1.26E-07	6.7	2E-07	6.8	1.58E-07
7.2	6.30597E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.9	1.5849E-07	6.9	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	7.0	1E-07	6.9	1.58E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.0	0.000001	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07
7.1	7.94328E-08	6.8	1.58489E-07	6.8	1.58E-07	7.0	1E-07	6.8	1.26E-07	6.7	2E-07

NPDES Permit Fact Sheet Fox Township STP

NPDES Permit No. PA0038482

Copper

Facility:	Fox Township STP
NPDES #:	PA0038482
Outfall No.:	001
n (Samples/Month):	4
Reviewer/Permit Engineer:	Aaron Baar
Parameter Name	Total Copper
Units	mg/l
Detection Limit	0.004
Sample Date	When entering values below the detection limit, enter "ND" or use the < notation (e.g. <0.02)
4/1/2025	0.005
4/8/2025	0.005
4/15/2025	0.006
4/25/2025	0.005
4/30/2025	0.008
5/4/2025	0.007
5/11/2025	0.005
5/18/2025	0.005
5/25/2025	0.006
2/4/2025	0.006
2/11/2025	0.007
2/18/2025	0.009
2/25/2025	0.006
1/7/2025	0.005
1/14/2025	0.005
1/22/2025	0.007
1/28/2025	0.005
12/3/2024	0.02
12/17/2024	0.006
12/22/2024	0.007
12/29/2024	0.005
11/5/2024	0.026
11/12/2024	0.054
11/19/2024	0.039
11/26/2024	0.012
10/1/2024	0.018
10/15/2024	0.014
10/22/2024	0.014
10/29/2024	0.019
9/3/2024	0.013
9/10/2024	0.019
9/17/2024	0.015
9/25/2024	0.013
8/6/2024	0.014
8/13/2024	0.012
8/20/2024	0.01
8/27/2024	0.015
7/1/2024	0.012
7/16/2024	0.013
7/23/2024	0.012
7/30/2024	0.013
6/4/2024	0.014
6/11/2024	0.012
6/19/2024	0.005
6/25/2024	0.007
5/7/2024	0.008
5/14/2024	0.009
5/21/2024	0.009
5/29/2024	0.013


Daguscahonda Run Watershed
StreamStats Report

Region ID: PA

Workspace ID: PA20250601154924360000

Clicked Point (Latitude, Longitude): 41.42104, -78.64413

Time: 2025-06-01 11:49:47 -0400



✖ [Collapse All](#)

» Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	13.4	square miles
ELEV	Mean Basin Elevation	1928	feet
PRECIP	Mean Annual Precipitation	45	inches

» Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	13.4	square miles	2.33	1720
ELEV	Mean Basin Elevation	1928	feet	898	2700
PRECIP	Mean Annual Precipitation	45	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	1.86	ft ³ /s	43	43
30 Day 2 Year Low Flow	2.63	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.897	ft ³ /s	54	54
30 Day 10 Year Low Flow	1.18	ft ³ /s	49	49
90 Day 10 Year Low Flow	1.71	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Elk Creek Up


StreamStats Report

Region ID: PA

Workspace ID: PA20250601115623907000

Clicked Point (Latitude, Longitude): 41.42147, -78.64524

Time: 2025-06-01 07:56:47 -0400



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	47.1	square miles
ELEV	Mean Basin Elevation	1864	feet
PRECIP	Mean Annual Precipitation	45	inches

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	47.1	square miles	2.33	1720
ELEV	Mean Basin Elevation	1864	feet	898	2700
PRECIP	Mean Annual Precipitation	45	inches	38.7	47.9


Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	6.53	ft ³ /s	43	43
30 Day 2 Year Low Flow	9.06	ft ³ /s	38	38
7 Day 10 Year Low Flow	3.37	ft ³ /s	54	54
30 Day 10 Year Low Flow	4.36	ft ³ /s	49	49
90 Day 10 Year Low Flow	6.21	ft ³ /s	41	41

Elk Creek Down
StreamStats Report

Region ID: PA
Workspace ID: PA20250601133006046000
Clicked Point (Latitude, Longitude): 41.41764, -78.65438
Time: 2025-06-01 09:30:28 -0400



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	47.4	square miles
ELEV	Mean Basin Elevation	1863	feet
PRECIP	Mean Annual Precipitation	45	inches

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	47.4	square miles	2.33	1720
ELEV	Mean Basin Elevation	1863	feet	898	2700
PRECIP	Mean Annual Precipitation	45	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	6.57	ft ³ /s	43	43
30 Day 2 Year Low Flow	9.11	ft ³ /s	38	38
7 Day 10 Year Low Flow	3.39	ft ³ /s	54	54
30 Day 10 Year Low Flow	4.38	ft ³ /s	49	49
90 Day 10 Year Low Flow	6.25	ft ³ /s	41	41

TMS



Toxics Management Spreadsheet
Version 1.4, May 2023

Discharge Information

Instructions Discharge Stream

Facility: **Fox Township STP** NPDES Permit No.: **PA0038482** Outfall No.: **001**

Evaluation Type: **Custom / Additives** Wastewater Description: **Treated Sewage**

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.4	100	6.8						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod
Total Copper	mg/L	0.0220799			0.6115					
Total Lead	mg/L	< 0.005								
Total Zinc	mg/L	0.064								
Total Aluminum	mg/L	0.06								
Total Iron	mg/L	0.488								
Total Manganese	mg/L	0.11								



Stream / Surface Water Information

Instructions **Discharge** **Stream**

Fox Township STP, NPDES Permit No. PA0038482, Outfall 001

Receiving Surface Water Name: Unnamed Tributary to the Daguscahon

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	050459	6.92	1471.32	47.1			Yes
End of Reach 1	050459	5.53	1449.31	48.8			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary Hardness	Stream pH	Hardness*	pH*	Analysis
Point of Discharge	6.92	3.37									100	7	
End of Reach 1	5.53	3.5											

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary Hardness	Stream pH	Hardness*	pH*	Analysis
Point of Discharge	6.92												
End of Reach 1	5.53												



Model Results

Instructions Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

Fox Township STP, NPDES Permit No. PA0038482, Outfall 001

Hydrodynamics

Wasteload Allocations

AFC

CCT (min):

PMF:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	13.439	14.0	64.8
Total Lead	0	0	0	0	64.581	81.6	378
Total Zinc	0	0	0	0	117.180	120	555
Total Aluminum	0	0	0	0	750	750	3,474
Total Iron	0	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	0	N/A	N/A	N/A

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	8.956	9.33	60.1
Total Lead	0	0	0	0	2.517	3.18	20.5
Total Zinc	0	0	0	0	118.139	120	772
Total Aluminum	0	0	0	0	N/A	N/A	N/A
Total Iron	0	0	0	0	1,500	1,500	9,669
Total Manganese	0	0	0	0	N/A	N/A	N/A

THH

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	0	N/A	N/A	N/A
Total Zinc	0	0	0	0	N/A	N/A	N/A

Total Aluminum	0	0	0	N/A	N/A	N/A
Total Iron	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	1,000	1,000	6,446

CRL

CCT (min): **14.416**

Analysis Hardness (mg/l):

Analysis Hardness (mg/l): Analysis pH:

Analysis Hardness (mg/l):	N/A
Analysis pH:	N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQA Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Concentration Limits				Comments	
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	Governing WQBEL	WQBEL Basis
Total Copper	Report	Report	Report	Report	mg/L	0.046
Total Zinc	Report	Report	Report	Report	mg/L	0.36
					AFC	Discharge Conc > 10% WQBEL (no RP)
					AFC	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

TRC_CALC Elk Creek

1A	B	C	D	E	F	G
2 TRC EVALUATION						
3 Input appropriate values in B4:B8 and E4:E7						
4	3.37	= Q stream (cfs)		0.5	= CV Daily	
5	0.4	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA_afc = 1.756	1.3.2.iii	WLA_cfc = 1.705	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc= 0.654	5.1d	LTA_cfc = 0.991	
14						
15	Source					
16 PENTOXSD TRG 5.1f AML MULT = 1.231						
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ		
18			INST MAX LIMIT (mg/l) = 1.635			
WLA_afc		(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)*(1-FOS/100)]				
LTAMULT_afc		EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)				
LTA_afc		wla_afc*LTAMULT_afc				
WLA_cfc		(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)*(1-FOS/100)]				
LTAMULT_cfc		EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)				
LTA_cfc		wla_cfc*LTAMULT_cfc				
AML_MULT		EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))				
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
INST MAX LIMIT		1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)				

TRC

Outfall 001

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
17A	50483	Trib 50483 to Daguscahonda Run					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.430	Fox Twp STP	PA0038482*	0.400	CBOD5	25		
				NH3-N	18	36	
				Dissolved Oxygen			4

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
17A	50483	Trib 50483 to Daguscahonda Run					

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.430	Fox Twp STP	NA	36	13.12	36	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.430	Fox Twp STP	NA	18	1.51	18	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.43	Fox Twp STP	25	25	18	18	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
17A	50483	Trib 50483 to Daguscahonda Run		
<u>RMI</u>		<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
0.430		0.400	24.549	6.815
<u>Reach Width (ft)</u>		<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
8.626		0.482	17.908	0.164
<u>Reach CBOD5 (mg/L)</u>		<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
22.93		1.486	16.39	0.993
<u>Reach DO (mg/L)</u>		<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
4.382		27.772	Owens	NA
<u>Reach Travel Time (days)</u>		Subreach Results		
0.160		TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
			D.O. (mg/L)	
		0.016	22.26	16.13
		0.032	21.62	15.87
		0.048	21.00	15.62
		0.064	20.39	15.38
		0.080	19.80	15.13
		0.096	19.23	14.89
		0.112	18.67	14.66
		0.128	18.13	14.43
		0.144	17.61	14.20
		0.160	17.10	13.98
				4.27

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.3883	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	4		

WQM 7.0 Hydrodynamic Outputs

SWP Basin			Stream Code		Stream Name								
17A			50483		Trib 50483 to Daguscahonda Run								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
Q7-10 Flow													
0.430	0.06	0.00	0.06	.6188	0.00419	.482	8.63	17.91	0.16	0.160	24.55	6.81	
Q1-10 Flow													
0.430	0.04	0.00	0.04	.6188	0.00419	NA	NA	NA	0.16	0.163	24.70	6.81	
Q30-10 Flow													
0.430	0.09	0.00	0.09	.6188	0.00419	NA	NA	NA	0.17	0.157	24.40	6.82	

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC				
Stream Data												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.100	0.06	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
Discharge Data									Disc Temp (°C)	Disc pH		
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor						
	Fox Twp STP	PA0038482*	0.4000	0.4000	0.4000	0.000			25.00	6.80		
Parameter Data									Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
	Parameter Name											
	CBOD5		25.00	2.00	0.00	1.50						
	Dissolved Oxygen		4.00	8.24	0.00	0.00						
	NH3-N		18.00	0.10	0.00	0.70						

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17A	50483	Trib 50483 to Daguscahonda Run	0.001	1866.37	1.27	0.00000	0.00	<input type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	(°C)	pH
Q7-10	0.100	0.07	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

Outfall 001*

WQM 7.0 Effluent Limits

SWP Basin 17A	Stream Code 50459	Stream Name ELK CREEK					
		Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
6.920	Elk Twp at Elk	PA0038482a	0.400	CBOD5	17.1		
				NH3-N	13.98	27.96	
				Dissolved Oxygen			4

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
17A	50459	ELK CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
6.920	Elk Twp at Elk	24.59	27.96	24.59	27.96	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
6.920	Elk Twp at Elk	2.17	13.98	2.17	13.98	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
6.92	Elk Twp at Elk	17.1	17.1	13.98	13.98	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
17A	50459	ELK CREEK	
<u>RMI</u>	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
6.920	0.400	20.776	5.105
<u>Reach Width (ft)</u>	Reach Depth (ft)	Reach WDRatio	Reach Velocity (fps)
32.010	0.666	48.099	0.187
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
4.34	0.787	2.25	0.743
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
7.585	5.435	Tsivoglou	6
<u>Reach Travel Time (days)</u>	Subreach Results		
0.454	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
		0.045	4.18
		0.091	4.03
		0.136	3.89
		0.181	3.75
		0.227	3.61
		0.272	3.48
		0.318	3.35
		0.363	3.23
		0.408	3.11
		0.454	3.00
			2.18
			7.39
			2.11
			7.25
			2.04
			7.16
			1.97
			7.11
			1.90
			7.08
			1.84
			7.08
			1.78
			7.09
			1.72
			7.11
			1.66
			7.15
			1.61
			7.18

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.2938	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Hydrodynamic Outputs

SWP Basin			Stream Code			Stream Name						
17A			50459			ELK CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
6.920	3.37	0.00	3.37	.6188	0.00300	.666	32.01	48.1	0.19	0.454	20.78	5.10
Q1-10 Flow												
6.920	2.16	0.00	2.16	.6188	0.00300	NA	NA	NA	0.15	0.556	21.11	4.95
Q30-10 Flow												
6.920	4.36	0.00	4.36	.6188	0.00300	NA	NA	NA	0.21	0.401	20.62	5.20

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17A	50459	ELK CREEK			6.920	1471.32	47.10	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.100	3.37	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000				0.00	0.00
Q30-10		0.00	0.00	0.000	0.000				0.00	0.00
Discharge Data										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Elk Twp at Elk	PA0038482a	0.4000	0.4000	0.4000	0.000	25.00	4.30		
Parameter Data										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	17.10	2.00	0.00	1.50					
	Dissolved Oxygen	4.00	8.24	0.00	0.00					
	NH3-N	13.98	0.10	0.00	0.70					

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC			
17A	50459	ELK CREEK	5.530	1449.31	48.80	0.00000	0.00	<input checked="" type="checkbox"/>			
Stream Data											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.100	3.50	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
Discharge Data											
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
		0.0000	0.0000	0.0000	0.000	0.00	7.00				
Parameter Data											
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)							
CBOD5	25.00	2.00	0.00	1.50							
Dissolved Oxygen	3.00	8.24	0.00	0.00							
NH3-N	25.00	0.00	0.00	0.70							