

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0038920
APS ID 28391
Authorization ID 1336587

Applicant and Facility Information

Applicant Name	<u>Burnham Borough Authority</u>	Facility Name	<u>Burnham Borough STP</u>
Applicant Address	<u>200 1st Avenue</u> <u>Burnham, PA 17009-1640</u>	Facility Address	<u>80 Railroad Street</u> <u>Burnham, PA 17009</u>
Applicant Contact	<u>Robert Knepp</u>	Facility Contact	<u>David Rheinholder</u>
Applicant Phone	<u>(717) 248-2692</u>	Facility Phone	<u>(717) 248-6351</u>
Client ID	<u>62129</u>	Site ID	<u>251524</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Burnham Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Mifflin</u>
Date Application Received	<u>December 15, 2020</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>December 30, 2020</u>	If No, Reason	<u>, DEP Discretion</u>
Purpose of Application	<u>NPDES permit renewal for discharge of treated sewage</u>		

Summary of Review

1.0 General Discussion

This factsheet supports the renewal of an existing NPDES permit for discharge of treated domestic wastewater from Burnham Borough Authority (Authority) wastewater treatment plant. The Authority owns, operates, and maintains the wastewater treatment plant located in Burnham Borough, Mifflin County. The facility receives flows from Burnham Borough and portion Derry Township. There are 3 pump stations within the collection system located at Beech Street, Logan Boulevard and Orchard Grove Avenue. The last combined sewer overflow in the collection system was eliminated in 2014. The facility is sequential Batch Reactor with a design annual average flow of 0.64 MGD, hydraulic design of capacity of 0.90MGD and an organic design capacity of 1,140lbs/day. The facility discharges to Kishacoquillas Creek which is designated for High-Quality cold-water fishes and migratory fishes. The existing NPDES permit was issued on March 23, 2016 with an expiration date of March 30, 2021. The facility is currently operating under the terms and conditions in the existing permit pending Department action on the renewal application. A topographic map showing the discharge location is presented in attachment A.

1.1 Sludge use and disposal description and location(s):

Digested sludge is dewatered using reed beds. Reed beds are cleaned periodically to removed solids to a landfill. Liquid sludge is hauled out as needed by license hauler.

1.2 Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request

Approve	Deny	Signatures	Date
X		<i>J. Pascal Kwedza</i> J. Pascal Kwedza, P.E. / Environmental Engineer	January 4, 2022
X		Daniel W. Martin Daniel W. Martin, P.E. / Environmental Engineer Manager	January 16, 2022

Summary of Review

or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

1.3 Changes to Existing Permit

Quarterly monitoring of E.Coli has been added to the permit

1.4 Existing Limit and Monitoring Requirements

DISCHARGE LIMITATIONS								MONITORING REQUIREMENTS	
Discharge Parameter	Mass Units lbs/day			Concentrations mg/l				Monitoring Frequency	Sample Type
	Average Monthly	Average Weekly	Maximum Daily	Average Monthly	Average Weekly	Maximum Daily	Inst. Maximum		
Flow (mgd)	Monitor & Report	XXX	Monitor & Report	XXX	XXX	XXX	XXX	continuous	measured
pH (S.U.)	XXX	XXX	XXX	From 6.0 to 9.0 inclusive				1/day	Grab
D.O.	XXX	XXX	XXX	Minimum of 5.0 mg/l at all times				1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	XXX	1.6	1/day	Grab
TSS	160	240	XXX	30	45	XXX	60	1/week	24-hour comp
CBOD ₅	133	200	XXX	25	40	XXX	50	1/week	24-hour comp
NH ₃ -N (5/1 to 10/31)	70	XXX	XXX	14	XXX	XXX	XXX	1/week	24-hour comp
NH ₃ -N (11/1 to 4/30)	Report	XXX	XXX	Report	XXX	XXX	XXX	1/week	24-hour comp
Total Phos.	Report	XXX	XXX	Report	XXX	XXX	4.0	2/week	24-hour comp
Fecal Col. (5/1 to 9/30)	XXX	XXX	XXX	200	XXX	1000	XXX	1/week	Grab
Fecal Col. (10/1 to 4/30)	XXX	XXX	XXX	2000	XXX	10000	XXX	1/week	Grab

Summary of Review

1.4.1 Chesapeake Bay Permit Requirements

Discharge Parameter	Effluent Limitations					Monitoring Requirements	
	Mass Load(lbs)		Concentrations (mg/l)			Minimum Measurement Frequency	Required Sample Type
	Monthly	Annual	Minimum	Monthly Average	Maximum		
Ammonia---N	Report	Report	XXX	Report	XXX	2/week	24-hr Comp
Kjeldahl---N	Report	XXX	XXX	Report	XXX	2/Week	24-hr Comp
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	2/Week	24-hr Comp
Total Nitrogen	Report	Report	XXX	Report	XXX	1/Month	Calculate
Total Phosphorus	Report	Report	XXX	Report	XXX	2/week	24-hr Comp
Net Total Nitrogen	Report	11689	XXX	XXX	XXX	1/Month	Calculate
Net Total Phos.	Report	1559	XXX	XXX	XXX	1/Month	Calculate

1.5 Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.64
Latitude	40° 37' 46.39"	Longitude	-77° 33' 48.42"
Quad Name		Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	Kishacoquillas Creek (HQ-CWF)	Stream Code	12429
NHD Com ID	66204601	RMI	3.749
Drainage Area	174	Yield (cfs/mi ²)	0.113
Q ₇₋₁₀ Flow (cfs)	19.66	Q ₇₋₁₀ Basis	USGS Gage Station
Elevation (ft)	495	Slope (ft/ft)	
Watershed No.	12-A	Chapter 93 Class.	HQ-CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Background/Ambient Data		Data Source	
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake	Mifflintown Municipal Authority		
PWS Waters		Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	13

Changes Since Last Permit Issuance: None

1.5.1 Water Supply Intake:

The nearest downstream public water supply intake is about 13 miles downstream by Mifflintown Municipal Authority on Juniata River in Mifflintown, Juniata County

Kishacoquillas Creek (12429) From Discharge to Juniata River	(RMI 3.749 – 0.00)	3.749 mi
Juniata River (11414) Juniata River to intake	(RMI 46.56 – 37.26)	<u>9.30 mi</u>
		13.53 mi

Because of distance and dilution, the discharge is not expected to have an effect on the water supply.

2.0 Treatment Facility Summary				
Treatment Facility Name: Burnham STP				
WQM Permit No.		Issuance Date		
4487402 12-1		11/13/2012		
4487402 11-1		02/22/2012		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	Chlorine	0.64
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.9	1,140	Not Overloaded	Aerobic digestion	Reed bed/disposal offsite

Changes Since Last Permit Issuance: None

2.1 Treatment Facility Description

The treatment facility consists of fine screen with comminutor bypass, influent pump chamber with 3 pumps, grit removal unit, 2 SBR units with 2 post Equalization tanks, 2 chlorine contact tanks for disinfection and 2 aerobic tanks for digestion with 3 reed beds.

2.2 Treatment Chemicals

- Sodium Hypochlorite for disinfection.
- Delpac.
- Soda ash for alkalinity or pH adjustment as needed

3.0 Compliance History

3.1 DMR Data for Outfall 001 (from November 1, 2020 to October 31, 2021)

Parameter	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20
Flow (MGD) Average Monthly	0.381	0.945	0.393	0.381	0.301	0.313	0.296	0.425	0.409	0.347	0.436	0.276
Flow (MGD) Daily Maximum	0.793	3.336	1.470	0.973	0.778	0.626	0.526	1.185	1.508	0.786	2.268	0.0970
pH (S.U.) Minimum	7.3	6.9	7.4	7.2	7.5	7.6	7.1	7.2	7.4	7.5	7.0	7.0
pH (S.U.) Maximum	7.9	7.9	7.9	8.0	8.0	7.9	7.9	8.1	8.1	8.1	8.5	7.8
DO (mg/L) Minimum	8.2	5.8	7.8	7.3	8.6	9.0	8.9	7.8	10.9	8.9	9.3	9.1
TRC (mg/L) Average Monthly	0.5	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.6	0.5	0.3	0.03
TRC (mg/L) Instant. Maximum	0.8	0.7	0.7	0.7	0.6	0.7	0.8	0.8	1.1	0.9	0.8	0.05
CBOD5 (lbs/day) Average Monthly	< 8.3	< 84.5	< 15.3	< 12.9	9.7	< 11.9	13.4	< 18.5	23.3	< 20.4	40.3	46.4
CBOD5 (lbs/day) Weekly Average	9.8	< 269.0	37.8	26.7	17.8	18.4	17.6	22.0	40.0	27.6	60.8	94.9
CBOD5 (mg/L) Average Monthly	< 3.4	< 5.4	< 3.3	< 4.7	4.5	< 4.4	5.8	< 6.2	7.5	< 8.0	14.7	17.5
CBOD5 (mg/L) Weekly Average	4.8	9.7	4.0	9.5	8.1	6.9	6.9	9.9	10.3	12.7	25.4	41.1
BOD5 (lbs/day) Raw Sewage Influent Ave. Monthly	387.2	739	< 960	405	547	365	421	423	462	430	673	447
BOD5 (mg/L) Raw Sewage Influent Ave. Monthly	147	72	< 138	146	224	129	162	120	145	149	254	145
TSS (lbs/day) Average Monthly	7.1	308.2	45.0	10.5	< 14.0	14.5	< 16.2	< 15.5	26.3	19.1	47.3	60.1
TSS (lbs/day) Raw Sewage Influent Ave. Monthly	327.7	757	1162	424	562	637	392	441	534	384	783	690
TSS (lbs/day) Weekly Average	8.7	1124.0	152.0	15.8	21.9	25.6	32.6	41.1	59.8	26.1	98.1	93.3
TSS (mg/L) Average Monthly	2.9	17.0	6.1	3.8	< 6.6	6.2	< 7.0	< 5.1	10.4	7.5	18.9	20.0

**NPDES Permit Fact Sheet
Swatara Township STP**

NPDES Permit No. PA0026735

TSS (mg/L) Raw Sewage Influent Ave. Monthly	122.8	70	167	147	231	209	146	128	151	132	276	146
TSS (mg/L) Weekly Average	3.2	40.4	12.4	5.6	10.8	12.4	12.8	14.4	29.5	10.4	49.2	40.4
Fecal Coliform (CFU/100 ml) Geometric Mean	31	45	29	< 4	15	4	28	113	53	11	480	151
Fecal Coliform (CFU/100 ml) Instant. Maximum	641	1011	99	40	46	69	291	7945	1102	34	9678	295
Nitrate-Nitrite (mg/L) Average Monthly	< 2.1	< 3.0	< 2.8	2.5	1.6	1.5	3.7	5.2	5.5	2.5	2.1	1.4
Nitrate-Nitrite (lbs) Total Monthly	< 220.0	< 1072.1	< 327.3	235.2	108.8	142.6	297.1	500.5	418.8	210.7	203.9	139.5
Total Nitrogen (mg/L) Average Monthly	< 3.0	< 4.2	< 3.8	< 4.0	3.0	< 3.1	6.9	10.0	9.7	4.1	8.7	5.8
Total Nitrogen (lbs) Effluent Net Total Monthly	< 300	< 1447	< 429	< 360	210	< 261	524	972	775	347	764	492
Total Nitrogen (lbs) Total Monthly	< 299.9	< 1447.4	< 429.2	< 360.3	210.2	< 261	524	972.2	775.2	346.5	763.5	491.6
Total Nitrogen (lbs) Effluent Net Total Annual		< 7014										
Total Nitrogen (lbs) Total Annual		< 7014										
Ammonia (lbs/day) Average Monthly	< 1.3	< 3.0	1.8	2.5	2.3	< 2.7	6.8	13.1	11.2	11.2	3.3	3.4
Ammonia (mg/L) Average Monthly	< 0.5	< 0.4	0.6	0.9	1.0	< 1.2	2.9	4.3	3.5	0.7	1.2	1.2
Ammonia (lbs) Total Monthly	< 39.6	< 90.3	56.6	76.3	69.0	< 83.7	203.3	407.4	312.8	58.4	103.3	103.1
Ammonia (lbs) Total Annual		< 1658										
TKN (mg/L) Average Monthly	< 1.0	1.2	< 1.0	< 1.4	1.5	< 1.7	3.2	4.8	4.1	1.7	6.6	4.4
TKN (lbs) Total Monthly	< 79.9	375.3	< 101.8	< 123	101.3	< 117.8	221.1	462.6	346.3	135.8	559.6	352.1
Total Phosphorus (mg/L) Ave. Monthly	0.5	0.8	1.1	1.0	0.8	0.8	1.2	1.9	2.1	1.8	1.7	1.2
Total Phosphorus (lbs) Effluent Net Total Monthly	47	238	109	85	52	61	84	245	158	139	134	95

Total Phosphorus (lbs) Total Monthly	46.9	237.8	108.6	84.5	52.4	60.9	84.3	244.7	157.9	138.8	133.6	95.2
Total Phosphorus (lbs) Effluent Net Total Annual		1475										
Total Phosphorus (lbs) Total Annual		1475										

3.2 Effluent Violations for Outfall 001, from: December 1, 2020 To: October 31, 2021

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	02/28/21	Avg Mo	0.6	mg/L	0.5	mg/L
CBOD5	09/30/21	Wkly Avg	< 269.0	lbs/day	200.0	lbs/day
TSS	09/30/21	Avg Mo	308.2	lbs/day	160.0	lbs/day
TSS	09/30/21	Wkly Avg	1124.0	lbs/day	240.0	lbs/day
TSS	12/31/20	Wkly Avg	49.2	mg/L	45.0	mg/L
Fecal Coliform	09/30/21	IMAX	1011	CFU/100 ml	1000	CFU/100 ml

3.3 Summary of Discharge Monitoring Reports (DMRs):

DMRs review for the facility for the last 12 months of operation, presented on the table above in section 3.1 indicate permit limits have been met most of the time. TRC, CBOD5, Fecal Coliform and TSS effluent violations were noted on DMRs during the period reviewed and presented in section 3.2 above. The violations appear to be operation related. The violations recorded on 09/30/21 were attributed to extremely high flows to the facility from Hurricane Ida

3.4 Summary of Inspections:

The facility has been inspected a couple times during last permit cycle. A couple of operational violations were identified during plant inspections and recommendations were made to address them. No effluent violations were found during plant inspections. A notice of violation (NOV) was sent on 1/29/21 for a series of effluent violations in 2020. The response to the NOV attributed the violations to malfunctioning of SBR # 2 decanter. The decanter has since been repaired and functioning well.

4.0 Development of Effluent Limitations

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.64</u>
Latitude	<u>40° 37' 46.45"</u>	Longitude	<u>-77° 33' 48.23"</u>
Wastewater Description: <u>Sewage Effluent</u>			

4.1 Basis for Effluent Limitations

In general, the Clean Water Act(AWA) requires that the effluent limits for a particular pollutant be the more stringent of either technology-based limits or water quality-based limits. Technology-based limits are set according to the level of treatment that is achievable using available technology. A water quality-based effluent limit is designed to ensure that the water quality standards applicable to a waterbody are being met and may be more stringent than technology-based effluent limits.

4.2 Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

4.3 Mass-Based Limits

The federal regulation at 40 CFR 122.45(f) requires that effluent limits be expressed in terms of mass, if possible. The regulation at 40 CFR 122.45(b) requires that effluent limitations for POTWs be calculated based on the design flow of the facility. The mass based limits are expressed in pounds per day and are calculated as follows:

$$\text{Mass based limit (lb/day)} = \text{concentration limit (mg/L)} \times \text{design flow (mgd)} \times 8.34$$

4.4 Water Quality-Based Limitations

4.4.1 Receiving Stream

The receiving stream is, Kishacoquillas Creek. According to 25 PA § 93.9n, from the Main Stem, Yeagertown/Burnham Railroad Bridge to SR 2005 (Mill Road) Bridge at Mount Rock the creek is protected for High-Quality Cold-Water Fishes (HQ-CWF) and Migratory Fishes (MF). It is located in Drainage List N and State Watershed 12-A. It has been assigned stream code 12429. The segment of the creek that receives discharge from this facility is attaining its designated uses.

4.4.2 Stream flows

The Technical Support Document for Water Quality-Based Toxics Control (TSD) (EPA, 1991) and the Pennsylvania Water Quality Standards PA WQS) recommend the flow conditions for use in calculating water quality-based effluent limits (WQBELs) using steady-state modeling. The TSD and the PA WQS state that WQBELs intended to protect aquatic life uses should be based on the lowest seven-day average flow rate expected to occur once every ten years (Q₇₋₁₀) for chronic criteria and the lowest one-day average flow rate expected to occur once every ten years (Q₁₋₁₀) for acute criteria. However,

because the chronic criterion for ammonia is a 30-day average concentration not to be exceeded more than once every three years, EPA has used the Q_{30-10} for the chronic ammonia criterion instead of the Q_{7-10} . The Q_{30-10} is a biologically-based design flow intended to ensure an excursion frequency of once every three years for a 30-day average flow rate. These flows were determined by correlating with the yield of nearby USGS gauging station No 01565000 on Kishacoquillas Creek near Reedsville, PA. The Q_{7-10} and drainage area of the gage 18.6cfs and 164 sq.mi respectively. The yield at the gage are:

- $Q_{7-10} = (18.6)/(164) = 0.113$ cfs/sq.mi.
- $Q_{30-10} / Q_{7-10} = 1.09$
- $Q_{1-10} / Q_{7-10} = 0.95$

The drainage area at the discharge point was found from streamstats calculation to be 174sq.mi. The design streamflow (Q_{7-10}) at the discharge point is calculated as:

$$Q_{7-10} = (0.113)(174) = 19.66\text{cfs}$$

4.4.3 NH₃N Calculations

NH₃N calculations will be based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the instream NH₃N criteria used in the attached computer model of the stream:

- STP pH = 7.2 (DMR Median July-Sept)
- STP Temperature = 25 ° C (default)
- Stream pH = 8.15 (Previous fact sheet)
- Stream Temperature = 19 ° C (Previous factsheet)
- Background NH₃-N = 0.0 (default)

4.4.4 CBOD₅

Brown Township STP and Burnham Borough STP discharges were modeled together due to their proximity to each other. The attached results of the WQM 7.0 stream model presented in attachment B indicates that for the and Burnham Borough STP discharge, a monthly average limit of 25 mg/l CBOD₅ is required to protect the water quality of the stream. This is consistent with the existing permit and facility is meeting the limit. Therefore, an average monthly limit (AML) of 25 mg/l, average weekly limit (AWL) of 40mg/l and IMAX of 50mg/l will remain in the permit. Mass limits are calculated using the equation presented in section 4.3.

4.4.5 NH₃-N

The attached results of the WQM 7.0 stream model (attachment B) also indicates a summer monthly average limit of 16.49 mg/l of NH₃-N is necessary to protect the aquatic life from toxicity effects. However, the existing summer average monthly limit of 14 mg/l and monitoring for winter months will remain in the permit due to anti-backsliding restrictions. Mass limits are calculated using the equation presented in section 4.3.

4.4.6 Dissolved Oxygen

The existing permit contains a limit of 5 mg/l for Dissolved Oxygen (DO). DEP's Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001, 10/97) suggests that either the adopted minimum stream D.O. criteria for the receiving stream or the effluent level determined through water quality modeling be used for the limit. Since the WQM 7.0 model was run using a minimum D.O. of 5.0 mg/l, this limit will be continued in the renewed permit with a daily monitoring requirement.

4.4.7 Total Suspended Solids (TSS):

There is no water quality criterion for TSS. A limit of 30 mg/l AML in the existing permit which was based on the minimum level of effluent quality attainable by secondary treatment as defined in 40 CFR 133.102b(1) and 25 PA § 92a.47(a)(1) will remain in the permit. In addition, an AWL of 45mg/l per 40CFR 133.102(b)(2) and 25 PA § 92a.47(a)(2) is added to the permit. Mass-based limits are calculated based on the equation presented in section 4.3.

4.4.8 Phosphorus

The existing monitoring requirement and instantaneous maximum limit requirement to control phosphorus loading will be carried over in the renewed permit.

4.4.9 Chesapeake Bay Strategy:

The Department formulated a strategy in April 2007, to comply with the EPA and Chesapeake Bay Foundation requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5(below 0.2mgd) are required to monitor and report TN and TP during permit renewal and any facility in Phases 4 and 5 that undergoes expansion is subjected to cap load right away. EPA published Chesapeake Bay TMDL in December of 2010. In order to address the TMDL, Pennsylvania developed Chesapeake Watershed Implementation Plan (WIP) Phase 1, Phase 2 and currently Phase 3 WIP and a supplement to the WIPs to be implemented with the original Chesapeake Bay Strategy.

As outlined in the current Phase 3 WIP and the current supplement to the WIP, re-issuing permits for significant dischargers would follow the same phased approach formulated in the original Bay strategy whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewals.

This facility falls in phase 3 of the strategy and is required to meet a total maximum annual Total Nitrogen Cap load of 11,689 lbs/year based on a design annual wasteflow of 0.64 MGD and 6 mg/l total nitrogen and a TP cap load of 1,559 lbs/year based on annual wasteflow of 0.64 MGD and 0.8 mg/l total phosphorus. The facility is in compliance with the bay cap load requirements.

4.4.10 Total Residual Chlorine

The attached results of TRC calculation presented in attachment C utilizes the equations and calculations as presented in the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID No. 391-2000-015) for developing chlorine limitations. The Guidance references Chapter 92a, Section 92a.48 (b) which establishes a standard BAT limit of 0.5 mg/l unless a facility-specific BAT has been developed. The attached result indicates that a technology limit of 0.5 mg/l and 1.6mg/l IMAX would be needed to prevent toxicity concerns. This is consistent with the existing permit. The facility has no problem meeting the limits.

4.4.11 Toxics

The facility treats mainly domestic sewage, there are no parameters of concern associated with this discharge.

4.4.12 Influent BOD and TSS Monitoring

The permit will include influent BOD5 and TSS monitoring at the same frequency as is done for effluent in order to implement Chapter 94.12 and assess percent removal requirements.

4.4.13 Stormwater

There is no stormwater outfall associated with this facility.

4.4.14 Industrial Users

The wastewater treatment plant does not receive wastewater from any significant industrial users.

4.4.15 Pretreatment Requirements

The design annual average flow of the treatment plant is 0.64 MGD and the facility receives no flow from significant Industrial users. EPA does not require development of pretreatment program for facilities with design flow less than 5MGD. However, the permit contains standard conditions requiring the permittee to monitor and control industrial users if applicable.

4.4.16 Fecal Coliform and E. Coli

The existing Fecal Coliform limit is consistent with the technology limits recommended in 92a.47(a)(4) and (a)(5) and will remain in the permit. Quarterly monitoring of E. Coli is required in the permit following DEP recommendation of 1/quarter monitoring of E. Coli at a minimum for this type of facility.

5.0 Other Requirements

5.1 Anti-backsliding

Not applicable to this permit

5.2 Anti-Degradation (93.4)

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The facility discharge to a stream segment designated as High-Quality Waters. The discharge is not expected to impact the stream negatively. No Exceptional Value Waters are impacted by this discharge.

5.3 Class A Wild Trout Fisheries

The discharge is into a stream segment which is identified as Class A Wild Trout Stream by PA Fish and Boat Commission. The discharge is not expected to the stream negatively.

5.4 303d Listed Streams

The discharge is not located on a 303d listed stream segment.

5.5 Special Permit Conditions

The permit contains the following special conditions:

- Stormwater Prohibition, Approval Contingencies, Solids Management, Restriction on receipt of hauled in waste under certain conditions, and chlorine minimization.

5.6 Basis for Effluent and Surface Water Monitoring

Section 308 of the CWA and federal regulation 40 CFR 122.44(i) require monitoring in permits to determine compliance with effluent limitations. Monitoring may also be required to gather effluent and surface water data to determine if additional effluent limitations are required and/or to monitor effluent impacts on receiving water quality. The permittee is responsible for conducting the monitoring and for reporting results on Discharge Monitoring Reports (DMRs).

5.7 Effluent Monitoring Frequency

Monitoring frequencies are based on the nature and effect of the pollutant, as well as a determination of the minimum sampling necessary to adequately monitor the facility's performance. Permittees have the option of taking more frequent samples than are required under the permit. These samples can be used for averaging if they are conducted using EPA-approved test methods (generally found in 40 CFR 136) and if the Method Detection Limits are less than the effluent limits. The sampling location must be after the last treatment unit and prior to discharge to the receiving water. If no discharge occurs during the reporting period, "no discharge" shall be reported on the DMR.

6.0 Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	133.0	200.0	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	160.0	240.0	XXX	30.0	45.0	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Nitrate-Nitrite (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	2/week	Calculation

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Ammonia May 1 - Oct 31	70.0	XXX	XXX	14.0	XXX	28.0	2/week	24-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TKN (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	2/week	Calculation
Total Phosphorus	XXX	XXX	XXX	Report	XXX	4	2/week	24-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	2/week	Calculation

Compliance Sampling Location: Outfall 001

6.1 Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Total Nitrogen (lbs) Effluent Net	XXX	11689 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Nitrogen (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Ammonia (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs) Effluent Net	XXX	1559 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

Compliance Sampling Location: Outfall 001

7.0 Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing effluent limitation for individual sewage permit.
<input type="checkbox"/>	Other: [redacted]

8.0 Attachments

A. Topographical Map



B. WQM Model Results

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
12A		12429		KISHA COQUILLA S CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
6.934	Brown Twp	PA0028088	0.600	CBOD5	25		
				NH3-N	9.82	19.64	
				Dissolved Oxygen			5
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
3.749	Burnham Boro	PA0038920	0.640	CBOD5	25		
				NH3-N	16.49	32.98	
				Dissolved Oxygen			5

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
12A	12429	KISHACOQUILLAS CREEK	6.934	577.00	68.53	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.113	0.00	0.00	0.000	0.000	0.0	0.00	0.00	19.00	8.15	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q36-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Brown Twp	PA0026088	0.6000	0.6000	0.6000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
12A	12429	KISHACQUILLAS CREEK	3.749	495.00	174.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.113	0.00	0.00	0.000	0.000	0.0	0.00	0.00	19.00	8.15	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Burnham Boro	PA0038920	0.6400	0.6400	0.6400	0.000	25.00	7.20

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
12A	12429	KISHACQUILLAS CREEK	3.547	490.00	184.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.113	0.00	0.00	0.000	0.000	0.0	0.00	0.00	19.00	8.15	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
12A	12429	KI SHACOQUILLA S CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
6.934	Brown Twp	6.24	50	6.24	50	0	0
3.749	Burnham Boro	4.1	50	5.3	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
6.934	Brown Twp	1.06	10.68	1.06	9.82	2	8
3.749	Burnham Boro	.79	17.93	.95	16.49	2	8

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
6.93	Brown Twp	25	25	9.82	9.82	5	5	0	0
3.75	Burnham Boro	25	25	16.49	16.49	5	5	0	0

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
12A	12429	KI SHA COQUILLA S CREEK	
<hr/>			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
6.934	0.600	19.642	7.769
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
42.338	0.739	57.320	0.277
<u>Reach CBO5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
4.46	0.708	1.05	0.681
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
7.896	12.740	Tsivoglou	5
<u>Reach Travel Time (days)</u>	Subreach Results		
0.702	<u>TravTime (days)</u>	<u>CBO5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
	<u>D.O. (mg/L)</u>		
	0.070	4.25	1.00
	0.140	4.05	0.96
	0.211	3.85	0.91
	0.281	3.67	0.87
	0.351	3.49	0.83
	0.421	3.33	0.79
	0.491	3.17	0.75
	0.562	3.02	0.72
	0.632	2.87	0.68
	0.702	2.74	0.65
<hr/>			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
3.749	1.240	19.533	7.865
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
66.907	0.860	77.828	0.375
<u>Reach CBO5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
3.35	0.675	1.02	0.675
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
8.094	11.870	Tsivoglou	5
<u>Reach Travel Time (days)</u>	Subreach Results		
0.033	<u>TravTime (days)</u>	<u>CBO5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
	<u>D.O. (mg/L)</u>		
	0.003	3.34	1.02
	0.007	3.34	1.01
	0.010	3.33	1.01
	0.013	3.32	1.01
	0.016	3.31	1.01
	0.020	3.31	1.00
	0.023	3.30	1.00
	0.026	3.29	1.00
	0.030	3.29	1.00
	0.033	3.28	1.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.95	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.09	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
12A		12429				KISHACOQUILLA S CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
6.934	7.74	0.00	7.74	.9282	0.00488	.739	42.34	57.32	0.28	0.702	19.64	7.77
3.749	19.66	0.00	19.66	1.9183	0.00469	.86	66.91	77.63	0.38	0.033	19.53	7.86
Q1-10 Flow												
6.934	7.36	0.00	7.36	.9282	0.00488	NA	NA	NA	0.27	0.720	19.67	7.76
3.749	18.68	0.00	18.68	1.9183	0.00469	NA	NA	NA	0.37	0.034	19.56	7.86
Q30-10 Flow												
6.934	8.44	0.00	8.44	.9282	0.00488	NA	NA	NA	0.29	0.672	19.59	7.79
3.749	21.43	0.00	21.43	1.9183	0.00469	NA	NA	NA	0.39	0.031	19.49	7.86

C. TRC Calculations

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
19.66	= Q stream (cfs)	0.5	= CV Daily	
0.64	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)	0	= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 6.353		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 2.367		5.1d
Source		Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635		
WLA_afc	(.019/e ^(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e ^(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)			
LTAMULT_afc	EXP((0.5*LN(cvh ² +1))-2.326*LN(cvh ² +1) ^{0.5})			
LTA_afc	wla_afc*LTAMULT_afc			
WLA_cfc	(.011/e ^(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e ^(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)			
LTAMULT_cfc	EXP((0.5*LN(cvd ² /no_samples+1))-2.326*LN(cvd ² /no_samples+1) ^{0.5})			
LTA_cfc	wla_cfc*LTAMULT_cfc			
AML_MULT	EXP(2.326*LN((cvd ² /no_samples+1) ^{0.5})-0.5*LN(cvd ² /no_samples+1))			
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)			
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)			