

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0039225
APS ID 1025109
Authorization ID 1330252

Applicant and Facility Information

Applicant Name	<u>Blaine E Rhodes</u> <u>DBA B.E. Rhodes Sewer Company</u>	Facility Name	<u>Reno Village STP</u>
Applicant Address	<u>PO Box 397</u> <u>Reno, PA 16343-0397</u>	Facility Address	<u>Rte 8</u> <u>Reno, PA 16343</u>
Applicant Contact	<u>Randall L Rhodes, Secretary/Operator</u>	Facility Contact	<u></u>
Applicant Phone	<u>(814) 676-2730</u>	Facility Phone	<u></u>
Applicant Fax	<u>(814)-676-2730</u>	Facility Fax	<u></u>
Applicant E-Mail	<u>vwc-rlr@pa.rr.com</u>	Facility E-Mail	<u></u>
Client ID	<u>271968</u>	Site ID	<u>246451</u>
Municipality	<u>Sugarcreek Borough</u>	County	<u>Venango5960.</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u>No Limitations</u>
SIC Code	<u>4952</u>	SIC Description	<u>Private sewage</u>
Application Received	<u>September 29, 2020</u>	EPA Waived?	<u>Yes</u>
Application Accepted	<u>October 21, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES discharge permit renewal</u>		

Summary of Review

This is a privately owned PUC regulated sewage collection and treatment facility with no listed violations in WMS. Daily DO, pH and TRC monitoring was proposed for the existing permit and was relaxed to 4/week upon issuance for the permit term. Daily monitoring is again proposed.

Randall Rhodes requested continuing the 4/week DO, pH and TRC monitoring and reducing the nutrient monitoring to quarterly. No DO, pH and TRC monitoring changes were made as the monitoring is based on written guidance. The nutrient monitoring was relaxed as nutrients are not limited and the data is being collected to study future nutrient requirements.

Sludge Disposal: Dried sludge is landfilled and liquid sludge sent to the Franklin General Authority.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		William H. Mentzer William H. Mentzer, P.E. Environmental Engineering Specialist	October 26, 2020
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	March 1, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0465</u>
Latitude NHD	<u>41° 24' 55.05"</u>	Longitude NHD	<u>-79° 46' 37.83"</u>
Latitude DP	<u>41° 24' 59.11"</u>	Longitude DP	<u>-79° 46' 39.20"</u>
Latitude MP	<u>41° 25' 6.37"</u>	Longitude MP	<u>-79° 46' 22.93"</u>
Quad Name	<u>Franklin</u>	Quad Code	<u>0707</u>
Wastewater:	<u>Treated municipal sanitary sewer wastes</u>		
Receiving Waters	<u>Unnamed tributary to the Allegheny River</u>	Stream Code	<u>unknown</u>
NHD Com ID	<u>100476659</u>	RMI	<u>0,31</u>
Drainage Area	<u>0.05</u>	Yield (cfs/mi ²)	<u>0</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>Dry swale</u>
Elevation (ft)	<u></u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>16-E</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>None</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>None</u>
Comments	<u>This is a dry drainage swale discharge previously evaluated at Allegheny River RMI 127.59 And 0.65-mile above Seneca Run Drainage 4700 square miles and elevation 956.09 feet; At the downstream at USGS station and RMI 124.30 Drainage 5960.50 square miles and elevation 937.30 feet. The monitoring point is the dry stream discharge</u>		
Low Flow Basis	<u>Allegheny River at Franklin</u>	Station	<u>03025500</u>
	Yield (cfs) <u>0.12</u>	Low Flow (cfs)	<u>683</u>
		Drainage (sq-mi)	<u>5690.508</u>
RMI	<u>124.30</u>		
Comments	<u>The Allegheny River is regulated below the outfall in Franklin at 1250-cfs</u>		
Assessment Status	<u>Impaired</u>		
Impairment Cause(s)	<u>mercury</u>		
Impairment Source(s)	<u>source unknown</u>		
TMDL Status	<u></u>	Name	<u></u>
Comments	<u></u>		
Background/Ambient Data		Data Source	
pH (SU)	<u>7.3</u>	WQN 805 at West Hickory	
Temperature (°C)	<u>25</u>	WWF	
Hardness (mg/L)	<u>57.133</u>	WQN 805 at West Hickory	
Alkalinity:	<u>36.445</u>	WQN 805 at West Hickory	
Nearest Downstream Public Water Supply Intake	<u>Emlenton Water Company/Aqua Pa</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>In Franklin 1250</u>
PWS RMI	<u>90.57</u>	Distance from Outfall (mi)	<u>37.1</u>

Changes Since Last Permit Issuance: none

Other Comments: none

Treatment Facility Summary				
Treatment Facility Name: Reno Village STP				
WQM Permit No.		Issuance Date		
6188402		26 October 1988		
6188402 T1		November 18, 1984		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.0465
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0465	85	Not Overloaded	Drying	landfill

Commercial and Industrial waste sources: Non-significant Categorical industrial users
Joy Mfg Chain Plant
Wegel Machine, inc
Webco Industries, Inc.

No hauled in wastes reported.

Changes Since Last Permit Issuance: none

Other Comments: WQM permits 362-S-33, 362-S-33 T-1, 6171401, and 6172408 are cancelled permits with parts retained by WQM permit 6188402.

	Month	Year	Mean MGD	Max MGD	Mean PPD	Max PPD	Min mg/L	Mean mg/L	Max mg/L	#	Min mg/L	Mean mg/L	Max mg/L	#
Annual Average Flow		2017	0.031											
Hydraulic Design Flow		2018	0.037											
Organic Design		2019	0.037											
Annual Average Flow		2017	0.031											
Highest Monthly Ave	June	2019	0.045											
Dissolved Oxygen											6.7		7.7	834
pH														
BOD5							240.63	380		8				
CBOD5											7.75	22.0	48	
TSS							299.25	552		8	6.35	18.0	48	
Nitrogen											37.1	5.6	48	
Ammonia											0.74	17.0	48	
Phosphorus											5.6	7.7	48	
Nitrite-Nitrate Nitrogen														
Total Dissolved Solids														
Chloride														
Sulfate														

Soda ash is used for pH adjustment
Sodium hypochlorite is used for disinfection
5.047-dry tons sludge removed in the previous year. 42.8-dry tons sent to the Northwest Sanitary Landfill and 5.047-dry tons sent to the Franklin City General Authority
Heffren Septic Tank Service hauls the liquid sludge and Waste Management hauls the dry sludge.

Compliance History

DMR Data for Outfall 001 (from September 1, 2019 to August 31, 2020)

Parameter	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19
Flow (MGD) Average Monthly	0.034	0.033	0.030	0.030	0.033	0.036	0.035	0.035	0.033	0.033	0.035	0.036
Flow (MGD) Daily Maximum	0.041	0.038	0.032	0.034	0.054	0.053	0.047	0.056	0.036	0.037	0.043	0.050
pH (S.U.) Minimum	6.94	6.92	6.88	6.83	6.79	6.87	6.85	6.88	6.88	7.02	6.72	6.99
pH (S.U.) Instant Maximum	7.47	7.4	7.41	7.26	7.33	7.25	7.26	7.28	7.36	7.39	7.35	7.38
DO (mg/L) Instant Minimum	4.85	4.42	4.72	4.57	5.12	4.74	5.14	6.27	5.63	5.71	5.43	4.58
TRC (mg/L) Average Monthly	0.39	0.34	0.36	0.41	0.29	0.36	0.35	0.42	0.5	< 0.40	0.37	0.38
TRC (mg/L) Instant Maximum	0.59	0.42	0.47	0.53	0.53	0.55	0.56	0.62	0.84	0.47	0.48	0.5
CBOD5 (mg/L) Average Monthly	3.75	2.5	2.75	4.15	3.5	5.0	4.85	2.35	< 2.05	3.85	< 2.05	3.75
BOD5 (lbs/day) Influent Ave Monthly			200			320			220			213
BOD5 (lbs/day) Influent Daily Max			200			320			220			213
BOD5 (mg/L) Influent Ave Monthly			200			320			220			213
TSS (lbs/day) Influent Ave Monthly			240			310			330			290
TSS (lbs/day) Influent Daily Max			240			310			330			290
TSS (mg/L) Average Monthly	< 5.0	5.0	5.5	9.5	< 5.0	5.0	< 5.0	< 5.0	< 5.5	< 5	5.0	< 5.0
TSS (mg/L) Influent Ave Monthly			240			310			330			290
Fecal Coliform (#/100 ml) Geometric Mean	< 10.0	< 10.0	31.15	29.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10	< 10.0	< 15.49
Total Nitrogen (mg/L) Average Monthly	51.6	48.6	50.9	45.55	34.35	48.05	38.55	40.0	37.74	40.77	38.1	33.4
Ammonia (mg/L) Average Monthly	< 0.21	0.14	< 0.1	0.11	0.34	0.53	1.70	< 0.11	< 0.1	< 0.1	< 0.10	0.16
Total Phosphorus (mg/L) Ave Monthly	7.85	8.34	8.35	6.52	6.40	6.70	5.83	6.18	4.67	5.52	5.85	5.61

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) 0.0465
 Latitude 41° 24' 59.11" Longitude -79° 46' 39.20"
 Wastewater Description: Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4.0			BPJ

Comments: none

Water Quality-Based Limitations

A Sewerage program based “Reasonable Potential Analysis” determined the following parameters were candidates for limitations: CBOD₅, TSS, nitrogen, ammonia, phosphorus, dissolved oxygen and pH

The following limitations were determined through water quality modeling (output files attached):

Parameter		Limit (mg/L)			SBC	Model		
Name	Period	Min	Mean	Max		Min	Mean	Max
CBOD ₅			25.0	50.0			25.0	50.0
TSS			30.0	60.0			30.0	60.0
Ammonia							25.0	
pH		6.0		9.0		6.0		9.0
DO		4.0			4.0			

Comments: No nutrient requirements have been established for the receiving waters and ammonia requirements are not necessary in the dry stream reach or Allegheny River. The discharge is to low laying area with several drains to the Allegheny River.

Best Professional Judgment (BPJ) Limitations

Comments: For effluent DO.

Anti-Backsliding

Not considered as the existing requirements are being achieved.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.2	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	6-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
TSS Raw Sewage Influent	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	8-Hr Composite
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	8-Hr Composite

Compliance Sampling Location: Outfall 001 after disinfection

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42122	ALLEGHENY RIVER	127.580	956.09	4700.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.120	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.30	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Reno Village	PA0039225	0.0465	0.0465	0.0465	0.000	25.00	7.20

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42122	ALLEGHENY RIVER	124.300	937.30	5960.50	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.120	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.30	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18A		42122				ALLEGHENY RIVER						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
127.580	564.00	0.00	564.00	.0719	0.00108	1.171	446.75	381.4	1.08	0.186	25.00	7.30
Q1-10 Flow												
127.580	360.96	0.00	360.96	.0719	0.00108	NA	NA	NA	0.84	0.239	25.00	7.30
Q30-10 Flow												
127.580	767.04	0.00	767.04	.0719	0.00108	NA	NA	NA	1.28	0.157	25.00	7.30

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Uniform Treatme	Use Inputted W/D Ratio	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input checked="" type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
18A	42122	ALLEGHENY RIVER

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
127.580	Reno Village	NA	50	5.22	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
127.580	Reno Village	NA	25	1.13	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
127.58	Reno Village	25	25	25	25	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18A	42122	ALLEGHENY RIVER		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
127.580	0.047	25.000	7.300	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
446.749	1.171	381.402	1.078	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.00	0.002	0.10	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.540	5.455	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.186	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.019	2.00	0.10	7.54
	0.037	2.00	0.10	7.54
	0.056	2.00	0.10	7.54
	0.074	2.00	0.10	7.54
	0.093	2.00	0.10	7.54
	0.112	2.00	0.10	7.54
	0.130	2.00	0.10	7.54
	0.149	2.00	0.10	7.54
	0.167	2.00	0.10	7.54
	0.186	2.00	0.10	7.54

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
18A		42122		ALLEGHENY RIVER			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
127.580	Reno Village	PA0039225	0.047	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

1A	B	C	D	E	F	G	H	I	J	K	L	M	
	Discharger Site	Reno Village							Wednesday, October 21, 2020				
	Municipality	Reno Village STP					Revised		Monday, March 1, 2021				
	County	Sugar Creek Borough											
	NPDES Permit	Venango											
		PA0039225											
2	TRC EVALUATION												
3	Input appropriate values in B4:B8 and E4:E7												
4	584.1156	= Q stream (cfs)				0.5	= CV Daily						
5	0.0465	= Q discharge (MGD)				0.5	= CV Hourly						
6	30	= no. samples				1	= AFC_Partial Mix Factor						
7	0.4	= Chlorine Demand of Stream				1	= CFC_Partial Mix Factor						
8	0	= Chlorine Demand of Discharge				15	= AFC_Criteria Compliance Time (min)						
9	0.5	= BAT/BPJ Value				720	= CFC_Criteria Compliance Time (min)						
	0	= % Factor of Safety (FOS)					= Decay Coefficient (K)						
10	Source	Reference	AFC Calculations					Reference	CFC Calculations				
11	TRC	1.3.2.iii	WLA_afc = 3285.802					1.3.2.iii	WLA_cfc = 3223.058				
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373					5.1c	LTAMULT_cfc = 0.581				
13	PENTOXSD TRG	5.1b	LTA_afc = 1224.368					5.1d	LTA_cfc = 1873.735				
14													
15	Source	Effluent Limit Calculations											
16	PENTOXSD TRG	5.1f	AML_MULT = 1.231										
17	PENTOXSD TRG	5.1g	LIMIT (mg/l) = 0.500					BAT/BPJ					
18			LIMIT (mg/l) = 1.635										
	WLA_afc	$(0.19/e^{-(k \cdot AFC_tc)}) + [(AFC_Yc \cdot Qs \cdot 0.019 / Qd) \cdot e^{-(k \cdot AFC_tc)}] \dots$											
	LTAMULT_afc	$\dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd) \cdot (1 - FOS / 100)$											
	LTA_afc	$EXP((0.5 \cdot LN((cvh^2 + 1))) - 2.326 \cdot LN((cvh^2 + 1)^{0.5}))$											
	WLA_cfc	$(0.11/e^{-(k \cdot CFC_tc)}) + [(CFC_Yc \cdot Qs \cdot 0.11 / Qd) \cdot e^{-(k \cdot CFC_tc)}] \dots$											
	LTAMULT_cfc	$\dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd) \cdot (1 - FOS / 100)$											
	LTA_cfc	$EXP((0.5 \cdot LN((cvd^2 / no_samples + 1))) - 2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}))$											
	AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN((cvd^2 / no_samples + 1)))$											
	AVG MON LIMIT	$MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) \cdot AML_MULT)$											
	INST MAX LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) \cdot LTA_MULT_afc)$											
	0.011/EXP(-K*CFC_tc/1440))+((CFC_Yc*Qs*0.011)/(1.547*Qd))...												
EXP(-K*CFC_tc/1440))+Xd+(CFC_Yc*Qs*Xs/1.547*Qd)*(1-FOS/100)												
	Stream	Chlorine Required	=	perennial	Chlorine Demand	+	Chlorine Residual						
	Stream	Reach/Node	2	1	2								
	Stream	Flow	Conditions	dry	perennial								
	Stream	Code		49939	42122								
	Stream	Function			secondary								
	Samples			30	30								
	reach	outfall	RMI	0.32	127.58								
	Reach End		RMI	0	124.3								
	reach		feet	1689.6	17318.4								
	drainage		sq miles	0.23	4700								
	TRC	limitation	average	mg/L	0.082	0.500							
			maximum	mg/L	0.270	1.635							
	elevation	modelled	feet	1628.95	956.9								
	elevation	modelled	feet	1238.19	937.3								
	slope	modelled	foot/foot	0.231	0.001								
	low flow		cfs/sq mi	0.120	0.120								
	discharge		mgd	0.0465	0.0465								
	Runoff	Period	hours	24.000	24.000								
	Dry stream discharge with no known need to protect aquatic life therefore no requirements are proposed.												
	stream	flow	cfs	0.02761	564.11563								
	stream	flow	MGD	0.017842	364.597522								
	stream	flow	total	MGD	0.064342	364.644022							
	stream	chlorine	demand	mg/L	0.4	0.4							
	discharge	discharge	demand	mg/L									
	stream	Total Stream/Waste	ratio	1.4	7841.8								
	The first point of use is the Allegheny River where water-quality based limits are not necessary. Mussel habitat was not evaluated but with the overland flow providing a rapid chlorine dissipation and Allegheny River dilution no critical habitat impairment is expected.												
	permitted	TRC	mean	BAT	0.5	0.5							
	permitted	TRC	maximum	WQ	1.2	1.2							
	Total Stream: Waste ratio:	14351	low flow	1250.0	cfs	drainage	5690.5	sq mil	yield	0.220	cfs/sq-mi		
		7842	low flow	683	cfs	drainage	5690.5	sq mil	yield	0.120	cfs/sq-mi		