

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0039233  
 APS ID 1084087  
 Authorization ID 1432073

**Applicant and Facility Information**

Applicant Name	<u>Blair Enterprises, LLC</u>	Facility Name	<u>Horse Creek Manor</u>
Applicant Address	<u>5639 Emlenton Clintonville Road</u> <u>Emlenton, PA 16373</u>	Facility Address	<u>1431 Horsecreek Road</u> <u>Seneca, PA 16346</u>
Applicant Contact	<u>Nicole Branan, Secretary</u> <u>(office@blairconstructionllc.com)</u>	Facility Contact	<u>Nicole Branan, Secretary</u> <u>(office@blairconstructionllc.com)</u>
Applicant Phone	<u>(724) 664-4403</u>	Facility Phone	<u>(724) 664-4403</u>
Client ID	<u>323193</u>	Site ID	<u>246585</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Cranberry Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Venango</u>
Date Application Received	<u>March 15, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 14, 2022</u>	If No, Reason	<u>-</u>

Purpose of Application Renewal of an existing NPDES Permit for an existing discharge of treated sanitary wastewater from a non-municipal sewer system. This application also transfers ownership from Blaine Rhodes d/b/a Rhodes Country Court to the Blair Construction, LLC, and renames the facility from the Rhodes Country Court to the Horse Creek Manor

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.  
 A Part II Water Quality Management permit is not required at this time.  
 The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

- |  |                            |
|--|----------------------------|
| <u>I. OTHER REQUIREMENTS:</u>                      | <u>SPECIAL CONDITIONS:</u> |
| A. Stormwater into Sewers                          | II. Solids Management      |
| B. Right of Way                                    |                            |
| C. Solids Handling                                 |                            |
| D. Public Sewerage Availability                    |                            |
| E. Effluent Chlorine Optimization and Minimization |                            |
| F. Little or No Assimilative Capacity              |                            |

There are no open violations in effects associated with the subject Client ID (323193) as of 9/20/2023. [9/22/2023 CWY](#)

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	9/20/2023
X		Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager	9/22/2023

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.013</u>
Latitude	<u>41° 23' 20.00"</u>	Longitude	<u>-79° 40' 23.00"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to the Sage Run (CWF)</u>	Stream Code	<u>N/A</u>
NHD Com ID	<u>100476739</u>	RMI	<u>N/A</u>
Drainage Area	<u>0.19</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.019</u>	Q <sub>7-10</sub> Basis	<u>calculated</u>
Elevation (ft)	<u>1390</u>	Slope (ft/ft)	<u>0.01908</u>
Watershed No.	<u>16-E</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Aqua Pennsylvania, Inc. - Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1,250</u>
PWS RMI	<u>90.0</u>	Distance from Outfall (mi)	<u>46.8</u>

Sludge use and disposal description and location(s): All sludge is hauled by Heffern Septic to the Franklin City General Authority STP where it is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.013 MGD of treated sewage from an existing non-municipal STP in Cranberry Township, Venango County.

Treatment permitted under Water Quality Management (WQM) Permit No. 367S016 T-1 consists of the following:

A comminutor with bypass bar screen, a package plant with three 5,744 gallon aeration tanks in series, a 3,405 gallon settling tank, and liquid chlorine disinfection with a 970 gallon contact tank. A 14,000 gallon polishing pond

**1. Streamflow:**

Oil Creek at Rouseville, PA (1934-2008) - USGS Gage 03020500:

Drainage Area:	<u>283</u>	sq. mi.	(USGS StreamStats)
Q <sub>7-10</sub> :	<u>30.1</u>	cfs	(USGS StreamStats)
Yieldrate:	<u>0.1</u>	cfsm	Calculated)

Unnamed Tributary to the Sage Run at Outfall 001:

Yieldrate:	<u>0.1</u>	cfsm	
Drainage Area:	<u>0.19</u>	sq. mi.	(USGS StreamStats)
% of stream allocated:	<u>100%</u>	Basis:	No nearby discharges
Q <sub>7-10</sub> :	<u>0.019</u>	cfs	(USGS StreamStats)

**2. Wasteflow:**

Maximum discharge: 0.013 MGD = 0.020 cfs

Runoff flow period: 16 hours Basis: Runoff flow for MHPs

24 hour flow: 0.013 MGD x 24/16 = 0.019 MGD = 0.030 cfs

The calculated stream flow is only slightly more than the proposed discharge flow. In accordance with the SOP, since there is less than 3 parts stream flow (Q7-10) to 1 part effluent (design flow), the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were evaluated. Based on eDMR data, the treatment requirements are not attainable, so they will not be implemented in this NPDES Permit renewal *because this is an existing discharge 9/22/2023 CWY.*

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

**3. Parameters:**

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH<sub>3</sub>-N, CBOD<sub>5</sub>, Dissolved Oxygen, and Disinfection.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency was previously set to 2/week due to a Permittee request. The measurement frequency was increased to 1/day, as recommended in the SOP, based on Table

6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)  
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)  
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows between 0.002 MGD and 0.05 MGD.

e. Phosphorus

Chapter 96.5 does not apply. The previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH<sub>3</sub>-N)

Median discharge pH to be used: 7.4 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background NH<sub>3</sub>-N concentration: 0.1 mg/l

Basis: Default value

Calculated NH<sub>3</sub>-N Summer limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Calculated NH<sub>3</sub>-N Winter limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 1). The winter limits are calculated as three times the summer limits, but since the technology-based limits would govern, they will be used. The calculated limits are less restrictive than the previous renewal, so the previous limits will be retained.

h. CBOD<sub>5</sub>

Median discharge pH to be used: 7.4 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background CBOD<sub>5</sub> concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD<sub>5</sub> limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the limits above (see Attachment 1). The calculated limits are the same as the previous permit and will be retained.

i. Dissolved Oxygen (DO)

The Dissolved Oxygen minimum of 4.0 mg/l will be retained with this renewal. The technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61.

The measurement frequency was previously set to 2/week due to a Permittee request. The measurement frequency was increased to 1/day, as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

j. Disinfection

Ultraviolet (UV) light

Basis: N/A

TRC limits: 0.5 mg/l (monthly average)  
1.6 mg/l (instantaneous maximum)

Basis: The TRC limits above were calculated using the Department's TRC Calculation Spreadsheet (see Attachment 2). The monthly average limit is the same as in the previous NPDES Permit and will be retained. The instantaneous maximum limit was previously set as 1.2 mg/l, but it will be reduced to 1.6 mg/l to comply with the SOP.

The measurement frequency was previously set to 2/week due to a Permittee request. The measurement frequency was increased to 1/day, as recommended in the SOP, based on

Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

**4. Reasonable Potential Analysis for Receiving Stream:**

A Reasonable Potential Analysis was not performed in accordance with State practices for Outfall 001 using the Department's Toxics Management Spreadsheet since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

**5. Reasonable Potential for Downstream Public Water Supply (PWS):**

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). Since no relevant sampling was provided, mass-balance calculations were not performed.

Nearest Downstream potable water supply (PWS): Aqua Pennsylvania, Inc. - Emlenton

Distance downstream from the point of discharge: 46.8 miles (approximate)

Result: No limits or monitoring are necessary as there is significant dilution available.

**6. Anti-Backsliding:**

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

**7. Attachment List:**

Attachment 1 - WQ Modeling Printouts

Attachment 2 - TRC Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from July 1, 2022 to June 30, 2023)

Parameter	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22
Flow (MGD) Average Monthly	0.0024	0.004	0.003	0.012	0.0057	0.0121	0.008	0.003	0.002	0.003	0.002	0.002
pH (S.U.) Instantaneous Minimum	7.45	7.08	7.09	7.19	7.36	7.06	7.17	7.21	7.45	7.24	7.39	7.37
pH (S.U.) Instantaneous Maximum	7.83	7.63	7.81	7.57	7.76	7.56	7.58	7.76	7.84	7.64	7.65	7.74
DO (mg/L) Instantaneous Minimum	5.62	5.88	6.60	8.09	9.04	8.35	9.01	7.74	7.84	6.23	6.04	5.52
TRC (mg/L) Average Monthly	0.32	0.24	0.34	0.40	0.29	0.35	0.31	0.40	0.44	0.38	0.32	0.32
TRC (mg/L) Instantaneous Maximum	0.53	0.51	0.61	0.54	0.62	0.62	0.53	0.53	0.56	0.58	0.61	0.47
CBOD5 (mg/L) Average Monthly	5.85	4.61	8.08	3.62	4.33	6.80	2.22	2.46	2.91	3.65	3.7	3.6
TSS (mg/L) Average Monthly	< 5.0	< 5.0	9.5	< 5.0	< 5.0	11.0	< 5.0	6.5	5.5	9.5	6.5	6.5
Fecal Coliform (No./100 ml) Geometric Mean	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0	< 10.0
Total Nitrogen (mg/L) Daily Maximum	8.89			9.42			2.77			9.21		
Ammonia (mg/L) Average Monthly	< 0.2	< 0.20							5.45	0.747	2.02	8.888
Ammonia (mg/L) Daily Maximum	< 0.2	< 0.20	< 0.20	< 0.20	< 0.20	< 0.10	< 0.8	< 0.8	5.45	0.747	2.02	8.888
Total Phosphorus (mg/L) Daily Maximum	0.96			2.08			5.45			9.12		

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Estimate
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	17.0 Avg Qrtly	XXX	34	1/quarter	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite

Compliance Sampling Location: at Outfall 001, after disinfection.



Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The limits for Total Residual Chlorine (TRC) are technology based on Chapter 92a.47. The limits for CBOD<sub>5</sub>, Total Suspended Solids (TSS), and Fecal Coliforms are technology-based on Chapter 92a.47. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61.

Attachment 1

**WQM 7.0 Effluent Limits** (Perennial Reach Model)

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
16E		54711		SAGE RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.100	perennial	1	0.019	CBOD5	3.3		
				NH3-N	6.94	13.88	
				Dissolved Oxygen			2

Since the results are the same as the inputs for the Dry Reach Model, those inputs are protective of the receiving stream.

Horse Creek Manor

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16E	54711	SAGE RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
3.100	0.019	21.102		7.062
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
4.825	0.367	13.146		0.075
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.29	0.051	1.53		0.762
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
6.867	25.162	Owens		6
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
2.515	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.251	2.26	1.26	8.08
	0.503	2.23	1.04	8.08
	0.754	2.20	0.86	8.08
	1.006	2.17	0.71	8.08
	1.257	2.14	0.59	8.08
	1.509	2.11	0.48	8.08
	1.760	2.08	0.40	8.08
	2.012	2.05	0.33	8.08
	2.263	2.03	0.27	8.08
	2.515	2.00	0.23	8.08

Horse Creek Manor

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

Horse Creek Manor

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54711	SAGE RUN	3.100	1299.00	1.04	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
perennial	1	0.0190	0.0000	0.0000	0.000	25.00	7.40

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	3.30	2.00	0.00	1.50
Dissolved Oxygen	2.00	8.24	0.00	0.00
NH3-N	6.94	0.00	0.00	0.70

(inputs from th Dry Reach Model results)

Horse Creek Manor

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54711	SAGE RUN	0.000	987.00	5.46	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16E		54711				SAGE RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
3.100	0.10	0.00	0.10	.0294	0.01906	.367	4.82	13.15	0.08	2.515	21.10	7.06
<b>Q1-10 Flow</b>												
3.100	0.07	0.00	0.07	.0294	0.01906	NA	NA	NA	0.06	3.024	21.53	7.09
<b>Q30-10 Flow</b>												
3.100	0.14	0.00	0.14	.0294	0.01906	NA	NA	NA	0.09	2.189	20.86	7.05

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
16E	54711	SAGE RUN

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.100	perennial	13.59	13.88	13.59	13.88	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.100	perennial	1.75	6.94	1.75	6.94	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
3.10	perennial	3.3	3.3	6.94	6.94	2	2	0	0



Horse Creek Manor

**WQM 7.0 D.O.Simulation** (Dry Reach Model)

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16E	54711	SAGE RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
4.000	0.019	23.037	7.198	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
2.412	0.323	7.464	0.062	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
15.18	1.500	15.18	0.884	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
3.215	29.284	Owens	2	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.886	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.089	13.03	14.04	2.00
	0.177	11.19	12.98	2.00
	0.266	9.60	12.00	2.00
	0.354	8.24	11.10	2.00
	0.443	7.07	10.26	2.00
	0.532	6.07	9.49	2.00
	0.620	5.21	8.77	2.00
	0.709	4.47	8.11	2.00
	0.797	3.84	7.50	2.00
	0.886	3.30	6.94	2.00

(input results into Perennial Reach Model)

Horse Creek Manor

**WQM 7.0 Modeling Specifications**

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Simulation	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	2		

Horse Creek Manor

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54711	SAGE RUN	4.000	1390.00	0.19	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Horse Creek	PA0039233	0.0190	0.0000	0.0000	0.000	25.00	7.40

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	0.00	0.00	1.50
Dissolved Oxygen	4.00	2.00	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Horse Creek Manor

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54711	SAGE RUN	3.100	1299.00	1.04	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
perennial	1	0.0190	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	3.30	2.00	0.00	1.50
Dissolved Oxygen	2.00	8.24	0.00	0.00
NH3-N	6.94	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16E		54711				SAGE RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
4.000	0.02	0.00	0.02	NA	0.01915	.323	2.41	7.46	0.06	0.886	23.04	7.20
<b>Q1-10 Flow</b>												
4.000	0.01	0.00	0.00	NA	0.01915	NA	NA	NA	0.00	0.000	0.00	0.00
<b>Q30-10 Flow</b>												
4.000	0.03	0.00	0.00	NA	0.01915	NA	NA	NA	0.00	0.000	0.00	0.00

<b>TRC EVALUATION</b>				
Input appropriate values in A3:A9 and D3:D9				
0.104	= Q stream (cfs)	0.5	= CV Daily	
0.02	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)	0	= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 1.091		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.407		5.1d
				WLA_cfc = 1.056
				LTAMULT_cfc = 0.581
				LTA_cfc = 0.614
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635		
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	$1.5 \cdot ((av\_mon\_limit / AML\_MULT) / LTAMULT\_afc)$			