

Application Type
 Facility Type
 Major / Minor

 Renewal
 Municipal
 Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

 Application No. **PA0039489**
 APS ID **1102479**
 Authorization ID **1464724**
Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|----------------------------|
| Applicant Name | Garrett Borough | Facility Name | Garrett Borough STP |
| Applicant Address | PO Box 218 307 Municipal Road | Facility Address | Berlin Street Sr 2037 |
| Applicant Contact | Garrett, PA 15542-0218 | Facility Contact | Garrett, PA 15542 |
| Applicant Phone | (814) 634-8147 | Facility Phone | 814-634-8147 |
| Client ID | 61972 | Site ID | 245619 |
| Ch 94 Load Status | Existing Hydraulic Overload | Municipality | Garrett Borough |
| Connection Status | Dept. Imposed Connection Prohibitions | County | Somerset |
| Date Application Received | December 11, 2023 | EPA Waived? | Yes |
| Date Application Accepted | | If No, Reason | |
| Purpose of Application | NPDES permit hydraulic capacity rerate and renewal. | | |

Summary of Review

The PA Department of Environmental Protection (PADEP/Department) received an NPDES renewal application from The EADS Group, Inc. (consultant) on behalf of Garrett Borough (permittee) on December 11, 2023 for permittee's Garrett Borough STP (facility). The facility is in Garrett Borough, Somerset County and the treated effluent is discharged into Casselman River in state watershed 19-F. The current permit expired on June 30, 2024. The terms and conditions of the current permit is automatically extended since the renewal application was received at least 180 days prior to the expiration date. Renewal NPDES permit applications under Clean Water program are not covered by PADEP's PDG per 021-2100-001. This fact sheet is developed in accordance with 40 CFR §124.56.

Changes in this renewal: E. Coli monitoring added.

Sludge use and disposal description and location(s): Sludge is hauled off by licensed hauler.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date |
|---------|------|---|-----------------|
| ✓ | | Reza H. Chowdhury, E.I.T. / Project Manager  | January 6, 2025 |
| ✓ | | Mahbuba Iasmin  Mahbuba Iasmin, Ph. D, P.E. / Environmental Engineer Manager | January 7, 2025 |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|--------------------------------|---|----------------------------------|
| Outfall No. | 001 | Design Flow (MGD) | .067 |
| Latitude | 39° 51' 51" | Longitude | -79° 3' 44" |
| Quad Name | Meyersdale | Quad Code | 2013 |
| Wastewater Description: | Sewage Effluent | | |
| Receiving Waters | Casselman River (WWF) | Stream Code | 38579 |
| NHD Com ID | 69920163 | RMI | 29.46 |
| Drainage Area | 254 mi ² | Yield (cfs/mi ²) | 0.044 |
| Q ₇₋₁₀ Flow (cfs) | 11.3 | Q ₇₋₁₀ Basis | StreamStats |
| Elevation (ft) | 1901.20 | Slope (ft/ft) | |
| Watershed No. | 19-F | Chapter 93 Class. | WWF |
| Existing Use | WWF | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | METALS, METALS, METALS, PH, PH | | |
| Source(s) of Impairment | ACID MINE DRAINAGE | | |
| TMDL Status | Final, Final | Name | Casselman River ,Casselman River |
| Background/Ambient Data | | Data Source | |
| pH (SU) | 7.0 | Default | |
| Temperature (°C) | 25 | Default | |
| Hardness (mg/L) | 100 | Default | |
| Other: | | | |
| Nearest Downstream Public Water Supply Intake | | Indian Creek Valley Water Authority on Saltlick | |
| PWS Waters | Youghiogheny River | Flow at Intake (cfs) | |
| PWS RMI | 62.7 | Distance from Outfall (mi) | 40.05 |

Changes Since Last Permit Issuance: The permittee requested for a hydraulic rerate of the treatment plant from existing flow of 0.067 MGD to 0.099 MGD. This request will require a Part II WQM permit amendment application. Once received, the WQM amendment application will be reviewed, and if approved, the hydraulic design capacity will be adjusted in the NPDES permit.

Streamflow:

There's no nearby StreamGage from this discharge point. The USGS's web based watershed delineation tool StreamStats (accessible at <https://streamstats.usgs.gov/ss/>, accessed on December 18, 2024) was utilized to determine the drainage area at discharge point and at confluence with Piney Run (node 2). The drainage area at Outfall 001 was found to be 254 mi² and 257 mi² at node 2. The Q₇₋₁₀ at discharge point was found to be 11.3 cfs. The resulting yield is 11.3 cfs/254 mi² or 0.044 cfs/mi². The default Q₁₋₁₀:Q₇₋₁₀ of 0.64 and default Q₃₀₋₁₀:Q₇₋₁₀ of 1.36 will be used for modeling, as appropriate.

PWS Intake:

The nearest downstream public water supply is Indian Creek Valley Water Authority in Saltlick Township, Fayette County, on Youghiogheny River at RMI 62.7. Its approximately 40.05 miles downstream of Outfall 001. Discharge from this facility is expected not to impact the PWS intake.

Wastewater Characteristics:

Default discharge pH of 7.0 S.U., temperature of 25°C and hardness of 100 mg/l will be used for modeling, as appropriate.

Background data:

There's no nearby WQN station to collect the stream data from. In absence of site specific data, a default pH of 7.0, temperature of 25°C, and hardness of 100 mg/l will be used for modeling, as appropriate.

Casselman River TMDL:

There's a TMDL for metals in the impaired segment of Casselman River. This TMDL, as any AMD TMDL, identified three primary metals associated with the AMD- Iron, Manganese, and Aluminum. Treated sewage discharge from a minor STP, like this facility, is expected to be less than water quality criteria and not contributing to the stream impairment. There's no WLA for this facility, therefore, monitoring for these pollutants wasn't required in previous permits.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The receiving streams are designated as Warm Water Fishes (WWF). No High-Quality stream or Exceptional Value water is impacted by this discharge; therefore, no Antidegradation Analysis is performed for the discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

| Treatment Facility Summary | | | | |
|---|--------------------------------|-----------------------------|----------------------|------------------------|
| Treatment Facility Name: Garrett Borough STP | | | | |
| WQM Permit No. | | Issuance Date | | |
| 466S91 | | 2/17/1967 | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary with NH3-N Reduction | Extended Air | Chlorine | 0.067 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.067 | 115 | Existing Hydraulic Overload | Aerated holding tank | Other WWTP |

Changes Since Last Permit Issuance: None

| Facility Information | | | | |
|---|--|--|--|--|
| Garrett Borough owns and operates a wastewater treatment plant named Garrett Borough STP (facility) located in Garrett Borough, Somerset County. It is a minor sewage treatment facility with a design flow of 0.067 MGD, hydraulic design capacity of 0.067 MGD, and organic design capacity of 115 lbs. BOD5/day. | | | | |

Due to Ch. 94 Hydraulic Overload determination, the facility was under a Corrective Action Plan (CAP), approved on March 10, 2021. The permittee began implementing the CAP. The CAP included system mapping, I&I investigation, defect repair, smoke & dye testing, and STP re-rating. The permittee stated that they investigated and repaired sources of I&I to the maximum extent practicable and requested a hydraulic rerate of the facility from 0.067 MGD to 0.09 MGD. A review of the supplied monthly flow data for the years 2019-2023 indicated that the facility was hydraulically overloaded for the months Jan-May 2019, Dec-May 2020, and Nov-Jan 2021, at current approved flow of 0.069 MGD. To compare with proposed 0.09 MGD flow, the facility would still be overloaded status for the months Nov 2018-Feb 2019 and Dec 2019-Feb 2020. The Consultant later requested to hydraulically rerate the facility to 0.099 MGD. This hydraulic rerate will require a Part II WQM permit amendment. Based on the findings of the WQM amendment application review, if the request is justified, the facility can be rerated to higher flow of 0.099 MGD. The draft NPDES permit will have the existing flow since hydraulic rerate request should be approved via a WQM amendment.

Based on the December 5, 2019 inspection report, the facility consists of two grinder pumps, one EQ tank, one comminutor, one bar screen, two aeration tanks, two foam spray, two sludge holding tanks, two clarifiers, one chlorinator, and three blowers (with one as back-up).

Inspection Reports:

12/09/2024: RTPT conducted. Collected sample showed high TSS. The inspector suspected that the facility has cloudy discharge during every heavy rainfall which is as a result of high TSS. Regular samples might not have been collected during those days.

12/5/2019: CEI conducted. Facility was determined to be hydraulically overloaded per 2018 Ch. 94 report.

| Existing Limits | | | | | | | | |
|--|-------------------------------------|------------------|-----------------------|------------------|---------|------------------|--|----------------------|
| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | 1/week | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/weekday | Grab |
| Dissolved Oxygen | XXX | XXX | 4.0 Inst Min | XXX | XXX | XXX | 1/weekday | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/weekday | Grab |
| CBOD5 | 14.0 | XXX | XXX | 25.0 | XXX | 50.0 | 2/month | Grab |
| BOD5 Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 2/month | Grab |
| TSS | 16.75 | XXX | XXX | 30.0 | XXX | 60.0 | 2/month | Grab |
| TSS Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 2/month | Grab |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 2/month | Grab |
| Ammonia-Nitrogen | XXX | XXX | XXX | Report | XXX | Report | 2/month | Grab |
| Total Phosphorus | XXX | XXX | XXX | Report Daily Max | XXX | XXX | 1/year | Grab |
| Total Nitrogen | XXX | XXX | XXX | Report Daily Max | XXX | XXX | 1/year | Grab |

Compliance History

DMR Data for Outfall 001 (from November 1, 2023 to October 31, 2024)

| Parameter | OCT-24 | SEP-24 | AUG-24 | JUL-24 | JUN-24 | MAY-24 | APR-24 | MAR-24 | FEB-24 | JAN-24 | DEC-23 | NOV-23 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.0301 | 0.0269 | 0.0289 | 0.0246 | 0.0291 | 0.0413 | 0.0821 | 0.0711 | 0.0674 | 0.0921 | 0.0669 | 0.0582 |
| Flow (MGD) Daily Maximum | 0.0812 | 0.0419 | 0.1191 | 0.0307 | 0.0325 | 0.0675 | 0.1774 | 0.1529 | 0.1126 | 0.1715 | 0.1046 | 0.176 |
| pH (S.U.) IMIN | 7.2 | 7.3 | 7.2 | 7.2 | 7.2 | 7.3 | 7.2 | 7.2 | 7.2 | 7.1 | 7.2 | 7.2 |
| pH (S.U.) IMAX | 7.4 | 7.4 | 7.4 | 7.3 | 7.4 | 7.4 | 7.4 | 7.3 | 7.3 | 7.6 | 7.4 | 7.3 |
| DO (mg/L) Instantaneous Minimum | 7.6 | 7.6 | 6.8 | 6.7 | 7.0 | 7.3 | 7.0 | 7.9 | 7.7 | 8.3 | 8.2 | 8.0 |
| TRC (mg/L) Average Monthly | 0.4 | 0.3 | 0.4 | 0.3 | 0.3 | 0.3 | 0.4 | 0.4 | 0.3 | 0.3 | 0.3 | 0.3 |
| TRC (mg/L) IMAX | 0.4 | 0.5 | 0.5 | 0.4 | 0.5 | 0.4 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.4 |
| CBOD5 (lbs/day) Average Monthly | 0.33 | 0.29 | 0.28 | 0.21 | 0.04 | 0.61 | 1.2 | 1.66 | 4.5 | 4.16 | 1.24 | 1.0 |
| CBOD5 (mg/L) Average Monthly | < 2.0 | < 1.5 | < 1.5 | < 1.5 | < 1.6 | < 1.5 | < 2.3 | < 2.3 | 8.5 | 3.8 | 2.0 | 2.3 |
| CBOD5 (mg/L) IMAX | < 2.0 | < 1.5 | < 1.5 | < 1.5 | < 1.7 | < 1.5 | 3.0 | 3.0 | 14.0 | 6.0 | 2.0 | 3.0 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 32.35 | 54.40 | 62.57 | 10.15 | 2.72 | 10.87 | 226.3 | 33.90 | 37.34 | 110.8 | 27.14 | 43.34 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 151 | 94.50 | 169.5 | 65.2 | 115 | 26.0 | 506.5 | 57.25 | 71.0 | 101 | 45.0 | 94.0 |
| TSS (lbs/day) Average Monthly | 0.43 | 0.61 | 0.65 | 1.00 | 0.19 | 2.77 | 4.93 | 5.37 | 10.49 | 4.95 | 31.54 | 2.37 |
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 15.38 | 20.73 | 18.03 | 16.57 | 2.24 | 22.91 | 23.63 | 40.40 | 27.05 | 102.7 | 66.10 | 32.58 |
| TSS (mg/L) Average Monthly | < 0.10 | < 3.0 | < 4.0 | 7.0 | 8.0 | 7.0 | 3.0 | 6.5 | 9.0 | 4.5 | 44.5 | 5.5 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 72.00 | 98.0 | 97.50 | 124.5 | 94 | 58 | 43.50 | 59.0 | 50.5 | 93.5 | 104 | 68.0 |
| TSS (mg/L) IMAX | < 0.10 | 4.0 | 5.0 | 8.0 | 8.0 | 8.0 | 3.5 | 11.0 | 11.0 | 6.56 | 78.0 | 9.0 |
| Fecal Coliform (No./100 ml) Geometric Mean | < 1.0 | < 1.0 | < 1.0 | < 2.5 | 10.6 | < 4.1 | < 1.0 | 5.0 | 3.6 | 5.9 | < 1.0 | < 3.1 |
| Fecal Coliform (No./100 ml) IMAX | < 1.0 | < 1.0 | < 1.0 | 6.3 | 21.8 | 16.7 | < 1.0 | 24.6 | 4.1 | 34.9 | 1.0 | 9.8 |

NPDES Permit Fact Sheet
Garrett Borough STP

NPDES Permit No. PA0039489

| | | | | | | | | | | | |
|---|--------|--------|------|------|--------|------|------|--------|------|--------|------|
| Total Nitrogen (mg/L) Daily Maximum | | | | | | | | | | < 22.5 | |
| Ammonia (lbs/day) Average Monthly | 0.02 | 0.04 | 0.06 | 1.73 | 0.002 | 1.86 | 2.19 | 0.37 | 0.08 | 0.51 | 0.45 |
| Ammonia (mg/L) Average Monthly | < 0.10 | < 0.22 | 0.3 | 9.8 | < 0.10 | 3.96 | 4.93 | < 0.84 | 0.14 | 0.47 | 0.63 |
| Ammonia (mg/L) IMAX | < 0.10 | 0.33 | 0.38 | 19.5 | < 0.10 | 7.82 | 4.03 | 1.58 | 0.16 | 0.60 | 1.15 |
| Total Phosphorus (mg/L) Daily Maximum | | | | | | | | | | | 3.12 |

Compliance History

Effluent Violations for Outfall 001, from: December 1, 2023 To: October 31, 2024

| Parameter | Date | SBC | DMR Value | Units | Limit Value | Units |
|-----------|----------|--------|-----------|---------|-------------|---------|
| TSS | 12/31/23 | Avg Mo | 31.54 | lbs/day | 16.75 | lbs/day |
| TSS | 12/31/23 | Avg Mo | 44.5 | mg/L | 30.0 | mg/L |
| TSS | 12/31/23 | IMAX | 78.0 | mg/L | 60.0 | mg/L |

| Development of Effluent Limitations | | | | |
|-------------------------------------|-----------------|-------------------|----------------|--|
| Outfall No. | 001 | Design Flow (MGD) | .067 | |
| Latitude | 39° 51' 51.00" | Longitude | -79° 3' 44.00" | |
| Wastewater Description: | Sewage Effluent | | | |

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Mass-Based Limits

The federal regulation at 40 CFR 122.45(f) requires that effluent limits be expressed in terms of mass, if possible. The regulation at 40 CFR 122.45(b) requires that effluent limitations for POTWs be calculated based on the design flow of the facility. The mass-based limits are expressed in pounds per day and are calculated as follows:

Mass based limit (lb/day) = concentration limit (mg/L) × design flow (mgd) × 8.34

Model input data

The following data will be used for modeling, as needed:

- Discharge pH 7.0 (Default)
- Discharge Temperature 25°C (Default)
- Discharge Hardness 100 mg/l (Default)
- Stream pH 7.0 (Default)
- Stream Temperature 25.0°C (Default)
- Stream Hardness 100 mg/l (Default)

The following two nodes were used in modeling:

Node 1: At the outfall 001 on Casselman River (38579)
 Elevation: 1901.20 ft (National Map-Advanced Viewer, 12/18/2024)
 Drainage Area: 254 mi² (StreamStat Version 3.0, 12/18/2024)
 River Mile Index: 29.46 (PA DEP eMapPA)
 Low Flow Yield: 0.044 cfs/mi²
 Q₇₋₁₀: 11.3 cfs
 Discharge Flow: 0.067 MGD

Node 2: At confluence with Piney Run (39064)
 Elevation: 1883.99 ft (National Map-Advanced Viewer, 12/18/2024)
 Drainage Area: 257 mi² (StreamStat Version 3.0, 12/18/2024)
 River Mile Index: 28.72 (PA DEP eMapPA)
 Low Flow Yield: 0.044 cfs/mi²

Discharge Flow: 0.0 MGD

WQM 7.0 Model

WQM 7.0 version 1.11 is a water quality model designed to assist DEP to determine appropriate effluent limits for CBOD₅, NH₃-N and DO. The model simulates two basic processes. In the NH₃-N module, the model simulates the mixing and degradation of NH₃-N in the stream and compares calculated instream NH₃-N concentrations to NH₃-N water quality criteria. In the D.O. module, the model simulates the mixing and consumption of D.O. in the stream due to the degradation of CBOD₅ and NH₃N and compares calculated instream D.O. concentrations to D.O. water quality criteria. The model was utilized for this permit renewal by using Q₇₋₁₀ and current background water quality levels of the stream.

NH₃-N

WQM 7.0 suggested NH₃-N limit of 25 mg/l as monthly average and 50 mg/l as IMAX limit during summer to protect water quality standards. The current permit has monitoring requirements which will be carried over, per SOP, when WMS recommends AML of 25 mg/l for a renewal application.

CBOD5

WQM 7.0 suggests CBOD5 limit of 25.0 mg/l as AML during summer season which is the same as existing limit. Existing AML and IMAX will be carried over, along with the AML mass limits.

DO

WQM 7.0 suggests minimum DO of 4.0 mg/l which is the model input and same as existing limit. Existing limit will be carried over.

Toxics Management Spreadsheet (TMS)

Minor facilities with design flow less than 0.1 MGD aren't required to sample for Total Copper, Total Lead, Total Zinc, and any other parameters unless they are accepting flows from industrial or commercial users. No toxics modeling is conducted.

Other Requirements/BPJ based limits

Total Phosphorus:

PADEP's SOP BCW-PMT-033 recommends monitoring for Total Phosphorus for facilities with design flow more than 2000-GPD, which is also supported by Pa Code 25 Ch. 92a.61. Current monitoring requirement will be continued.

Total Nitrogen:

PADEP's SOP BCW-PMT-033 recommends monitoring for Total Nitrogen for facilities with design flow more than 2000-GPD, which is also supported by Pa Code 25 Ch. 92a.61. Current monitoring requirement will be continued.

Fecal Coliform:

The recent coliform guidance in 25 Pa. code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml. These are existing requirements and will be carried over in this renewal.

E. Coli:

Pa Code 25 § 92a. 61 requires monitoring of E. Coli. DEP's SOP titled "Establishing Effluent Limitations for Individual Sewage Permits (BCW-PMT-033, revised March 24, 2021) recommends quarterly E. Coli monitoring for minor sewage dischargers with a design flow between ≥ 0.05 MGD and 1.0 MGD. This requirement will be applied from this permit term.

pH:

The TBEL for pH is above 6.0 and below 9.0 S.U. (40 CFR §133.102(c) and Pa Code 25 §§ 95.2(1), 92a.47) which are existing limits and will be carried over.

Total Suspended Solids (TSS):

There is no water quality criterion for TSS. The existing limits of 30 mg/L average monthly and 60 mg/L instantaneous maximum will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment, 25

Pa. Code § 92a.47 and 40CFR 133.102(b). The mass based average monthly limit is calculated to be 16.75 lbs./day which is the same as were in existing permit and will be carried over.

Total Residual Chlorine (TRC):

The attached computer printout utilizes the equation and calculations as presented in the Department's 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID#391-2000-015) for developing chlorine limitations. The attached printout indicates that the existing limits are still protective and will be carried over.

Monitoring Frequency and Sample Types:

Otherwise specified above, the monitoring frequency and sample type of compliance monitoring for existing parameters are recommended by DEP's SOP and Permit Writers Manual and/or on a case-by-case basis using best professional judgment (BPJ).

Flow and Influent BOD₅ and TSS Monitoring Requirement:

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii). Influent BOD₅ and TSS monitoring requirements are established in the permit per the requirements set in Pa Code 25 Chapter 94.

Anti-Backsliding

Anti-backsliding prohibition is justified in sections where an exception is justified for the affected pollutant(s). For remaining pollutants, this prohibition isn't applicable since the proposed limits are at least as stringent as were in current permit.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------|-----------------------|------------------|---------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | 1/week | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/weekday | Grab |
| DO | XXX | XXX | 4.0 Inst Min | XXX | XXX | XXX | 1/weekday | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/weekday | Grab |
| CBOD5 | 14.0 | XXX | XXX | 25.0 | XXX | 50.0 | 2/month | Grab |
| BOD5 | | | | | | | | |
| Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 2/month | Grab |
| TSS | 16.75 | XXX | XXX | 30.0 | XXX | 60.0 | 2/month | Grab |
| TSS | | | | | | | | |
| Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 2/month | Grab |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX Geo Mean | 2000 Geo Mean | XXX | 10000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 2/month | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/quarter | Grab |
| Total Nitrogen | XXX | XXX | XXX | Report Daily Max | XXX | XXX | 1/year | Grab |
| Ammonia-Nitrogen | Report | XXX | XXX | Report | XXX | Report | 2/month | Grab |
| Total Phosphorus | XXX | XXX | XXX | Report Daily Max | XXX | XXX | 1/year | Grab |


Compliance Sampling Location: At Outfall 001

| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [REDACTED]) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 386-2000-002, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 386-2000-007, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 386-2000-003, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input checked="" type="checkbox"/> | SOP: BCW-PMT-033 |
| <input type="checkbox"/> | Other: [REDACTED] |

StreamStats at Outfall 001

PA0039489 at Outfall 001

Region ID: PA
Workspace ID: PA20241219015750593000
Clicked Point (Latitude, Longitude): 39.86352, -79.06448
Time: 2024-12-18 20:58:11 -0500



[Collapse All](#)

► Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|---|-------|--------------|
| DRNAREA | Area that drains to a point on a stream | 254 | square miles |
| ELEV | Mean Basin Elevation | 2447 | feet |

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|----------------------|-------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 254 | square miles | 2.26 | 1400 |
| ELEV | Mean Basin Elevation | 2447 | feet | 1050 | 2580 |


Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

| Statistic | Value | Unit | SE | ASEp |
|-------------------------|-------|--------------------|----|------|
| 7 Day 2 Year Low Flow | 27.9 | ft ³ /s | 43 | 43 |
| 30 Day 2 Year Low Flow | 43.4 | ft ³ /s | 38 | 38 |
| 7 Day 10 Year Low Flow | 11.3 | ft ³ /s | 66 | 66 |
| 30 Day 10 Year Low Flow | 17.1 | ft ³ /s | 54 | 54 |
| 90 Day 10 Year Low Flow | 31.4 | ft ³ /s | 41 | 41 |

PA0039489 at node 2

Region ID: PA
Workspace ID: PA20241219021046905000
Clicked Point (Latitude, Longitude): 39.87001, -79.07077
Time: 2024-12-18 21:11:07 -0500



[Collapse All](#)

► Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|---|-------|--------------|
| DRNAREA | Area that drains to a point on a stream | 257 | square miles |
| ELEV | Mean Basin Elevation | 2446 | feet |

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|----------------------|-------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 257 | square miles | 2.26 | 1400 |
| ELEV | Mean Basin Elevation | 2446 | feet | 1050 | 2580 |

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

| Statistic | Value | Unit | SE | ASEp |
|-------------------------|-------|--------------------|----|------|
| 7 Day 2 Year Low Flow | 28.3 | ft ³ /s | 43 | 43 |
| 30 Day 2 Year Low Flow | 44 | ft ³ /s | 38 | 38 |
| 7 Day 10 Year Low Flow | 11.5 | ft ³ /s | 66 | 66 |
| 30 Day 10 Year Low Flow | 17.3 | ft ³ /s | 54 | 54 |
| 90 Day 10 Year Low Flow | 31.8 | ft ³ /s | 41 | 41 |

WQM 7.0

Input Data WQM 7.0

| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Stream Data | | PWS Withdrawal (mgd) | Apply FC | | | | | | | |
|-----------------------|---------------|--------------------|----------------------|-------------------------|-----------------------|------------------|-------------------|--------------------------|-------------|---------------------------|--------------------------|------------------------|--------------|-------------------------------------|--------------|----------------|--|---------|--|
| | | | | | | | | | RMI (ft) | Elevation (sq mi) | Drainage Area (sq mi) | Slope (ft/ft) | Tributary pH | Stream Temp (°C) | Temp (°C) | pH | | | |
| Q7-10 | 0.044 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 29.460 | 1901.20 | 254.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> | | | | | |
| Q1-10 | | | | | | | | | | | | | | | | | | | |
| Q30-10 | | | | | | | | | | | | | | | | | | | |
| Discharge Data | | | | | | | | | | | | | | | | | | | |
| | | | | Name | | Permit Number | | Existing Disc Flow (mgd) | | Permitted Disc Flow (mgd) | | Design Disc Flow (mgd) | | Reserve Factor | | Disc Temp (°C) | | Disc pH | |
| | | | | Garrett Boro | | PA0039489 | | 0.0670 | | 0.0670 | | 0.0670 | | 0.000 | | 25.00 | | 7.00 | |
| Parameter Data | | | | | | | | | | | | | | | | | | | |
| | | | | Parameter Name | | Disc Conc (mg/L) | | Trib Conc (mg/L) | | Stream Conc (mg/L) | | Fate Coef (1/days) | | | | | | | |
| | | | | CBOD5 | | 25.00 | | 2.00 | | 0.00 | | 1.50 | | | | | | | |
| | | | | Dissolved Oxygen | | 4.00 | | 8.24 | | 0.00 | | 0.00 | | | | | | | |
| | | | | NH3-N | | 25.00 | | 0.00 | | 0.00 | | 0.70 | | | | | | | |

Input Data WQM 7.0

| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Stream Data | | PWS Withdrawal (mgd) | Apply FC | | | | | | | |
|-----------------------|---------------|--------------------|----------------------|-------------------------|-----------------------|------------------|-------------------|--------------------------|-------------|---------------------------|--------------------------|------------------------|--------------|-------------------------------------|--------------|----------------|--|---------|--|
| | | | | | | | | | RMI (ft) | Elevation (sq mi) | Drainage Area (sq mi) | Slope (ft/ft) | Tributary pH | Stream Temp (°C) | Temp (°C) | pH | | | |
| Q7-10 | 0.044 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 28.720 | 1883.99 | 257.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> | | | | | |
| Discharge Data | | | | | | | | | | | | | | | | | | | |
| | | | | Name | | Permit Number | | Existing Disc Flow (mgd) | | Permitted Disc Flow (mgd) | | Design Disc Flow (mgd) | | Reserve Factor | | Disc Temp (°C) | | Disc pH | |
| | | | | Garrett Boro | | PA0039489 | | 0.0000 | | 0.0000 | | 0.0000 | | 0.000 | | 25.00 | | 7.00 | |
| Parameter Data | | | | | | | | | | | | | | | | | | | |
| | | | | Parameter Name | | Disc Conc (mg/L) | | Trib Conc (mg/L) | | Stream Conc (mg/L) | | Fate Coef (1/days) | | | | | | | |
| | | | | CBOD5 | | 25.00 | | 2.00 | | 0.00 | | 1.50 | | | | | | | |
| | | | | Dissolved Oxygen | | 3.00 | | 8.24 | | 0.00 | | 0.00 | | | | | | | |
| | | | | NH3-N | | 25.00 | | 0.00 | | 0.00 | | 0.70 | | | | | | | |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | | | | | | |
|--------------------|-------------|--------------------|-----------------|--------------------|-------------|-------|-------|-----------|----------|-----------------|---------------|-------------|
| 19F | | 38579 | | CASSELMAN RIVER | | | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
| | (cfs) | | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | |
| Q7-10 Flow | | | | | | | | | | | | |
| 29.460 | 11.18 | 0.00 | 11.18 | .1036 | 0.00440 | .832 | 56.78 | 68.27 | 0.24 | 0.189 | 25.00 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 29.460 | 7.15 | 0.00 | 7.15 | .1036 | 0.00440 | NA | NA | NA | 0.19 | 0.242 | 25.00 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 29.460 | 15.20 | 0.00 | 15.20 | .1036 | 0.00440 | NA | NA | NA | 0.28 | 0.160 | 25.00 | 7.00 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 4 | | |

WQM 7.0 Wasteload Allocations

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | | | | |
|------------------|--|--------------------|--|--------------------|--|--|--|--|--|--|
| 19F | | 38579 | | CASSELMAN RIVER | | | | | | |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 29.460 | Garrett Boro | 11.07 | 50 | 11.07 | 50 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 29.460 | Garrett Boro | 1.37 | 25 | 1.37 | 25 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | CBOD5 | | NH3-N | | Dissolved Oxygen | | Critical Reach | Percent Reduction |
|-------|----------------|-----------------|-----------------|-----------------|-----------------|------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 29.46 | Garrett Boro | 25 | 25 | 25 | 25 | 4 | 4 | 0 | 0 |

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|--------------------|-----------------------------------|----------------------------------|-----------------------------|
| 19F | 38579 | CASSELMAN RIVER | | |
| <u>RMI</u> | | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> |
| 29.460 | | 0.067 | 25.000 | 7.000 |
| <u>Reach Width (ft)</u> | | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> |
| 56.784 | | 0.832 | 68.268 | 0.239 |
| <u>Reach CBOD5 (mg/L)</u> | | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> |
| 2.21 | | 0.133 | 0.23 | 1.029 |
| <u>Reach DO (mg/L)</u> | | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> |
| 8.204 | | 8.082 | Tsivoglou | 4 |
| <u>Reach Travel Time (days)</u> | | <u>Subreach Results</u> | | |
| 0.189 | | TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) |
| | | | 0.019 | 2.20 |
| | | | 0.038 | 2.20 |
| | | | 0.057 | 2.19 |
| | | | 0.076 | 2.18 |
| | | | 0.095 | 2.18 |
| | | | 0.114 | 2.17 |
| | | | 0.133 | 2.16 |
| | | | 0.151 | 2.16 |
| | | | 0.170 | 2.15 |
| | | | 0.189 | 2.14 |
| | | | | 0.19 |
| | | | | 7.54 |

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | |
|------------------|--------------------|--------------------|-----------------|------------------|-------------------------------|
| 19F | 38579 | CASSELMAN RIVER | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Eff. Limit 30-day Ave. (mg/L) |
| 29.460 | Garrett Boro | PA0039489 | 0.067 | CBOD5 | 25 |
| | | | | NH3-N | 25 |
| | | | | Dissolved Oxygen | 50 |
| | | | | | 4 |

TRC

TRC_CALC

| TRC EVALUATION | | | | | | | |
|---|--------------------------------|---|-----|--------------------------------------|---------------------|--|--|
| Input appropriate values in A3:A9 and D3:D9 | | | | | | | |
| 11.3 | = Q stream (cfs) | | 0.5 | = CV Daily | | | |
| 0.067 | = Q discharge (MGD) | | 0.5 | = CV Hourly | | | |
| 30 | = no. samples | | 1 | = AFC_Partial Mix Factor | | | |
| 0.3 | = Chlorine Demand of Stream | | 1 | = CFC_Partial Mix Factor | | | |
| 0 | = Chlorine Demand of Discharge | | 15 | = AFC_Criteria Compliance Time (min) | | | |
| 0.5 | = BAT/BPJ Value | | 720 | = CFC_Criteria Compliance Time (min) | | | |
| 0 | = % Factor of Safety (FOS) | | | =Decay Coefficient (K) | | | |
| Source | Reference | AFC Calculations | | Reference | CFC Calculations | | |
| TRC | 1.3.2.iii | WLA_afc = 34.797 | | 1.3.2.iii | WLA_cfc = 33.917 | | |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | | 5.1c | LTAMULT_cfc = 0.581 | | |
| PENTOXSD TRG | 5.1b | LTA_afc= 12.966 | | 5.1d | LTA_cfc = 19.718 | | |
| Effluent Limit Calculations | | | | | | | |
| PENTOXSD TRG | 5.1f | AML MULT = 1.231 | | | | | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | | | BAT/BPJ | | |
| | | INST MAX LIMIT (mg/l) = 1.635 | | | | | |
| WLA_afc | | $(.019/e(-k* AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k* AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)]^*(1-FOS/100)$ | | | | | |
| LTAMULT_afc | | $EXP((0.5^*LN(cvh^2+1))-2.326^*LN(cvh^2+1)^0.5)$ | | | | | |
| LTA_afc | | $wla_afc^*LTAMULT_afc$ | | | | | |
| WLA_cfc | | $(.011/e(-k* CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k* CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)]^*(1-FOS/100)$ | | | | | |
| LTAMULT_cfc | | $EXP((0.5^*LN(cvd^2/no_samples+1))-2.326^*LN(cvd^2/no_samples+1)^0.5)$ | | | | | |
| LTA_cfc | | $wla_cfc^*LTAMULT_cfc$ | | | | | |
| AML MULT | | $EXP(2.326^*LN((cvd^2/no_samples+1)^0.5)-0.5^*LN(cvd^2/no_samples+1))$ | | | | | |
| AVG MON LIMIT | | $MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)^*AML_MULT)$ | | | | | |
| INST MAX LIMIT | | $1.5^*((av_mon_limit/AML_MULT)/LTAMULT_afc)$ | | | | | |