



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0039730

APS ID

810232

Authorization ID

1515091

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

| | | | |
|---------------------------|--------------------------|------------------|-----------------------------|
| Applicant Name | Pure Events LP | Facility Name | Lake Raystown Resort |
| Applicant Address | 3101 Chipmunk Crossing | Facility Address | 3101 Chipmunk Crossing |
| | Entriiken, PA 16638-8623 | | Entriiken, PA 16638-8623 |
| Applicant Contact | Joshua Patt | Facility Contact | Joshua Patt |
| Applicant Phone | (814) 658-3500 | Facility Phone | (814) 658-3500 |
| Client ID | 303993 | Site ID | 453148 |
| Ch 94 Load Status | Not Overloaded | Municipality | Lincoln Township |
| Connection Status | No Limitations | County | Huntingdon |
| Date Application Received | February 4, 2025 | EPA Waived? | Yes |
| Date Application Accepted | February 7, 2025 | If No, Reason | |
| Purpose of Application | NPDES permit renewal | | |

Summary of Review

Keller Engineers Inc. on behalf of the Pure Events, LP applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on August 17, 2020, and became effective on September 1, 2020. The permit expires on August 31, 2025.

Pure Events, LP owns, operates, and maintains the Lake Raystown Resort wastewater treatment plant located in Lincoln Township, Huntingdon County. The treatment plant discharges treated municipal wastewater to Tatman Run to Lake Raystown, which is classified for High Quality-Cold Water Fishes (HQ-CWF). The facility has a design average annual flow of 0.1 MGD.

The WQM No. 3185402 was issued on 7/22/1995. The 3185402 T-3 were issued on 9/22/2014.

Sludge use and disposal description and location(s): N/A because sludge is hauled by the facility's contractor.

Changes from the previous permit: The E. Coli. monitoring and report requirements will be added to the permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

| Approve | Deny | Signatures | Date |
|---------|------|---|--------------------|
| X | | Hilaryle Hilary H Le / Environmental Engineering Specialist | August 1, 2025 |
| x | | Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager | September 17, 2025 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|---|---|------------------------------|-----------------------|
| Outfall No. | 001 | Design Flow (MGD) | 0.1 |
| Latitude | 40° 18' 26.97" | Longitude | -78° 10' 30.10" |
| Quad Name | Entriiken | Quad Code | |
| Wastewater Description: | Sewage Effluent | | |
| Receiving Waters | Tatman Run to Raystown Branch Juniata River (HQ-CWF, MF) | Stream Code | 13653 |
| NHD Com ID | 65841033 | RMI | 0.4 |
| Drainage Area | 7.81 mi. ² | Yield (cfs/mi ²) | See comments below |
| Q ₇₋₁₀ Flow (cfs) | See comments below | Q ₇₋₁₀ Basis | USGS StreamStats |
| Elevation (ft) | 786.5 | Slope (ft/ft) | |
| Watershed No. | 11-D | Chapter 93 Class. | HQ-CWF, MF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Attaining Use(s) | | |
| Cause(s) of Impairment | | | |
| Source(s) of Impairment | | | |
| TMDL Status | Name | | |
| Nearest Downstream Public Water Supply Intake | Newport Borough Water Authority | | |
| PWS Waters | Juniata River | Flow at Intake (cfs) | |
| PWS RMI | | Distance from Outfall (mi) | Approximate 112 miles |

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Tatman Run at RMI 0.4 mile. A drainage area upstream of the discharge is estimated to be 7.81 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Slow Flow

According to StreamStats, the gage station No. 1562000 on Raystown Branch Juniata River at Saxton, PA has a Q₇₋₁₀ of 44.8 cfs and a drainage area of 754 mi.², which is near Manchester, PA. The Q₇₋₁₀ of discharge was calculated as follows:

$$\begin{aligned}
 \text{Low Flow Yield} &= Q_{7-10\text{gage}} / \text{Drainage Area}_{\text{gage}} = 44.8 \text{ cfs} / 754 \text{ mi.}^2 = 0.06 \text{ cfs/mi.}^2 \\
 Q_{7-10\text{discharge}} &= 0.14 \text{ cfs/mi.}^2 * \text{Drainage Area}_{\text{discharge}} = 0.06 \text{ cfs/mi.}^2 * 7.81 \text{ mi.}^2 = 0.5 \text{ cfs} \\
 Q_{30-10} &= 1.36 * Q_{7-10\text{discharge}} = 1.36 * 0.5 \text{ cfs} = 0.68 \text{ cfs} \\
 Q_{1-10} &= 0.64 * Q_{7-10\text{discharge}} = 0.64 * 0.5 \text{ cfs} = 0.35 \text{ cfs}
 \end{aligned}$$

Tatman Run


25 Pa Code § 93.9n classifies Tatman Run as High-Quality Cold-Water Fishes (HQ-CWF) and Migratory Fishes (MF) surface water. Based on the 2024 Integrated Report, Tatman Run, assessment unit ID 6983, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Public Water Supply

The nearest downstream public water supply intake is the Newport Borough Water Authority on the Juniata River, approximately 112 miles downstream of this discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

| Treatment Facility Summary | | | | |
|--|----------------------------|----------------------|---------------------|------------------------|
| Treatment Facility Name: Lake Raystown Resort | | | | |
| WQM Permit No. | | Issuance Date | | |
| 3185402 | | 11/4/1995 | | |
| 3185402 T-3 | | 9/22/2014 | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Extended Aeration | Hypochlorite | 0.1 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.1 | | Not Overloaded | Aerobic Digestion | Combination of methods |

Changes Since Last Permit Issuance: none



Other Comments:

The WWTP train is as follows:

Comminutor (1) \Rightarrow Extended Aeration (2) \Rightarrow Clarification (2) \Rightarrow Tertiary Filter (1) \Rightarrow Chlorine Contact Tank (1) \Rightarrow Discharge (outfall)

The system incorporates chemical addition in the form of chlorine for disinfection, lime for pH adjustment, and Alum for coagulation.

Industrial/Commercial Users:

The permit application indicated there is no industrial/commercial contributor to the treatment plant

| Compliance History | |
|--------------------------------|---|
| Summary of DMRs: | DMRs reported last 12 months are summarized in the next page. |
| Summary of Inspections: | 8/15/2024: Mr. Clark, DEP WQS, conducted a compliance evaluation inspection. The discharge was clear. The field test results indicated in permit limits. There were no violations indicate during inspection. |
| Other Comments: | There are currently no open violations associated with the permittee or the facility. |

Compliance History

DMR Data for Outfall 001 (from June 1, 2024 to May 31, 2025)

| Parameter | MAY-25 | APR-25 | MAR-25 | FEB-25 | JAN-25 | DEC-24 | NOV-24 | OCT-24 | SEP-24 | AUG-24 | JUL-24 | JUN-24 |
|--|--------|--------|--------|--------|--------|---------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.057 | 0.049 | 0.020 | 0.022 | 0.014 | 0.014 | 0.013 | 0.026 | 0.028 | 0.046 | 0.043 | 0.039 |
| Flow (MGD) Daily Maximum | 0.099 | 0.086 | 0.043 | 0.051 | 0.037 | 0.032 | 0.024 | 0.054 | 0.057 | 0.078 | 0.064 | 0.07 |
| pH (S.U.) Instantaneous Minimum | 7.64 | 7.85 | 8.1 | 8.09 | 8.13 | 7.67 | 7.11 | 6.96 | 7.44 | 7.48 | 7.45 | 7.47 |
| pH (S.U.) Instantaneous Maximum | 8.11 | 8.4 | 8.42 | 8.32 | 8.53 | 8.44 | 8.04 | 7.72 | 7.93 | 7.84 | 7.8 | 7.98 |
| DO (mg/L) Instantaneous Minimum | 8.16 | 8.58 | 10.27 | 11.97 | 11.91 | 10.82 | 8.48 | 8.27 | 7.5 | 6.31 | 6.49 | 6.93 |
| TRC (mg/L) Average Monthly | 0.24 | 0.25 | 0.26 | 0.25 | 0.35 | 0.29 | 0.38 | 0.28 | 0.32 | 0.27 | 0.33 | 0.29 |
| TRC (mg/L) IMAX | 0.43 | 0.54 | 0.73 | 0.45 | 0.88 | 0.47 | 0.63 | 0.42 | 0.7 | 0.67 | 0.61 | 0.72 |
| CBOD5 (mg/L) Average Monthly | < 3 | 22.5 | < 3 | < 3.01 | < 3.9 | < 3 | < 3 | < 3.0 | < 3 | < 3 | < 3 | < 3 |
| TSS (mg/L) Average Monthly | 2.4 | 8.8 | < 3.6 | < 2.4 | < 5.2 | 3.6 | < 2.8 | < 2 | < 2.4 | 2.8 | < 1.6 | < 1.6 |
| Fecal Coliform (No./100 ml) Geometric Mean | 4 | 2 | < 1 | 3 | 26 | 2 | 5 | 2 | 15 | 7 | < 2 | < 11 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 4.1 | 3.1 | 2 | 7.5 | 93.3 | 3.1 | 6.2 | 5.2 | 25.9 | 13.1 | 4.1 | 131 |
| Nitrate-Nitrite (mg/L) Annual Average | | | | | | < 1.257 | | | | | | |
| Total Nitrogen (mg/L) Annual Average | | | | | | < 1.757 | | | | | | |
| Ammonia (mg/L) Annual Average | | | | | | < 0.1 | | | | | | |
| TKN (mg/L) Annual Average | | | | | | < 0.5 | | | | | | |
| Total Phosphorus (mg/L) Average Monthly | 0.085 | 0.194 | 0.209 | 0.191 | 0.526 | 0.375 | 0.97 | 1.046 | 0.57 | 0.444 | 0.125 | 0.208 |

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|---------------|-----------------------|--------------------|---------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| D.O. | XXX | XXX | 5.0 | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD ₅ | XXX | XXX | XXX | 25.0 | XXX | 50.0 | 2/month | 8-Hr Composite |
| TSS | XXX | XXX | XXX | 30.0 | XXX | 60.0 | 2/month | 8-Hr Composite |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 2/month | Grab |
| Total Phosphorus | XXX | XXX | XXX | 2.0 | XXX | 4.0 | 2/month | 8-Hr Composite |
| Ammonia-Nitrogen | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | 8-Hr Composite |
| Total Kjeldahl Nitrogen | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | 8-Hr Composite |
| Nitrate-Nitrite as N | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | 8-Hr Composite |
| Total Nitrogen | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Calculation |

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 18' 26.97"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.1
Longitude -78° 10' 31.10"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Comments:

Water Quality-Based Limitations

Ammonia (NH₃-N):

Since the facility discharges to Lake Raystown embayment where there is sufficient dilution, the WQM 7.0 was not conducted for this facility.

And the Lake Raystown is so large to compare the discharge from the facility, therefore, no Ammonia-Nitrogen limitations are needed to protect the aquatic life from toxicity effects. Secondary treatment is adequate treatment to protect the receiving stream. Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1/year.

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

Since the facility discharges into Lake Raystown where there is sufficient dilution, the facility will be subject to TBEL Limits. No water quality-based modeling was implemented.

The existing limit of 25.0 mg/L AML & 50.0 mg/L IMAX will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has been consistently achieving concentrations well below this existing limit.

Dissolved Oxygen (D.O.):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/quarter will be included in the permit to be consistent with the recommendation from this SOP.

Lake Raystown Resort

Total Suspended Solids (TSS):

The existing limits of 30.0 mg/L average monthly and 60.0 mg/L instantaneous maximum will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving concentrations well below these limits.

Phosphorus:

Technology-based phosphorus limits of 2.0 mg/L average monthly and 4.0 mg/L instantaneous maximum were applied by the original 1998 protection report. The limits will remain in the proposed permit. Recent DMR data and inspection reports indicate consistent achievement.

Toxics:

Review of the permit application revealed no toxic parameters of concern. The application states that there are no industrial wastewater contributions.

Total Residual Chlorine (TRC):

Based on the attached TRC Excel Spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), the facility's discharge must meet a monthly average limit of 0.48 (0.5) mg/L and an instantaneous maximum limit of 1.575 (1.6) mg/L. The existing limits of 0.5 mg/L monthly average and 1.6 mg/L instantaneous maximum will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

| TRC EVALUATION | | | | | | | |
|---|--------------------------------|--|--------------------------------------|--|-----------|------------------|-------|
| Input appropriate values in A3:A9 and D3:D9 | | | | | | | |
| 0.5 | = Q stream (cfs) | 0.5 | = CV Daily | | | | |
| 0.1 | = Q discharge (MGD) | 0.5 | = CV Hourly | | | | |
| 30 | = no. samples | 1 | = AFC_Partial Mix Factor | | | | |
| 0.3 | = Chlorine Demand of Stream | 1 | = CFC_Partial Mix Factor | | | | |
| 0 | = Chlorine Demand of Discharge | 15 | = AFC_Criteria Compliance Time (min) | | | | |
| 0.5 | = BAT/BPJ Value | 720 | = CFC_Criteria Compliance Time (min) | | | | |
| 0 | = % Factor of Safety (FOS) | | = Decay Coefficient (K) | | | | |
| Source | | AFC Calculations | | | Reference | CFC Calculations | |
| TRC | 1.3.2.iii | WLA_afc = | 1.050 | | 1.3.2.iii | WLA_cfc = | 1.016 |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = | 0.373 | | 5.1c | LTAMULT_cfc = | 0.581 |
| PENTOXSD TRG | 5.1b | LTA_afc = | 0.391 | | 5.1d | LTA_cfc = | 0.591 |
| Effluent Limit Calculations | | | | | | | |
| PENTOXSD TRG | 5.1f | AML MULT = | 1.231 | | | | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = | 0.482 | | AFC | | |
| | | INST MAX LIMIT (mg/l) = | 1.575 | | | | |
| WLA_afc | | $(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$ | | | | | |
| LTAMULT_afc | | $\exp((0.5*\ln(cvh^2+1))-2.326*\ln(cvh^2+1)^0.5)$ | | | | | |
| LTA_afc | | wla_afc*LTAMULT_afc | | | | | |
| WLA_cfc | | $(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$ | | | | | |
| LTAMULT_cfc | | $\exp((0.5*\ln(cvd^2/no_samples+1))-2.326*\ln(cvd^2/no_samples+1)^0.5)$ | | | | | |
| LTA_cfc | | wla_cfc*LTAMULT_cfc | | | | | |
| AML MULT | | $\exp(2.326*\ln((cvd^2/no_samples+1)^0.5)-0.5*\ln(cvd^2/no_samples+1))$ | | | | | |
| AVG MON LIMIT | | $\min(BAT_BPJ, \min(LTA_afc, LTA_cfc)*AML_MULT)$ | | | | | |
| INST MAX LIMIT | | $1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$ | | | | | |

Chesapeake Bay Strategy:

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases I, II, and III) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase IV (0.2 - 0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly and Phase V (below 0.2 MGD) will monitor during current permit renewal once a year. However, any facility in Phases IV and V that undergoes expansion is subjected to cap load right away. This plant is classified as phase V, it will be required to monitor and report Ammonia-Nitrogen, Total Kjeldahl Nitrogen, Nitrate-Nitrite as N, and TN 1/year. These "Monitor & Report" requirements will remain in the proposed permit.

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the proposed permit per 40 CFR § 122.44(i)(1)(ii).

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge

Anti-Degradation Requirements

The subject facility's discharge will be to a special protection water.

The STP discharges to Tatnum Run embayment of the lake. Tatnum Run itself has been reclassified as a HQ-CWF, MF stream because of spawning smelt runs in the spring. The embayment is still protected as a WWF stream (Fact Sheet from December 2007).

The permit conditions are imposed to protect existing instream water quality and uses.



Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------|-----------------------|--------------------|---------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| D.O. | XXX | XXX | 5.0 | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD ₅ | XXX | XXX | XXX | 25.0 | XXX | 50.0 | 2/month | 8-Hr Composite |
| TSS | XXX | XXX | XXX | 30.0 | XXX | 60.0 | 2/month | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 2/month | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/quarter | Grab |
| Nitrate-Nitrite | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | 8-Hr Composite |
| Total Nitrogen | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Calculation |
| Ammonia | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | 8-Hr Composite |
| TKN | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | 8-Hr Composite |
| Total Phosphorus | XXX | XXX | XXX | 2.0 | XXX | 4.0 | 2/month | 8-Hr Composite |

Compliance Sampling Location:



Copyright © 2013 National Geographic Society, i-cubed

NPDES Permit Fact Sheet

Lake Raystown Resort

NPDES Permit No. PA0039730

USGS StreamStats

SELECT A STATE / REGION: Pennsylvania

IDENTIFY A STUDY AREA: Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computer basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button.

Show Basin Characteristics

Select available reports to display:

- ✓ Basin Characteristics Report
- ✓ Scenario Flow Reports
- Hydrologic Features Report

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Zoom Level: Map Scale: 1 Lat: 40.2671 1 km 3000 ft



Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|-------|-----------------------|
| CARBON | Percentage of area of carbonate rock | 0 | percent |
| DRNAREA | Area that drains to a point on a stream | 7.81 | square miles |
| PRECIP | Mean Annual Precipitation | 38 | inches |
| ROCKDEP | Depth to rock | 4.2 | feet |
| STRDEN | Stream Density -- total length of streams divided by drainage area | 2.11 | miles per square mile |

Low-Flow Statistics


Low-Flow Statistics Parameters [Low Flow Region 2]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| CARBON | Percent Carbonate | 0 | percent | 0 | 99 |
| DRNAREA | Drainage Area | 7.81 | square miles | 4.93 | 1280 |
| PRECIP | Mean Annual Precipitation | 38 | inches | 35 | 50.4 |
| ROCKDEP | Depth to Rock | 4.2 | feet | 3.32 | 5.65 |
| STRDEN | Stream Density | 2.11 | miles per square mile | 0.51 | 3.1 |

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

| Statistic | Value | Unit | SE | ASEp |
|-------------------------|-------|--------------------|----|------|
| 7 Day 2 Year Low Flow | 0.439 | ft ³ /s | 38 | 38 |
| 30 Day 2 Year Low Flow | 0.636 | ft ³ /s | 33 | 33 |
| 7 Day 10 Year Low Flow | 0.176 | ft ³ /s | 51 | 51 |
| 30 Day 10 Year Low Flow | 0.258 | ft ³ /s | 46 | 46 |
| 90 Day 10 Year Low Flow | 0.456 | ft ³ /s | 36 | 36 |



USGS StreamStats

Hide Basin Characteristics

Basin Characteristics can be edited here

| | |
|-----------|-------|
| Parameter | Value |
| DRNAREA | 754 |
| PRECIP | 38 |
| STRDEN | 2.34 |
| ROCKDEP | 4.3 |
| CARBON | 15.92 |

Select available reports to display:


- ✓ Basin Characteristics Report
- ✓ Scenario Flow Reports
- Hydrologic Features Report

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Zoom Level: Map Scale: 1 Lat: 40.2671 10 km 5 mi



| Tools and References Used to Develop Permit | |
|---|--|
| <input type="checkbox"/> | WQM for Windows Model (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [REDACTED]) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 386-2000-002, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 386-2000-007, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008. |
| <input checked="" type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09. |
| <input checked="" type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 386-2000-003, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97. |
| <input checked="" type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input checked="" type="checkbox"/> | SOP: BCW-PMT-033 |
| <input type="checkbox"/> | Other: [REDACTED] |