

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

**PA0040878**

APS ID

**1109875**

Authorization ID

**1477577**

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<u>Gentile Enterprises, LLC</u>	Facility Name	<u>Keystone Adolescent Center</u>
Applicant Address	<u>95 South Race Street</u> <u>Greenville, PA 16125</u>	Facility Address	<u>270 Sharon Road</u> <u>Greenville, PA 16125-8109</u>
Applicant Contact	<u>Robert Gentile, President</u>	Facility Contact	<u>Rod Donghia, Operator</u> <u>(rdonghia@gmail.com)</u>
Applicant Phone	<u>(724) 589-5546</u>	Facility Phone	<u>(724) 813-8838</u>
Client ID	<u>111062</u>	Site ID	<u>481697</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>West Salem Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Mercer</u>
Date Application Received	<u>February 16, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 20, 2024</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of NPDES Permit for an existing discharge of treated sanitary wastewater.</u>		

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

**I. OTHER REQUIREMENTS:**

- A. Stormwater into sewers
- B. Right of way
- C. Solids handling
- D. Public Sewerage Availability
- E. Effluent Chlorine Optimization and Minimization
- F. Little or No Assimilative Capacity

**SPECIAL CONDITIONS:**

- II. Solids Management

There are no open violations in efacts associated with the subject Client ID (111062) as of 1/30/2025.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Project Manager	1/30/2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	2/7/2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.0043
Latitude	41° 22' 5.10"	Longitude	80° 24' 10.60"
Quad Name	-	Quad Code	-
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to the Big Run (WWF)	Stream Code	N/A
NHD Com ID	130034271	RMI	0.59
Drainage Area	26.5	Yield (cfs/mi <sup>2</sup> )	0.1 (default)
Q <sub>7-10</sub> Flow (cfs)	2.65	Q <sub>7-10</sub> Basis	calculated
Elevation (ft)	1010	Slope (ft/ft)	0.005769
Watershed No.	20-A	Chapter 93 Class.	WWF
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	-		
Source(s) of Impairment	-		
TMDL Status	- Name -		
Background/Ambient Data	Data Source		
pH (SU)	-	-	
Temperature (°F)	-	-	
Hardness (mg/L)	-	-	
Other:	-	-	
Nearest Downstream Public Water Supply Intake	Sharpsville Municipal Water Authority		
PWS Waters	Shenango River	Flow at Intake (cfs)	94.3
PWS RMI	33.2	Distance from Outfall (mi)	17.0

#### Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Narrative:** This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.0043 MGD of treated sewage from an existing discharge in West Salem Township, Mercer County.

Treatment under Water Quality Management Permit No. 4372412 consists of: A comminutor with bypass bar screen, a 5,025 gallon aeration tank, a 1,145 gallon settling tank, a 354 gallon dosing tank, two intermittent 189 square foot sand filters, and tablet chlorine disinfection with a 302 gallon chlorine contact tank.

**1. Streamflow:**

Unnamed Tributary to the Big Run @ Outfall 001:

Drainage Area: 26.5 sq. mi.  
Yieldrate: 0.1 cfs/m (default)  
Q<sub>7-10</sub>: 2.65 cfs

**2. Wasteflow:**

Maximum discharge: 0.0043 MGD = 0.0066 cfs  
Runoff flow period: 16 hours Basis: small non-municipal STP  
24 hour flow: 0.0043 MGD x 24/16 = 0.0064 MGD = 0.0099 cfs

In accordance with the SOP, since there is greater than 3 parts stream flow (Q7-10) to 1 part effluent (design flow), the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were not evaluated.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

**3. Parameters:**

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH<sub>3</sub>-N, CBOD<sub>5</sub>, Dissolved Oxygen, and Disinfection.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency was set to 4/week during the previous renewal. Since the sampling is being performed, and the Permit is in compliance, the frequency will not be increased to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200 No./100ml (monthly average)  
1,000 No./100ml (instantaneous maximum)  
10/01 - 04/30: 2,000 No./100ml (monthly average)  
10,000 No./100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows between 0.002 MGD and 0.05 MGD.

e. Total Phosphorus

Chapter 96.5 does not apply. However, the previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH<sub>3</sub>-N)

Median discharge pH to be used: 7.1 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (Default value used for modeling purposes)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: Default value used for modeling purposes

Stream Temperature: 20°C (Default value used for CWF modeling purposes)

Background NH<sub>3</sub>-N concentration: 0.1 mg/l

Basis: Default value used for modeling purposes

NH<sub>3</sub>-N Summer limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

NH<sub>3</sub>-N Winter limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits calculated above (see Attachment 1), which are the same as the previous permit. The winter limits are set as three times the summer limits, but since the technology-based limits are more protective, they will be used.

h. CBOD<sub>5</sub>

Median discharge pH to be used: 7.1 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (Default value used for modeling purposes)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: Default value used for modeling purposes

Stream Temperature: 20°C (Default value used for CWF modeling)

Background CBOD<sub>5</sub> concentration: 2.0 mg/l

Basis: Default value used for modeling purposes

Calculated CBOD<sub>5</sub> limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated CBOD5 limits above (see Attachment 1), which are the same as the previous NPDES Permit.

i. Dissolved Oxygen (DO)

The Dissolved Oxygen technology-based minimum of 4.0 mg/l will be retained as recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61.

The measurement frequency was set to 4/week during the previous renewal. Since the sampling is being performed, and the Permit is in compliance, the frequency will not be increased to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

j. Disinfection

Ultraviolet (UV) light monitoring  
 Total Residual Chlorine (TRC) limits: 0.5 mg/l (monthly average)  
1.2 mg/l (instantaneous maximum)

Basis: The TRC limits above are technology-based using the TRC\_Calc Spreadsheet (see Attachment 2). The instantaneous maximum limit was previously set as 1.2 mg/l. Since the Permittee is meeting the more restrictive limit, it will be retained to comply with antibacksliding requirements.

The measurement frequency was set to 4/week during the previous renewal. Since the sampling is being performed, and the Permit is in compliance, the frequency will not be increased to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

**4. Reasonable Potential Analysis for Receiving Stream:**

A Reasonable Potential Analysis was not performed in accordance with State practices for Outfall 001 using the Department's Toxics Management Spreadsheet since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

**5. Reasonable Potential for Downstream Public Water Supply (PWS):**

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). Since no relevant sampling was provided, mass-balance calculations were not performed.

Nearest Downstream potable water supply (PWS): Sharpsville Municipal Water Authority  
Distance downstream from the point of discharge: 17.0 miles (approximate)

**6. Anti-Backsliding:**

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

**7. Attachment List:**

Attachment 1 - WQ Modeling Printouts

Attachment 2 - TRC\_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from December 1, 2023 to November 30, 2024)

Parameter	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23
Flow (MGD) Average Monthly	0.0007	0.0009	0.0007	0.0006	0.0007	0.0005	0.0008	0.0009	0.0009	0.0006	0.0006	0.0006
Flow (MGD) Daily Maximum	0.0009	0.0010	0.0008	0.0008	0.0008	0.0006	0.0010	0.0010	0.0010	0.0007	0.0007	0.0008
pH (S.U.) Instantaneous Minimum	6.9	7.0	7.0	7.0	6.7	7.0	6.8	6.9	7.0	7.1	7.1	7.1
pH (S.U.) Instantaneous Maximum	7.4	7.4	7.5	7.4	7.4	7.4	7.3	7.6	7.4	7.4	7.4	7.4
DO (mg/L) Instantaneous Minimum	6.7	7.0	7.1	7.0	6.9	6.8	6.9	7.1	7.1	7.1	7.1	7.1
TRC (mg/L) Average Monthly	0.3	0.3	0.2	0.3	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.3
TRC (mg/L) Instantaneous Maximum	0.4	0.4	0.3	0.4	0.4	0.3	0.4	0.3	0.4	0.4	0.4	0.4
CBOD5 (mg/L) Average Monthly	4	5	4	4	5	5	4	5	5	4	4	4
TSS (mg/L) Average Monthly	16	16	12	16	18	17	16	16	15	16	16	17
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1
Total Nitrogen (mg/L) Average Monthly	20.7	24.4	21.3	20.8	19.4	20.5	20.6	21	21.7	20.7	21.1	21.0
Ammonia (mg/L) Average Monthly	9.15	12.4	10.0	10.0	9.8	9.9	10.0	9.64	9.62	9.88	9.87	9.94
Ammonia (mg/L) Instantaneous Maximum	9.98	15.1	10.1	10.0	9.9	10.0	10.1	9.96	9.84	9.99	9.89	10.1
Total Phosphorus (mg/L) Average Monthly	5.300	5.325	5.235	5.210	5.230	5.300	5.135	4.960	3.030	5.465	4.955	5.180

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	4/week	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	4/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.2	4/week	Grab
CBOD <sub>5</sub>	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	Report	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only. The limits for pH are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limit is technology-based on Chapter 92a.48. The limits for CBOD<sub>5</sub>, Total Suspended Solids, Dissolved Oxygen, and Fecal Coliform are technology based on Chapter 92a.47. The summer limits for Ammonia-Nitrogen are technology-based on Chapter 93.7. Monitoring for Total Nitrogen, Total Phosphorus, and winter Ammonia-Nitrogen is based on Chapter 92a.61.

Attachment 1

**WQM 7.0 Effluent Limits** (Perennial Reach)

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20A	35482	SHENANGO RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
51.000	Perennial	PA0040878p	0.004	CBOD5	2		
				NH3-N	1	2	
				Dissolved Oxygen			8.09

Since the calculated limits are equal to the dry reach outputs, the dry reach inputs are protective.

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20A	35482	SHENANGO RIVER		
<u>RMI</u> 51.000	<u>Total Discharge Flow (mgd)</u> 0.004	<u>Analysis Temperature (°C)</u> 20.013	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 25.977	<u>Reach Depth (ft)</u> 0.619	<u>Reach WDRatio</u> 41.967	<u>Reach Velocity (fps)</u> 0.165	
<u>Reach CBOD5 (mg/L)</u> 2.00	<u>Reach Kc (1/days)</u> 0.000	<u>Reach NH3-N (mg/L)</u> 0.00	<u>Reach Kn (1/days)</u> 0.701	
<u>Reach DO (mg/L)</u> 8.243	<u>Reach Kr (1/days)</u> 3.525	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 0.999	<u>Subreach Results</u>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.100	2.00	0.00	8.24
	0.200	2.00	0.00	8.24
	0.300	2.00	0.00	8.24
	0.399	2.00	0.00	8.24
	0.499	2.00	0.00	8.24
	0.599	2.00	0.00	8.24
	0.699	2.00	0.00	8.24
	0.799	2.00	0.00	8.24
	0.899	2.00	0.00	8.24
	0.999	2.00	0.00	8.24

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	51.000	952.00	26.50	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)			
Perennial	PA0040878p	0.0043	0.0000	0.0000	0.000	25.00	7.10
<b>Parameter Data</b>							
Parameter Name		Disc Conc	Trib Conc	Stream Conc	Fate Coef		
		(mg/L)	(mg/L)	(mg/L)	(1/days)		
CBOD5		2.00	2.00	0.00	1.50		
Dissolved Oxygen		8.09	8.24	0.00	0.00		
NH3-N		1.00	0.00	0.00	0.70		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	48.300	920.00	340.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp (°C)	Disc pH
		(mgd)	(mgd)	(mgd)			
		0.0000	0.0000	0.0000	0.000	25.00	7.00
<b>Parameter Data</b>							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>									
20A		35482		SHENANGO RIVER									
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
51.000	2.65	0.00	2.65	.0067	0.00224	.619	25.98	41.97	0.17	0.999	20.01	7.00	
<b>Q1-10 Flow</b>													
51.000	1.70	0.00	1.70	.0067	0.00224	NA	NA	NA	0.13	1.281	20.02	7.00	
<b>Q30-10 Flow</b>													
51.000	3.60	0.00	3.60	.0067	0.00224	NA	NA	NA	0.20	0.841	20.01	7.00	

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
20A	35482	SHENANGO RIVER					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
51.000	Perennial	16.73	2	16.73	2	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
51.000	Perennial	1.89	1	1.89	1	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
51.00	Perennial	2	2	1	1	8.09	8.09
						0	0

**WQM 7.0 D.O.Simulation** (Dry Reach)

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20A	35482	SHENANGO RIVER		
<u>RMI</u> 0.590	<u>Total Discharge Flow (mgd)</u> 0.004	<u>Analysis Temperature (°C)</u> 21.003	<u>Analysis pH</u> 7.018	
<u>Reach Width (ft)</u> 5.761	<u>Reach Depth (ft)</u> 0.340	<u>Reach WDRatio</u> 16.927	<u>Reach Velocity (fps)</u> 0.017	
<u>Reach CBOD5 (mg/L)</u> 6.62	<u>Reach Kc (1/days)</u> 0.536	<u>Reach NH3-N (mg/L)</u> 5.02	<u>Reach Kn (1/days)</u> 0.756	
<u>Reach DO (mg/L)</u> 7.392	<u>Reach Kr (1/days)</u> 10.610	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 2	
<u>Reach Travel Time (days)</u> 2.132	<u>Subreach Results</u>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.213	5.87	4.27	7.08
	0.426	5.21	3.63	7.29
	0.640	4.62	3.09	7.52
	0.853	4.10	2.63	7.72
	1.066	3.64	2.24	7.90
	1.279	3.23	1.91	8.05
	1.492	2.86	1.62	8.09
	1.706	2.54	1.38	8.09
	1.919	2.25	1.18	8.09
	2.132	2.00	1.00	8.09

## WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Simulation	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	2		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	0.590	1010.00	26.50	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)			
Dry Reach	PA0040878d	0.0043	0.0000	0.0000	0.000	25.00	7.10
<b>Parameter Data</b>							
Parameter Name		Disc Conc	Trib Conc	Stream Conc	Fate Coef		
		(mg/L)	(mg/L)	(mg/L)	(1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		4.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	0.000	952.00	27.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp (°C)	Disc pH
		(mgd)	(mgd)	(mgd)			
		0.0000	0.0000	0.0000	0.000	0.00	7.00
<b>Parameter Data</b>							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
20A		35482		SHENANGO RIVER								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.590	0.03	0.00	0.03	NA	0.01862	.34	5.76	16.93	0.02	2.132	21.00	7.02
<b>Q1-10 Flow</b>												
0.590	0.02	0.00	0.00	NA	0.01862	NA	NA	NA	0.00	0.000	0.00	0.00
<b>Q30-10 Flow</b>												
0.590	0.04	0.00	0.00	NA	0.01862	NA	NA	NA	0.00	0.000	0.00	0.00

Attachment 2

TRC EVALUATION									
Input appropriate values in A3:A9 and D3:D9									
Source		Reference		AFC Calculations		Reference		CFC Calculations	
TRC	1.3.2.iii			WLA_afc = 5.697		1.3.2.iii		WLA_cfc = 5.546	
PENTOXSD TRG	5.1a			LTAMULT_afc = 0.373		5.1c		LTAMULT_cfc = 0.581	
PENTOXSD TRG	5.1b			LTA_afc = 2.123		5.1d		LTA_cfc = 3.224	
Effluent Limit Calculations									
PENTOXSD TRG	5.1f			AML MULT = 1.231					
PENTOXSD TRG	5.1g			AVG MON LIMIT (mg/l) = 0.500				BAT/BPJ	
				INST MAX LIMIT (mg/l) = 1.635					
WLA_afc				(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)					
LTAMULT_afc				EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)					
LTA_afc				wla_afc*LTAMULT_afc					
WLA_cfc				(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)					
LTAMULT_cfc				EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)					
LTA_cfc				wla_cfc*LTAMULT_cfc					
AML_MULT				EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))					
AVG_MON_LIMIT				MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)					
INST_MAX_LIMIT				1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)					