

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0041009
APS ID 608652
Authorization ID 1201312

Applicant and Facility Information

Applicant Name	<u>Chelsea Sandwich LLC</u>	Facility Name	<u>Buckeye Terminals LLC Macungie Terminal</u>
Applicant Address	<u>800 South Street PO Box 9161 Waltham, MA 02454-9161</u>	Facility Address	<u>Shippers Lane PO Box 459 Macungie, PA 18062</u>
Applicant Contact	<u>Thomas Keefe</u>	Facility Contact	<u>Larry Zabower</u>
Applicant Phone	<u>(781) 398-4132</u>	Facility Phone	<u>(610) 965-7285</u>
Client ID	<u>250767</u>	Site ID	<u>239275</u>
SIC Code	<u>5171</u>	Municipality	<u>Lower Macungie Township</u>
SIC Description	<u>Wholesale Trade - Petroleum Products, Nec</u>	County	<u>Lehigh</u>
Date Application Received	<u>September 21, 2017</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 4, 2017</u>	If No, Reason	<u></u>
Purpose of Application	<u>RENEWAL OF EXISTING NPDES PERMIT WITH NAME CHANGE FROM PIPELINE PETROLEUM INC TO CHELSEA SANDWICH LLC/GLOBAL CO LLC..</u>		

Summary of Review

The applicant is requesting renewal of an NPDES permit to discharge stormwater from a petroleum marketing terminal to an unnamed tributary to Little Lehigh Creek, a High Quality, Cold Water Fishery, Migratory Fishery (HQ-CWF,MF) receiving stream in State Water Plan watershed 02-C (Lower Lehigh River). Per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than the designated use.

The facility is owned by Chelsea Sandwich, LLC and is operated by Global Companies, LLC. The facility is categorized by SIC Code 5171 (Petroleum Bulk Stations and Terminals) and falls under Appendix L monitoring requirements of the PAG-03 General Permit.

Appendix L of the latest statewide PAG-03 General Permit issued on 9/24/2016 includes benchmark values for Oil & Grease (O&G) and Total Suspended Solids (TSS). All industries classified under Appendix L should be within 30 mg/L for O&G and 100 mg/L for TSS. The IMAX limitations for O&G and TSS were added to the permit.

The drainage area for Outfall 001 consists of bulk storage tanks in Dike Area #1. The drainage area for Outfall 002 consists of bulk storage tanks in Dike Area #2 and includes oil/water separators for both east and west loading rack operations.

Special conditions for Petroleum Marketing Terminals are included in the permit, including authorization to discharge hydrostatic test water.

The DMRs submitted for the past 10 years have consistently reported no discharge. Per the application cover letter, stormwater accumulates within the facility's two AST dike areas, from where it dissipates. The monitoring frequency will remain annually, since a discharge is not likely.

Approve	Deny	Signatures	Date
X		/s/ Amy M. Bellanca, P.E. / Environmental Engineer Manager	July 10, 2019
X		/s/ Bharat Patel, P.E. / Environmental Program Manager	July 10, 2019

Summary of Review

The previously issued permit expired on 3/31/2018 and the renewal application was received on 9/21/2017. An Inspection query was performed and a CEI was performed on 3/15/2018 with "No Violations Noted". There are no open violations for this client that may delay issuance of this permit.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

