

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0041220  
 APS ID 967533  
 Authorization ID 1438669

**Applicant and Facility Information**

Applicant Name	<u>Hershey Rv Park &amp; Lodging LLC</u>	Facility Name	<u>Hershey RV Park &amp; Lodging</u>
Applicant Address	<u>PO Box 544</u> <u>Glenmoore, PA 19343</u>	Facility Address	<u>1688 Hershey Road</u> <u>Elizabethtown, PA 17022-8919</u>
Applicant Contact	<u>Gary Ott</u>	Facility Contact	<u>Gary Ott</u>
Applicant Phone	<u>(610) 506-1121</u>	Facility Phone	<u>(610) 506-1121</u>
Client ID	<u>342854</u>	Site ID	<u>2101</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Conewago Township</u>
Connection Status		County	<u>Dauphin</u>
Date Application Received	<u>May 4, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 17, 2023</u>	If No, Reason	
Purpose of Application	<u>NPDES permit renewal</u>		

**Summary of Review**

**1.0 General Discussion**

This fact sheet supports the renewal of an existing NPDES permit for the discharge of treated sewage from Hershey RV Park formerly known as Hershey Conewago Recreational (HRC) wastewater treatment facility. The facility was purchased by Hershey RV Park & Lodging LLC and owns and operates the facility. The facility treats sewage from the Conewago Valley Motor Inn, the Oak Knoll Estates Mobile Home Park, and the KOA Campground. A new wastewater treatment plant has been built to replace the old malfunctioning wastewater treatment during last permit cycle. The facility has a design capacity of 0.048MGD and discharges to an UNT to Conewago Creek which is classified for trout stocking (TSF). The facility owner and the other contributors to the wastewater treatment plant have addressed excessive infiltration and inflow to the wastewater treatment. The existing NPDES permit was issued on October 29, 2018 with effective date of November 1, 2018 and expiration date of October 31, 2023. The applicant submitted an administratively complete NPDES renewal application to the Department and is currently operating under the terms and conditions in the existing permit under administrative extension provisions pending Department action on the renewal application. A topographic map showing the discharge location is presented in attachment A.

**1.1 Sludge use and disposal description and location(s):**

Sludge is hold up in an aerobic digester and hauled out by a licensed hauler periodically

Approve	Deny	Signatures	Date
X		<i>J. Pascal Kwedza</i> J. Pascal Kwedza, P.E. / Environmental Engineer	May 15, 2024
X		<i>Maria D. Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	May 15, 2024
X		<i>Maria D. Bebenek</i> Maria D. Bebenek, P.E. / Program Manager	May 15, 2024

**Summary of Review**

**1.2 Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**1.3 Changes to the existing Permit**

Annual E. Coli monitoring has been added.

1.4 Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.048</u>
Latitude	<u>40° 11' 52.98"</u>	Longitude	<u>-76° 36' 36.67"</u>
Quad Name	_____	Quad Code	_____
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Conewago Creek</u>	Stream Code	<u>09625</u>
NHD Com ID	<u>56404075</u>	RMI	<u>0.70</u>
Drainage Area	<u>1.9</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.11</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.21</u>	Q <sub>7-10</sub> Basis	_____
Elevation (ft)	_____	Slope (ft/ft)	_____
Watershed No.	<u>7-G</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	_____	Existing Use Qualifier	_____
Exceptions to Use	_____	Exceptions to Criteria	_____
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Nutrients, Siltation</u>		
Source(s) of Impairment	<u>Agriculture, Agriculture</u>		
TMDL Status	<u>Final</u>	Name	<u>Conewago Creek Watershed</u>
Background/Ambient Data		Data Source	
pH (SU)	_____	_____	
Temperature (°F)	_____	_____	
Hardness (mg/L)	_____	_____	
Other:	_____	_____	
Nearest Downstream Public Water Supply Intake	<u>Columbia Borough</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	_____
PWS RMI	_____	Distance from Outfall (mi)	<u>25</u>

Changes Since Last Permit Issuance: None

**1.4.1 Water Supply Intake:**

The nearest water supply intake is approximately 25 miles downstream at Columbia Borough, Lancaster County located on the Susquehanna River by the Columbia Water Company. No adverse impact is expected from this discharge.

2.1 Treatment Facility Summary				
<b>Treatment Facility Name:</b> Hershey Rv Park & Lodging				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
2218404		10/3/2019		
2294412		12/28/1994		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia And Phosphorus	Activated Sludge	Hypochlorite	0.048
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.048		Not Overloaded		

Changes Since Last Permit Issuance: A new treatment plant was built to replace the old treatment plant.

**2.1 Treatment facility**

The treatment facility consists of:

- Raw influent screening and grinding (existing)
- Influent Pumping Station (250 gpm @ 20' TDH, duplex submersibles)
- EQ Tank (20,600-gal effective volume)
- EQ Pumping Station (90 gpm @ 15' TDH, duplex submersibles)
- Extended Aeration Reactors (52,442-gal capacity over two trains)
- Secondary Clarifiers (168 ft<sup>2</sup>) over two clarifiers
- Tablet Chlorinator (1,042 gal)
- Tablet De-Chlorinator (0.050 mgd capacity)
- Sludge Holding Tank (11,600 gal)
- Effluent Flow Metering
- Chemical Feed Systems (Alum)

3.0 Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.4	XXX	1.4	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Calculation
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	15.0	XXX	30	2/month	24-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	5.0	XXX	10	2/month	24-Hr Composite
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4	2/month	24-Hr Composite
Total Phosphorus (lbs/year)	XXX	292.1 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

3.1 Compliance History

3.1.1 DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)

Parameter	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23
Flow (MGD) Average Monthly	0.02	0.018	0.022	0.0019	0.016	0.017	0.016	0.015	0.015	0.011	0.011	0.013
Flow (MGD) Daily Maximum	0.026	0.022	0.032	0.0038	0.024	0.024	0.025	0.02	0.021	0.018	0.017	0.018
pH (S.U.) Daily Minimum	6.8	6.9	7.0	6.8	6.6	6.6	6.7	6.5	6.6	6.5	6.7	6.7
pH (S.U.) Daily Maximum	7.2	7.2	7.3	7.2	7.2	7.5	7.7	7.1	7.1	7.1	7.5	7.3
DO (mg/L) Daily Minimum	8.3	8.1	7.3	7.3	7.5	6.9	6.4	6.5	6.1	6.1	6.0	6.5
TRC (mg/L) Average Monthly	0.2	< 0.17	< 0.19	0.18	0.25	0.23	0.2	0.12	0.11	< 0.19	< 0.11	0.12
TRC (mg/L) Instantaneous Maximum	0.34	0.36	0.36	0.38	0.38	0.39	0.38	0.38	0.37	0.38	0.38	0.38
CBOD5 (mg/L) Average Monthly	< 7.5	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2.2
TSS (mg/L) Average Monthly	< 5	< 5	< 5	< 5	< 6	< 5	< 6	< 6	6	< 7	< 6	7
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 1	1	< 1	3	< 2	4	4	< 2	< 20	3
Fecal Coliform (No./100 ml) Instant. Maximum	< 1	< 1	< 1	2	< 1	9	6	8	6	5	411	5
Nitrate-Nitrite (mg/L) Average Monthly	26.8	16.6	10.62	27.2	22.9	30.2	31.8	29.5	28.8	28.2	17.1	26.3
Total Nitrogen (mg/L) Average Monthly	< 27.8	< 17.6	< 11.6	< 28.2	< 23.9	< 31.2	< 32.8	< 30.5	< 29.8	< 29.2	< 18.1	< 27.9
Ammonia (mg/L) Average Monthly	< 0.167	< 0.1	< 0.1	0.548	0.289	< 0.186	0.348	< 0.1	< 0.187	1.349	1.317	1.039
TKN (mg/L) Average Monthly	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1.6
Total Phosphorus (lbs/year) Total Annual				< 12.4								
Total Phosphorus (mg/L) Average Monthly	0.16	< 0.12	0.15	0.24	0.51	0.31	0.53	0.78	< 0.1	0.31	0.37	0.26

**3.1.2 Summary of Discharge Monitoring Reports (DMRs):**

DMRs reviewed for the facility for the last 12 months of operation, presented on the table above in section 3.1.1 indicate permit limits have been met consistently. No effluent violations were noted on DMRs for the period reviewed.

**3.1.3 Summary of Inspections:**

The facility has been inspected a couple times during last permit cycle. No effluent violations were found during plant inspections. The facility is operated and maintained well.

**4.0 Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.048</u>
<b>Latitude</b> <u>40° 11' 52.97"</u>	<b>Longitude</b> <u>-76° 36' 36.96"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**4.1 Basis for Effluent Limitations**

In general, the Clean Water Act (CWA) requires that the effluent limits for a particular pollutant be the more stringent of either technology-based limits or water quality-based limits. Technology-based limits are set according to the level of treatment that is achievable using available technology. A water quality-based effluent limit is designed to ensure that the water quality standards applicable to a waterbody are being met and may be more stringent than technology-based effluent limits.

**4.2 Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: Weekly averages are not applicable to this discharge.

**4.3 Water Quality-Based Limitations**

**4.3.1 WQM 7.0 Stream Model**

WQM 7.0 is a water quality model DEP utilizes to establish appropriate effluent limits for CBOD<sub>5</sub>, NH<sub>3</sub>-N and DO in permits. The model simulates mixing and degradation of NH<sub>3</sub>-N in the stream and compares calculated instream NH<sub>3</sub>-N concentrations to NH<sub>3</sub>-N water quality criteria and also simulates mixing and consumption of D.O. in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>N and compares calculated instream D.O. concentrations to D.O. water quality criteria and recommends effluent limits.

**4.3.2 Receiving Stream**

The receiving stream is an unnamed tributary of Conewago Creek. According to 25 PA § 93.9o, this stream is protected for Trout Stocking (TSF) and Migratory Fishes (MF). It is located in Drainage List O and State Watershed 7-G. It has been assigned stream code 09265. According to the Department's *Integrated Water Quality Monitoring and Assessment Report*, this segment of the stream is not attaining its designated uses. A TMDL was developed for Conewago Watershed for Total phosphorus and was approved by EPA in 2001. See further discussion under Total Phosphorus section for waste load allocation to this discharge.



### **4.3.3 Stream flows**

Streamflows were determined by correlating with the yield of USGS gage station No. 01571500 on Susquehanna River at Harrisburg. The  $Q_{7-10}$  and drainage area at the gage is 2610ft<sup>3</sup>/s and 24100mi<sup>2</sup> respectively. The resulting yields are as follows:

- $Q_{7-10} = (2610\text{ft}^3/\text{s})/24100 \text{ mi}^2 = 0.11 \text{ ft}^3/\text{s}/ \text{mi}^2$
- $Q_{30-10} / Q_{7-10} = 1.17$
- $Q_{1-10} / Q_{7-10} = 0.95$
- $Q_{7-10} (\text{winter}) / Q_{7-10} = 1.18$

The drainage area at discharge taken from the previous permit= 1.9 mi<sup>2</sup>

The  $Q_{7-10}$  at discharge = 1.9 mi<sup>2</sup> x 0.110 ft<sup>3</sup>/s/mi<sup>2</sup> = 0.21 ft<sup>3</sup>/s.

### **4.3.4 NH<sub>3</sub>N Calculations**

NH<sub>3</sub>N calculations will be based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the instream NH<sub>3</sub>N criteria used in the attached computer model of the stream:

STP pH	=	6.6 (DMR median July-September.)
STP Temp	=	25°C (Default)
Stream pH	=	7.8 (Taken from the Chickies Creek and also compared with Swatara Creek)
Stream Temp	=	22°C (Average between Chickies Creek and Swatara Creek)

### **4.3.5 CBOD<sub>5</sub>**

The results of the WQM 7.0 stream model presented in attachment B indicates an average monthly limit (AML) of 25mg/L CBOD<sub>5</sub> is required to protect the water quality of the stream. This limit is consistent with the existing permit and past DMRs and inspection reports show that the facility has been consistently complying the limitation. Therefore, a limit of 25mg/L AML and 50 mg/L IMAX is recommended again for this permit cycle.

### **4.3.6 NH<sub>3</sub>-N**

The results of the WQM 7.0 stream model (attachment B) also indicates that a summer limitation of 6.27 mg/L NH<sub>3</sub>-N as a monthly average is necessary to protect the aquatic life from toxicity effects. This limit is less stringent than the existing limit and will not be written in the permit due to anti-backsliding restrictions. The existing summer limitation of 5.0 mg/L with the existing the winter limit of 15 mg/L which is 3 times the summer limit will remain in the permit for the current cycle. The facility is complying with the limitation.

### **4.3.7 Dissolved Oxygen**

The existing permit contains a limit of 5 mg/l for Dissolved Oxygen (DO). DEP's Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001, 10/97) suggests that either the adopted minimum stream D.O. criteria for the receiving stream or the effluent level determined through water quality modeling be used for the limit. Since the WQM 7.0 model was run using a minimum D.O. of 5.0 mg/l, this limit will be continued in the renewed permit with a daily monitoring requirement.

#### **4.3.8 Phosphorus**

An average monthly limit of 2 mg/L was established in the previous permits prior to TMDL development. A TMDL for the Conewago Creek basin was completed and approved on March 2, 2001. The TMDL allocates Phosphorus annual load of 292.1 lbs/yr based on the design flow of 0.048 MGD and a concentration of 2 mg/l. This allocation has been incorporated and will remain permit. Due to anti-backsliding restrictions, the existing average monthly phosphorus limitation of 2 mg/L will remain in the permit. This STP was designed to remove phosphorus and has been complying with the limits.

#### **4.3.9 Total Residual Chlorine**

TRC analysis was based on the equations and calculations presented in the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID No. 391-2000-015) for developing chlorine limitations. The Guidance references Chapter 92a, Section 92a.48 (b) which establishes a standard BAT limit of 0.5 mg/L unless a facility-specific BAT has been developed. The attached results presented in attachment C indicates a water quality limit of 0.40 mg/L AML and IMAX of 1.4 mg/L would be needed to prevent toxicity concerns. This recommendation is consistent with the existing permit and will remain in the permit for the current permit cycle. DMRs and inspection reports indicate the facility has been complying with the limitation.

#### **4.3.10 Total Suspended Solids:**

There are no water quality criteria for TSS. A limit of 30 mg/l is the required minimum level of effluent quality attainable by secondary treatment as defined in EPA's 40 CFR Chapter 1, Part 133, Section 133.102(b). in the existing permit will remain.

#### **4.3.11 Toxics**

The facility treats mainly domestic sewage, there are no parameters of concern associated with this discharge.

#### **4.3.12 Chesapeake Bay Strategy**

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized based on their delivered TN and TP loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets if approved by DEP. Phase 4 (0.2 -0.4mgd) and Phase 5(below 0.2mdg) will be required to monitor and report TN and TP during permit renewal. Any facility in Phases 4 and 5 that undergoes expansion is subjected to cap load right away. This facility is a 0.048 mgd plant, classified as a phase 5, has been monitoring and reporting Nitrate-Nitrite as N, Total Kjeldahl Nitrogen and Total Nitrogen 2/month and will continue during the current permit cycle. Total Phosphorus monitoring is not required since a Total phosphorus limitation is in the permit.

#### **4.3.13 Fecal Coliform and E. Coli**

The existing Fecal Coliform limit is consistent with the technology limits recommended in 92a.47(a)(4) and (a)(5) and will remain in the permit. In March of 2021, EPA approved DEP's Triennial Review of Water Quality Standards, which included a new swimming season criterion for E. coli. As a result, DEP is including monitoring requirements for E. Coli in new and renewed sewage permits above 2000gpd. Monitoring frequency is based on annual average flow as follows: 1/month for design flows  $\geq$  1 MGD, 1/quarter for design flows  $\geq$  0.05 and  $<$  1 MGD and 1/year for design flows of 0.002 – 0.05 MGD. Your discharge of 0.048 MGD requires 1/year monitoring as included in the permit

## **5.0 Other Considerations and Requirements**

### **5.1 Anti-backsliding**

Not applicable to this permit

### **5.2 Stormwater:**

No storm water outfall is associated with this facility

### **5.3 Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

### **5.4 Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.

### **5.5 303d Listed Streams:**

The discharge is not located on a 303d listed stream segment. However, the main stem of the Conewago Creek downstream was listed as impaired due to excessive nutrient and sediment loads from agriculture. A TMDL for the Conewago Watershed (Watershed B) basin was completed and approved on March 2, 2001. The TMDL allocates a Phosphorus annual load of 292.1 lbs/yr based on the design flow of 0.048 MGD and a concentration of 2 mg/l. This allocation has been added to the NPDES permit during the past permit cycle and will remain in the current permit. The facility has been complying with the TMDL limitation.

### **5.6 Special Permit Conditions**

The permit will contain the following special conditions:

Stormwater Prohibition, Approval Contingencies, Management of collected screenings, slurries, sludges and other solids, Requirement to connect if a public sewer becomes available in the area, Chlorine minimization and Solids Management.

### **5.7 Basis for Effluent and Surface Water Monitoring**

Section 308 of the CWA and federal regulation 40 CFR 122.44(i) require monitoring in permits to determine compliance with effluent limitations. Monitoring may also be required to gather effluent and surface water data to determine if additional effluent limitations are required and/or to monitor effluent impacts on receiving water quality. The permittee is responsible for conducting the monitoring and for reporting results on Discharge Monitoring Reports (DMRs).

### **5.8 Effluent Monitoring frequency**

Monitoring frequencies are based on the nature and effect of the pollutant, as well as a determination of the minimum sampling necessary to adequately monitor the facility's performance. Permittees have the option of taking more frequent samples than are required under the permit. These samples can be used for averaging if they are conducted using EPA-approved test methods (generally found in 40 CFR 136) and if the Method Detection limits are less than the effluent limits. The sampling location must be after the last treatment unit and

prior to discharge to the receiving water. If no discharge occurs during the reporting period, "no discharge" shall be reported on the DMR.

**6.0 Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.4	XXX	1.4	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Calculation
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	15.0	XXX	30	2/month	24-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	5.0	XXX	10	2/month	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4	2/month	24-Hr Composite
Total Phosphorus (lbs/year)	XXX	292.1 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

Compliance Sampling Location: At outfall 001

<b>7.0 Tools and References Used to Develop Permit</b>	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment <b>B</b> )
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment <b>[REDACTED]</b> )
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment <b>C</b> )
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment <b>[REDACTED]</b> )
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing effluent limitation for individual sewage permit
<input type="checkbox"/>	Other: <b>[REDACTED]</b>

8. Attachments

A. Topographical Map





**B. WQM Model Results**

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
07G		9205		Trib 9205 to Coverage Creek			
RMI	Name	Permit Number	Disc. Flow (mgd)	Parameter	Eff. Limit 30-day Avg. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
0.700	Hershey RV Park	PA0041220	0.048	CBOD5	25		
				NH3-N	6.37	12.74	
				Dissolved Oxygen			5

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07G	6265	Trib 06265 to Conowingo Creek	0.700	426.00	1.80	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Trib Temp (°C)	Trib pH	Stream Temp (°C)	Stream pH
Q1-10	0-110	0.00	0.00	0.000	0.000	0.0	0.00	0.00	22.00	7.80	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reuse Factor	Disc Temp (°C)	Disc pH
Hershey Rv Park	PA0041220	0.0000	0.0000	0.0000	0.000	25.00	6.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.20	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft)	PWS Withdrawal (mgd)	Apply PC
07G	0205	Trib 09265 to Conowingo Creek	00 10	419.00	2.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (ft/m)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q1-10	0.110	0.00	0.00	0.000	0.000	0.0	0.00	0.00	22.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q10-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Dis. Flow (mgd)	Permitted Dis. Flow (mgd)	Design Dis. Flow (mgd)	Reuse Factor	Dis. Temp (°C)	Dis. pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

**Parameter Data**

Parameter Name	Dis. Conc. (mg/L)	Trib Conc. (mg/L)	Stream Conc. (mg/L)	Fate Coef. (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.20	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### WQM 7.0 Wasteload Allocations

SWP Basin      Stream Code      Stream Name  
07G                      6065                      Trib 06065 to Conewago Creek

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	0.700 Hershey Rv Park	12.11	44.5	12.11	44.5	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	0.700 Hershey Rv Park	1.46	6.37	1.46	6.37	1	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	0.700 Hershey Rv Park	25	25	6.37	6.37	5	5	0	0

**WQM 7.0 D.O. Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07G	0005	Trib 0005 to Conestogo Creek		
<u>RM</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.700	0.040	22.760	7.110	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
7.000	0.427	16.700	0.000	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
0.00	1.100	1.07	0.007	
<u>Reach DO (mg/L)</u>	<u>Reach R (1/days)</u>	<u>R Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.000	21.100	Owens	0	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>	<u>DO</u>		
0.507	<u>Travel Time (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>DO (mg/L)</u>
	0.051	7.53	1.00	7.00
	0.101	7.07	1.03	7.71
	0.152	6.63	1.06	7.79
	0.203	6.23	1.00	7.63
	0.254	5.80	1.34	7.63
	0.304	5.47	1.20	7.63
	0.355	5.13	1.23	7.63
	0.406	4.81	1.17	7.63
	0.456	4.52	1.12	7.63
	0.507	4.24	1.08	7.63

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows.	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.65	Use Inputted Reach Travel Times.	<input type="checkbox"/>
Q30-10/Q9-10 Ratio	1.17	Temperature Adjust K <sub>r</sub>	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>			<u>Stream Name</u>							
075		9292			Trib 09292 to Conewago Creek							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc. Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(ft/s)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.700	0.21	0.00	0.21	0.743	0.00192	4.27	7.99	19.73	0.08	0.507	22.79	7.11
<b>Q1-10 Flow</b>												
0.700	0.20	0.00	0.20	0.743	0.00192	NA	NA	NA	0.08	0.519	22.82	7.10
<b>Q30-10 Flow</b>												
0.700	0.24	0.00	0.24	0.743	0.00192	NA	NA	NA	0.09	0.475	22.70	7.15

C. TRC Calculations

<b>TRC EVALUATION</b>					
Input appropriate values in A3:A9 and D3:D9					
0.21	= Q stream (cfs)	0.5	= CV Daily		
0.048	= Q discharge (MGD)	0.5	= CV Hourly		
30	= no. samples	1	= AFC_Partial Mix Factor		
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)		
0	= % Factor of Safety (FOS)	0	= Decay Coefficient (K)		
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.921		1.3.2.iii	WLA_cfc = 0.891
PENTOXSD TRC	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRC	5.1b	LTA_afc = 0.343		5.1d	LTA_cfc = 0.518
Source	Effluent Limit Calculations				
PENTOXSD TRC	5.1f	AML_MULT = 1.231			
PENTOXSD TRC	5.1g	AVG MON LIMIT (mg/l) = 0.422		AFC	
		INST MAX LIMIT (mg/l) = 1.382			
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) \cdot [(AFC\_Yc \cdot Qs \cdot .019/Qd \cdot e^{-k \cdot AFC\_tc}) \dots \cdot Xd \cdot (AFC\_Yc \cdot Qs \cdot Xs/Qd)]^{(1-FOS/100)}$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) \cdot [(CFC\_Yc \cdot Qs \cdot .011/Qd \cdot e^{-k \cdot CFC\_tc}) \dots \cdot Xd \cdot (CFC\_Yc \cdot Qs \cdot Xs/Qd)]^{(1-FOS/100)}$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				