

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0041441  
APS ID 836286  
Authorization ID 1275524

**Applicant and Facility Information**

|                           |  |                  |   |
|---------------------------|--|------------------|---|
| Applicant Name            | <u>Somerset Township Municipal Authority Somerset County</u>                     | Facility Name    | <u>Wells Creek STP</u>  |
| Applicant Address         | <u>PO Box 247</u><br><u>Somerset, PA 15501-0247</u>                              | Facility Address | <u>356 Coleman Station Road</u><br><u>Friedens, PA 15541-8205</u> |
| Applicant Contact         | <u>Carolyn Zambanini; <a href="mailto:zamc@comcast.net">zamc@comcast.net</a></u> | Facility Contact | <u>***same as applicant***</u>                                    |
| Applicant Phone           | <u>(814) 445-5842</u>  | Facility Phone   | <u>***same as applicant***</u>                                    |
| Client ID                 | <u>25312</u>   | Site ID          | <u>238899</u>   |
| Ch 94 Load Status         | <u>Not Overloaded</u>  | Municipality     | <u>Somerset Township</u>  |
| Connection Status         | <u></u>  | County           | <u>Somerset</u>   |
| Date Application Received | <u>June 3, 2019</u>  | EPA Waived?      | <u>Yes</u>  |
| Date Application Accepted | <u>June 5, 2019</u>  | If No, Reason    | <u></u>   |
| Purpose of Application    | <u>NPDES permit renewal for treated sewage discharges from a POTW.</u>           |                  |   |

**Summary of Review**

On June 3, 2019, the Somerset Township Municipal Authority (STMA) submitted an application to renew the NPDES permit for STMA's Wells Creek Sewage Treatment Plant (Wells Creek STP). The permit currently in effect was issued on November 24, 2014 with a December 1, 2014 effective date and a November 30, 2019 expiration date. The renewal application was received 180 days before the permit expired, so the terms and conditions of the 2014 permit were automatically continued and remain in effect.

The treatment process at the Wells Creek STP was described by STMA in the permit renewal application as follows:

Influent is collected to the Wells Creek Wastewater Sewage Treatment Plant control building wet well. One of three pumps transfer the wastewater through a flow meter to the Influent Control Structure comminutor and normally onward into Lagoon No. 1 as a manageable liquid. Lagoon No. 1 is separated in two by a baffle to provide extended retention time and permit differing levels of aeration before the wastewater decants through Control Structure No. 1 and a diversion box into Lagoon No. 2. Lagoon No. 2 provides additional biological treatment before decanting through Control Structure No. 2 and into Lagoon No. 3. Control Structure No. 2 contains a Poly-Aluminum Chloride Compound (PAC) injection system to precipitation phosphorus out into Lagoon No. 3. Lagoon No. 3 decants through Control Structure No. 3, the Control Manhole, and into the Bio-Tower Pump Station Wet Well. Wastewater in the wet well receives Sodium Bi-Carbonate by injection to raise alkalinity before being pumped into, or recirculated through the Bio-Towers No. 1 and/or No. 2. The processed wastewater then flows through Control Structure No. 4 and into the Chlorine Contact Tank. Effluent released from the Chlorine Contact Tank is then automatically measured for flow, residual chlorine, and pH level before release through Outfall 001 and into Wells Creek.

| Approve | Deny | Signatures  | Date           |
|---------|------|---|----------------|
| X       |      | <i>Ryan C. Decker</i><br>Ryan C. Decker, P.E. / Environmental Engineer        | April 30, 2021 |
| X       |      | <i>Donald Leone</i><br>Donald J. Leone, P.E. / Environmental Engineer Manager | May 3, 2021    |
| X       |      | <i>Christopher Kriley</i><br>Christopher Kriley, P.E. / Program Manager       | May 3, 2021    |

### Summary of Review

Each part of the treatment plant, prior to reaching the Chlorine Contact Tank, is interconnected by by-pass and recycle lines to provide isolation for maintenance or continued treatment back to any separate structure. The Lagoon Recycle Line from Lagoon No. 3 back to the Control Building Wet Well is integrated with an elevated 500-gallon dump tank to allow hauled-in wastes to be accepted with the normal influent.

Wells Creek's designated aquatic life use is impaired by nutrients from agriculture. A nutrient Total Maximum Daily Load (TMDL) was finalized for Wells Creek in December 2006 to address the nutrient impairment of the stream. In addition, Wells Creek is part of the Kiskiminetas-Conemaugh River Watershed, which has a final TMDL from January 2010. Outfall 001 from Wells Creek was assigned waste load allocations in both TMDLs, but only the Wells Creek TMDL's waste load allocations have been imposed in the NPDES permit to date.

The renewed permit includes the following changes:

- New, more stringent seasonal water quality-based effluent limits for ammonia-nitrogen and CBOD-5 resulting from updated water quality modeling to implement recent revisions to ammonia-nitrogen water quality criteria in 25 Pa. Code Chapter 93 (promulgated in October 2020 and approved by U.S. EPA in March 2021).
- New, more stringent water quality-based effluent limits for Total Residual Chlorine based on updated stream and discharge chlorine demands consistent with DEP's permitting policies. A two-year compliance schedule is provided for the new TRC limits.
- New water quality-based effluent limits for aluminum, iron, and manganese imposed pursuant to the Total Maximum Daily Load for Streams Impaired by Acid Mine Drainage in the Kiskiminetas-Conemaugh River Watershed.
- A new quarterly monitoring requirement for *E. Coli* resulting from revised Chapter 93 water quality criteria and updated DEP permitting policies.
- Removal of weekly average limits for ammonia-nitrogen and total phosphorus consistent with DEP's permitting policies.

Sludge use and disposal description and location(s): No sludge was removed from the facility in the previous year.

### Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Discharge, Receiving Waters and Water Supply Information**

|  |  |                              |  |
|--|--|------------------------------|--|
| Outfall No.                                    | <u>001</u>   | Design Flow (MGD)            | <u>0.8</u>   |
| Latitude                                       | <u>40° 3' 11.58"</u>                                       | Longitude                    | <u>-78° 58' 11.93"</u>   |
| Quad Name                                      | <u>Stoystown</u>   | Quad Code                    | <u>1814</u>  |
| Wastewater Description: <u>Sewage effluent</u> |  |                              |  |
| Receiving Waters                               | <u>Wells Creek (CWF)</u>                                   | Stream Code                  | <u>45675</u>   |
| NHD Com ID                                     | <u>123723739</u>   | River Mile Index (RMI)       | <u>2.57</u>  |
| Drainage Area                                  | <u>13.9</u>  | Yield (cfs/mi <sup>2</sup> ) | <u>0.0643</u>  |
| Q7-10 Flow (cfs)                               | <u>0.894</u>   | Q7-10 Basis                  | <u>USGS StreamStats</u>  |
| Elevation (ft)                                 | <u>2,009</u>   | Slope (ft/ft)                | <u>0.0022</u>  |
| Watershed No.                                  | <u>18-E</u>  | Chapter 93 Class.            | <u>CWF</u>   |
| Existing Use                                   | <u></u>  | Existing Use Qualifier       | <u></u>  |
| Exceptions to Use                              | <u></u>  | Exceptions to Criteria       | <u></u>  |
| Assessment Status                              | <u>Impaired</u>  |                              |  |
| Cause(s) of Impairment                         | <u>Metals; Nutrients</u>                                   |                              |  |
| Source(s) of Impairment                        | <u>Acid mine drainage; agriculture</u>                     |                              |  |
| TMDL Status                                    | <u>Final (January 29, 2010);<br/>Final (December 2006)</u> | Name                         | <u>Kiskiminetas-Conemaugh River<br/>Watersheds TMDL; Wells Creek</u> |
| Nearest Downstream Public Water Supply Intake  | <u>Hooversville Municipal Authority</u>                    |                              |  |
| PWS Waters                                     | <u>Stonycreek River</u>                                    | Flow at Intake (cfs)         | <u></u>  |
| PWS RMI  | <u>24.9</u>  | Distance from Outfall (mi)   | <u>9.22 (river miles)</u>  |

Changes Since Last Permit Issuance: No changes

Other Comments: RMI for Outfall 001 updated from 2.27 to 2.57 (there was no physical change to the outfall location, just an updated RMI measurement).

3/5/2021

StreamStats

# StreamStats Report

Region ID: PA  
 Workspace ID: PA20210305192706255000  
 Clicked Point (Latitude, Longitude): 40.05321, -78.97003  
 Time: 2021-03-05 14:27:23 -0500



| Basin Characteristics |   |       |              |
|-----------------------|---|-------|--------------|
| Parameter Code        | Parameter Description                   | Value | Unit         |
| DRNAREA               | Area that drains to a point on a stream | 13.9  | square miles |
| ELEV                  | Mean Basin Elevation                    | 2250  | feet         |
| PRECIP                | Mean Annual Precipitation               | 43    | inches       |

| Low-Flow Statistics Parameters (100 Percent (13.9 square miles) Low Flow Region 3) |                |       |       |           |           |
|--|----------------|-------|-------|-----------|-----------|
| Parameter Code   | Parameter Name | Value | Units | Min Limit | Max Limit |
|  |                |       |       |           |           |

3/5/2021

StreamStats

| Parameter Code | Parameter Name            | Value | Units        | Min Limit | Max Limit |
|----------------|---------------------------|-------|--------------|-----------|-----------|
| DRNAREA        | Drainage Area             | 13.9  | square miles | 2.33      | 1720      |
| ELEV           | Mean Basin Elevation      | 2250  | feet         | 898       | 2700      |
| PRECIP         | Mean Annual Precipitation | 43    | inches       | 38.7      | 47.9      |

**Low-Flow Statistics Flow Report** [100 Percent (13.9 square miles) Low Flow Region 3]

PI: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

| Statistic               | Value | Unit               | SE | SEp |
|-------------------------|-------|--------------------|----|-----|
| 7 Day 2 Year Low Flow   | 1.95  | ft <sup>3</sup> /s | 43 | 43  |
| 30 Day 2 Year Low Flow  | 2.69  | ft <sup>3</sup> /s | 38 | 38  |
| 7 Day 10 Year Low Flow  | 0.894 | ft <sup>3</sup> /s | 54 | 54  |
| 30 Day 10 Year Low Flow | 1.16  | ft <sup>3</sup> /s | 49 | 49  |
| 90 Day 10 Year Low Flow | 1.7   | ft <sup>3</sup> /s | 41 | 41  |

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.4.0

| Treatment Facility Summary  |                                     |  |                                     |                        |
|---|-------------------------------------|--|-------------------------------------|------------------------|
| <p><b>Treatment Facility:</b> Wells Creek Sewage Treatment Plant – The STP consists of a comminutor, a bar screen, three continuously aerated lagoons (Lagoon #1 has two cells, A and B, separated by a baffle), a wet well, two bio-towers, and an aerated chlorine contact tank with baffles.</p> |                                     |  |                                     |                        |
| WQM Permit No.  | Issuance Date                       | Purpose  |                                     |                        |
| 5672408   | April 28, 1972                      | Permit issued to Somerset Township Municipal Authority for a 0.305 MGD sewage treatment plant consisting of grit channels, a comminutor, two partial mix aerated lagoons (Lagoon No. 1 with a capacity of 5.6 million gallons and Lagoon No. 2 with a capacity of 3.5 million gallons), chlorination, and an outfall sewer .   |                                     |                        |
| 5672408 A-1   | April 25, 1995                      | Permit issued to Somerset Township Municipal Authority for upgrades to and expansion of the STP. The average design flow was increased to 0.8 MGD (peak 2.0 MGD). Upgrades included a new influent pump station; new grit channels, comminutor, and bar screen; a new partial mix aerated lagoon (in addition to the two existing lagoons) with a capacity of 4.2 million gallons with a synthetic liner, helixor static tube aerators, and an underdrain groundwater monitoring system; a new bio-tower pump station; two new 25-ft diameter bio-towers; a new chlorine contact tank; three new air blowers at 1,000 scfm; new chemical feed systems for alkalinity control. The existing effluent flow meter and standby electrical power from the secondary electrical substation were maintained. In addition, the upgrades included the removal of sludge from Lagoon No. 1; the installation of a new synthetic liner in Lagoon No. 2; and new groundwater monitoring wells for Lagoon Nos. 1 and 2. |                                     |                        |
| Waste Type  | Degree of Treatment                 | Process Type   | Disinfection                        | Avg Annual Flow (MGD)  |
| Sewage  | Secondary with Phosphorus Reduction | Aerated lagoons  | Gas Chlorine                        | 0.662                  |
| Hydraulic Capacity (MGD)  | Organic Capacity (lbs/day)          | Load Status  | Biosolids Treatment                 | Biosolids Use/Disposal |
| 0.8   | 1,360                               | Not Overloaded   | No solids disposed in previous year |                        |

Changes Since Last Permit Issuance: None

Compliance History

DMR Data for Outfall 001 (from February 1, 2020 to January 31, 2021)

| Parameter  | JAN-21 | DEC-20 | NOV-20 | OCT-20 | SEP-20 | AUG-20 | JUL-20 | JUN-20 | MAY-20 | APR-20 | MAR-20 | FEB-20 |
|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD)<br>Average Monthly                              | 0.507  | 0.468  | 0.391  | 0.237  | 0.338  | 0.272  | 0.243  | 0.248  | 0.509  | 0.797  | 0.708  | 0.732  |
| Flow (MGD)<br>Daily Maximum                                | 1.224  | 1.148  | 0.794  | 0.779  | 0.680  | 0.929  | 0.530  | 0.547  | 1.000  | 1.319  | 1.454  | 1.465  |
| pH (S.U.)<br>Minimum                                       | 6.3    | 6.8    | 6.7    | 6.6    | 7.1    | 7.6    | 6.3    | 6.3    | 6.1    | 6.3    | 6.4    | 6.7    |
| pH (S.U.)<br>Maximum                                       | 8.0    | 7.7    | 7.8    | 7.4    | 7.7    | 8.1    | 7.1    | 7.4    | 7.4    | 7.8    | 7.6    | 7.6    |
| DO (mg/L)<br>Minimum                                       | 6.2    | 6.2    | 6.4    | 6.7    | 7.1    | 6.9    | 6.2    | 6.6    | 6.5    | 5.5    | 6.4    | 6.4    |
| TRC (mg/L)<br>Average Monthly                              | 0.19   | 0.15   | 0.08   | 0.18   | 0.16   | 0.10   | 0.10   | 0.12   | 0.10   | 0.12   | 0.14   | 0.18   |
| TRC (mg/L)<br>Instantaneous<br>Maximum                     | 0.55   | 0.35   | 0.41   | 0.47   | 0.48   | 0.42   | 0.30   | 0.37   | 0.34   | 0.27   | 0.26   | 0.35   |
| CBOD5 (lbs/day)<br>Average Monthly                         | 15     | 19     | 7      | 3      | 6      | 6      | 8      | 9      | 11     | 40     | 18     | 33     |
| CBOD5 (lbs/day)<br>Weekly Average                          | 45     | 46     | 12     | 5      | 10     | 8      | 12     | 28     | 19     | 66     | 35     | 68     |
| CBOD5 (mg/L)<br>Average Monthly                            | 3      | 4      | 2      | 2      | 2      | 4      | 5      | 4      | 3      | 5      | 4      | 4      |
| CBOD5 (mg/L)<br>Weekly Average                             | 5      | 6      | 3      | 3      | 2      | 4      | 8      | 8      | 4      | 9      | 5      | 6      |
| TSS (lbs/day)<br>Average Monthly                           | 28     | 36     | 30     | 5      | 20     | 26     | 25     | 16     | 40     | 137    | 39     | 44     |
| TSS (lbs/day)<br>Weekly Average                            | 89     | 77     | 58     | 7      | 66     | 36     | 47     | 21     | 57     | 154    | 71     | 91     |
| TSS (mg/L)<br>Average Monthly                              | 5      | 8      | 9      | 4      | 6      | 14     | 12     | 9      | 11     | 18     | 8      | 6      |
| TSS (mg/L)<br>Weekly Average                               | 10     | 10     | 10     | 4      | 13     | 24     | 16     | 12     | 12     | 23     | 10     | 8      |
| Fecal Coliform<br>(CFU/100 ml)<br>Geometric Mean           | 4      | 40     | 23     | 1      | 3      | 13     | 3      | 5      | 6      | 48     | 21     | 96     |
| Fecal Coliform<br>(CFU/100 ml)<br>Instantaneous<br>Maximum | 201    | 2481   | 192    | 2      | 18     | 47     | 4      | 36     | 13     | 636    | 355    | 2481   |

**NPDES Permit Fact Sheet  
Wells Creek STP**

**NPDES Permit No. PA0041441**

|  |     |      |      |      |     |     |     |      |     |      |     |     |
|--|-----|------|------|------|-----|-----|-----|------|-----|------|-----|-----|
| Total Nitrogen (mg/L)<br>Daily Maximum           |     | 22.5 |      |      |     |     |     |      |     |      |     |     |
| Ammonia (lbs/day)<br>Average Monthly             | 22  | 51   | 59   | 11   | 4   | 1   | 10  | 26   | 11  | 35   | 28  | 39  |
| Ammonia (lbs/day)<br>Weekly Average              | 54  | 69   | 154  | 16   | 14  | 2   | 15  | 89   | 17  | 58   | 54  | 93  |
| Ammonia (mg/L)<br>Average Monthly                | 4.9 | 11.7 | 14.9 | 7.5  | 1.7 | 0.3 | 4.5 | 8.9  | 2.6 | 4.3  | 5.6 | 4.9 |
| Ammonia (mg/L)<br>Weekly Average                 | 7.7 | 15.1 | 26.4 | 10.3 | 6.5 | 1.0 | 6.6 | 25.2 | 3.5 | 5.9  | 7.6 | 8.1 |
| Total Phosphorus<br>(lbs/day)<br>Average Monthly | 4.1 | 9.5  | 16.1 | 5.1  | 4.3 | 2.1 | 3.9 | 2.5  | 3.0 | 10.3 | 6.9 | 7.6 |
| Total Phosphorus<br>(lbs/day)<br>Weekly Average  | 12  | 15   | 33   | 6    | 9   | 3   | 7   | 5    | 4   | 15   | 12  | 14  |
| Total Phosphorus<br>(mg/L)<br>Average Monthly    | 0.7 | 2.2  | 4.6  | 3.4  | 1.4 | 1.2 | 1.8 | 1.2  | 0.8 | 1.3  | 1.4 | 1.0 |
| Total Phosphorus<br>(mg/L)<br>Weekly Average     | 1.3 | 4.1  | 5.6  | 3.8  | 1.9 | 1.8 | 2.3 | 1.5  | 1.0 | 1.6  | 1.7 | 1.2 |



Compliance History

Effluent Violations for Outfall 001, from: March 1, 2020 To: January 31, 2021

| Parameter        | Date     | SBC      | DMR Value | Units   | Limit Value | Units   |
|------------------|----------|----------|-----------|---------|-------------|---------|
| Ammonia          | 06/30/20 | Wkly Avg | 89        | lbs/day | 45          | lbs/day |
| Ammonia          | 11/30/20 | Wkly Avg | 154       | lbs/day | 134         | lbs/day |
| Ammonia          | 11/30/20 | Avg Mo   | 14.9      | mg/L    | 13.5        | mg/L    |
| Ammonia          | 06/30/20 | Avg Mo   | 8.9       | mg/L    | 4.5         | mg/L    |
| Ammonia          | 10/31/20 | Avg Mo   | 7.5       | mg/L    | 4.5         | mg/L    |
| Ammonia          | 11/30/20 | Wkly Avg | 26.4      | mg/L    | 20.0        | mg/L    |
| Ammonia          | 10/31/20 | Wkly Avg | 10.3      | mg/L    | 6.8         | mg/L    |
| Ammonia          | 06/30/20 | Wkly Avg | 25.2      | mg/L    | 6.8         | mg/L    |
| Total Phosphorus | 11/30/20 | Avg Mo   | 16.1      | lbs/day | 13.4        | lbs/day |
| Total Phosphorus | 11/30/20 | Wkly Avg | 33        | lbs/day | 20          | lbs/day |
| Total Phosphorus | 11/30/20 | Avg Mo   | 4.6       | mg/L    | 2.0         | mg/L    |
| Total Phosphorus | 12/31/20 | Avg Mo   | 2.2       | mg/L    | 2.0         | mg/L    |
| Total Phosphorus | 10/31/20 | Avg Mo   | 3.4       | mg/L    | 2.0         | mg/L    |
| Total Phosphorus | 12/31/20 | Wkly Avg | 4.1       | mg/L    | 3.0         | mg/L    |
| Total Phosphorus | 10/31/20 | Wkly Avg | 3.8       | mg/L    | 3.0         | mg/L    |
| Total Phosphorus | 11/30/20 | Wkly Avg | 5.6       | mg/L    | 3.0         | mg/L    |

Summary of Inspections:           

Other Comments:

**Development of Effluent Limitations**

|   |   |
|---|---|
| <b>Outfall No.</b> <u>001</u>                         | <b>Design Flow (MGD)</b> <u>0.8</u>     |
| <b>Latitude</b> <u>40° 3' 8.00"</u>                   | <b>Longitude</b> <u>-78° 58' 11.00"</u> |
| <b>Wastewater Description:</b> <u>Sewage effluent</u> |   |

The STP consists of a comminutor, bar screen, three continuously aerated lagoons (Lagoon No. 1 with baffles and two cells: Cell A and Cell B), a wet well, two bio-towers, and an aerated and baffled chlorine contact tank.

**Technology-Based Effluent Limitations (TBELs)**

25 Pa. Code § 92a.47 – Sewage Permits

Regulations at 25 Pa. Code § 92a.47 specify TBELs and effluent standards that apply to sewage discharges. Section 92a.47(a) requires that sewage be given a minimum of secondary treatment with significant biological treatment that achieves the following:

**Table 1. Regulatory TBELs for Sanitary Wastewaters**

| Parameter   | Average Monthly (mg/L)                     | Weekly Average (mg/L) | Instant. Max (mg/L)            | Basis  |
|---|--|-----------------------|--------------------------------|--|
| CBOD5   | 25   | 40                    | 50 <sup>†</sup>                | 25 Pa. Code § 92a.47(a)(1), (a)(2) & 40 CFR § 133.102(a)(4)(i) |
| Total Suspended Solids                              | 30   | 45                    | 60 <sup>†</sup>                | 25 Pa. Code § 92a.47(a)(1), (a)(2) & 40 CFR § 133.102(b)(1)    |
| Fecal Coliform (No./100 mL)<br>May 1 – September 30 | 200<br>(Geometric Mean)                    | N/A                   | 1,000                          | 25 Pa. Code § 92a.47(a)(4)                                     |
| Fecal Coliform (No./100 mL)<br>October 1 – April 30 | 2,000<br>(Geometric Mean)                  | N/A                   | 10,000                         | 25 Pa. Code § 92a.47(a)(5)                                     |
| Total Residual Chlorine                             | 0.5<br>(or facility-specific)              | N/A                   | 1.00<br>(or facility-specific) | 25 Pa. Code § 92a.47(a)(8) & § 92a.48(b)(2)                    |
| pH (s.u.)   | not less than 6.0 and not greater than 9.0 |                       |                                | 25 Pa. Code § 92a.47(a)(7) & § 95.2(1), & 40 CFR § 133.102(c)  |

<sup>†</sup> Value is calculated as two times the monthly average in accordance with Chapter 2 of DEP's "Technical Guidance for the Development and Specification of Effluent Limitations. and Other Permit Conditions in NPDES Permits" [Doc. No. 362-0400-001].

The CBOD<sub>5</sub>, TSS, and pH limits are the same as those in EPA's secondary treatment regulation (40 CFR § 133.102).

Flow must be reported pursuant to 25 Pa. Code § 92a.61(d)(1). The average annual design flow of the STP, 0.8 MGD, will be imposed as the average monthly limit for flow per Table 5-3 of DEP's "Technical Guidance for the Development and Specification of Effluent Limitations. and Other Permit Conditions in NPDES Permits". Also, the existing minimum dissolved oxygen limit of 5.0 mg/L and the annual reporting requirement for Total Nitrogen will be maintained at Outfall 001 pursuant to 25 Pa. Code § 92a.61(b) (regarding reasonable monitoring requirements) and 40 CFR § 122.44(l) (regarding anti-backsliding).

In accordance with Section I of DEP's "Standard Operating Procedure for Clean Water Program Establishing Effluent Limitations for Individual Sewage Permits" [SOP No. BCW-PMT-033, Version 1.9, March 22, 2021] and under the authority of 25 Pa. Code § 92a.61(b), Total Nitrogen and Total Phosphorus reporting is required for sewage discharges with design flows greater than 2,000 gpd to help evaluate treatment effectiveness and to monitor nutrient loading to the receiving watershed. Pursuant to that same SOP and under the authority of § 92a.61(b), a quarterly reporting requirement for *E. coli* will be added to Outfall 001.

**Mass Limits**

In accordance with Table 5-3 of DEP's "Technical Guidance for the Development and Specification of Effluent Limitations. and Other Permit Conditions in NPDES Permits" and Section IV of DEP's "Standard Operating Procedure for Clean Water Program Establishing Effluent Limitations for Individual Sewage Permits", mass limits are calculated for CBOD<sub>5</sub> and TSS. Average monthly and average weekly mass limits (in units of pounds per day) are calculated using the following formula with the concentration limits in Table 1 and the Wells Creek STP's 0.8 MGD design flow:

Design flow (average annual) (MGD) × concentration limit (mg/L) at design flow × conversion factor (8.34) = mass limit (lb/day)

**Table 2. Mass TBELs for Sanitary Wastewaters**

| Parameter              | Average Monthly (mg/L) | Average Weekly (mg/L) |
|------------------------|------------------------|-----------------------|
| CBOD5                  | 165.0                  | 265.0                 |
| Total Suspended Solids | 200.0                  | 300.0                 |

Pursuant to Chapter 5, Section C.2 of DEP’s “Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits” mass limits for conventional pollutants with a magnitude greater than 60.0 are rounded down to the nearest 5.0 mg/L (the mass limits in Table 2 account for this rounding convention).

**Water Quality-Based Effluent Limitations (WQBELs)**

Pursuant to EPA’s approval of Pennsylvania’s 2017 Triennial Review of Water Quality Standards and corresponding regulatory changes published in the *Pennsylvania Bulletin* on July 11, 2020, new water quality criteria for ammonia-nitrogen apply to waters of the Commonwealth. Therefore, WQBELs are re-evaluated even though there have been no changes to the STP.

WQM 7.0 Water Quality Modeling Program

WQM 7.0 is a water quality modeling program for Windows that determines Waste Load Allocations (“WLAs”) and effluent limitations for carbonaceous biochemical oxygen demand (“CBOD5”), ammonia nitrogen (“NH3-N”), and dissolved oxygen (“DO”) for single and multiple point-source discharge scenarios. To accomplish this, the model simulates two basic processes. In the NH3-N module, the model simulates the mixing and degradation of NH3-N in the stream and compares calculated instream NH3-N concentrations to NH3-N water quality criteria. In the DO module, the model simulates the mixing and consumption of DO in the stream due to the degradation of CBOD5 and NH3-N, and compares calculated instream DO concentrations to DO water quality criteria. WQM 7.0 then determines the highest pollutant loadings that the stream can assimilate while still meeting water quality criteria under design conditions.

Water Quality Modeling with WQM 7.0

**Table 3. 001 WQM 7.0 Inputs**

| Discharge Characteristics             |        |
|---------------------------------------|--------|
| Parameter                             | Value  |
| River Mile Index                      | 2.57   |
| Discharge Flow (MGD)                  | 0.8    |
| Discharge Temp. (°C) (Summer)         | 20.0   |
| Discharge Temp. (°C) (Winter)         | 15.0   |
| Basin/Stream Characteristics          |        |
| Parameter                             | Value  |
| Area in Square Miles                  | 13.9   |
| Q7-10 (cfs)                           | 0.894  |
| Low-flow yield (cfs/mi <sup>2</sup> ) | 0.0643 |
| Elevation (ft)                        | 2,009  |
| Slope                                 | 0.0022 |
| Stream Temp. (°C) (Summer)            | 20.0   |
| Stream Temp. (°C) (Winter)            | 5.0    |
| Stream pH (s.u.)                      | 6.5    |

The WQM 7.0 model is run for Outfall 001 to determine whether WQBELs are necessary for CBOD<sub>5</sub>, ammonia-nitrogen, and/or dissolved oxygen. Input values for the WQM 7.0 model are shown in Table 3.

DEP’s modeling for sewage discharges is a two-step process. First, a discharge is modeled for the summer period (May through October) using warm temperatures for the discharge and the receiving stream. Modeling for the summer period is done first because allowable ammonia concentrations in a discharge are lower at higher temperatures (i.e., warm temperatures are more likely to result in critical loading conditions). Reduced dissolved oxygen levels also appear to increase ammonia toxicity and the maximum concentration of dissolved oxygen in water is lower at higher temperatures.

The second step is to evaluate WQBELs for the winter period, but only if modeling shows that WQBELs are needed for the summer period. For the summer period, pursuant to DEP’s “Implementation Guidance of Section 93.7 Ammonia Criteria” [Doc. No. 391-2000-013] (Ammonia Guidance) and in the absence of site-specific data, the discharge temperature is assumed to be 20°C and the design stream temperature and pH are assumed to be 20°C and 6.5 s.u., respectively, based on the recommendations for free stone cold water streams in DEP’s Ammonia Guidance (Wells Creek is designated for cold water fishes). The flow used for modeling is the average design flow (0.8 MGD).

The results of the WQM 7.0 modeling (see Attachment A) indicate that new WQBELs are needed for CBOD5 and ammonia-nitrogen. Consistent with Section IV.D of DEP’s Ammonia Guidance, limits from WQM 7.0 greater than 10 mg/L are rounded down to the nearest whole number and limits less than 10 mg/L and greater than 1 mg/L are rounded down to the nearest

0.5 mg/L. Limits less than 1 mg/L are rounded down to the nearest 0.1 mg/L. Limits greater than 60.0 are rounded down to the nearest 5 mg/L.

The average monthly and instantaneous maximum ammonia-nitrogen WQBELs calculated by WQM 7.0 for the summer period are 3.5 mg/L and 7.0 mg/L, respectively (rounded down from 3.52 and 7.04 to the nearest 0.5 mg/L), and the average monthly WQBEL for CBOD5 is 11.0 mg/L (rounded down from 11.7 to the nearest 1.0 mg/L).

Pursuant to Section IV.C.2 of DEP’s Ammonia Guidance, average weekly and instantaneous maximum limits for CBOD5 are calculated using average monthly limit multipliers of 1.5 and 2.0, which results in average weekly and instantaneous maximum CBOD5 WQBELs of 16.0 mg/L (rounded down from 16.5 to the nearest 1.0 mg/L) and 22.0 mg/L, respectively.

DEP generally does not impose average weekly limits for ammonia-nitrogen under current policy—only CBOD5 and TSS are subject to average weekly limits. STMA reported intermittent violations of the average weekly ammonia-nitrogen limits with four violations reported in the last twelve months (March 2020 through February 2021). Even though violating an effluent limit generally does not support the elimination of that limit, removing the average weekly ammonia-nitrogen limits, which are based on waste load allocations from WQM 7.0, is consistent with Section 303(d)(4) of the Clean Water Act.<sup>1</sup> Average monthly limits for ammonia-nitrogen will control the average concentrations of ammonia-nitrogen in the STP’s effluent and those average monthly limits will be more stringent than those in the current permit. Therefore, the permit will be more protective overall even with average weekly ammonia-nitrogen limits removed. DEP notes that STMA reported average monthly violations on the same DMRs as it reported average weekly violations, so non-compliance over longer durations (represented by ‘average’ values) still will be reflected in the STP’s average monthly results.

DEP mistakenly omitted instantaneous maximum limits for ammonia-nitrogen from the previous permit. Therefore, IMAX limits for ammonia-nitrogen will be imposed in this renewal, but do not need to be reported on DMRs.

Since WQBELs are calculated for the summer period, winter limits also are evaluated. Pursuant to DEP’s Ammonia Guidance, WQBELs for the winter period are set by multiplying the summer limits by three, unless modeling indicates that more stringent WQBELs are needed for winter.

For winter period modeling, the low-flow yield (representing Q<sub>7-10</sub> flow) is doubled to 0.1286 cfs/mi<sup>2</sup> consistent with DEP’s Ammonia Guidance. Default stream and discharge temperatures of 5°C and 15°C, respectively, also are assumed based on the Ammonia Guidance. The results of the modeling (see Attachment A) indicate that winter limits for ammonia-nitrogen (10.0 mg/L and 20.0 mg/L after rounding) calculated using a summer limit multiplier of three are more stringent than the winter modeling results (13.12 mg/L and 26.24 mg/L). Therefore, WQBELs calculated for ammonia-nitrogen using the summer limit multiplier of 3 will apply from November through April. Standard secondary limits are recommended by WQM 7.0 for CBOD5 (see Table 1) during the winter period. The WQBELs are summarized in the table below (after rounding). For comparison, the existing limits also are shown.

**Table 4. WQBELs for Outfall 001 versus Existing Limits**

| Parameter                                 | Permit | Average Monthly (mg/L)            | Average Weekly (mg/L)              | Instant. Maximum (mg/L)  |
|---|--------|-----------------------------------|------------------------------------|--------------------------|
| CBOD5<br>May 1 – October 31               | Old    | 25.0                              | 40.0                               | 50.0                     |
|   | New    | <b>11.0</b> (rounded)             | 11.0 × 1.5 = <b>16.0</b> (rounded) | 11.0 × 2.0 = <b>22.0</b> |
| CBOD5<br>November 1 – April 30            | Old    | 25.0                              | 40.0                               | 50.0                     |
|   | New    | <b>25.0</b>                       | <b>40.0</b>                        | <b>50.0</b>              |
| Ammonia-Nitrogen<br>May 1 – October 31    | Old    | 4.5                               | 6.8                                | N/A                      |
|   | New    | <b>3.5</b> (rounded)              | N/A                                | <b>7.0</b> (rounded)     |
| Ammonia-Nitrogen<br>November 1 – April 30 | Old    | 13.5                              | 20.0                               | N/A                      |
|   | New    | 3.5 × 3.0 = <b>10.0</b> (rounded) | N/A                                | 10.0 × 2 = <b>20.0</b>   |

<sup>1</sup> “Nonattainment water: CWA section 303(d)(4)(A) allows the establishment of a less stringent effluent limitation when the receiving water has been identified as not meeting applicable water quality standards (i.e., a nonattainment water) if the permittee meets two conditions. First, the existing effluent limitation must have been based on a total maximum daily load (TMDL) or other wasteload allocation (WLA) established under CWA section 303. Second, relaxation of the effluent limitation is only allowed if attainment of water quality standards will be ensured or the designated use not being attained is removed in accordance with the water quality standards regulations. This subsection does not provide an exception for establishing less stringent limitations where the original limitation was based on state permitting standards (e.g., state treatment standards) and was not based on a TMDL or WLA.”

Mass Limits

Since CBOD5 limits during the summer period are more stringent than the TBELs in Table 1, mass limits for CBOD5 are recalculated. In accordance with Section IV of DEP’s “Standard Operating Procedure for Clean Water Program Establishing Effluent Limitations for Individual Sewage Permits”, only average monthly mass limits are calculated for ammonia-nitrogen (no average weekly mass limits).

Average monthly and average weekly mass limits (in units of pounds per day) are calculated using the concentration limits in Table 4 and the Wells Creek STP’s 0.80 MGD design flow based on the following formula:

$$\text{Design flow (average annual) (MGD)} \times \text{concentration limit (mg/L) at design flow} \times \text{conversion factor (8.34)} = \text{mass limit (lb/day)}$$

The calculated mass WQBELs are summarized in Table 5 (after rounding).

**Table 5. Mass WQBELs for Sanitary Wastewaters**

| Parameter                                 | Average Monthly (lb/day) | Average Weekly (lb/day) |
|---|--------------------------|-------------------------|
| CBOD5<br>May 1 – October 31               | 70.0<br>(rounded)        | 105.0<br>(rounded)      |
| Ammonia-Nitrogen<br>May 1 – October 31    | 23.0<br>(rounded)        | —                       |
| Ammonia-Nitrogen<br>November 1 – April 30 | 65.0<br>(rounded)        | —                       |

Nutrient Total Maximum Daily Load for Wells Creek

A section of Wells Creek was identified on the 1996 Section 303(d) list as being impaired by nutrients stemming from agriculture and the Wells Creek STP discharge. In December 2006, DEP finalized a nutrient TMDL for Wells Creek. The TMDL report states the following:

Pennsylvania’s 1996 303(d) list indicates that the nutrient impairment stems from agricultural practices. Field visits conducted from August to December 2006 verified this. Runoff from fertilized cropland appears to be carrying high concentrations of nutrients into the stream. In addition, Wells Creek Sewage Treatment Plant (PA0041441) is currently discharging into this impaired section. Its permitted discharge currently has no limit for nutrients, specifically for phosphorus. As a result of these two sources, periphyton (attached algae) has covered much of the available substrate within the impaired reach. According to Title 25 PA Code Chapter 96.5(c), “When it is determined that the discharge of phosphorus, alone or in combination with the discharge of other pollutants, contributes or threatens to impair existing or designated uses in a free flowing surface water, phosphorus discharges from point source discharges shall be limited to an average monthly concentration of 2 mg/l. More stringent controls on point source discharges may be imposed, or may be otherwise adjusted as a result of a TMDL which has been developed”. No other point sources of pollution, including MS4s (municipal separate storm sewer systems) and CSOs (Combined Sewer Overflows) currently exist within the watershed.

Pursuant to 40 CFR § 122.44(d)(1)(vii)(B)<sup>2</sup>, WQBELs must be consistent with available waste load allocations (WLAs) from a final TMDL. Therefore, the following phosphorus limitations will be re-imposed in STMA’s permit:

**Table 6. Phosphorus TMDL WLAs for Outfall 001**

| Effluent Characteristic | Average Monthly | Instant. Maximum |
|-------------------------|-----------------|------------------|
| Concentration (mg/L)    | 2.0             | 4.0              |
| Mass (lb/day)           | 13.4            | —                |

<sup>2</sup> “(vii) When developing water quality-based effluent limits under this paragraph the permitting authority shall ensure that: [cont’d...] (B) Effluent limits developed to protect a narrative water quality criterion, a numeric water quality criterion, or both, are consistent with the assumptions and requirements of any available wasteload allocation for the discharge prepared by the State and approved by EPA pursuant to 40 CFR 130.7.”

Instantaneous maximum limits for phosphorus are calculated using the 2.0 average monthly limit multipliers discussed previously in this fact sheet. Mass limits also are calculated for phosphorus using the formula described above. Consistent with DEP’s “Standard Operating Procedure for Clean Water Program Establishing Effluent Limitations for Individual Sewage Permits”, average weekly limits for total phosphorus are not imposed, so the 3.0 mg/L average weekly limit will be removed from the final permit. The removal of the average weekly limit is consistent with Section 303(d)(4)(A) of the Clean Water Act (regarding limits on effluent limit revisions) because the cumulative effect of the revised TMDL WQBELs for phosphorus still will ensure that water quality standards are attained.

Kiskiminetas-Conemaugh River Watershed TMDL

A TMDL for the Kiskiminetas-Conemaugh River Watershed ("Kiski-Conemaugh TMDL")—of which Wells Creek (via the Stonycreek River) is a part—was completed on January 29, 2010 for the control of acid mine drainage pollutants: aluminum, iron, manganese, sediment and pH. In accordance with 40 CFR § 122.44(d)(1)(vii)(B), when developing WQBELs, the permitting authority shall ensure that effluent limits developed to protect a narrative water quality criterion, a numeric water quality criterion, or both, are consistent with the assumptions and requirements of any available wasteload allocation (WLA) for the discharge prepared by the State and approved by EPA pursuant to 40 CFR § 130.7. The Wells Creek STP was assigned wasteload allocations (WLAs) for aluminum, iron, and manganese by the Kiski-Conemaugh TMDL (see Attachment B). Therefore, pursuant to § 122.44(d)(1)(vii)(B), WQBELs will be imposed at Outfall 001. Only aluminum, iron, and manganese WQBELs are imposed because the TMDL does not establish wasteload allocations for sediment or pH. The TMDL used a surrogate approach for both of those constituents by which reductions of in-stream concentrations of aluminum, iron, and manganese would result in acceptable reductions of sediment and mitigation of acidic pH.

The TMDL’s allocated concentrations for aluminum, iron, and manganese are equivalent to the most stringent water quality criteria for those pollutants and those criteria will be imposed as end-of-pipe limits at Outfall 001. The methods used to implement water quality criteria are described in 25 Pa. Code §§ 96.3 and 96.4. Also, DEP’s “Water Quality Toxics Management Strategy” [Doc. No. 361-2000-003] addresses design conditions in detail (Table 1 in that document), including the appropriate durations to assign to water quality criteria. The design duration for Criteria Maximum Concentration (CMC) criteria is 1 hour (acute). The design duration for Criteria Continuous Concentration (CCC) criteria is 4 days (chronic). The design duration for Threshold Human Health (THH) criteria is 30 days (chronic). The design duration for Cancer Risk Level (CRL) criteria is 70 years (chronic).

The 750 µg/L aluminum criterion in 25 Pa. Code § 93.8c is a CMC (acute) criterion. Therefore, 750 µg/L is imposed as a maximum daily limit. There is no CCC criterion for aluminum necessitating the imposition of a more stringent average monthly limit. Imposing 750 µg/L as both a maximum daily and average monthly limit is protective of water quality uses.

The 1.5 mg/L iron criterion is given as a 30-day average in 25 Pa. Code § 93.7(a). Therefore, 1.5 mg/L is imposed as an average monthly limit and the maximum daily effluent limit is calculated using a multiplier of two times the average monthly limit based on DEP’s “Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits” [Doc. No. 362-0400-001, Chapter 3, pp. 15, 16].

The 1 mg/L potable water supply criterion for manganese in 25 Pa. Code § 93.7(a) is a human health criterion (chronic). Per Table 1 of DEP’s “Water Quality Toxics Management Strategy”, the duration for a THH criterion is 30 days. Therefore, an average monthly effluent limit of 1 mg/L is imposed, and the maximum daily effluent limit is calculated using a multiplier of two times the average monthly limit consistent with the technical guidance cited above for iron.

Since the allocated concentrations are equivalent to water quality criteria, the Wells Creek STP’s compliance with concentration limits for aluminum, iron, and manganese will not result in excursions above water quality criteria and the permit will be consistent with the TMDL’s WLAs. Consequently, the TMDL’s load limits are not required. The TMDL’s wasteload allocations and the applicable WQBELs are summarized in the table below.

**Table 7. TMDL WQBELs for Outfall 001**

| Parameter        | Average Monthly (mg/L) | Maximum Daily (mg/L) |
|------------------|------------------------|----------------------|
| Aluminum, Total  | 0.75                   | 0.75                 |
| Iron, Total      | 1.5                    | 3.0                  |
| Manganese, Total | 1.0                    | 2.0                  |

STMA did not report aluminum, iron, and manganese concentrations on the NPDES permit renewal application, but DEP does not expect concentrations in the STP's effluent to be significant. Therefore, the new TMDL WQBELs will take effect on the permit effective date.

Total Residual Chlorine

To determine if WQBELs are required for discharges containing total residual chlorine (TRC), a discharge evaluation is performed using a DEP program called TRC\_CALC created with Microsoft Excel for Windows. TRC\_CALC calculates TRC Waste Load Allocations (WLAs) through the application of a mass balance model which considers TRC losses due to stream and discharge chlorine demands and first-order chlorine decay. Input values for the program include flow rates and chlorine demands for the receiving stream and the discharge, the number of samples taken per month, coefficients of TRC variability, partial mix factors, and an optional factor of safety. The mass balance model calculates WLAs for acute and chronic criteria that are then converted to long term averages using calculated multipliers. The multipliers are functions of the number of samples taken per month and the TRC variability coefficients (normally kept at default values unless site-specific information is available). The most stringent limitation between the acute and chronic long-term averages is converted to an average monthly limit for comparison to the BAT average monthly limit of 0.5 mg/L from 25 Pa. Code § 92a.48(b)(2). The more stringent of these average monthly TRC limitations is imposed in the permit.

The results of the modeling, included in Attachment C, indicate that more stringent WQBELs are necessary for TRC as summarized in the table below.

**Table 8. WQBELs for TRC at Outfall 001**

| <b>Parameter</b>        | <b>Average Monthly (mg/L)</b> | <b>Instant. Maximum (mg/L)</b> |
|-------------------------|-------------------------------|--------------------------------|
| Total Residual Chlorine | 0.114                         | 0.374                          |

Water quality criteria for chlorine have not changed. However, pursuant to DEP's "Standard Operating Procedure for Clean Water Program Establishing Effluent Limitations for Individual Sewage Permits", the in-stream and discharge chlorine demands used for modeling are 0.3 mg/L and 0 mg/L in the absence of site-specific data (compared to 0.8 mg/L and 0 mg/L used to develop the previous TRC limits). The  $Q_{7-10}$  of Wells Creek is also slightly lower (0.894 cfs versus 0.915 cfs).

Discharge Monitoring Report data for TRC indicate that STMA will be unable to comply with the new limits—the average of the average monthly and instantaneous maximum TRC concentrations over the last two years are 0.184 mg/L and 0.436 mg/L. Therefore, a two-year schedule of compliance will be imposed pursuant to 25 Pa. Code § 92a.51(a). The existing TRC limits of 0.30 mg/L average monthly and 0.90 mg/L instantaneous maximum will be in effect for the interim two-year period.

In accordance with 25 Pa. Code §§ 92a.12 and 92a.61, effluent limits applicable at Outfall 001 are the more stringent of TBELs, WQBELs, regulatory effluent standards, and monitoring requirements as summarized in the tables on the following pages.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through two years after the Permit Effective Date.**

| Parameter                                     | Effluent Limitations                |                  |                       |                  |                   |                  | Monitoring Requirements                      |                      |
|---|-------------------------------------|------------------|-----------------------|------------------|-------------------|------------------|--|----------------------|
|   | Mass Units (lbs/day) <sup>(1)</sup> |                  | Concentrations (mg/L) |                  |                   |                  | Minimum <sup>(2)</sup> Measurement Frequency | Required Sample Type |
|   | Average Monthly                     | Weekly Average   | Instant. Minimum      | Average Monthly  | Weekly Average    | Instant. Maximum |  |                      |
| Flow (MGD)                                    | 0.80                                | Report Daily Max | XXX                   | XXX              | XXX               | XXX              | Continuous                                   | Recorded             |
| pH (S.U.)                                     | XXX                                 | XXX              | 6.0                   | XXX              | XXX               | 9.0              | 1/day  | Grab                 |
| DO  | XXX                                 | XXX              | 5.0                   | XXX              | XXX               | XXX              | 1/day  | Grab                 |
| TRC   | XXX                                 | XXX              | XXX                   | 0.30             | XXX               | 0.90             | 1/day  | Grab                 |
| CBOD5<br>Nov 1 - Apr 30                       | 165.0                               | 265.0            | XXX                   | 25.0             | 40.0              | 50.0             | 1/week                                       | 8-Hr Composite       |
| CBOD5<br>May 1 - Oct 30                       | 70.0                                | 105.0            | XXX                   | 11.0             | 16.0              | 22.0             | 1/week                                       | 8-Hr Composite       |
| TSS   | 200.0                               | 300.0            | XXX                   | 30.0             | 45.0              | 60.0             | 1/week                                       | 8-Hr Composite       |
| Fecal Coliform (No./100 ml)<br>Oct 1 - Apr 30 | XXX                                 | XXX              | XXX                   | 2000<br>Geo Mean | XXX               | 10000            | 1/week                                       | Grab                 |
| Fecal Coliform (No./100 ml)<br>May 1 - Sep 30 | XXX                                 | XXX              | XXX                   | 200<br>Geo Mean  | XXX               | 1000             | 1/week                                       | Grab                 |
| E.Coli<br>(No./100 ml)                        | XXX                                 | XXX              | XXX                   | XXX              | XXX               | Report           | 1/quarter                                    | Grab                 |
| Ammonia-Nitrogen<br>May 1 - Oct 31            | 23.0                                | XXX              | XXX                   | 3.5              | XXX               | 7.0              | 1/week                                       | 8-Hr Composite       |
| Ammonia-Nitrogen<br>Nov 1 - Apr 30            | 65.0                                | XXX              | XXX                   | 10.0             | XXX               | 20.0             | 1/week                                       | 8-Hr Composite       |
| Total Phosphorus                              | 13.4                                | XXX              | XXX                   | 2.0              | XXX               | 4.0              | 1/week                                       | 8-Hr Composite       |
| Total Nitrogen                                | XXX                                 | XXX              | XXX                   | XXX              | Report Daily Max  | XXX              | 1/year                                       | Grab                 |
| Aluminum, Total                               | XXX                                 | XXX              | XXX                   | 0.75             | 0.75<br>Daily Max | XXX              | 1/week                                       | 24-Hr Composite      |



**Outfall 001 (continued), Effective Period: Permit Effective Date through two years after the Permit Effective Date.**

| Parameter        | Effluent Limitations                |                   |                       |                    |                   |                     | Monitoring Requirements                            |                            |
|------------------|-------------------------------------|-------------------|-----------------------|--------------------|-------------------|---------------------|--|----------------------------|
|                  | Mass Units (lbs/day) <sup>(1)</sup> |                   | Concentrations (mg/L) |                    |                   |                     | Minimum <sup>(2)</sup><br>Measurement<br>Frequency | Required<br>Sample<br>Type |
|                  | Average<br>Monthly                  | Weekly<br>Average | Instant.<br>Minimum   | Average<br>Monthly | Weekly<br>Average | Instant.<br>Maximum |  |                            |
| Iron, Total      | XXX                                 | XXX               | XXX                   | 1.5                | 3.0<br>Daily Max  | XXX                 | 1/week   | 24-Hr<br>Composite         |
| Manganese, Total | XXX                                 | XXX               | XXX                   | 1.0                | 2.0<br>Daily Max  | XXX                 | 1/week   | 24-Hr<br>Composite         |

Requirements shown in red in the table above are more stringent than the previous permit. Requirements shown in green are less stringent than the previous permit.

Compliance Sampling Location: Outfall 001

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: two years after the Permit Effective Date through Permit Expiration Date.**

| Parameter                                     | Effluent Limitations                |                  |                       |                  |                   |                  | Monitoring Requirements                      |                      |
|---|-------------------------------------|------------------|-----------------------|------------------|-------------------|------------------|--|----------------------|
|   | Mass Units (lbs/day) <sup>(1)</sup> |                  | Concentrations (mg/L) |                  |                   |                  | Minimum <sup>(2)</sup> Measurement Frequency | Required Sample Type |
|   | Average Monthly                     | Weekly Average   | Instant. Minimum      | Average Monthly  | Weekly Average    | Instant. Maximum |  |                      |
| Flow (MGD)                                    | 0.80                                | Report Daily Max | XXX                   | XXX              | XXX               | XXX              | Continuous                                   | Recorded             |
| pH (S.U.)                                     | XXX                                 | XXX              | 6.0                   | XXX              | XXX               | 9.0              | 1/day  | Grab                 |
| DO  | XXX                                 | XXX              | 5.0                   | XXX              | XXX               | XXX              | 1/day  | Grab                 |
| TRC   | XXX                                 | XXX              | XXX                   | 0.114            | XXX               | 0.374            | 1/day  | Grab                 |
| CBOD5<br>Nov 1 - Apr 30                       | 165.0                               | 265.0            | XXX                   | 25.0             | 40.0              | 50.0             | 1/week                                       | 8-Hr Composite       |
| CBOD5<br>May 1 - Oct 30                       | 70.0                                | 105.0            | XXX                   | 11.0             | 16.0              | 22.0             | 1/week                                       | 8-Hr Composite       |
| TSS   | 200.0                               | 300.0            | XXX                   | 30.0             | 45.0              | 60.0             | 1/week                                       | 8-Hr Composite       |
| Fecal Coliform (No./100 ml)<br>Oct 1 - Apr 30 | XXX                                 | XXX              | XXX                   | 2000<br>Geo Mean | XXX               | 10000            | 1/week                                       | Grab                 |
| Fecal Coliform (No./100 ml)<br>May 1 - Sep 30 | XXX                                 | XXX              | XXX                   | 200<br>Geo Mean  | XXX               | 1000             | 1/week                                       | Grab                 |
| E.Coli<br>(No./100 ml)                        | XXX                                 | XXX              | XXX                   | XXX              | XXX               | Report           | 1/quarter                                    | Grab                 |
| Ammonia-Nitrogen<br>May 1 - Oct 31            | 23.0                                | XXX              | XXX                   | 3.5              | XXX               | 7.0              | 1/week                                       | 8-Hr Composite       |
| Ammonia-Nitrogen<br>Nov 1 - Apr 30            | 65.0                                | XXX              | XXX                   | 10.0             | XXX               | 20.0             | 1/week                                       | 8-Hr Composite       |
| Total Phosphorus                              | 13.4                                | XXX              | XXX                   | 2.0              | XXX               | 4.0              | 1/week                                       | 8-Hr Composite       |
| Total Nitrogen                                | XXX                                 | XXX              | XXX                   | XXX              | Report Daily Max  | XXX              | 1/year                                       | Grab                 |
| Aluminum, Total                               | XXX                                 | XXX              | XXX                   | 0.75             | 0.75<br>Daily Max | XXX              | 1/week                                       | 24-Hr Composite      |

**Outfall 001, Effective Period: two years after the Permit Effective Date through Permit Expiration Date.**

| Parameter        | Effluent Limitations                |                   |                       |                    |                   |                     | Monitoring Requirements                            |                            |
|------------------|-------------------------------------|-------------------|-----------------------|--------------------|-------------------|---------------------|--|----------------------------|
|                  | Mass Units (lbs/day) <sup>(1)</sup> |                   | Concentrations (mg/L) |                    |                   |                     | Minimum <sup>(2)</sup><br>Measurement<br>Frequency | Required<br>Sample<br>Type |
|                  | Average<br>Monthly                  | Weekly<br>Average | Instant.<br>Minimum   | Average<br>Monthly | Weekly<br>Average | Instant.<br>Maximum |  |                            |
| Iron, Total      | XXX                                 | XXX               | XXX                   | 1.5                | 3.0<br>Daily Max  | XXX                 | 1/week   | 24-Hr<br>Composite         |
| Manganese, Total | XXX                                 | XXX               | XXX                   | 1.0                | 2.0<br>Daily Max  | XXX                 | 1/week   | 24-Hr<br>Composite         |

Requirements shown in red in the table above are more stringent than the previous permit. Requirements shown in green are less stringent than the previous permit.

Compliance Sampling Location: Outfall 001

| Tools and References Used to Develop Permit |  |
|---|--|
| <input checked="" type="checkbox"/>         | WQM for Windows Model (see Attachment A)   |
| <input type="checkbox"/>                    | Toxics Management Spreadsheet (see Attachment <span style="background-color: yellow;">      </span> )  |
| <input checked="" type="checkbox"/>         | TRC Model Spreadsheet (see Attachment C)   |
| <input type="checkbox"/>                    | Temperature Model Spreadsheet (see Attachment <span style="background-color: yellow;">      </span> )  |
| <input type="checkbox"/>                    | Water Quality Toxics Management Strategy, 361-0100-003, 4/06.  |
| <input checked="" type="checkbox"/>         | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.   |
| <input type="checkbox"/>                    | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.  |
| <input type="checkbox"/>                    | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.  |
| <input type="checkbox"/>                    | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.   |
| <input type="checkbox"/>                    | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.  |
| <input type="checkbox"/>                    | Pennsylvania CSO Policy, 385-2000-011, 9/08.   |
| <input type="checkbox"/>                    | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.  |
| <input type="checkbox"/>                    | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.   |
| <input type="checkbox"/>                    | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.  |
| <input type="checkbox"/>                    | Implementation Guidance Design Conditions, 391-2000-006, 9/97.   |
| <input type="checkbox"/>                    | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.  |
| <input type="checkbox"/>                    | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.   |
| <input type="checkbox"/>                    | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.   |
| <input type="checkbox"/>                    | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.  |
| <input checked="" type="checkbox"/>         | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.  |
| <input type="checkbox"/>                    | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.   |
| <input type="checkbox"/>                    | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.   |
| <input type="checkbox"/>                    | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.  |
| <input type="checkbox"/>                    | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.   |
| <input type="checkbox"/>                    | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.       |
| <input type="checkbox"/>                    | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.   |
| <input type="checkbox"/>                    | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input type="checkbox"/>                    | Design Stream Flows, 391-2000-023, 9/98.   |
| <input type="checkbox"/>                    | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.                                     |
| <input type="checkbox"/>                    | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.   |
| <input type="checkbox"/>                    | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.   |
| <input checked="" type="checkbox"/>         | SOP: Standard Operating Procedure for Clean Water Program Establishing Effluent Limitations for Individual Sewage Permits  |
| <input type="checkbox"/>                    | Other: <span style="background-color: yellow;">      </span>   |

ATTACHMENT A  
WQM 7.0 Modeling Results

Summer Analysis

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI   | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC                            |
|-----------|-------------|-------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 18E       | 45675       | WELLS CREEK | 2.570 | 2009.00        | 13.90                 | 0.00220       | 0.00                 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY    | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
|              | (cfsm) | (cfs)     | (cfs)       | (days)        | (fps)        |          | (ft)      | (ft)      | (°C)           |              | (°C)        |           |
| Q7-10        | 0.064  | 0.00      | 0.00        | 0.000         | 0.000        | 0.0      | 0.00      | 0.00      | 20.00          | 6.50         | 0.00        | 0.00      |
| Q1-10        |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |                |              |             |           |
| Q30-10       |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |                |              |             |           |

Discharge Data

| Name        | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Outfall 001 | PA0041441     | 0.8000                   | 0.0000                    | 0.0000                 | 0.000          | 20.00          | 7.00    |

Parameter Data

| Parameter Name   | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5            | 25.00            | 2.00             | 0.00               | 1.50               |
| Dissolved Oxygen | 5.00             | 9.17             | 0.00               | 0.00               |
| NH3-N            | 4.50             | 0.00             | 0.00               | 0.70               |

Summer Analysis

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI   | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC                            |
|-----------|-------------|-------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 18E       | 45675       | WELLS CREEK | 0.270 | 1927.00        | 17.00                 | 0.00220       | 0.00                 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfs) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary |      | Stream    |      |
|--------------|-----------|-----------------|-------------------|----------------------|--------------------|----------|----------------|----------------|-----------|------|-----------|------|
|              |           |                 |                   |                      |                    |          |                |                | Temp (°C) | pH   | Temp (°C) | pH   |
| Q7-10        | 0.064     | 0.00            | 0.00              | 0.000                | 0.000              | 0.0      | 0.00           | 0.00           | 20.00     | 6.50 | 0.00      | 0.00 |
| Q1-10        |           | 0.00            | 0.00              | 0.000                | 0.000              |          |                |                |           |      |           |      |
| Q30-10       |           | 0.00            | 0.00              | 0.000                | 0.000              |          |                |                |           |      |           |      |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
|      |               | 0.0000                   | 0.0000                    | 0.0000                 | 0.000          | 25.00          | 7.00    |

Parameter Data

| Parameter Name   | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5            | 25.00            | 2.00             | 0.00               | 1.50               |
| Dissolved Oxygen | 3.00             | 8.24             | 0.00               | 0.00               |
| NH3-N            | 25.00            | 0.00             | 0.00               | 0.70               |

Summer Analysis

**WQM 7.0 Modeling Specifications**

|                    |        |                                     |                                     |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters         | Both   | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method         | EMPR   | Use Inputted W/D Ratio              | <input type="checkbox"/>            |
| Q1-10/Q7-10 Ratio  | 0.64   | Use Inputted Reach Travel Times     | <input type="checkbox"/>            |
| Q30-10/Q7-10 Ratio | 1.36   | Temperature Adjust Kr               | <input checked="" type="checkbox"/> |
| D.O. Saturation    | 90.00% | Use Balanced Technology             | <input checked="" type="checkbox"/> |
| D.O. Goal          | 6      |                                     |                                     |



Summer Analysis

**WQM 7.0 Hydrodynamic Outputs**

| <u>SWP Basin</u>   |                      | <u>Stream Code</u> |                          |                             |                        | <u>Stream Name</u> |               |           |                   |                           |                       |             |
|--------------------|----------------------|--------------------|--------------------------|-----------------------------|------------------------|--------------------|---------------|-----------|-------------------|---------------------------|-----------------------|-------------|
| 18E                |                      | 45675              |                          |                             |                        | WELLS CREEK        |               |           |                   |                           |                       |             |
| RMI                | Stream Flow<br>(cfs) | PWS With<br>(cfs)  | Net Stream Flow<br>(cfs) | Disc Analysis Flow<br>(cfs) | Reach Slope<br>(ft/ft) | Depth<br>(ft)      | Width<br>(ft) | W/D Ratio | Velocity<br>(fps) | Reach Trav Time<br>(days) | Analysis Temp<br>(°C) | Analysis pH |
| <b>Q7-10 Flow</b>  |                      |                    |                          |                             |                        |                    |               |           |                   |                           |                       |             |
| 2.570              | 0.89                 | 0.00               | 0.89                     | 1.2376                      | 0.00220                | .586               | 21.64         | 36.93     | 0.17              | 0.836                     | 20.00                 | 6.72        |
| <b>Q1-10 Flow</b>  |                      |                    |                          |                             |                        |                    |               |           |                   |                           |                       |             |
| 2.570              | 0.57                 | 0.00               | 0.57                     | 1.2376                      | 0.00220                | NA                 | NA            | NA        | 0.15              | 0.917                     | 20.00                 | 6.77        |
| <b>Q30-10 Flow</b> |                      |                    |                          |                             |                        |                    |               |           |                   |                           |                       |             |
| 2.570              | 1.22                 | 0.00               | 1.22                     | 1.2376                      | 0.00220                | NA                 | NA            | NA        | 0.18              | 0.773                     | 20.00                 | 6.68        |

Summer Analysis

**WQM 7.0 Wasteload Allocations**

|                  |                    |                    |
|------------------|--------------------|--------------------|
| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
| 18E              | 45675              | WELLS CREEK        |

**NH3-N Acute Allocations**

| RMI | Discharge Name    | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-----|-------------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
|     | 2.570 Outfall 001 | 19.83                     | 9                   | 19.83                     | 9                   | 0              | 0                 |

**NH3-N Chronic Allocations**

| RMI | Discharge Name    | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-----|-------------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
|     | 2.570 Outfall 001 | 2.06                      | 4.09                | 2.06                      | 4.09                | 0              | 0                 |

**Dissolved Oxygen Allocations**

| RMI | Discharge Name   | <u>CBOD5</u>    |                 | <u>NH3-N</u>    |                 | <u>Dissolved Oxygen</u> |                 | Critical Reach | Percent Reduction |
|-----|------------------|-----------------|-----------------|-----------------|-----------------|-------------------------|-----------------|----------------|-------------------|
|     |                  | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L)         | Multiple (mg/L) |                |                   |
|     | 2.57 Outfall 001 | 11.72           | 11.72           | 3.52            | 3.52            | 5                       | 5               | 0              | 0                 |

Summer Analysis

**WQM 7.0 D.O.Simulation**

| <u>SWP Basin</u>                | <u>Stream Code</u>                | <u>Stream Name</u>               |                             |                             |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|-----------------------------|
| 18E                             | 45675                             | WELLS CREEK                      |                             |                             |
| <u>RMI</u>                      | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> |                             | <u>Analysis pH</u>          |
| 2.570                           | 0.800                             | 20.000                           |                             | 6.720                       |
| <u>Reach Width (ft)</u>         | <u>Reach Depth (ft)</u>           | <u>Reach WDRatio</u>             |                             | <u>Reach Velocity (fps)</u> |
| 21.643                          | 0.586                             | 36.929                           |                             | 0.168                       |
| <u>Reach CBOD5 (mg/L)</u>       | <u>Reach Kc (1/days)</u>          | <u>Reach NH3-N (mg/L)</u>        |                             | <u>Reach Kn (1/days)</u>    |
| 7.64                            | 0.603                             | 2.04                             |                             | 0.700                       |
| <u>Reach DO (mg/L)</u>          | <u>Reach Kr (1/days)</u>          | <u>Kr Equation</u>               | <u>Reach DO Goal (mg/L)</u> |                             |
| 6.749                           | 3.513                             | Tsivoglou                        | 6                           |                             |
| <u>Reach Travel Time (days)</u> | <b>Subreach Results</b>           |                                  |                             |                             |
| 0.836                           | <u>TravTime (days)</u>            | <u>CBOD5 (mg/L)</u>              | <u>NH3-N (mg/L)</u>         | <u>D.O. (mg/L)</u>          |
|                                 | 0.084                             | 7.27                             | 1.93                        | 6.42                        |
|                                 | 0.167                             | 6.91                             | 1.82                        | 6.22                        |
|                                 | 0.251                             | 6.57                             | 1.71                        | 6.12                        |
|                                 | 0.335                             | 6.25                             | 1.62                        | 6.09                        |
|                                 | 0.418                             | 5.94                             | 1.52                        | 6.11                        |
|                                 | 0.502                             | 5.65                             | 1.44                        | 6.16                        |
|                                 | 0.586                             | 5.37                             | 1.36                        | 6.24                        |
|                                 | 0.669                             | 5.11                             | 1.28                        | 6.34                        |
|                                 | 0.753                             | 4.86                             | 1.21                        | 6.44                        |
|                                 | 0.836                             | 4.62                             | 1.14                        | 6.55                        |

Summer Analysis

**WQM 7.0 Effluent Limits**

| <u>SWP Basin</u> |             | <u>Stream Code</u> |                 | <u>Stream Name</u> |                                |                            |                            |
|------------------|-------------|--------------------|-----------------|--------------------|--------------------------------|----------------------------|----------------------------|
| 18E              |             | 45675              |                 | WELLS CREEK        |                                |                            |                            |
| RMI              | Name        | Permit Number      | Disc Flow (mgd) | Parameter          | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 2.570            | Outfall 001 | PA0041441          | 0.800           | CBOD5              | 11.72                          |                            |                            |
|                  |             |                    |                 | NH3-N              | 3.52                           | 7.04                       |                            |
|                  |             |                    |                 | Dissolved Oxygen   |                                |                            | 5                          |

Winter Analysis

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI   | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC                            |
|-----------|-------------|-------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 18E       | 45675       | WELLS CREEK | 2.570 | 2009.00        | 13.90                 | 0.00220       | 0.00                 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY    | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary |      | Stream    |      |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|-----------|------|-----------|------|
|              | (cfsm) | (cfs)     | (cfs)       | (days)        | (fps)        |          | (ft)      | (ft)      | Temp (°C) | pH   | Temp (°C) | pH   |
| Q7-10        | 0.129  | 0.00      | 0.00        | 0.000         | 0.000        | 0.0      | 0.00      | 0.00      | 5.00      | 6.50 | 0.00      | 0.00 |
| Q1-10        |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |           |      |           |      |
| Q30-10       |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |           |      |           |      |

Discharge Data

| Name        | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Outfall 001 | PA0041441     | 0.8000                   | 0.0000                    | 0.0000                 | 0.000          | 15.00          | 7.00    |

Parameter Data

| Parameter Name   | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5            | 25.00            | 2.00             | 0.00               | 1.50               |
| Dissolved Oxygen | 5.00             | 12.80            | 0.00               | 0.00               |
| NH3-N            | 13.50            | 0.00             | 0.00               | 0.70               |

Winter Analysis

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI   | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC                            |
|-----------|-------------|-------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 18E       | 45675       | WELLS CREEK | 0.270 | 1927.00        | 17.00                 | 0.00220       | 0.00                 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY    | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
|              | (cfsm) | (cfs)     | (cfs)       | (days)        | (fps)        |          | (ft)      | (ft)      | (°C)           |              | (°C)        |           |
| Q7-10        | 0.129  | 0.00      | 0.00        | 0.000         | 0.000        | 0.0      | 0.00      | 0.00      | 5.00           | 6.50         | 0.00        | 0.00      |
| Q1-10        |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |                |              |             |           |
| Q30-10       |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |                |              |             |           |

| Discharge Data   |                  |                          |                           |                        |                |                |         |
|------------------|------------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Name             | Permit Number    | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|                  |                  | 0.0000                   | 0.0000                    | 0.0000                 | 0.000          | 25.00          | 7.00    |
| Parameter Data   |                  |                          |                           |                        |                |                |         |
| Parameter Name   | Disc Conc (mg/L) | Trib Conc (mg/L)         | Stream Conc (mg/L)        | Fate Coef (1/days)     |                |                |         |
| CBOD5            | 25.00            | 2.00                     | 0.00                      | 1.50                   |                |                |         |
| Dissolved Oxygen | 3.00             | 8.24                     | 0.00                      | 0.00                   |                |                |         |
| NH3-N            | 25.00            | 0.00                     | 0.00                      | 0.70                   |                |                |         |

Winter Analysis

**WQM 7.0 Modeling Specifications**

|                    |        |                                     |                                     |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters         | Both   | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method         | EMPR   | Use Inputted W/D Ratio              | <input type="checkbox"/>            |
| Q1-10/Q7-10 Ratio  | 0.64   | Use Inputted Reach Travel Times     | <input type="checkbox"/>            |
| Q30-10/Q7-10 Ratio | 1.36   | Temperature Adjust Kr               | <input checked="" type="checkbox"/> |
| D.O. Saturation    | 90.00% | Use Balanced Technology             | <input checked="" type="checkbox"/> |
| D.O. Goal          | 6      |                                     |                                     |

Winter Analysis

**WQM 7.0 Hydrodynamic Outputs**

| <u>SWP Basin</u>   |                      | <u>Stream Code</u> |                          |                             |                        | <u>Stream Name</u> |               |           |                   |                           |                       |             |
|--------------------|----------------------|--------------------|--------------------------|-----------------------------|------------------------|--------------------|---------------|-----------|-------------------|---------------------------|-----------------------|-------------|
| 18E                |                      | 45675              |                          |                             |                        | WELLS CREEK        |               |           |                   |                           |                       |             |
| RMI                | Stream Flow<br>(cfs) | PWS With<br>(cfs)  | Net Stream Flow<br>(cfs) | Disc Analysis Flow<br>(cfs) | Reach Slope<br>(ft/ft) | Depth<br>(ft)      | Width<br>(ft) | W/D Ratio | Velocity<br>(fps) | Reach Trav Time<br>(days) | Analysis Temp<br>(°C) | Analysis pH |
| <b>Q7-10 Flow</b>  |                      |                    |                          |                             |                        |                    |               |           |                   |                           |                       |             |
| 2.570              | 1.79                 | 0.00               | 1.79                     | 1.2376                      | 0.00220                | .613               | 24.14         | 39.4      | 0.20              | 0.687                     | 9.09                  | 6.64        |
| <b>Q1-10 Flow</b>  |                      |                    |                          |                             |                        |                    |               |           |                   |                           |                       |             |
| 2.570              | 1.14                 | 0.00               | 1.14                     | 1.2376                      | 0.00220                | NA                 | NA            | NA        | 0.18              | 0.786                     | 10.20                 | 6.69        |
| <b>Q30-10 Flow</b> |                      |                    |                          |                             |                        |                    |               |           |                   |                           |                       |             |
| 2.570              | 2.43                 | 0.00               | 2.43                     | 1.2376                      | 0.00220                | NA                 | NA            | NA        | 0.23              | 0.617                     | 8.37                  | 6.61        |



Winter Analysis

**WQM 7.0 Wasteload Allocations**

|                  |                    |                    |
|------------------|--------------------|--------------------|
| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
| 18E              | 45675              | WELLS CREEK        |

**NH3-N Acute Allocations**

| RMI   | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 2.570 | Outfall 001    | 29.91                     | 27                  | 29.91                     | 27                  | 0              | 0                 |

**NH3-N Chronic Allocations**

| RMI   | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 2.570 | Outfall 001    | 4.43                      | 13.12               | 4.43                      | 13.12               | 0              | 0                 |

**Dissolved Oxygen Allocations**

| RMI  | Discharge Name | <u>CBOD5</u>    |                 | <u>NH3-N</u>    |                 | <u>Dissolved Oxygen</u> |                 | Critical Reach | Percent Reduction |
|------|----------------|-----------------|-----------------|-----------------|-----------------|-------------------------|-----------------|----------------|-------------------|
|      |                | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L)         | Multiple (mg/L) |                |                   |
| 2.57 | Outfall 001    | 25              | 25              | 13.12           | 13.12           | 5                       | 5               | 0              | 0                 |

Winter Analysis

**WQM 7.0 D.O.Simulation**

| <u>SWP Basin</u>                | <u>Stream Code</u>                | <u>Stream Name</u>               |                             |                    |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|--------------------|
| 18E                             | 45675                             | WELLS CREEK                      |                             |                    |
| <u>RMI</u>                      | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u>          |                    |
| 2.570                           | 0.800                             | 9.091                            | 6.643                       |                    |
| <u>Reach Width (ft)</u>         | <u>Reach Depth (ft)</u>           | <u>Reach WDRatio</u>             | <u>Reach Velocity (fps)</u> |                    |
| 24.144                          | 0.613                             | 39.395                           | 0.204                       |                    |
| <u>Reach CBOD5 (mg/L)</u>       | <u>Reach Kc (1/days)</u>          | <u>Reach NH3-N (mg/L)</u>        | <u>Reach Kn (1/days)</u>    |                    |
| 11.41                           | 1.293                             | 5.37                             | 0.302                       |                    |
| <u>Reach DO (mg/L)</u>          | <u>Reach Kr (1/days)</u>          | <u>Kr Equation</u>               | <u>Reach DO Goal (mg/L)</u> |                    |
| 9.609                           | 3.299                             | Tsivoglou                        | 6                           |                    |
| <u>Reach Travel Time (days)</u> | <b>Subreach Results</b>           |                                  |                             |                    |
| 0.687                           | <u>TravTime (days)</u>            | <u>CBOD5 (mg/L)</u>              | <u>NH3-N (mg/L)</u>         | <u>D.O. (mg/L)</u> |
|                                 | 0.069                             | 10.81                            | 5.26                        | 8.74               |
|                                 | 0.137                             | 10.24                            | 5.15                        | 8.10               |
|                                 | 0.206                             | 9.71                             | 5.04                        | 7.64               |
|                                 | 0.275                             | 9.20                             | 4.94                        | 7.32               |
|                                 | 0.344                             | 8.72                             | 4.84                        | 7.10               |
|                                 | 0.412                             | 8.26                             | 4.74                        | 6.98               |
|                                 | 0.481                             | 7.82                             | 4.64                        | 6.92               |
|                                 | 0.550                             | 7.41                             | 4.54                        | 6.91               |
|                                 | 0.619                             | 7.03                             | 4.45                        | 6.94               |
|                                 | 0.687                             | 6.66                             | 4.36                        | 7.00               |

Winter Analysis

**WQM 7.0 Effluent Limits**

| <u>SWP Basin</u> |             | <u>Stream Code</u> |                 | <u>Stream Name</u> |                                |                            |                            |
|------------------|-------------|--------------------|-----------------|--------------------|--------------------------------|----------------------------|----------------------------|
| 18E              |             | 45675              |                 | WELLS CREEK        |                                |                            |                            |
| RMI              | Name        | Permit Number      | Disc Flow (mgd) | Parameter          | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 2.570            | Outfall 001 | PA0041441          | 0.800           | CBOD5              | 25                             |                            |                            |
|                  |             |                    |                 | NH3-N              | 13.12                          | 26.24                      |                            |
|                  |             |                    |                 | Dissolved Oxygen   |                                |                            | 5                          |

## ATTACHMENT B

### TMDL Waste Load Allocations

### Kiskiminetas River Watershed Minor Non-Mining Wasteload Allocations

| Region | SWS  | PERMIT    | PIPE | Metal     | Baseline Load (lbs/yr) | Baseline Concentration (mg/L) | Allocated Load (lbs/yr) | Allocated Concentration (mg/L) | % Reduction | Comments |
|--------|------|-----------|------|-----------|------------------------|-------------------------------|-------------------------|--------------------------------|-------------|----------|
| 6      | 4223 | PA0041441 | 1    | Aluminum  | 1,828                  | 0.75                          | 1,828                   | 0.75                           | 0           |          |
| 6      | 4223 | PA0041441 | 1    | Iron      | 3,656                  | 1.50                          | 3,656                   | 1.50                           | 0           |          |
| 6      | 4223 | PA0041441 | 1    | Manganese | 2,437                  | 1.00                          | 2,437                   | 1.00                           | 0           |          |

# ATTACHMENT C

## TRC Modeling Results

TRC EVALUATION – Outfall 001

|       |                                |     |                                      |
|-------|--------------------------------|-----|--------------------------------------|
| 0.894 | = Q stream (cfs)               | 0.5 | = CV Daily                           |
| 0.8   | = Q discharge (MGD)            | 0.5 | = CV Hourly                          |
| 30    | = no. samples                  | 1   | = AFC_Partial Mix Factor             |
| 0.3   | = Chlorine Demand of Stream    | 1   | = CFC_Partial Mix Factor             |
| 0     | = Chlorine Demand of Discharge | 15  | = AFC_Criteria Compliance Time (min) |
| 0.5   | = BAT/BPJ Value                | 720 | = CFC_Criteria Compliance Time (min) |
|       | = % Factor of Safety (FOS)     |     | =Decay Coefficient (K)               |

  

| Source       | Reference | AFC Calculations    | Reference | CFC Calculations    |
|--------------|-----------|---------------------|-----------|---------------------|
| TRC          | 1.3.2.iii | WLA_afc = 0.249     | 1.3.2.iii | WLA_cfc = 0.236     |
| PENTOXSD TRG | 5.1a      | LTAMULT_afc = 0.373 | 5.1c      | LTAMULT_cfc = 0.581 |
| PENTOXSD TRG | 5.1b      | LTA_afc= 0.093      | 5.1d      | LTA_cfc = 0.137     |

  

| Source       | Reference | Effluent Limit Calculations   |     |
|--------------|-----------|-------------------------------|-----|
| PENTOXSD TRG | 5.1f      | AML_MULT = 1.231              |     |
| PENTOXSD TRG | 5.1g      | AVG MON LIMIT (mg/l) = 0.114  | AFC |
|              |           | INST MAX LIMIT (mg/l) = 0.374 |     |

  

|                |   |
|----------------|---|
| WLA_afc        | $(.019/e(-k*AFC\_tc)) + [(AFC\_Yc*Qs*.019/Qd*e(-k*AFC\_tc)) + Xd + (AFC\_Yc*Qs*Xs/Qd)]*(1-FOS/100)$                   |
| LTAMULT_afc    | $EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$  |
| LTA_afc        | $wla\_afc*LTAMULT\_afc$   |
| <b>WLA_cfc</b> | <b><math>(.011/e(-k*CFC\_tc)) + [(CFC\_Yc*Qs*.011/Qd*e(-k*CFC\_tc)) + Xd + (CFC\_Yc*Qs*Xs/Qd)]*(1-FOS/100)</math></b> |
| LTAMULT_cfc    | $EXP((0.5*LN(cvd^2/no\_samples+1))-2.326*LN(cvd^2/no\_samples+1)^0.5)$  |
| <b>LTA_cfc</b> | <b><math>wla\_cfc*LTAMULT\_cfc</math></b>   |
| AML_MULT       | $EXP(2.326*LN((cvd^2/no\_samples+1)^0.5)-0.5*LN(cvd^2/no\_samples+1))$  |
| AVG MON LIMIT  | $MIN(BAT\_BPJ,MIN(LTA\_afc,LTA\_cfc)*AML\_MULT)$  |
| INST MAX LIMIT | <b><math>1.5*((av\_mon\_limit/AML\_MULT)/LTAMULT\_afc)</math></b>   |