

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. **PA0042561**  
APS ID **1068764**  
Authorization ID **1405456**

**Applicant and Facility Information**

Applicant Name	<b>Upper Stonycreek Joint Municipal Authority</b>	Facility Name	<b>Upper Stonycreek STP</b>
Applicant Address	PO Box 24	Facility Address	Myers Street
	Hooversville, PA 15936-0024		Hooversville, PA 15936
Applicant Contact	John Toth	Facility Contact	
Applicant Phone	(814) 242-8588	Facility Phone	
Client ID	67100	Site ID	249484
Ch 94 Load Status		Municipality	Shade Township
Connection Status		County	Somerset
Date Application Received	<u>August 4, 2022</u>	EPA Waived?	Yes
Date Application Accepted	<u>August 5, 2022</u>	If No, Reason	
Purpose of Application	<u>Renewal application to discharge treated sewage</u>		

**Summary of Review**

This review is in response to a renewal application received on August 4, 2022. Additional information was received on July 1, 2024. Upper Stonycreek Joint Municipal Authority owns a sewage treatment plant in Shade Township, Somerset County. Sewage from Stoystown Borough, Hooversville Borough, Shade Township and Quemahoning Township is collected and treated with grit removal, comminution, aerated lagoons, ammonia bio-tower, bio-tower clarifier, and chlorine disinfection before discharging to the Stonycreek River through outfall 001.

Sludge use and disposal description and location(s): The plant does not dewater any sludge. The plant does not landfill any sludge. The plant has never removed sludge since 2003 and has no plans to remove sludge in the future.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>James Vanek</i> James Vanek, P.E. / Environmental Engineer	August 8, 2024
X		<i>Mahbuba Iasmin</i> Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineering Manager	August 12, 2024

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.656
Latitude	40° 9' 29.49"	Longitude	-78° 55' 6.07"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Stonycreek River (TSF)	Stream Code	45084
NHD Com ID	123719559	RMI	22.0
Drainage Area	136 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.035
Q <sub>7-10</sub> Flow (cfs)	4.76	Q <sub>7-10</sub> Basis	Previous fact sheet
Elevation (ft)	1640	Slope (ft/ft)	0.035
Watershed No.	18-E	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use	none	Exceptions to Criteria	none
Assessment Status	Impaired		
Cause(s) of Impairment	METALS, TOTAL DISSOLVED SOLIDS (TDS)		
Source(s) of Impairment	ACID MINE DRAINAGE		
TMDL Status	Final	Name	Kiskiminetas-Conemaugh River Watersheds TMDL
Background/Ambient Data		Data Source	
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake		Blairsville MA	
PWS Waters	Conemaugh River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	

Changes Since Last Permit Issuance:

Other Comments:

<b>Treatment Facility Summary</b>				
<b>Treatment Facility Name:</b> Upper Stonycreek JMA				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
5672401	4/9/1999			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Lagoon	Chlorine	0.346
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.656	918	Not overloaded	None	None

Changes Since Last Permit Issuance:

Other Comments: This plant never removes solids

### Compliance History

Effluent Violations for Outfall 001, from: May 1, 2023 To: March 31, 2024

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
CBOD5	03/31/24	Wkly Avg	219.1	lbs/day	208.0	lbs/day

Other Comments: This plant never removes solids

## Operations Compliance Check Summary Report

Facility: Upper Stonycreek Joint Municipal Authority

NPDES Permit No.: PA0042561

Compliance Review Period: 6/2019 – 6/2024

### Inspection Summary:

INSP ID	INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC	CREATION DATE
<a href="#">2953538</a>	10/03/2019	Compliance Evaluation	PA Dept of Environmental Protection	Violation(s) Noted	11/04/2019

### Violation Summary:

VIOL ID	VIOLATION DATE	VIOLATION TYPE	VIOLATION TYPE DESC	RESOLVED DATE	INSP ID
866970	10/03/2019	92A.41(A)5	NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance	11/04/2019	2953538

### Open Violations by Client ID:

No open violations for Client ID 67100

**Enforcement Summary:**

ENF ID	ENF TYPE	ENF CREATION DATE	VIOLATIONS	ENF FINAL STATUS	ENF CLOSED DATE
380439	NOV	11/04/2019	92A.41(A)5	Administrative Close Out	04/13/2021

**DMR Violation Summary:**

START	END	PARAMETER	SAMPLE	PERMIT	UNIT OF MEASURE	STATISTICAL BASE CODE
03/01/2024	03/31/2024	Carbonaceous Biochemical Oxygen Demand (CBOD5)	219.1	208.0	lbs/day	Weekly Average

**Compliance Status:**

In compliance

**Completed by:** John Murphy

**Completed date:** 6/4/2024

**Development of Effluent Limitations**

**Outfall No.** 001  
**Latitude** 40° 9' 29.00"  
**Wastewater Description:** Sewage Effluent

**Design Flow (MGD)** .656  
**Longitude** -78° 55' 9.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

Water quality analysis was performed using the TRC Spreadsheet and WQM7.0. Modeling showed no need for water quality based effluent limits. The outputs from these models are attached to this report.

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
NH <sub>3</sub> N	9.45	Average Monthly	WQM 7.0
Total Residual Chlorine	0.42	Average Monthly	TRC Spreadsheet

A review of the DMR's shows that the plant is currently achieving the above water quality-based effluent limits. The water quality-based effluent limits will be imposed upon permit issuance.

**Best Professional Judgment (BPJ) Limitations**

Dissolved oxygen will be limited at 4.0 mg/l as an instantaneous minimum.

**Anti-Backsliding**

Anti-backsliding was not utilized for this permit renewal.

### **Kiski – Conemaugh TMDL**

This discharge is within the Kiskiminetas – Conemaugh Rivers watershed. This watershed has a total maximum daily load requirement for pollutants present in acid mine drainage. The parameters are aluminum, total iron and manganese. The official TMDL for the Kiski watershed does not give an allocation to any sewage discharges. The contribution for metals from a sewage plant is expected to be less than water quality criteria and therefore not contributing to stream impairment. Quarterly monitoring is imposed for plants rated larger than 0.499 mgd. Monitoring for aluminum, iron and manganese is required to ensure there are no impacts on the quality of the receiving stream.

### **Industrial/Commercial Contributors**

The applicant stated that the plant does not have any industrial or commercial customers.

### **E. Coli**

In accordance with Section I of DEP's "Standard Operating Procedure for Clean Water Program Establishing Effluent Limitations for Individual Sewage Permits" [SOP No. BCW-PMT-033, Version 1.9, March 22, 2021] and under the authority of 25 Pa. Code § 92a.61(b), a quarterly reporting requirement for *E. coli* will be added to Outfall 001. *E. coli* was recently added to the bacteria water quality criteria in 25 Pa. Code § 93.7(a) and the monitoring will be used to determine if *E. coli* concentrations require additional controls.

### **Mass Loadings**

Mass loading limits are applicable for publicly owned treatment works. Current policy requires average monthly mass loading limits be established for CBOD5 and TSS, and average weekly mass loading limits be established for CBOD5 and TSS.

Mass loading limits (lbs/day) are based on the formula: design flow (MGD) x concentration limit (mg/L) x conversion factor (8.34).

### **Total Nitrogen and Total Phosphorus**

Nutrient monitoring is required to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). Sewage discharges with design flows > 2,000 gpd require annual monitoring for Total Nitrogen and Total Phosphorus in new and reissued permits.

### **Monitoring Frequency Considerations**

For pH, Dissolved Oxygen (DO) and Total Residual Chlorine (TRC), a monitoring frequency of 1/day has been imposed. The daily monitoring frequencies are consistent with current policy and Table 6-3 of DEP's Technical Guidance for the Development and Specification of Effluent Limitations.

### **Influent Monitoring**

For POTWs with design flows greater than 2,000 GPD, influent BOD<sub>5</sub> and TSS monitoring must be established in the permit, and the monitoring should be consistent with the same frequency and sample type as is used for other effluent parameters.

### **Industrial Contributors**

The applicant reported that the system has no commercial or industrial contributors.

**Solids Disposal**

The applicant has stated that the plant has not wasted sludge since it was constructed in 2001. The most recent inspection report stated that sludge hasn't been removed from the lagoons since 2003. The applicant submitted three years of hauled in municipal wastes reports. During the years 2021-2023, the sewage plant received an average of 221,000 gallons per year of septage and/or sludge/MLSS from other sewage plants. However, this plant does not waste sludge, the plant has no solids processing equipment, and does not even have a landfill listed to eventually receive generated sludges from this plant.

The following condition has been in Part C of the permit:

*The permittee shall manage and properly dispose of sewage sludge produced by the system by balancing the amount of solids maintained within the lagoon. The permittee shall monitor sludge blanket depth in all lagoons by taking measurements on an annual basis. A sampling grid shall be established for each lagoon in a manner that will measure deposition throughout the lagoon. The permittee shall develop a detailed plan and schedule for removal of excess sewage sludge when the sludge blanket volume exceeds twenty (20%) of the lagoon volume or 18 inches in depth, or at a lesser accumulated volume or depth if sludge accumulation is causing or contributing to effluent violations. The plan shall be implemented as needed and made available to DEP upon request.*

Since the applicant has never complied with the above condition and because the sewage plant does not digest, dewater, and dispose of solids, this plant will no longer be permitted to accept hauled in municipal wastes or septage. This is stipulated in Part C.II.D. of the permit.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Measured
TRC	XXX	XXX	XXX	0.42	XXX	1.37	1/day	Grab
CBOD5	136.9	208.0	XXX	25	38	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	Report Daily Max	XXX	1/week	8-Hr Composite
TSS	164.2	246.3	XXX	30	45	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	Grab

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	25.0	XXX	50	1/week	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	9.45	XXX	18.9	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Aluminum	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	8-Hr Composite
Total Iron	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	8-Hr Composite
Total Manganese	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	8-Hr Composite

Compliance Sampling Location: outfall 001

Other Comments: This plant does not remove solids

## **WQM Output Warm Months**

## Input Data WQM 7.0

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream Temp (°C)	pH
									Temp	pH		
Q7-10	0.035	0.00	0.00	0.000	0.000	66.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

  

Discharge Data							
Name		Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)
USJMA		PA0042561	0.6560	0.6560	0.6560	0.000	25.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.10	0.00	0.70		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RML	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18E	45084	STONYCREEK RIVER	21.000	1620.50	150.00	0.00370	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.035	0.00	0.00	0.000	0.000	66.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)			
		0.0000	0.0000	0.0000	0.000	25.00	7.00
<b>Parameter Data</b>							
Parameter Name		Disc Conc	Trib Conc	Stream Conc	Fate Coef		
		(mg/L)	(mg/L)	(mg/L)	(1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

## **WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	85.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin			Stream Code		Stream Name								
18E			45084		STONYCREEK RIVER								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
22.000	4.76	0.00	4.76	1.0148	0.00370	.742	41.95	56.56	0.19	0.329	25.00	7.00	
<b>Q1-10 Flow</b>													
22.000	3.05	0.00	3.05	1.0148	0.00370	NA	NA	NA	0.15	0.401	25.00	7.00	
<b>Q30-10 Flow</b>													
22.000	6.47	0.00	6.47	1.0148	0.00370	NA	NA	NA	0.21	0.285	25.00	7.00	

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
18E	45084	STONYCREEK RIVER					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
22.000 USJMA		11.07	44.01	11.07	44.01	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
22.000 USJMA		1.37	9.45	1.37	9.45	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
22.00 USJMA		25	25	9.45	9.45	3	3
						0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18E	45084	STONYCREEK RIVER		
<u>RMI</u> 22.000	<u>Total Discharge Flow (mgd)</u> 0.656	<u>Analysis Temperature (°C)</u> 25.000	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 41.948	<u>Reach Depth (ft)</u> 0.742	<u>Reach WDRatio</u> 56.563	<u>Reach Velocity (fps)</u> 0.186	
<u>Reach CBOD5 (mg/L)</u> 6.04	<u>Reach Kc (1/days)</u> 0.990	<u>Reach NH3-N (mg/L)</u> 1.74	<u>Reach Kn (1/days)</u> 1.029	
<u>Reach DO (mg/L)</u> 7.322	<u>Reach Kr (1/days)</u> 7.348	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 0.329	<b>Subreach Results</b>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.033	5.80	1.68	6.99
	0.066	5.57	1.63	6.75
	0.099	5.34	1.57	6.58
	0.132	5.13	1.52	6.47
	0.165	4.92	1.47	6.40
	0.198	4.72	1.42	6.36
	0.230	4.53	1.38	6.35
	0.263	4.35	1.33	6.36
	0.296	4.18	1.29	6.38
	0.329	4.01	1.24	6.41

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
18E	45084	STONYCREEK RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
22.000	USJMA	PA0042561	0.656	CBOD5	25		
				NH3-N	9.45	18.9	
				Dissolved Oxygen			3

## **WQM Output Cold Months**

## Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name				RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC	
18E	45084	STONYCREEK RIVER				22.000	1640.00	136.00	0.00370	0.00	<input checked="" type="checkbox"/>	
<b>Stream Data</b>												
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
		(cfsm)	(cfs)	(cfs)								
Q7-10	0.070	0.00	0.00	0.000	0.000	66.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
<b>Discharge Data</b>												
			Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
			USJMA	PA0042561	0.6560	0.6560	0.6560	0.000	20.00	7.00		
<b>Parameter Data</b>												
Parameter Name				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
CBOD5				25.00	2.00	0.00	1.50					
Dissolved Oxygen				3.00	8.24	0.00	0.00					
NH3-N				25.00	0.10	0.00	0.70					

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18E	45084	STONYCREEK RIVER	21.000	1620.50	150.00	0.00370	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.070	0.00	0.00	0.000	0.000	66.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## **WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	85.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin			Stream Code			Stream Name						
18E			45084			STONYCREEK RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
22.000	9.52	0.00	9.52	1.0148	0.00370	.789	51.37	65.12	0.26	0.235	6.44	7.00
<b>Q1-10 Flow</b>												
22.000	6.09	0.00	6.09	1.0148	0.00370	NA	NA	NA	0.21	0.293	7.14	7.00
<b>Q30-10 Flow</b>												
22.000	12.95	0.00	12.95	1.0148	0.00370	NA	NA	NA	0.30	0.201	6.09	7.00

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
18E	45084	STONYCREEK RIVER					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
22.000	USJMA	24.1	50	24.1	50	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
22.000	USJMA	4.36	25	4.36	25	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)
22.00	USJMA	25	25	25	25	3	3
						0	0

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18E	45084	STONYCREEK RIVER		
RMI 22.000	Total Discharge Flow (mgd) 0.656	Analysis Temperature (°C) 6.445	Analysis pH 7.000	
Reach Width (ft) 51.373	Reach Depth (ft) 0.789	Reach WDRatio 65.117	Reach Velocity (fps) 0.260	
Reach CBOD5 (mg/L) 4.22	Reach Kc (1/days) 0.822	Reach NH3-N (mg/L) 2.50	Reach Kn (1/days) 0.247	
Reach DO (mg/L) 7.738	Reach Kr (1/days) 4.759	Kr Equation Tsivoglou	Reach DO Goal (mg/L) 6	
<u>Reach Travel Time (days)</u> 0.235	<u>Subreach Results</u>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.024	4.17	2.48	8.09
	0.047	4.13	2.47	8.24
	0.071	4.09	2.46	8.24
	0.094	4.04	2.44	8.24
	0.118	4.00	2.43	8.24
	0.141	3.96	2.41	8.24
	0.165	3.92	2.40	8.24
	0.188	3.88	2.39	8.24
	0.212	3.84	2.37	8.24
	0.235	3.80	2.36	8.24

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
18E	45084		STONYCREEK RIVER				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
22.000	USJMA	PA0042561	0.656	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

## TRC Spreadsheet

TRC\_CALC (1)

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
4.76	= Q stream (cfs)		0.5	= CV Daily	
0.656	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		0.6	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			= Decay Coefficient (K)	
Source	Reference	AFC Calculations	Reference	CFC Calculations	
TRC	<b>1.3.2.iii</b>	WLA_afc = 0.917	<b>1.3.2.iii</b>	WLA_cfc = 1.470	
PENTOXSD TRG	<b>5.1a</b>	LTAMULT_afc = 0.373	<b>5.1c</b>	LTAMULT_cfc = 0.581	
PENTOXSD TRG	<b>5.1b</b>	LTA_afc = 0.342	<b>5.1d</b>	LTA_cfc = 0.854	
Effluent Limit Calculations					
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.420		AFC	
		INST MAX LIMIT (mg/l) = 1.375			
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$				
LTA_afc	wla_afc*LTAMULT_afc				
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$				
LTA_cfc	wla_cfc*LTAMULT_cfc				
AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$				
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$				