

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0043036  
 APS ID 1033448  
 Authorization ID 1345163

**Applicant and Facility Information**

Applicant Name	<u>PA Conference Association of Seventh Day Adventists Inc.</u>	Facility Name	<u>Laurel Lake Camp &amp; Retreat Center</u>
Applicant Address	<u>76 Lodge Road</u> <u>Rossiter, PA 15772-6720</u>	Facility Address	<u>76 Lodge Road</u> <u>Rossiter, PA 15772-6720</u>
Applicant Contact	<u>Ezequiel Perez (Manager)</u> <u>(814) 938-9300</u> <u>(laurellake@paconference.org)</u>	Facility Contact	<u></u>
Applicant Phone	<u></u>	Facility Phone	<u></u>
Client ID	<u>45112</u>	Site ID	<u>269</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Banks Township</u>
Connection Status	<u></u>	County	<u>Indiana</u>
Date Application Received	<u>February 11, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 15, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit for an existing discharge of treated sewage</u>		

**Summary of Review**

This is a non-municipal STP serving a church camp and retreat center. The facility does not receive hauled in waste.

No changes to discharge quality or quantity are proposed as part of this NPDES Permit renewal.

According to eDMRs and inspection reports, flows are in the range of 350 gallons/day most of the year except for occasional spikes in the summer when camps are going on and flows peak, which is way below the design loading of 10,500 gallons/day.

There are currently 26 open violations listed in EFACTS for this client (3/19/2024)

Sludge use and disposal description and location(s): Sludge is hauled offsite for further processing at a WWTP.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Adam J. Pesek Adam J. Pesek, E.I.T. / Project Manager	March 19, 2024
X		Vacant / Environmental Engineer Manager	Okay to Draft JCD 3/25/2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0105</u>
Latitude	<u>40° 51' 27"</u>	Longitude	<u>-78° 53' 29"</u>
Quad Name	<u>Rochester Mills</u>	Quad Code	<u>01214</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Straight Run</u>	Stream Code	<u>47606</u>
NHD Com ID	<u>123853469</u>	RMI	<u>2.75</u>
Drainage Area	<u>0.91</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0607</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.0553</u>	Q <sub>7-10</sub> Basis	<u>USGS Streamstats</u>
Elevation (ft)	<u>1695</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>17-D</u>	Chapter 93 Class.	<u>HQ-CWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	<u></u>
Temperature (°C)	<u>20</u>	Default (CWF)	<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Kittanning Suburban Joint Water Authority</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>2070</u>
PWS RMI	<u>48.4</u>	Distance from Outfall (mi)	<u></u>

Changes Since Last Permit Issuance: Streamflow was updated due to new information.

Other Comments:

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Laurel Lake Camp STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
3277405 A-1		5/4/2007		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Chlorine Disinfection	
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.0105	201	Not Overloaded	Aerated Sludge Holding	Other WWTP

Changes Since Last Permit Issuance:

Other Comments:

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	There have been 16 effluent violations reported since the beginning of 2019. One for TRC, two for CBOD5, one for D.O., seven for ammonia nitrogen, and five for fecal coliform.
<b>Summary of Inspections:</b>	Last site inspection was conducted on 2/6/2020. The inspection report did not report any violations.

Other Comments: An NOV was issued 12/28/2023 for failure to pay the Chapter 302 Operator Certification Service Fee. NOVs were also issued for failure to pay the 2022 and 2023 NPDES Permit Annual Fee.

Compliance History

DMR Data for Outfall 001 (from November 1, 2022 to October 31, 2023)

Parameter	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22
Flow (MGD) Average Monthly	0.0010	0.0006	0.0045	0.00500 0	0.0043	0.0007	0.0004					
pH (S.U.) Minimum	6.7	6.7	6.7	6.4	6.2	7.1	7.1					
pH (S.U.) Maximum	7.0	7.1	7.2	7.5	7.8	7.4	7.9					
DO (mg/L) Minimum	6.8	6.8	6.9	6.1	7.0	7.2	8.5					
TRC (mg/L) Average Monthly	0.14	0.12	0.13	0.14	0.28	0.186	0.27					
TRC (mg/L) Instantaneous Maximum	0.2	0.17	0.25	0.22	0.96	0.34	0.81					
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.0	< 3.0	< 4.1	< 3.0	< 4.54					
CBOD5 (mg/L) Instantaneous Maximum	< 3.0	< 3.0	< 3.0	< 3.0	5.19	< 3.0	6.07					
TSS (mg/L) Average Monthly	8.0	< 1.8	2.0	< 2.4	20.0	6.2	< 1.8					
TSS (mg/L) Instantaneous Maximum	12.4	2.0	2.0	2.8	22.0	9.6	< 2.0					
Fecal Coliform (CFU/100 ml) Average Monthly	6.0	4.0	< 1.0	< 1.0	3.0	< 1.0	< 1.0					
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	34.5	17.3	1.0	1.0	4.1	< 1.0	< 1.0					
Total Nitrogen (mg/L) Daily Maximum											< 0.5	
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.004	< 0.1	< 0.1	< 0.1					
Ammonia (mg/L) Instantaneous Maximum	< 0.1	< 0.1	< 0.1	0.1299	< 0.1	< 0.1	< 0.1					
Total Phosphorus (mg/L) Daily Maximum											5.48	

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.0105</u>
<b>Latitude</b> <u>40° 51' 27.00"</u>	<b>Longitude</b> <u>-78° 53' 29.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX	-	92a.61

Comments: Monitoring for E. Coli is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
CBOD <sub>5</sub>	15.0	Average Monthly	Previous WQAM 6.3 modeling
Ammonia Nitrogen	3.0	Average Monthly	Previous WQAM 6.3 modeling
Dissolved Oxygen	5.0	Daily Minimum	Previous WQAM 6.3 modeling
Total Residual Chlorine	0.3	Average Monthly	TRC Spreadsheet
Total Residual Chlorine	1.0	IMAX	TRC Spreadsheet

Comments: WQM 7.0 modeling and the TRC Spreadsheet conducted for this renewal (attached) did not calculate more stringent effluent limits for this renewal.

A seasonal multiplier of "3" was applied to the ammonia nitrogen effluent limit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

**Best Professional Judgment (BPJ) Limitations**

Comments: Monitoring for total nitrogen and total phosphors was placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

**Anti-Backsliding**

N/A

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.3	XXX	1.0	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	15.0	XXX	30	2/month	Grab
Total Suspended Solids	XXX	XXX	XXX	25.0	XXX	50	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 (after disinfection)

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17D	47606	STRAIGHT RUN	2.750	1695.00	0.91	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Laurel Lake C&R	PA0043036	0.0105	0.0000	0.0000	0.000	20.00	7.10

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70



**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17D	47606	STRAIGHT RUN	2.200	1670.00	2.55	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
17D		47606				STRAIGHT RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
2.750	0.06	0.00	0.06	.0162	0.00861	.331	4.22	12.75	0.05	0.656	20.00	7.02
<b>Q1-10 Flow</b>												
2.750	0.04	0.00	0.04	.0162	0.00861	NA	NA	NA	0.04	0.788	20.00	7.03
<b>Q30-10 Flow</b>												
2.750	0.08	0.00	0.08	.0162	0.00861	NA	NA	NA	0.06	0.572	20.00	7.02

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Wasteload Allocations**

SWP Basin      Stream Code                      Stream Name  
 17D                      47606                                      STRAIGHT RUN

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.750	Laurel Lake C&R	16.33	50	16.33	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.750	Laurel Lake C&R	1.88	10.09	1.88	10.09	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
2.75	Laurel Lake C&R	25	25	10.09	10.09	4	4	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
17D	47606	STRAIGHT RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.750	0.011	20.000	7.021	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
4.219	0.331	12.753	0.051	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
7.23	1.033	2.37	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.279	22.933	Owens	6	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.656	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.066	6.75	2.26	8.13
	0.131	6.31	2.16	8.24
	0.197	5.90	2.06	8.24
	0.263	5.51	1.97	8.24
	0.328	5.15	1.88	8.24
	0.394	4.81	1.80	8.24
	0.459	4.50	1.72	8.24
	0.525	4.20	1.64	8.24
	0.591	3.93	1.57	8.24
	0.656	3.67	1.50	8.24

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
17D		47606		STRAIGHT RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.750	Laurel Lake C&R	PA0043036	0.010	CBOD5	25		
				NH3-N	10.09	20.18	
				Dissolved Oxygen			4

1A	B	C	D	E	F	G
<b>TRC EVALUATION</b> Laurel Lake Camp & Retreat Center						
Input appropriate values in B4:B8 and E4:E7						
4	0.0553	= Q stream (cfs)		0.5	= CV Daily	
5	0.0105	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA_afc = 1.105	1.3.2.iii	WLA_cfc = 1.070	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 0.412	5.1d	LTA_cfc = 0.622	
14						
15	Source		Effluent Limit Calculations			
16	PENTOXSD TRG	5.1f	AML_MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
18			INST MAX LIMIT (mg/l) = 1.635			
	WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019/Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs/Qd)] \cdot (1-FOS/100)$				
	LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2+1)) - 2.326 \cdot LN(cvh^2+1)^{0.5})$				
	LTA_afc	wla_afc * LTAMULT_afc				
	WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011/Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs/Qd)] \cdot (1-FOS/100)$				
	LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2/no\_samples+1)) - 2.326 \cdot LN(cvd^2/no\_samples+1)^{0.5})$				
	LTA_cfc	wla_cfc * LTAMULT_cfc				
	AML_MULT	$EXP(2.326 \cdot LN((cvd^2/no\_samples+1)^{0.5}) - 0.5 \cdot LN(cvd^2/no\_samples+1))$				
	AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
	INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				

Laurel Lake Camp & Retreat Center  
 Banks Township, Indiana County  
 PA0043036

Discharge pH

Outfall 001

<u>Date</u>	<u>pH min</u>	<u>pH max</u>	<u>10<sup>-pH min</sup></u>	<u>10<sup>-pH max</sup></u>	<u>&amp; pH max</u>	<u>-Log (Ave pH)</u>
Jul-21	7.0	8.0	1E-07	1E-08	5.5E-08	<b>7.3</b>
Aug-21	6.9	7.3	1.26E-07	5.01E-08	8.8E-08	<b>7.1</b>
Sep-21	6.7	7.8	2E-07	1.58E-08	1.08E-07	<b>7.0</b>
Jul-22	6.9	7.3	1.26E-07	5.01E-08	8.8E-08	<b>7.1</b>
Aug-22	6.9	7.1	1.26E-07	7.94E-08	1.03E-07	<b>7.0</b>
Sep-22	6.9	7.4	1.26E-07	3.98E-08	8.29E-08	<b>7.1</b>
Jul-23	6.4	7.5	3.98E-07	3.16E-08	2.15E-07	<b>6.7</b>
Aug-23	6.7	7.2	2E-07	6.31E-08	1.31E-07	<b>6.9</b>
Sep-23	6.7	7.1	2E-07	7.94E-08	1.39E-07	<b>6.9</b>
					Median:	<b>7.1</b>



Approve	Deny	Signatures	Date
X		Adam J. Pesek Adam J. Pesek, E.I.T. / Project Manager	March 19, 2024
X		<i>Vacant</i> / Environmental Engineer Manager	Okay to Draft JCD 3/25/2024