

NORTHCENTRAL REGIONAL OFFICE  
CLEAN WATER PROGRAM

Application Type Renewal  
 Facility Type Sewage  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
ADDENDUM**

Application No. PA0044245  
 APS ID 982822  
 Authorization ID 1255154

**Applicant and Facility Information**

Applicant Name <u>PA DCNR</u> Applicant Address <u>28 Fairview Road</u> <u>Penfield, PA 15849-7902</u> Applicant Contact <u>James McCorkle</u> Applicant Phone <u>(814) 765-0630</u> Client ID <u>52524</u> SIC Code <u>8412</u> SIC Description <u>Services - Museums And Art Galleries</u> Date Published in PA Bulletin <u>August 17, 2019</u> Comment Period End Date <u>September 16, 2019</u>	Facility Name <u>Parker Dam State Park</u> Facility Address <u>28 Fairview Road</u> <u>Penfield, PA 15849-7902</u> Facility Contact <u>James McCorkle</u> Facility Phone <u>(814) 765-0630</u> Site ID <u>261798</u> Municipality <u>Huston Township</u> County <u>Clearfield</u> EPA Waived? <u>Yes</u> If No, Reason _____
Purpose of Application <u>Application for a renewal of an NPDES permit for discharge of treated Sewage</u>	

**Internal Review and Recommendations**

The subject permit was redrafted on August 2, 2019.

No comments were received from either the permittee or the public on this draft. In addition, internal review of the draft permit resulted in no changes from the previous draft permit.

However, the August 2, 2019 draft NPDES Permit did not include the final limitations of 0.02 mg/L for TRC that were listed in the Fact Sheet.

Therefore, it is recommended that this permit be drafted again to include the missing final limits. The two-year compliance schedule was included in Part C and this will remain unchanged.

Approve	Return	Deny	Signatures	Date
✓			Keith C. Allison / Project Manager	October 17, 2019
			Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	
			Thomas M. Randis / Program Manager	

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Weir
pH (S.U.) Oct 1 - Apr 30	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	3/week	Grab
pH (S.U.) May 1 - Sep 30	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO Oct 1 - Apr 30	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	3/week	Grab
DO May 1 - Sep 30	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5 Nov 1 - Apr 30	XXX	XXX	XXX	20	XXX	40	2/month	8-Hr Composite
CBOD5 May 1 - Oct 31	XXX	XXX	XXX	10	XXX	20	2/month	8-Hr Composite
TSS Nov 1 - Apr 30	XXX	XXX	XXX	20	XXX	40	2/month	8-Hr Composite
TSS May 1 - Oct 31	XXX	XXX	XXX	10	XXX	20	2/month	8-Hr Composite
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9	XXX	18	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3	XXX	6	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
TRC - Interim Oct 1 - Apr 30	XXX	XXX	XXX	0.05	XXX	0.05	3/week	Grab
TRC - Interim May 1 - Sep 30	XXX	XXX	XXX	0.05	XXX	0.05	1/day	Grab

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
TRC - Final Oct 1 - Apr 30	XXX	XXX	XXX	0.02	XXX	0.02	3/week	Grab
TRC - Final May 1 - Sep 30	XXX	XXX	XXX	0.02	XXX	0.02	1/day	Grab

Compliance Sampling Location: Outfall 001