

Application Type Renewal
Facility Type Municipal
Major / Minor Major

Application No. PA0045985
APS ID 762659
Authorization ID 1463992

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|---|
| Applicant Name | <u>Mountaintop Area Joint Sanitary Authority (MAJSA) Luzerne County</u> | Facility Name | <u>Mountaintop Area Joint Sanitary Authority POTW</u> |
| Applicant Address | <u>290 Morio Drive</u> <u>Mountain Top, PA 18707</u> | Facility Address | <u>290 Morio Drive</u> <u>Mountain Top, PA 18707</u> |
| Applicant Contact | <u>Jeffery Mylet</u> | Facility Contact | <u>Jeffery Mylet (alternate contact Jayce Temperance)</u> |
| Applicant Phone | <u>(570) 678-7411</u> | Facility Phone | <u>(570) 678-7411</u> |
| Client ID | <u>169775</u> | Site ID | <u>1478</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Dorrance Township</u> |
| Connection Status | <u>Legally Modified Connection Ban</u> | County | <u>Luzerne</u> |
| Date Application Received | <u>November 21, 2023</u> | EPA Waived? | <u>No</u> |
| Date Application Accepted | <u>January 16, 2024</u> | If No, Reason | <u>Major Facility, Significant CB Discharge</u> |
| Purpose of Application | <u>Renewal of NPDES Permit.</u> | | |

Summary of Review

This is a 4.16 MGD POTW that discharges to a 4:1 effluent-dominated impaired stream (impairment causes include Organic Enrichment from Municipal Point Sources, i.e. Treatment Plant) and is a significant Chesapeake Bay discharger with annual mass caps.

- Application:
 - Public Upload# 253053 (received 8/15/2024) – revised NPDES Application
 - Public Upload# 245577 (received 7/15/2024) – site specific studies (Zinc TRE from previous NPDES Permit Term)
 - Public Upload# 270536 (received 11/12/2024) – supplemental information
 - Public Upload# 104010 (received 1/3/2024) – original NPDES renewal application
 - Public Upload# 201565 (received 1/16/2024) – supplemental information (Predraft Survey Workbook and lab sheets)
- Flows: AADF flows were 2.77 MGD (2022), 3.01 MGD (2021) and 2.96 MGD (2020), with 4.47 MGD highest monthly average flow in April 2022, and peak instantaneous flow of 9.32 MGD.
- POTW bypasses and Overflows:
 - Overflows (2019, 2020, 2021, 2022, 2023): There is a pattern (12) of overflows at the (offsite) Walden Park Pump Station in the last 5 years. MAJSA blamed the overflows on I&I (groundwater and stormwater) in the Walden Park collection system area, and has been doing I&I work (smoke testing, inline flow measurements, televising, and visual manhole inspections).
 - WWTP bypasses (2020 and 2023): There have been two (2) WWTP EQ Tank overflow discharges, said to be "necessary to prevent severe property damage" to the MAJSA's treatment facility. I&I work in progress (including a sewer replacement project) is expected to reduce peak influent wet weather flows.
- Previous Zinc TRE: A Zinc TRE/Final WQBEL Compliance Report was done in the previous NPDES Permit term, which concluded they could comply with the Final Zinc WQBELs. Related submittals included:

| Approve | Deny | Signatures | Date |
|---------|------|---|----------------|
| X | | James D. Berger (signed) James D. Berger, P.E. / Environmental Engineer | March 21, 2025 |
| X | |  Edward Dudick, P.E. / Environmental Engineer Manager | March 21, 2025 |

Summary of Review

- On-Base No. 9200 (uploaded 12/24/2020): This information was regarding the separate Part C.II CBOD5/TSS WQBELs
- On-Base No. 9201 (uploaded 12/24/2020): Part C.IV Site-specific information) contained collected site-specific information at that time.
- On-Base No. 9202 (uploaded 12/24/2020): Industrial Waste Survey
- On-Base No. 25208 (uploaded 6/25/2021): Final WQBEL Compliance Report submittal. Additional site-specific sampling data was included.

Sludge use and disposal description and location(s): 222 dry tons was disposed at Wayne Township Landfill.

Part A: Substantial changes flagged below (in addition to permit template updates):

- **Part A.I.A and B (Outfall No. 001)**: Interim monitoring and Final WQBELs (Total Copper and Hexachlorobutadiene) due to Reasonable Potential Analysis. See also related Part C.IV requirements/options.
- **Part A.I.C (Outfall No. 001)**: Revised Ammonia-N limits due to water quality modeling (2020 Chapter 93 revised WQS), new E Coli monitoring (2020 Chapter 93 WQS), and new PFAS Strategy monitoring requirements (with footnote). TRC limits slightly revised. New Total Aluminum, Hexavalent Chromium, and Total Manganese monitoring requirement per Reasonable Potential Analysis. Several previous monitoring requirements and WET Test TUC limits dropped per Effluent Limitations and WET Test Sections below.
- **Part A.I.D (Outfall No. 002) and A.I.E (Outfall No. 003)**: Several PAG-03 Appendix J (Miscellaneous) monitoring requirements added (Chemical Oxygen Demand, TN, TP). See also Part C.VII requirements.

Part C Special Conditions: Changes bolded.

- **Part C.I**: Existing Standard Chesapeake Bay conditions for this significant Chesapeake Bay discharger.
- **Part C.II**: **Updated POTW Pretreatment Program Implementation Conditions (including new PFAS related requirements)**
- **Part C.III**: Existing Standard Solids Management Conditions
- **Part C.IV**: **New WQBEL for Toxic Pollutants Permit Condition (Total Copper and Hexachlorobutadiene) with 3-year schedule of compliance per Reasonable Potential Analysis.**
- **Part C.V**: **Updated Chronic WET Test conditions (No limits per WET Test section)**. Slight change in the dilution ratios.
- **Part C.VI**: **New WQBELs below Quantitation Limits (Hexachlorobutadiene)**
- **Part C.VII**: **Updated stormwater standard conditions for major POTW, (with existing language to address infiltration/sheet flow scenarios due to Authority statements that stormwater infiltrates prior to reaching main branch of Big Wapwallopen Creek). Added IW Stormwater Annual Report submittal requirement and benchmark language for Chemical Oxygen Demand (COD).**
- **Parts C.VIII.A, B, & C**: Existing Standard Sewage conditions (stormwater prohibition; necessary property rights; proper management of residuals).
- **Part C.VIII.D**: **Updated Chlorine minimization condition**
- **Part C.VIII.E**: Existing Dry Stream condition due to limited dilution at facility discharge outfalls.
- **Part C.VIII.F**: **New High Flow Management Plan condition due to several Influent EQ tank overflow incidents.**
- **Part C.VIII.G**: Existing Site-specific Condition (discharge/stream changes).

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information

| | | | |
|------------------------------|-----------------------------------|------------------------------|---------------------|
| Outfall No. | 001 | Design Flow (MGD) | 4.16 |
| Latitude | 41° 6' 47.58" | Longitude | -75° 57' 33.50" |
| Quad Name | Freeland | Quad Code | 1038 (4.20.3) |
| Wastewater Description: | Sewage Effluent | | |
| Receiving Waters | Big Wapwallopen Creek (CWF, MF) | Stream Code | 28231 |
| NHD Com ID | 65636529 | RMI | - |
| Drainage Area | 18.8 square miles | Yield (cfs/mi ²) | 0.0781 |
| Q ₇₋₁₀ Flow (cfs) | 1.47 | Q ₇₋₁₀ Basis | USGS PA Streamstats |
| Elevation (ft) | ~1060 Feet (USGS Terrain Mapper) | Slope (ft/ft) | - |
| Watershed No. | 5-B | Chapter 93 Class. | CWF, MF |
| Existing Use | None | Existing Use Qualifier | |
| Exceptions to Use | - | Exceptions to Criteria | - |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | ORGANIC ENRICHMENT | | |
| Source(s) of Impairment | MUNICIPAL POINT SOURCE DISCHARGES | | |
| TMDL Status | None | Name | |

Background/Ambient Data

| | |
|--------------------------|-------|
| pH (SU) | 7.06 |
| Temperature (°C) | 0.4 |
| Hardness (mg/L) | 32 |
| CBOD ₅ (mg/l) | 1.92 |
| Total N (mg/l) | 0.66 |
| Total P (mg/l) | <0.01 |
| TSS (mg/l) | 12 |
| Aluminum (ug/l) | 17.3 |
| Manganese (ug/l) | 54.0 |
| Zinc (ug/l) | <5.00 |

Data Source

| |
|--|
| 1/17/2019 Upstream Sample ID: 227465; Sequence Number: 678; ~0.09 miles upstream of Outfall No. 001. |
| 1/17/2019 Downstream Sample ID: 2274645 (was at 7.46 SU), ~0.09 miles downstream of Outfall No. 001 (downstream of UNT confluence). |
| See above. Downstream Sample at 1.6 C. |
| See above. Downstream Sample at 73 mg/l. Application information was 49.4 mg/l (7/24/2020 48 mg/l; 7/21/2020 56 mg/l; 7/27/2020 54 mg/l; 8/22/2020 40 mg/l). |
| See above. Downstream Sample at 1.90 mg/l. |
| See above (0.60 Nitrate-N). Downstream sample was 2.06 mg/l (1.88 mg/l Nitrate-Nitrite). |
| See above. Downstream sample was 0.095 mg/l |
| See above. Downstream Sample at 14 mg/l. |
| See above. Downstream Sample at 30.100 ug/l |
| See above. Downstream Sample at 51.0 ug/l. |
| See above. Downstream Sample at 6.930 ug/l. Copper, Lead, Total Iron were ND for both samples. |

Nearest Downstream Public Water Supply Intake

| | |
|------------|-------------------|
| PWS Waters | Susquehanna River |
| PWS RMI | - |

DANVILLE BORO MUNI AUTH (ID# 101934-001)

| | |
|----------------------------|-----------|
| Flow at Intake (cfs) | - |
| Distance from Outfall (mi) | ~41 miles |

Changes Since Last Permit Issuance:

- The Chapter 93 Water Quality Standards were revised in 2020 (revised Ammonia-N criteria; new E Coli criteria). The previous 5/21/2019 NPDES Permit was issued prior to their 7/11/2020 effective date.

- See attached 5/23/2019 DEP Biologist (Tim Daley) Cause/Effect Stream Survey Memo. Stream improvement noted, but 2018-2019 were very wet years which might bias results (aquatic life benefitting from abnormal wet weather years' dilution as compared to more normal conditions). Facility also supplied stream data in terms of Dissolved Oxygen (DO) levels in previous NPDES Permit Renewal application that showed low oxygen was not contributing to stream impairment.



MAJSASurvey
.pdf

Other Comments:

Background Information:

- This is a natural trout reproduction stream.
- Effluent Dominated-stream: This is a 4:1 effluent-dominated stream at NPDES Permit Basis flow.
- Q7-10/Low Flow: USGS PA Streamstats (at Outfall 001 coordinates) was used as more conservative than the previously used USGS Report 2011-1070 "Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania" by Maria H. Stuckey and Mark A. Roland (Table 2, page 25) regarding the downstream USGS Gage #01538000 (Wapwallopen Creek near Wapwallopen PA), about 9.2 miles downstream (and which would also include the MAJSA discharge flows during low flow conditions).
 - The previous LFY used was 0.0820 CFS/square miles. The new LFY is slightly reduced to 0.0781 CFS/square mile.
 - The Outfall No. 001 Q7-10 low flow was reduced from 1.606 CFS (~1.038 MGD) to 1.47 CFS.
 - The (~9.2 mile downstream) gage location is on the larger Wapwallopen Creek, with assorted changes in elevation, etc.:

| | Outfall No. 001 on Big Wapwallopen Creek (ungaged) | Gage No. 1538000 (Wapwallopen Creek near Wapwallopen PA) |
|--|---|---|
| Drainage area | 18.8 square miles | 43.8 square miles |
| Elevation | ~1060 Feet | 752.41 Feet |
| Precipitation (mean annual) | 44 inches | 43.7 inches |
| Depth to Rock | 4.4 feet | 4.47 feet |
| Stream density (total length of stream divided by drainage area) | 1.45 miles/square mile | 1.37 miles/square miles |
| Q7-10 Low Flow | 1.47 CFS per PA Streamstats | 3.6 CFS per PA Streamstats |
| Low Flow Yield | 0.0781 CFS/square mile (calculated) | 0.0821 CFS/square mile (calculated) |

- Ongoing Stream Impairment (aquatic life) Background Information: The known and/or potential causes (individually or synergistically/cumulatively) for stream impairment include:
 - Organic Enrichment (known cause of stream impairment):
 - Previous MAJSA stream sampling eliminated low DO as a known cause of stream impairment.
 - The previous NPDES permit incorporated more stringent ABACT-based CBOD5/TSS limits, and additional monitoring/reporting (CBOD5/TSS minimum monthly average reduction; TOC).
 - Potential Short Term Exceedances/Cumulative Impacts of Metals: The previous NPDES permit term included additional monitoring and IPP conditions. See updated Reasonable Potential Analysis.
 - Potential Nutrient impacts on Receiving Stream (TN and TP): The 12/20/2006 DEP Chesapeake Bay Letter (annual mass cap limits) stated that the Big Wapwallopen Creek had been identified as "susceptible to nutrient-related problems, or has previously been identified impaired and nutrients may be the cause. If at some time in the future a TMDL is implemented to correct a nutrient-related water quality

problem in this segment, nutrient effluent limits for your discharge may be more restrictive than the Chesapeake Bay cap loads". (Underlining added.) No such TMDL developed to date.

- Contribution of Historic Operational problems: During the previous renewal review, the DEP Biologist indicated that the WWTP had had operational problems of various kinds over the years (including flooding that burned out pumps, releasing raw sewage at one time) that might have contributed to historic stream impairment. Proper O&M prevent recurrences of these types of problem and their impact on the waters of the Commonwealth.
- Cumulative/Synergistic Impacts: The standard Whole Effluent Toxicity (WET) Test requirements address synergistic/cumulative effects.
- **6/21/2021 Final WQBEL Compliance Report (On-Base No. 25208, “Evaluation of Big Wapwallopen Creek for Zinc Levels”) and 2020 Site-specific data collection:** This Final WQBEL Compliance Report was submitted in accordance with the previous NPDES Permit Part C.IV (WQBELs for Toxic Pollutants - Zinc) condition. Earlier Site-specific data was submitted on 12/24/2020 (On-Base Nos. 9200 (CBOD5 and TSS sampling due to Part C.II new limits), 9201 (Zinc Metal Translator), and 9202 (TRE Industrial Waste Survey)). The Final WQBEL Compliance Report indicated that facility should meet the Final Zinc WQBELs based on the data and in the absence of any significant changes in the POTW Influent. The gathered site-specific data and analysis are discussed below and were incorporated into this Renewal's Reasonable Potential Analysis as appropriate:
 - Section 3.0 noted the presence of upstream dischargers that might contribute zinc to ambient stream conditions.
 - Section 2.0 (Water Quality Assessment) included Site-specific stream-sampling (grab sample at mid-stream) data “collected upstream of the POTW discharge #1” but also “samples were taken beyond the mixing zone to ensure the effluent is well mixed with the waters of the Big Wapwallopen Creek” (about 25 meters downstream of Outfall No. 001). Original 2020 sampling showed ND concentration levels of Zinc but data conflicts with Final WQBEL Compliance Report Section 2.0 where concentration levels were identified (along with discrepancy in table units and sampling dates). Additional sampling was conducted February 2021 – April 2021 (outside the normal July – November stream low flow periods) at more sensitive 0.005 mg/l detection levels. Some dissolved Zinc concentrations were above the Total Zinc concentrations or were ND. No lab sheets were provided. A Zinc Metal Translator of 0.982206 (Geo Mean, no TSS correlation available) was calculated.

▪ Upstream Sampling Data:

| Sampling Date | Background Total Zinc (mg/l) | Total Hardness Background Stream Grab Sample (mg/l) | Stream Flow (MGD) |
|---------------|------------------------------|---|-------------------|
| 7/16/2020 | <0.01 | 48 | 12.6 |
| 7/21/2020 | <0.01 | 56 | 8.5 |
| 7/27/2020 | <0.01 | 54 | 6.4 |
| 8/6/2020 | <0.01 | 40 | 15.7 |
| 8/13/2020 | <0.01 | 52 | 7.6 |
| 8/20/2020 | <0.01 | 46 | 6.6 |
| 8/26/2020 | <0.01 | 46 | 6.4 |
| 9/3/2020 | <0.01 | 40 | 17.2 |
| 9/10/2020 | <0.01 | 48 | 26.5 |
| 9/18/2020 | <0.01 | 52 | 5.6 |
| 2/5/2021 | 0.003 | 104 | - |
| 2/11/2021 | 0.006 | 50 | - |
| 2/17/2021 | 0.007 | 58 | - |
| 2/25/2021 | 0.008 | 64 | - |
| 3/3/2021 | 0.004 | 40 | - |
| 3/9/2021 | 0.003 | 40 | - |
| 3/16/2021 | 0.003 | 40 | - |
| 3/23/2021 | 0.003 | 32 | - |
| 4/6/2021 | 0.004 | 32 | - |
| Mean (Arith) | 0.0076 | - | - |
| Mean Detected | 0.0051 | - | - |

▪ Downstream Sampling Data:

| Date | Stream Calculated Total Hardness (mg/l) and stream flow (MGD) | Discharge Total Hardness (mg/l) And Plant Flow (MGD)* | Total Zinc (mg/l) | "Assumed" Dissolved Zinc (mg/l) | Field pH (SU) | TOC (mg/l) | TSS (mg/l) |
|---------------------|---|---|-------------------|---------------------------------|---------------|-------------|------------|
| 7/16/2020 | 48 12.6 | 422 2.31 | 0.014 | 0.01 | 7.79 | 2.6 | <3.0 |
| 7/21/2020 | 56 8.5 | 350 2.21 | 0.014 | 0.019 | 7.16 | 2.50 | <3.0 |
| 7/27/2020 | 54 6.4 | 356 2.02 | 0.020 | 0.019 | 7.85 | 2.60 | - |
| 8/7/2020 | 40 15.7 | 248 2.33 | 0.017 | 0.012 | 7.68 | 3.60 | - |
| 8/13/2020 | 52 7.6 | 344 2.27 | 0.013 | 0.022 | 7.79 | 3.00 | - |
| 8/20/2020 | 46 6.6 | 394 2.13 | 0.018 | 0.038 | 7.92 | 3.20 | - |
| 8/26/2020 | 46 6.4 | 374 2.16 | 0.022 | 0.017 | 7.74 | 3.20 | - |
| 9/4/2020 | 40 17.2 | 344 2.44 | <0.01 | <0.01 | 7.95 | 3.40 | - |
| 9/10/2020 | 48 26.5 | 334 2.18 | <0.01 | <0.01 | 7.6 | 2.30 | - |
| 9/18/2020 | 52 5.6 | 230 2.30 | 0.017 | 0.017 | 7.66 | 2.90 | - |
| 2/5/2021 | 104 - | 288 2.47 | 0.01 | 0.01 | 7.67 | 1 | - |
| 2/11/2021 | 50 - | 320 2.37 | 0.003 | 0.007 | 7.84 | 1.8 | - |
| 2/17/2021 | 58 - | 306 3.21 | 0.006 | 0.009 | 7.25 | 2.3 | - |
| 2/25/2021 | 64 - | 334 3.15 | 0.007 | 0.006 | 7.68 | 1.7 | - |
| 3/3/2021 | 40 - | 186 4.97 | 0.008 | 0.011 | 7.26 | 2 | - |
| 3/9/2021 | 40 - | 232 4.72 | 0.004 | 0.007 | 7.63 | 1.5 | - |
| 3/16/2021 | 40 - | 224 3.15 | 0.003 | 0.006 | 7.68 | 1.2 | - |
| 3/23/2021 | 32 - | 228 3.51 | 0.003 | 0.004 | 7.13 | 1.5 | - |
| 3/30/2021 | 32 - | 134 4.18 | 0.003 | 0.008 | 7.32 | 2.5 | - |
| 4/6/2021 | 50 - | 208 3.13 | 0.004 | 0.008 | 7.56 | 1.9 | - |
| Mean (Arith) | 49.4 | 292.8* | 0.0126 | 0.0127 | - | 2.34 | - |

*Lower discharge hardness at higher discharge rates noted, in addition to conflict with Renewal Application discharge data. Cause of discrepancy unknown. Given effluent-dominated stream, the higher Discharge total hardness values would normally be expected to contribute to higher downstream Total Hardness values.

Stream Design Total Hardness Calculation (log-normal calculation per DEP Policy No. 386-2000-005, 6/28/2023):

- The permittee took ten stream samples above the Outfall No. 001 during the normal low flow period (July through November), and additional sampling outside the low flow time frame.
- The DEP Policy referenced the EPA Technical Support Document for WQBELs Appendix E (Lognormal Distribution and Permit Limits Derivations) which uses a log normal distribution for ≤ 10 samples.
 - The DEP Policy indicates that when hardness correlates to flow, it is generally an inverse correlation (the higher the flow, the lower the hardness) which is expected due to stormwater contributions generally diluting the stream value, including AMD concentration.
 - Stream Discharge Hardness (calculated per DEP Technical Guidance Policy): 48.2 mg/l. See calculations below.
 - The Reported Discharge Hardness conflicted with new NPDES Permit Renewal Application data, and was discarded in the Renewal Reasonable Potential Analysis. Cause of change in effluent Total Hardness is unknown (possibly reduction of potential I&I over time, lab error, other).

| Date | Total Hardness Stream above Outfall, i.e. "x" (mg/l) | Reported Effluent Total Hardness for comparison only* (mg/l) | $Y = \ln(x)$ | $Y - u$ | $(Y - u)^2$ |
|--------------|--|--|----------------|----------|-------------------|
| 7/16/2020 | 48 | 422 | 3.8712 | 0.0019 | 0.0000361 |
| 7/21/2020 | 56 | 350 | 4.0253 | 0.156 | 0.024336 |
| 7/27/2020 | 54 | 356 | 3.9889 | 0.1196 | 0.01430416 |
| 8/6/2020 | 40 | 248 | 3.6888 | -0.1805 | 0.03258025 |
| 8/13/2020 | 52 | 344 | 3.9512 | 0.0819 | 0.00670761 |
| 8/20/2020 | 46 | 394 | 3.8286 | -0.0407 | 0.00165649 |
| 8/26/2020 | 46 | 374 | 3.8286 | -0.0407 | 0.00165649 |
| 9/4/2020 | 40 | 344 | 3.6888 | -0.1805 | 0.03258025 |
| 9/10/2020 | 48 | 334 | 3.8712 | 0.0019 | 0.0000361 |
| 9/18/2020 | 52 | 230 | 3.9512 | 0.0819 | 0.00670761 |
| Total | 482 | - | 38.6938 | - | 0.11389345 |

*2020 Effluent discharge Total Hardness data is inconsistent with renewal application sampling data (84 mg/l minimum, 125 mg/l max and 99.16 average for three samples), and therefore discarded in updated Reasonable Potential Analysis.

- Number of Samples (k): 10 in low flow period.
- Arithmetic Mean of x: 48.2
- U_y = Estimated Mean (log normal): 3.8693
- V_y = Estimated Variance (log normal): 0.01265 for $k - 1$ (9)
- Estimated Standard Deviation (log normal): 0.9709
- Estimated Coefficient of Variation (log normal): 0.3421
- **Ex = Mean (Daily Average, normal) = $\exp(U_y + variance/2)$** : 48.2 mg/l (used in updated TMS for ambient stream concentration)

December 22, 2020 MAJSA Part C.IV (WQBELs for Toxic Pollutants) Report, prepared by Dennis Peters, P.E. (Peters Consultant Inc.): The cover letter indicated that this Report would be incorporated into a subsequent Final WQBEL Compliance Report (due 6/30/2021). This report was superseded by the Final WQBEL Compliance Report but included the following additional information:

- Exhibit A (MAJSA Zinc Metal Translator): The Table footnote: "A change in the testing occurred when Total Suspended Solids in the samples were below the detection limits. Therefore, Total Organic Carbon was the only category continued for the samples".
 - The Report also only provided two samples (initial two samples) TSS data (ND at <3.0 mg/l) which prevented correlation to TSS concentrations at higher TSS concentration levels.
 - The Table provided TOC concentrations instead (in the range of 2.30 mg/l – 3.60 mg/l).
 - The pH range was 7.16 – 7.92 SU.
- Exhibit B (Cross-Section Sample Point Section B-B, Big Wapwallopen Creek): Table (3/27/2020 – 9/17/2020 measurement data, 22 data points) provided for Velocity, "Distance from Top or Rebar to Water Surface", "Depth of Water at Rebar"; "Cross Sectional Area (A) in sqft at Sampling Point" and "Flow Rate (Q) Cubic Feet/Second" provided. However, no statistical analysis was provided to calculate average velocity at Q7-10 low flow and/or evaluation of data in terms of Q7-10 low flows.

- Exhibit C (Sealed Cross-Section B-B Drawing): The figures show Cross-Section B-B but not relation to Outfall No. 001 location. Stream (3/5/2020) is shown at ~24 feet in width and 1.55 feet deep at deepest. Cross-flow area was calculated to be 26 square feet.
- Exhibit D (Effluent Zinc Hourly Coefficient of Variation): Table of measurements (date, time, Total Zinc concentration, lognormal Total Zinc concentration, Variance provided. Estimated 0.058078954 Long Term Average, with Variance of 0.000217393, and estimated hourly COV of 25%. 6 days of measurements with 4 – 5 sample points per day.
- Exhibit E (Effluent Zinc Daily Coefficient of Variability): Table of 39 data points (10/28/2019 – 9/15/2020, samples less than weekly apart and skipping months) was used to calculate the COV. The LTA was estimated at 0.0434594 mg/l with 0.000231163 daily COV, and “AMEC” of 0.000866029. See Effluent Section for TOXCONC-calculated LTAMEC and Daily COV using a 12-month data set (June 2023 – 2024), used in the updated Reasonable Potential Analysis.

Discharge, Receiving Waters and Water Supply Information

Outfall No. 002 and 003
41° 6' 55.50" (002)
Latitude 41° 6' 50.48" (003)
Quad Name Freeland
Wastewater Description: Stormwater

Design Flow (MGD) 0 (stormwater only)
-75° 57' 37.75" (002)
Longitude -75° 57' 37.61" (003)
Quad Code 1038

Receiving Waters Unnamed Tributary to Big Wapwallopen Creek (CWF, MF)
NHD Com ID 65636531
Drainage Area -
Q₇₋₁₀ Flow (cfs) -
Elevation (ft) -
Watershed No. 5-B
Existing Use -
Exceptions to Use -
Assessment Status E-maps indicates this UNT supports aquatic life
Cause(s) of Impairment -
Source(s) of Impairment -
TMDL Status -

Stream Code -
RMI 0.19 (002)
Yield (cfs/mi²) 0.10 (003)
Q₇₋₁₀ Basis -
Slope (ft/ft) -
Chapter 93 Class. CWF, MF
Existing Use Qualifier -
Exceptions to Criteria -

Background/Ambient Data: None available
pH (SU) -
Temperature (°F) -
Hardness (mg/L) -
Other: -

Data Source
DANVILLE BORO MUNI AUTH (ID# 101934-001)
Flow at Intake (cfs) -
Distance from Outfall (mi) ~41

Changes Since Last Permit Issuance: None known

Other Comments: This ~0.224 mile UNT is parallel and adjacent to I-81, and receives highway runoff (in addition to Treatment plant stormwater discharges).

| Treatment Facility Summary | | |
|---|---------------|--|
| Treatment Facility Name: Mountaintop Area Joint San Authority POTW | | |
| WQM Permit No. | Issuance Date | Scope |
| 4073404-T1 | 10/28/1976 | Original permit for collection and treatment of sewage transferred to MASJA. |
| 4099405 | 2/17/2000 | WWTP Expansion to 4.16 MGD, including new screening building, three aeration basins, new clarifiers, an aerobic digester, chlorine contact tank, sludge recirculation, and replacement of some existing equipment. |
| 4006403 | 5/12/2006 | Transformation of existing aerobic digesters to partitioned anaerobic/anoxic tanks (BNR process), two existing clarifiers to be converted to aerobic digesters, converting to UV disinfection, and installation of a 90-foot clarifier, an additional aerobic digester, and new gravity belt thickener. The WQM Application Module 1 identified the expected organic load capacity at 4,600 lbs BOD ₅ /day. |
| 4009401 | 5/13/2009 | Installation of 3 million-gallon EQ tank, a potassium permanganate feed system, a replacement sluice gate and concrete channels, piping, valves, and appurtenance. All done according to Authority. |
| 4013401 | 10/22/2013 | WQM Part II Permit to demolish a WWTP belt filter press, install new WWTP centrifuge for sludge dewatering, and improve (offsite) pump stations at I81 N/S Rest stops. Additional work at the treatment plant includes the installation of covers over the flumes conveying effluent to the clarifiers in an effort to minimize algae growth. <u>NOTE:</u> Construction certification for Centrifuge received 11/5/2013. Construction certification for pump stations received 5/9/2014. |

| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
|--------------------------|----------------------------|--------------------------------------|---------------------|------------------------|
| Sewage | Tertiary | Activated Sludge With Solids Removal | Ultraviolet | 4.16 |
| <hr/> | | | | |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 4.16 | 4600 | Not Overloaded | Anaerobic Digestion | Landfill |

Changes Since Last Permit Issuance: None known.

Other Comments:

Treatment Plant:

- Application indicates plans for a grit removal building with two automatic rag screens, grit chamber and grit removal conveyance system within the 5-year NPDES permit term. 2/16/2024 DEP Letter indicated a grit removal system could be installed without a WQM permit.
- Application indicates wastewater treatment chemicals include Soda Ash (influent pH adjustment), DEL PAC 2000 (for phosphorus removal and water polisher), and Defoamer.
- No hauled-in wastes.
- Facility has a 2.9-MG influent flow equalization tank that helps with peak wet weather influent flows. Several EQ Tank overflows have occurred but there has been I&I work at one (Walden Park) pump station area to eliminate overflows.
- 10/31/2025 DEP Inspection report indicated: One (1) influent screen, one (1) comminutor (muffin monster), one (1) secondary bar screen for rag removal), one (1) EQ Tank/Basin, three (3) Aeration basins, three (3)

nitrification/denitrification systems (aerobic and anoxic tanks), two (2) secondary clarifiers, and UV disinfection (two UV chambers). One (1) sludge thickener (centrifuge) and three (3) sludge digesters.

- Influent sampling data included low BOD5 (35 mg/l) and TSS (17 mg/l) values indicating times of high I&I contributions in the collection system.

2023 Chapter 94 Report (Upload No. 222612):

- Form Items 1, 2, 3, and 9: No existing or projected overloading.
 - Hydraulic Loading: 3.32 MGD 3-month Average for 4.16 MGD Hydraulic Design Capacity.
 - Organic Loading: 4,103 lbs BOD5/day max month for 4,600 lbs BOD5/day Organic Design Capacity.
 - Existing EDUs: 7,422 EDUs (3.5 persons per EDU, decreasing from 8,000 EDUs for 2022. Trending decrease in EDUs since 2019 (8,675 EDUs).
 - Cause of decreasing EDUs trend was not explained.
 - NPDES Permit Renewal Application indicated ~14,662 persons in service. This would be 5865 EDUs at 2.5 persons/EDU for comparison with expected dry weather sewage loading of 1.466 MGD (in absence of any industrial contribution) and 2,496 lbs BOD5/day per DWFM defaults.
 - Load/Capita: 0.089 lbs BOD5/day. DWFM default assumption is 0.17 lbs/capita for comparison.
- Form Item 4 (Sewer Extensions) & Attachment C: Attachment C figure provided showing "Heritage Oaks" development, without any other identified sewer extension (constructed or proposed).
- Form Item 5 (Sewer System monitoring/maintenance): Smoke testing has begun in the Walden Park Pump Station basin. Attachment D summarized other O&M work, but no breakdown by area. Attachment had WWTP O&M activities listed.
- Form Item 6 (Capacity exceedances): Walden Park SSOs due to stormwater inflow issues. Smoke testing and pump station rehab indicated in progress. Attachment E included SSO reports, but lacked a copy of the Corrective Action Plan for the Walden Park Pump Station/basin overflows and I&I issues. The report also did not mention the (issued) separate WQM permit application for a replacement sewer system the (Fairview) Glen Summit Development sewer system which would replace a failing sewer system area.
- Form Item 7 (Pump Stations): Eight (8) pump stations. Attachment F included 2023 Pump Station Draw Down Results per pump, not actual flow data by meter or estimation. For example, no information on Walden Pump Station flows given to clarify overload issues. Only two (2) pumps identified at the different pump stations.
Identified capacities:
 - Walden Park PS: 410 and 405 GPM capacities
 - Nuangola Elementary PS: 285 GPM (for each of the two pumps)
 - I-81 Southbound PS: 35 GPM (for each of the two pumps)
 - I-81 Northbound PS: 24 GPM (for each of the two pumps)
 - McDonalds PS: 42 GPM and 50 GPM
 - Lehigh Street PS: 20 GPM (for each of the two pumps)
 - Fawn Lake PS: 80 GPM (for each of the two pumps)
 - Ice Lakes PS: 125 GPM and 110 GPM
- Form Item 8 (IW):
 - IPP Annual Report not attached (NPDES Permit Part B.I.C.4.e and Part C.VIII.D). Attachment G indicated MAJSA adopted EPA-approved local limits on 4/19/2023 (Resolution 2-4-19-2023), with full EPA approval of the IPP on 11/2/2023. Annual IPP Report will be required in the next Chapter 94 Report.
 - Attachment G included Industrial Waste Report that indicated 5 SIUs.
 - Item 8.a (Applicable ordinance/reg): No copy of ordinance/reg included. Given adoption of local limits, this is problematic.
 - Item 8.b (Monitoring Program): Influent monitoring and IU monitoring data provided.
 - Item 8.c (problems): Several NOVs issued to IUs.
- Form Item 10 (Sewage Sludge Management Inventory): Attachment H included the DEP Operator worksheet for the required Sewage Sludge Management Inventory. The Sludge Production and Wasting Calculations were outside expected range (85 – 115%) with 83% (based on Chapter 94 Report) and 77% (based on Population).
- Form Item 12 (Flow Meter Calibration Report): Attachment I included WWTP effluent flow meter, UV channel flow meters, "North Bound PS", "Walden Park PS", "South Bound PS" calibration reports. No Calibration reports for Nuangola/Elementary School PS, McDonald PS, Lehigh Street PS, Fawn Lane PS, and Ice Lakes PS.

Compliance History

DMR Data for Outfall 001 (from February 1, 2024 to January 31, 2025)

| Parameter | JAN-25 | DEC-24 | NOV-24 | OCT-24 | SEP-24 | AUG-24 | JUL-24 | JUN-24 | MAY-24 | APR-24 | MAR-24 | FEB-24 |
|---|--------|--------|--------|--------|--------|-------------|--------|--------|--------|-------------|-------------|--------|
| Flow (MGD) Average Monthly | 2.39 | 2.78 | 2.17 | 1.88 | 2.05 | 2.63 | 2.11 | 2.24 | 2.81 | 3.73 | 4.12 | 2.93 |
| Flow (MGD) Daily Maximum | 3.54 | 6.44 | 3.79 | 2.21 | 2.85 | 7.98 | 2.51 | 2.77 | 3.77 | 7.87 | 6.49 | 5.99 |
| pH (S.U.) Instantaneous Minimum | 6.71 | 6.37 | 6.56 | 7.06 | 6.99 | 6.74 | 6.96 | 6.94 | 6.86 | 6.53 | 6.57 | 6.67 |
| pH (S.U.) Instantaneous Maximum | 7.44 | 7.42 | 7.51 | 7.48 | 7.41 | 7.42 | 7.51 | 7.26 | 7.14 | 7.1 | 6.91 | 7.04 |
| DO (mg/L) Instantaneous Minimum | 7.9 | 7.4 | 7.0 | 6.7 | 7.1 | 7.2 | 6.8 | 7.2 | 7.4 | 7.1 | 7.1 | 7.2 |
| TRC (mg/L) Average Monthly | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG |
| TRC (mg/L) Instantaneous Maximum | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG |
| CBOD5 (lbs/day) Average Monthly | < 63.3 | < 59.6 | < 54.2 | < 47.1 | < 50.9 | < 61.6 | < 53.8 | < 56.4 | < 69.8 | < 86.3 | < 107.0 | < 67.2 |
| CBOD5 (lbs/day) Weekly Average | < 93.0 | < 76.6 | < 75.1 | < 48.8 | < 57.0 | < 75.1 | < 57.9 | < 58.5 | 70.8 | < 110.3 | < 147.2 | < 75.3 |
| CBOD5 (mg/L) Average Monthly | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 |
| CBOD5 (mg/L) Weekly Average | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 |
| BOD5 (lbs/day) Influent Average Monthly | 1919 | 1859 | 2233 | 1900 | 1696 | 1551 | 1986 | 1840 | 2299 | 2092 | 2239 | 1953 |
| BOD5 (lbs/day) Influent Daily Maximum | 4624 | 2790 | 2837 | 2908 | 2262 | 2010 | 2606 | 2114 | 2724 | 3409 | 3461 | 2262 |
| BOD5 (mg/L) Influent Average Monthly | 90.4 | 96.1 | 128.3 | 123.3 | 101.3 | 77.2 | 110.9 | 98.1 | 98.9 | 76 | 62.2 | 87.5 |

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

| | | | | | | | | | | | | |
|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|---------|---------|--------|
| BOD5 (mg/L) Influent Daily Maximum | 176 | 148 | 170 | 197 | 155 | 92.7 | 148 | 119 | 115 | 140 | 95.1 | 100 |
| CBOD5 % Removal (%) Minimum Monthly Average | 96 | 96 | 97 | 97 | 97 | 96 | 97 | 97 | 96 | 94 | 93 | 96 |
| TSS (lbs/day) Average Monthly | < 50.9 | < 54.4 | < 45.1 | < 39.2 | < 42.4 | < 51.3 | < 45.2 | < 47.0 | < 58.1 | < 84.6 | < 104.9 | < 60.2 |
| TSS (lbs/day) Influent Average Monthly | 1562 | 1908 | < 2262 | 2530 | 2228 | 2298 | 2472 | 2431 | 2556 | 2075 | 2167 | 2450 |
| TSS (lbs/day) Influent Daily Maximum | 3402 | 3110 | 3157 | 3394 | 2573 | 4470 | 3183 | 2936 | 3278 | 2755 | 3875 | 3172 |
| TSS (lbs/day) Weekly Average | < 68.1 | < 63.8 | < 62.6 | < 40.7 | < 47.5 | < 62.6 | < 50.2 | < 48.8 | < 59.0 | < 141.7 | < 123.5 | < 67.7 |
| TSS (mg/L) Average Monthly | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 |
| TSS (mg/L) Influent Average Monthly | 79.3 | 98.7 | < 136 | 165 | 132 | 113 | 139 | 130 | 110 | 75 | 60.2 | 111 |
| TSS (mg/L) Daily Maximum | < 2.5 | 4.5 | < 2.5 | < 2.5 | < 2.5 | < 2.5 | 2.7 | < 2.5 | < 2.5 | < 6.25 | < 6.25 | < 3.0 |
| TSS (mg/L) Influent Daily Maximum | 188 | 165 | 228 | 238 | 158 | 203 | 188 | 163 | 150 | 112 | 88 | 154 |
| TSS % Removal (%) Minimum Monthly Average | 96 | 97 | 97 | 98 | 98 | 97 | 98 | 98 | 98 | 95 | 93 | 97 |
| Fecal Coliform (No./100 ml) Geometric Mean | < 3 | 2 | < 2 | < 2 | < 2 | < 2 | < 3 | 25 | 17 | 10 | 5 | 3 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 10.9 | 5.2 | 6.3 | 7.3 | 7.5 | 6.3 | 8.5 | 387.3 | 68.4 | 54.6 | 35 | 10.9 |
| UV Intensity (μ w/cm ²) Instantaneous Minimum | 24.53 | 24.04 | 24.26 | 24.04 | 24.07 | 24.3 | 24.24 | 24.1 | 24.1 | 23.56 | 24.05 | 24.04 |
| Nitrate-Nitrite (mg/L) Average Monthly | 3.54 | 3.17 | 3.59 | 5.04 | 4.55 | 4.37 | 3.94 | 3.75 | 4.32 | 3.48 | 3.13 | 2.96 |
| Nitrate-Nitrite (mg/L) Daily Maximum | 4.93 | 3.77 | 4.35 | 6.02 | 5.75 | 5.2 | 4.37 | 4.27 | 5.07 | 6.31 | 4.55 | 3.35 |

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

| | | | | | | | | | | | |
|------------------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|-------|--------|
| Nitrate-Nitrite (lbs) | | | | | | | | | | | |
| Total Monthly | 2165 | 1927 | 1862 | 2467 | 2297 | 2763 | 2186 | 2119 | 3107 | 2804 | 3303 |
| Total Nitrogen (mg/L) | | | | | | | | | | | |
| Average Monthly | 4.3 | < 3.72 | 4.36 | 5.91 | 5.47 | < 5.08 | 4.82 | 4.72 | 5.09 | 4.61 | 4.41 |
| Total Nitrogen (mg/L) | | | | | | | | | | | |
| Daily Maximum | 5.85 | 4.35 | 5.1 | 7.14 | 6.52 | 6.11 | 6.27 | 5.66 | 5.96 | 7.38 | 7.09 |
| Total Nitrogen (lbs) | | | | | | | | | | | |
| Effluent Net | | | | | | | | | | | |
| Total Monthly | 2631 | < 2269 | 2268 | 2891 | 2769 | < 3213 | 2678 | 2667 | 3663 | 3771 | 4527 |
| Total Nitrogen (lbs) | | | | | | | | | | | |
| Total Monthly | 2631 | < 2269 | 2268 | 2891 | 2769 | < 3213 | 2678 | 2667 | 3663 | 3771 | 4527 |
| Total Nitrogen (lbs) | | | | | | | | | | | |
| Effluent Net | | | | | | | | | | | |
| Total Annual | | | | | < 39999 | | | | | | |
| Total Nitrogen (lbs) | | | | | | | | | | | |
| Total Annual | | | | | < 39999 | | | | | | |
| Ammonia (lbs/day) | | | | | | | | | | | |
| Average Monthly | < 1.8 | < 1.7 | < 1.6 | < 1.4 | < 2.7 | < 2.4 | < 1.6 | < 1.6 | < 2.0 | 13.6 | 19.9 |
| Ammonia (mg/L) | | | | | | | | | | | |
| Average Monthly | < 0.0876 | < 0.0876 | < 0.0877 | < 0.0876 | < 0.1574 | < 0.1128 | < 0.0876 | < 0.0876 | < 0.0876 | 0.468 | 0.7175 |
| Ammonia (mg/L) | | | | | | | | | | | |
| Daily Maximum | < 0.0876 | < 0.0876 | 0.0881 | < 0.0876 | 0.692 | 0.251 | 0.0878 | < 0.0876 | < 0.0876 | 1.56 | 2.73 |
| Ammonia (lbs) | | | | | | | | | | | |
| Total Monthly | < 55.3 | < 54.0 | < 47.5 | < 42.6 | < 82.5 | < 73.1 | < 48.7 | < 49.4 | < 63.2 | 409.3 | 617.7 |
| Ammonia (lbs) | | | | | | | | | | | |
| Total Annual | | | | | < 1936 | | | | | | |
| TKN (mg/L) | | | | | | | | | | | |
| Average Monthly | 0.752 | < 0.548 | 0.768 | 0.87 | 0.918 | < 0.708 | 0.881 | 0.968 | 0.771 | 1.131 | 1.278 |
| TKN (mg/L) | | | | | | | | | | | |
| Daily Maximum | 0.937 | 0.626 | 1.01 | 1.12 | 1.49 | 0.905 | 1.9 | 1.64 | 0.894 | 2.41 | 3.45 |
| TKN (lbs) | | | | | | | | | | | |
| Total Monthly | 465 | < 341 | 406 | 424 | 472 | < 450 | 491 | 548 | 556 | 967 | 1224 |
| Total Phosphorus | | | | | | | | | | | |
| (lbs/day) | | | | | | | | | | | |
| Average Monthly | 18 | 18 | 22 | 38 | 21 | 16 | 21 | 20 | 18 | 15 | 21 |
| Total Phosphorus | | | | | | | | | | | |
| (mg/L) | | | | | | | | | | | |
| Average Monthly | 0.872 | 0.939 | 1.3 | 2.44 | 1.273 | 0.819 | 1.189 | 1.058 | 0.766 | 0.556 | 0.661 |
| Total Phosphorus | | | | | | | | | | | |
| (mg/L) | | | | | | | | | | | |
| Daily Maximum | 1.43 | 1.28 | 1.94 | 2.88 | 1.87 | 1.2 | 1.7 | 1.72 | 0.938 | 1.05 | 1.3 |
| Total Phosphorus (lbs) | | | | | | | | | | | |
| Effluent Net | | | | | | | | | | | |
| Total Monthly | 561 | 561 | 653 | 1182 | 636 | 498 | 659 | 597 | 554 | 456 | 661 |
| | | | | | | | | | | | 724 |

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

| | | | | | | | | | | | | |
|--|---------|---------------|---------|---------|----------|---------|---------|----------|---------|---------|-----------|-----------|
| Total Phosphorus (lbs) Total Monthly | 561 | 561 | 653 | 1182 | 636 | 498 | 659 | 597 | 554 | 456 | 661 | 724 |
| Total Phosphorus (lbs) Effluent Net Total Annual | | | | | 9335 | | | | | | | |
| Total Phosphorus (lbs) Total Annual | | | | | 9335 | | | | | | | |
| Total Cadmium (lbs/day) Average Monthly | GG | GG | GG | GG | < 0.005 | GG | GG | < 0.01 | GG | GG | < 0.01 | GG |
| Total Cadmium (lbs/day) Daily Maximum | GG | GG | GG | GG | < 0.005 | GG | GG | < 0.01 | GG | GG | < 0.01 | GG |
| Total Cadmium (mg/L) Average Monthly | GG | GG | GG | GG | < 0.0003 | GG | GG | < 0.0006 | GG | GG | < 0.0006 | GG |
| Total Cadmium (mg/L) Daily Maximum | GG | GG | GG | GG | < 0.0003 | GG | GG | < 0.0006 | GG | GG | < 0.0006 | GG |
| Total Chromium (lbs/day) Average Monthly | GG | GG | GG | GG | < 0.06 | GG | GG | < 0.07 | GG | GG | < 0.1 | GG |
| Total Chromium (lbs/day) Daily Maximum | GG | GG | GG | GG | < 0.06 | GG | GG | < 0.07 | GG | GG | < 0.1 | GG |
| Total Chromium (mg/L) Average Monthly | GG | GG | GG | GG | < 0.0035 | GG | GG | < 0.004 | GG | GG | < 0.004 | GG |
| Total Chromium (mg/L) Daily Maximum | GG | GG | GG | GG | < 0.0035 | GG | GG | < 0.004 | GG | GG | < 0.004 | GG |
| Total Copper (lbs/day) Average Monthly | 0.06 | 0.1 | 0.05 | 0.04 | < 0.08 | < 0.1 | < 0.1 | < 0.1 | < 0.2 | < 0.2 | < 0.2 | < 0.2 |
| Total Copper (lbs/day) Daily Maximum | 0.07 | 0.4 | 0.07 | 0.05 | < 0.1 | < 0.2 | < 0.1 | < 0.1 | 0.2 | < 0.3 | 0.4 | 0.3 |
| Total Copper (mg/L) Average Monthly | 0.00296 | 0.00683 | 0.00298 | 0.00316 | < | < | < | < | 0.00702 | < 0.007 | < 0.00642 | < 0.01017 |
| Total Copper (mg/L) Daily Maximum | 0.00346 | 0.0176 | 0.00356 | 0.00387 | < 0.007 | 0.00791 | 0.00778 | 0.0082 | 0.00707 | < 0.007 | 0.00786 | 0.0134 |
| Total Nickel (lbs/day) Average Monthly | 0.06 | 0.05 | 0.05 | 0.04 | < 0.1 | < 0.3 | < 0.2 | < 0.2 | < 0.3 | < 0.4 | < 0.4 | < 5 |
| Total Nickel (lbs/day) Daily Maximum | 0.08 | 0.08 | 0.06 | 0.05 | < 0.3 | < 0.3 | < 0.2 | < 0.2 | < 0.3 | < 0.5 | < 0.7 | < 21 |
| Total Nickel (mg/L) Average Monthly | 0.00289 | 0.00291 | 0.0031 | 0.00301 | < | 0.00609 | < 0.013 | < 0.013 | < 0.011 | < 0.013 | < 0.011 | < 0.263 |

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

| | | | | | | | | | | | | |
|--|--------------|---------|---------------|---------|----------|---------|---------|---------|---------|---------|---------|---------|
| Total Nickel (mg/L) Daily Maximum | 0.00412 | 0.00345 | 0.0043 | 0.00316 | < 0.013 | < 0.013 | < 0.013 | < 0.013 | < 0.013 | < 0.013 | < 0.013 | < 1.013 |
| Total Silver (lbs/day) Average Monthly | GG | GG | GG | GG | < 0.009 | GG | GG | < 0.02 | GG | GG | < 0.02 | GG |
| Total Silver (lbs/day) Daily Maximum | GG | GG | GG | GG | < 0.009 | GG | GG | < 0.02 | GG | GG | < 0.02 | GG |
| Total Silver (mg/L) Average Monthly | GG | GG | GG | GG | < 0.0005 | GG | GG | < 0.001 | GG | GG | < 0.001 | GG |
| Total Silver (mg/L) Daily Maximum | GG | GG | GG | GG | < 0.0005 | GG | GG | < 0.001 | GG | GG | < 0.001 | GG |
| Total Zinc (lbs/day) Average Monthly | 1.00 | 1.00 | 0.90 | 0.60 | 0.50 | 0.30 | 0.70 | 0.50 | 0.70 | 0.90 | 1.00 | 1.00 |
| Total Zinc (lbs/day) Daily Maximum | 2 | 2.0 | 1.0 | 0.7 | 1.0 | 0.4 | 1 | 0.60 | 0.80 | 1.0 | 2 | 1 |
| Total Zinc (mg/L) Average Monthly | 0.052 | 0.0525 | 0.0513 | 0.0407 | 0.0335 | 0.0154 | 0.0404 | 0.0286 | 0.0287 | 0.0332 | 0.0339 | 0.0463 |
| Total Zinc (mg/L) Daily Maximum | 0.115 | 0.0684 | 0.0883 | 0.0496 | 0.0736 | 0.0162 | 0.0878 | 0.0338 | 0.036 | 0.042 | 0.0364 | 0.0503 |
| Total Toxic Organics (lbs/day) Average Monthly | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG |
| Total Toxic Organics (lbs/day) Daily Maximum | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG |
| Total Toxic Organics (mg/L) Average Monthly | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG |
| Total Toxic Organics (mg/L) Daily Maximum | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG |
| TOC (lbs/day) Average Monthly | 105 | 83 | 91 | 88 | 91 | 114 | 120 | 114 | 119 | 140 | 150 | 111 |
| TOC (lbs/day) Daily Maximum | 133 | 93 | 135 | 93 | 112 | 140 | 194 | 140 | 151 | 177 | 205 | 136 |
| TOC (mg/L) Average Monthly | 5.24 | 4.72 | 5.17 | 6.17 | 5.53 | 5.63 | 6.91 | 6.27 | 5.16 | 4.96 | 4.05 | 4.99 |
| TOC (mg/L) Daily Maximum | 6.42 | 6.42 | 7.58 | 6.43 | 6.74 | 7.04 | 11 | 7.78 | 6.38 | 5.47 | 4.53 | 5.39 |
| Chronic WET - Ceriodaphnia Survival (TUC) Daily Maximum | | GG | | | 1.25 | | | GG | | | GG | |

| | | | | | | | | | | | | |
|--|--|----|--|--|------|--|--|----|--|--|----|--|
| Chronic WET - Ceriodaphnia Reproduction (TUC) Daily Maximum | | GG | | | 1.25 | | | GG | | | GG | |
|--|--|----|--|--|------|--|--|----|--|--|----|--|

DMR Data for Outfall 002 (from February 1, 2024 to January 31, 2025)

| Parameter | JAN-25 | DEC-24 | NOV-24 | OCT-24 | SEP-24 | AUG-24 | JUL-24 | JUN-24 | MAY-24 | APR-24 | MAR-24 | FEB-24 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| pH (S.U.) Instantaneous Minimum | | 6.73 | | | | | | 6.53 | | | | |
| pH (S.U.) Instantaneous Maximum | | 6.73 | | | | | | 6.53 | | | | |
| TSS (mg/L) Instantaneous Maximum | | 2.9 | | | | | | 16.7 | | | | |
| Oil and Grease (mg/L) Instantaneous Maximum | | < 4.78 | | | | | | < 5.0 | | | | |
| TKN (mg/L) Instantaneous Maximum | | < 0.5 | | | | | | < 0.5 | | | | |
| Total Iron (mg/L) Instantaneous Maximum | | < 0.2 | | | | | | 0.548 | | | | |

DMR Data for Outfall 003 (from February 1, 2024 to January 31, 2025)

| Parameter | JAN-25 | DEC-24 | NOV-24 | OCT-24 | SEP-24 | AUG-24 | JUL-24 | JUN-24 | MAY-24 | APR-24 | MAR-24 | FEB-24 |
|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| pH (S.U.) Instantaneous Minimum | | 6.64 | | | | | | 6.62 | | | | |
| pH (S.U.) Instantaneous Maximum | | 6.64 | | | | | | 6.62 | | | | |
| TSS (mg/L) Instantaneous Maximum | | < 2.58 | | | | | | 4.5 | | | | |

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

| | | | | | | | | | | | | |
|--|--|--------|--|--|--|--|--|-------|--|--|--|--|
| Oil and Grease (mg/L) Instantaneous Maximum | | < 4.95 | | | | | | < 5.0 | | | | |
| TKN (mg/L) Instantaneous Maximum | | < 0.5 | | | | | | < 0.5 | | | | |
| Total Iron (mg/L) Instantaneous Maximum | | 0.214 | | | | | | 0.237 | | | | |

DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)

| Parameter | MAR-24 | FEB-24 | JAN-24 | DEC-23 | NOV-23 | OCT-23 | SEP-23 | AUG-23 | JUL-23 | JUN-23 | MAY-23 | APR-23 |
|-------------------------------------|---------|--------|-------------|--------------|--------|--------|--------|--------|--------|--------|-------------|--------|
| Flow (MGD) Average Monthly | 4.12 | 2.93 | 4.27 | 4.11 | 2.66 | 3.19 | 3.1 | 2.96 | 2.71 | 2.16 | 3.27 | 2.39 |
| Flow (MGD) Daily Maximum | 6.49 | 5.99 | 5.54 | 11.42 | 3.64 | 5.85 | 5.15 | 5.14 | 3.98 | 3.73 | 9.02 | 2.8 |
| pH (S.U.) Instantaneous Minimum | 6.57 | 6.67 | 6.39 | 6.18 | 6.44 | 6.35 | 6.58 | 6.7 | 6.61 | 6.80 | 6.60 | 6.68 |
| pH (S.U.) Instantaneous Maximum | 6.91 | 7.04 | 7.12 | 7.12 | 7.26 | 7.04 | 7.06 | 7.13 | 7.24 | 7.16 | 7.21 | 7.1 |
| DO (mg/L) Instantaneous Minimum | 7.1 | 7.2 | 7.2 | 7.8 | 8.4 | 7.2 | 7.1 | 7.1 | 7.7 | 7.0 | 7.0 | 7.0 |
| TRC (mg/L) Average Monthly | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG |
| TRC (mg/L) Instantaneous Maximum | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG | GG |
| CBOD5 (lbs/day) Average Monthly | < 107.0 | < 67.2 | < 93.6 | < 116.6 | < 65.9 | < 78.9 | < 87.4 | < 69.6 | < 69.6 | < 57.8 | < 57.8 | < 44.1 |
| CBOD5 (lbs/day) Weekly Average | < 147.2 | < 75.3 | < 133.9 | < 176.8 | < 84.6 | < 94.1 | 126.9 | < 74.6 | < 86.6 | < 76.6 | < 106.6 | < 53.3 |
| CBOD5 (mg/L) Average Monthly | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 2.0 | < 2.0 |
| CBOD5 (mg/L) Weekly Average | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 |

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

| | | | | | | | | | | | | |
|--|---------|--------|---------|---------|--------|--------|---------|---------|--------|---------|---------|--------|
| BOD5 (lbs/day) Influent Average Monthly | 2239 | 1953 | 2474 | 2470 | 2006 | 1826 | 2493 | 1866 | 1211 | 1396 | 1976 | 2488 |
| BOD5 (lbs/day) Influent Daily Maximum | 3461 | 2262 | 3785 | 3473 | 2371 | 2293 | 3521 | 3229 | 2108 | 1974 | 2632 | 3542 |
| BOD5 (mg/L) Influent Average Monthly | 62.2 | 87.5 | 80.7 | 71.3 | 94.1 | 71.8 | 90.2 | 80.7 | 51.7 | 80 | 88 | 121 |
| BOD5 (mg/L) Influent Daily Maximum | 95.1 | 100 | 118 | 109 | 115 | 101 | 159 | 120 | 78 | 133 | 167 | 164 |
| CBOD5 % Removal (%) Minimum Monthly Average | 93 | 96 | 95 | 95 | 96 | 94 | 95 | 95 | 93 | 95 | 96 | 98 |
| TSS (lbs/day) Average Monthly | < 104.9 | < 60.2 | < 88.3 | < 201.9 | < 59.0 | < 91.5 | < 88.8 | < 97.4 | < 58.0 | < 61.4 | < 80.1 | < 64.7 |
| TSS (lbs/day) Influent Average Monthly | 2167 | 2450 | 2960 | 3354 | 2546 | 2240 | 2810 | 2583 | 1685 | 1285 | 1684 | 2037 |
| TSS (lbs/day) Influent Daily Maximum | 3875 | 3172 | 7248 | 6030 | 3348 | 3696 | 5244 | 6576 | 5661 | 2728 | 3342 | 3348 |
| TSS (lbs/day) Weekly Average | < 123.5 | < 67.7 | < 144.7 | 519.7 | < 86.0 | 114.6 | < 149.4 | < 233.4 | < 72.1 | < 117.1 | < 159.9 | < 74.6 |
| TSS (mg/L) Average Monthly | < 3.0 | < 3.0 | < 3.0 | < 5.0 | < 3.0 | < 3.0 | < 3.0 | < 4.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 |
| TSS (mg/L) Influent Average Monthly | 60.2 | 111 | 94.2 | 99 | 119 | 87.6 | 100.4 | 110.8 | 70.7 | 70.4 | 79 | 99 |
| TSS (mg/L) Daily Maximum | < 6.25 | < 3.0 | 3.9 | 14.3 | < 3.57 | 5.6 | 4.6 | < 14.3 | 2.5 | 6.32 | | |
| TSS (mg/L) Influent Daily Maximum | 88 | 154 | 153 | 180 | 174 | 160 | 175 | 282 | 181 | 155 | 212 | 159 |
| TSS (mg/L) Weekly Average | | | | | | | | | | | < 3.0 | < 4.0 |
| TSS % Removal (%) Minimum Monthly Average | 93 | 97 | 97 | 92 | 98 | 94 | 97 | 95 | 95 | 95 | 94 | 96 |
| Fecal Coliform (No./100 ml) Geometric Mean | 5 | 3 | < 3 | < 2 | < 3 | 3 | < 3 | < 4 | < 3 | < 2 | < 2 | 3 |

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

| | | | | | | | | | | | | |
|--|---------------|--------------------|--------------|--------------------|--------------------|---------------|--------------------|--------------------|--------------------|--------------------|-------------------|-------------|
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 35 | 10.9 | 12.1 | 7.3 | 5.2 | 9.8 | 17.1 | 114.5 | 114.3 | 5.2 | 9.8 | 10 |
| UV Intensity ($\mu\text{w}/\text{cm}^2$) Instantaneous Minimum | 24.05 | 24.04 | 24.09 | 20.2 | 24.0 | 24.02 | 24 | 24.01 | 24.08 | 24.16 | 24.13 | 24.13 |
| Nitrate-Nitrite (mg/L) Average Monthly | 3.13 | 2.96 | 2.65 | 2.68 | 3.74 | 3.71 | 3.60 | 3.14 | 3.707 | 2.995 | < 3.47 | < 3.44 |
| Nitrate-Nitrite (mg/L) Daily Maximum | 4.55 | 3.35 | 3.72 | 3.44 | 5.52 | 6.25 | 8.91 | 4.21 | 5.98 | 4.52 | < 4.34 | < 4.2 |
| Nitrate-Nitrite (lbs) Total Monthly | 3303 | 1931 | 2489 | 3063 | 2419 | 2981 | 3043 | 2231 | 2698 | 1724 | < 2830 | < 2130 |
| Total Nitrogen (mg/L) Average Monthly | 4.41 | 3.81 | < 3.55 | 3.53 | < 4.71 | 4.86 | 4.29 | 3.92 | < 4.57 | 3.94 | < 4.71 | < 4.69 |
| Total Nitrogen (mg/L) Daily Maximum | 7.09 | 4.36 | 4.58 | 4.52 | 6.87 | 7.37 | 9.45 | 5.09 | 6.68 | 5.84 | < 5.34 | < 5.61 |
| Total Nitrogen (lbs) Effluent Net Total Monthly | 4527 | 2477 | < 3349 | 4113 | < 3034 | 3928 | 3646 | 2799 | < 3342 | 2286 | < 3873 | < 2908 |
| Total Nitrogen (lbs) Total Monthly | 4527 | 2477 | < 3349 | 4113 | < 3034 | 3928 | 3646 | 2799 | < 3342 | 2286 | < 3873 | < 2908 |
| Total Nitrogen (lbs) Effluent Net Total Annual | | | | | | | | < 40609 | | | | |
| Total Nitrogen (lbs) Total Annual | | | | | | | | < 40609 | | | | |
| Ammonia (lbs/day) Average Monthly | 19.9 | < 2.4 | 6.7 | < 5.0 | < 2.0 | < 2.9 | < 2.6 | < 2.1 | < 2.6 | < 3.9 | < 13.8 | 8.7 |
| Ammonia (mg/L) Average Monthly | 0.7175 | < 0.1052 | 0.223 | < 0.1208 | < 0.0919 | 0.1139 | < 0.0903 | < 0.0894 | < 0.1047 | < 0.1869 | < 0.591 | 0.41 |
| Ammonia (mg/L) Daily Maximum | 2.73 | 0.182 | 0.488 | 0.278 | 0.122 | 0.279 | 0.103 | 0.095 | 0.236 | 0.416 | 1.12 | 0.91 |
| Ammonia (lbs) Total Monthly | 617.7 | < 69.7 | 208.4 | < 155.4 | < 61.5 | < 90.7 | < 79.5 | < 64.4 | < 79.7 | < 116.4 | < 426.6 | 260.5 |
| Ammonia (lbs) Total Annual | | | | | | | < 1468 | | | | | |
| TKN (mg/L) Average Monthly | 1.278 | 0.844 | < 0.893 | 0.847 | < 0.967 | 1.152 | 0.685 | 0.787 | < 0.86 | 0.947 | < 1.242 | < 1.25 |
| TKN (mg/L) Daily Maximum | 3.45 | 1.01 | 1.24 | 1.73 | 1.35 | 1.81 | 0.793 | 0.994 | 1.45 | 1.6 | 2.02 | 1.97 |
| TKN (lbs) Total Monthly | 1224 | 547 | < 860 | 1050 | < 615 | 947 | 604 | 569 | < 643 | 562 | < 1043 | < 778 |

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

| | | | | | | | | | | | | |
|---|--------------------|-----------|-----------|--------------------|-----------|-----------|--------------------|--------------------|-----------|--------------------|-----------|-----------|
| Total Phosphorus (lbs/day) | | | | | | | | | | | | |
| Average Monthly | 21 | 25 | 23 | 42 | 37 | 47 | 45 | 33 | 43 | 16 | 18 | 15 |
| Total Phosphorus (mg/L) | | | | | | | | | | | | |
| Average Monthly | 0.661 | 1.125 | 0.781 | 1.18 | 1.68 | 1.8 | 1.582 | 1.405 | 1.8 | 0.907 | 0.808 | 0.71 |
| Total Phosphorus (mg/L) | | | | | | | | | | | | |
| Daily Maximum | 1.3 | 1.32 | 1.11 | 1.71 | 2.04 | 2.15 | 2.09 | 2.22 | 2.84 | 2.09 | 1.28 | 1.14 |
| Total Phosphorus (lbs) Effluent Net Total Monthly | | | | | | | | | | | | |
| 661 | 724 | 722 | 1301 | 1096 | 1451 | 1352 | 1026 | 1323 | 481 | 572 | 445 | |
| Total Phosphorus (lbs) Total Monthly | | | | | | | | | | | | |
| 661 | 724 | 722 | 1301 | 1096 | 1451 | 1352 | 1026 | 1323 | 481 | 572 | 445 | |
| Total Phosphorus (lbs) Effluent Net Total Annual | | | | | | | | | | | | |
| | | | | | | | 8795 | | | | | |
| Total Phosphorus (lbs) Total Annual | | | | | | | 8795 | | | | | |
| Total Cadmium (lbs/day) | | | | | | | | | | | | |
| Average Monthly | < 0.01 | GG | GG | < 0.04 | GG | GG | < 0.5 | < 0.01 | GG | < 0.02 | GG | GG |
| Total Cadmium (lbs/day) | | | | | | | | | | | | |
| Daily Maximum | < 0.01 | GG | GG | < 0.04 | GG | GG | < 0.02 | < 0.01 | GG | < 0.02 | GG | GG |
| Total Cadmium (mg/L) Average Monthly | | | | | | | | | | | | |
| < 0.0006 | GG | GG | < 0.0006 | GG | GG | < 0.0006 | < 0.0006 | GG | < 0.0006 | GG | GG | |
| Total Cadmium (mg/L) Daily Maximum | < 0.0006 | GG | GG | < 0.0006 | GG | GG | < 0.0006 | < 0.0006 | GG | < 0.0006 | GG | GG |
| Total Chromium (lbs/day) | | | | | | | | | | | | |
| Average Monthly | < 0.1 | GG | GG | < 0.2 | GG | GG | < 2 | < 0.04 | GG | < 0.1 | GG | GG |
| Total Chromium (lbs/day) | | | | | | | | | | | | |
| Daily Maximum | < 0.1 | GG | GG | < 0.2 | GG | GG | < 0.05 | < 0.05 | GG | < 0.1 | GG | GG |
| Total Chromium (mg/L) Average Monthly | | | | | | | | | | | | |
| < 0.004 | GG | GG | < 0.004 | GG | GG | < 0.002 | < 0.002 | GG | < 0.004 | GG | GG | |
| Total Chromium (mg/L) Daily Maximum | < 0.004 | GG | GG | < 0.004 | GG | GG | < 0.002 | < 0.002 | GG | < 0.004 | GG | GG |
| Total Copper (lbs/day) Average Monthly | < 0.2 | < 0.2 | < 0.2 | < 0.3 | < 0.2 | < 0.2 | < 0.2 | < 0.1 | < 0.2 | < 0.1 | < 0.1 | < 0.08 |

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

| | | | | | | | | | | | | |
|--|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| Total Copper (lbs/day) | | | | | | | | | | | | |
| Daily Maximum | 0.4 | 0.3 | 0.4 | 0.3 | 0.2 | 0.2 | < 0.3 | < 0.2 | 0.4 | < 0.1 | < 0.2 | < 0.08 |
| Total Copper (mg/L) | < | < | < | < | < | < | < | < | < | < | < | < |
| Average Monthly | 0.00642 | 0.01017 | 0.00745 | 0.00675 | 0.00706 | 0.00713 | 0.00695 | < 0.0069 | < 0.0094 | 0.00614 | < 0.004 | < 0.004 |
| Total Copper (mg/L) Daily Maximum | 0.00786 | 0.0134 | 0.00927 | 0.00765 | 0.00724 | 0.00764 | < 0.007 | < 0.007 | 0.0188 | < 0.007 | < 0.007 | < 0.004 |
| Total Nickel (lbs/day) | | | | | | | | | | | | |
| Average Monthly | < 0.4 | < 5 | < 0.4 | < 0.4 | < 0.3 | < 0.3 | < 0.4 | < 0.3 | < 0.3 | < 0.2 | < 0.1 | 0.06 |
| Total Nickel (lbs/day) | | | | | | | | | | | | |
| Daily Maximum | < 0.7 | < 21 | < 0.6 | < 0.6 | < 0.4 | < 0.4 | < 0.5 | < 0.3 | < 0.4 | 0.2 | < 0.2 | 0.06 |
| Total Nickel (mg/L) | | | | | | | | | | | | |
| Average Monthly | < 0.011 | < 0.263 | < 0.013 | < 0.011 | < 0.013 | < 0.013 | < 0.013 | < 0.013 | < 0.013 | < 0.011 | < 0.005 | 0.003 |
| Total Nickel (mg/L) Daily Maximum | < 0.013 | < 1.013 | < 0.013 | 0.003 |
| Total Silver (lbs/day) | | | | | | | | | | | | |
| Average Monthly | < 0.02 | GG | GG | < 0.06 | GG | GG | < 3 | < 0.09 | GG | < 0.03 | GG | GG |
| Total Silver (lbs/day) | | | | | | | | | | | | |
| Daily Maximum | < 0.02 | GG | GG | < 0.06 | GG | GG | < 0.1 | < 0.09 | GG | < 0.03 | GG | GG |
| Total Silver (mg/L) | | | | | | | | | | | | |
| Average Monthly | < 0.001 | GG | GG | < 0.001 | GG | GG | < 0.004 | < 0.004 | GG | < 0.001 | GG | GG |
| Total Silver (mg/L) Daily Maximum | < 0.001 | GG | GG | < 0.001 | GG | GG | < 0.004 | < 0.004 | GG | < 0.001 | GG | GG |
| Total Zinc (lbs/day) | | | | | | | | | | | | |
| Average Monthly | 1.00 | 1.00 | 1.00 | 2.00 | 0.80 | 0.90 | 0.90 | 0.70 | 0.80 | 0.70 | 0.9 | 0.9 |
| Total Zinc (lbs/day) | | | | | | | | | | | | |
| Daily Maximum | 2 | 1 | 2 | 2.00 | 1.0 | 1.0 | 1 | 0.90 | 1.0 | 1.0 | 2.0 | 1.0 |
| Total Zinc (mg/L) | | | | | | | | | | | | |
| Average Monthly | 0.0339 | 0.0463 | 0.0329 | 0.0451 | 0.0346 | 0.0363 | 0.0329 | 0.0351 | 0.0365 | 0.0361 | 0.0353 | 0.046 |
| Total Zinc (mg/L) Daily Maximum | 0.0364 | 0.0503 | 0.0368 | 0.0549 | 0.0407 | 0.044 | 0.0371 | 0.0432 | 0.0454 | 0.0476 | 0.0415 | 0.053 |
| Total Toxic Organics (lbs/day) | | | | | | | | | | | | |
| Average Monthly | GG |
| Total Toxic Organics (lbs/day) | | | | | | | | | | | | |
| Daily Maximum | GG |
| Total Toxic Organics (mg/L) | | | | | | | | | | | | |
| Average Monthly | GG |
| Total Toxic Organics (mg/L) Daily Maximum | GG |
| TOC (lbs/day) | | | | | | | | | | | | |
| Average Monthly | 150 | 111 | 146 | 152 | 115 | 132 | 139 | 120 | 125 | 100 | 111 | 96 |

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

| | | | | | | | | | | | | |
|--|------|------|------|------|------|------|------|------|------|------|------|------|
| TOC (lbs/day) Daily Maximum | 205 | 136 | 195 | 205 | 151 | 167 | 205 | 166 | 200 | 108 | 240 | 107 |
| TOC (mg/L) Average Monthly | 4.05 | 4.99 | 4.73 | 4.59 | 5.41 | 5.17 | 4.95 | 5.61 | 5.55 | 6.37 | 4.22 | 4.87 |
| TOC (mg/L) Daily Maximum | 4.53 | 5.39 | 5.58 | 5.11 | 6.86 | 5.38 | 5.41 | 7.05 | 6.29 | 6.95 | 5.60 | 5.09 |
| Chronic WET - Ceriodaphnia Survival (TUC) Daily Maximum | GG | | | GG | | | 1.25 | | | GG | | |
| Chronic WET - Ceriodaphnia Reproduction (TUC) Daily Maximum | GG | | | GG | | | 1.25 | | | GG | | |

DMR Data for Outfall 002 (from April 1, 2023 to March 31, 2024)

| Parameter | MAR-24 | FEB-24 | JAN-24 | DEC-23 | NOV-23 | OCT-23 | SEP-23 | AUG-23 | JUL-23 | JUN-23 | MAY-23 | APR-23 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| pH (S.U.) Instantaneous Minimum | | | | 7.54 | | | | | | 7.15 | | |
| pH (S.U.) Instantaneous Maximum | | | | 7.54 | | | | | | 7.15 | | |
| TSS (mg/L) Instantaneous Maximum | | | | 4.00 | | | | | | 55.0 | | |
| Oil and Grease (mg/L) Instantaneous Maximum | | | | < 4.76 | | | | | | < 5.0 | | |
| TKN (mg/L) Instantaneous Maximum | | | | 0.514 | | | | | | < 1.00 | | |
| Total Iron (mg/L) Instantaneous Maximum | | | | 0.203 | | | | | | 0.444 | | |

DMR Data for Outfall 003 (from April 1, 2023 to March 31, 2024)

| Parameter | MAR-24 | FEB-24 | JAN-24 | DEC-23 | NOV-23 | OCT-23 | SEP-23 | AUG-23 | JUL-23 | JUN-23 | MAY-23 | APR-23 |
|-----------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|-----------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

| | | | | | | | | | | | | |
|---|--|--|--|--------|--|--|--|--|--|--------|--|--|
| pH (S.U.) Instantaneous Minimum | | | | 6.61 | | | | | | 6.70 | | |
| pH (S.U.) Instantaneous Maximum | | | | 6.61 | | | | | | 6.70 | | |
| TSS (mg/L) Instantaneous Maximum | | | | 8.98 | | | | | | 21.0 | | |
| Oil and Grease (mg/L) Instantaneous Maximum | | | | < 4.85 | | | | | | < 5.0 | | |
| TKN (mg/L) Instantaneous Maximum | | | | 2.56 | | | | | | < 1.00 | | |
| Total Iron (mg/L) Instantaneous Maximum | | | | 0.286 | | | | | | 0.658 | | |

Compliance History

Exceedances: No exceedances reported via EDMR in last 12 months.

Inspection History:

| FACILITY NAME | INSP PROGRAM | INSP ID | INSPECTED DATE | INSP TYPE | UPDATE DATE | # OF VIOLATIONS |
|------------------------------|--------------|-------------------------|----------------|----------------------------|-------------|-------------------|
| MOUNTAINTOP AREA JT SAN AUTH | WPCNP | 3026953 | 10/31/2024 | Administrative/File Review | | 0 |
| MOUNTAINTOP AREA JT SAN AUTH | WPCNP | 3861247 | 11/29/2022 | Compliance Evaluation | | 0 |
| MOUNTAINTOP AREA JT SAN AUTH | WPCNP | 3464064 | 05/18/2021 | Compliance Evaluation | | 0 |
| MOUNTAINTOP AREA JT SAN AUTH | WPCNP | 3193123 | 09/01/2020 | Compliance Evaluation | | 0 |

| | | | | | | |
|---------------------------------|-------|-------------------------|------------|--------------------------|------------|-------------------|
| MOUNTAINTOP AREA JT SAN AUTH | WPCNP | 3074550 | 04/28/2020 | Compliance Evaluation | 10/26/2020 | 1 |
|---------------------------------|-------|-------------------------|------------|--------------------------|------------|-------------------|

Other Comments:

Influent STP EQ Tank Overflows: There was one overflow in 2020 and one in 2023. MAJSA indicate the bypasses were necessary to prevent “severe property damage” but did not specify the exact nature of the avoided “severe property damage” in the application. I&I reduction work at Walden Park PS and WQM permitted sewer replacement project (Fairview Glen Summit) will further reduce peak wet weather influent flows.

Walden Park Pump Station Overflows: There has been a pattern of overflows at this pump station (blamed on groundwater and stormwater I&I). The application indicated smoke testing, inline flow measurements, televising and visual manhole inspections are being done to determine the I&I sources. The single 2023 overflow showed evidence of I&I improvement over the three 2022 overflow events and three 2021 overflow events.

Compliance History: No open violations per 3/20/2025 WMS query (open violation by client number):

Client ID: 169775

Client: All

Open Violations: 0

No data was found using the criteria entered. Please revise your choices and try again.

| Development of Effluent Limitations | | | |
|-------------------------------------|-----------------|-------------------|-----------------|
| Outfall No. | 001 | Design Flow (MGD) | 4.16 |
| Latitude | 41° 6' 47.62" | Longitude | -75° 57' 33.46" |
| Wastewater Description: | Sewage Effluent | | |

Permit Limits and Monitoring Requirements:

| Parameter | Limit (mg/l unless otherwise specified) | SBC | Model/Basis: See Previous Fact Sheets |
|--------------------------------------|---|---|--|
| CBOD ₅ | 346.9 lbs/d 520.4 lbs/d 10.0 15.0 20.0 | Monthly Average Weekly Average Monthly Avg Weekly Avg IMAX | Existing WQBELs (ABACT-based) supported by updated modeling. <u>Application data:</u> 3.06 mg/l max average, 2.62 mg/l LTA, and 5.00 mg/l Max (96 samples) |
| TSS | 346.9 lbs/d 520.4 lbs/d 10.0 15.0 20.0 | Monthly Average Weekly Average Monthly Average Weekly Average IMAX | Existing WQBELs (ABACT-based) <u>Application data:</u> 3.85 mg/l max average, 3.19 mg/l LTA, and 14.3 mg/l Max (95 samples) |
| Ammonia-Nitrogen (May 1 - Oct 31) | Report lbs 66.9 lbs/d 133.9 lb/d 1.93 3.86 3.86 | Annual Total Monthly Average Daily Max Monthly Average Daily Max IMAX | Revised WQBELs from updated water quality modeling that incorporated the revised 2020 WQS. Old WQBELs(2.5 mg/l monthly average and 5.0 mg/l) are not supported. As the POTW have been consistently meeting the new limits, the new limits are effective upon PED. <u>Application data:</u> 0.512 mg/l max average, 0.18 mg/l LTA, and 1.12 mg/l Max (96 samples). See EDMR section. |
| Ammonia-Nitrogen (Nov 1 - Apr 30) | Report lbs 200.8 lbs/d 401.7 lbs/d 5.79 11.58 11.58 | Annual Total Monthly Average Daily Max Monthly Average Daily Max IMAX | See above. Winter multiplier used. |
| Dissolved Oxygen (DO) | 6.0 | Inst. Minimum | Existing WQBEL supported by updated modeling. <u>Application data:</u> 7.0 mg/l instantaneous minimum (333 samples) |
| pH | 6.0 – 9.0 SU | Inst. Min - IMAX | Existing TBEL. <u>Application data:</u> 6.31 - 7.87 SU (333 samples) |
| Fecal Coliform (5/1 – 9/30) | 200/100 ml 1,000/100 ml | Geo Mean IMAX | Existing TBEL limit <u>Application data:</u> 2.03/100 ml max average value, 2.53/100 ml LTA and 121/100 ml max (96 samples) |
| Fecal Coliform (10/1 – 4/30) | 2,000/100 ml 10,000 ml/100 ml | Geo Mean IMAX | No change |
| E Coli | Report/100 ml | IMAX | New monthly reporting requirement due to Chapter 93 WQS. |

| | | | |
|--|--|---|--|
| Total Residual Chlorine (TRC) | 0.05 0.13 | Monthly Average IMAX | Updated WQBEL (when chlorine is used in a manner resulting in discharges). Previous limits were 0.06 mg/l monthly average and 0.14 mg/l IMAX. <u>Application data:</u> None. EDMR was "GG" |
| UV intensity | Report ($\mu\text{w}/\text{cm}^2$) | Inst. Minimum | Existing monitoring requirement. <u>Application data:</u> None. |
| Total Phosphorus | 10185 lbs Report lbs Report lbs/d Report Report | Net Total Annual Total Annual Monthly Average Monthly Average Daily Max | Existing Chesapeake Bay water quality annual mass load limit. <u>Application data:</u> 1.80 mg/l max average, 1.02 mg/l LTA, and 2.84 mg/l Max (95 samples). 24.32 lbs/day LTA. |
| Total Nitrogen (requiring TKN and Nitrate-Nitrite-N monitoring to calculate) | 76318 lbs Report lbs Report lbs/d Report Report | Net Total Annual Total Annual Monthly Average Monthly Average Daily Max | Existing Chesapeake Bay water quality annual mass load limit. <u>Application data:</u> 5.48 mg/l max average, 4.66 mg/l LTA, and Unidentified mg/l Max (96 samples). 113.02 lbs/day LTA. |
| Total Zinc | 7.1 lbs/day Report lb/d 0.206 0.321 0.412 | Monthly Average Daily Max Monthly Average Daily Max IMAX | Existing WQBELs supported by Reasonable Potential Analysis. Antibacksliding prohibition prevents any relief. <u>Application data:</u> 38.1 ug/l average (3 samples) and 38.5 ug/l max. LTAMEC value of 0.0444365 mg/l (44.4365 ug/l) based on one year of sampling data. |
| Total Copper (Final) | 0.32 (lb/d) 0.55 (lb/d) 9.2 ug/l 16.6 ug/l 23.0 ug/l | Monthly Average Daily Max Monthly Average Daily Max IMAX | New WQBEL per Reasonable Potential Analysis, effective in three years. Interim existing monitoring requirement. <u>Application data:</u> 3.89 ug/l average (3 samples) and 4.8 ug/l max. LTAMEC value of 0.0080842 mg/l (8.0842 ug/l) based on one year of sampling data. EDMR showed spiking. |
| Hexachlorobutadiene | Report (lb/d) Report (lb/d) Report Report | Monthly Average Daily Max Monthly Average Daily Max | New WQBEL per Reasonable Potential Analysis, effective in three years. New Interim existing monitoring requirement. <u>Application Data:</u> Inensitive ND concentrations reported (original application and resampling), not meeting DEP TQL (0.5 ug/l). |
| Total Organic Carbon (TOC) | Report (lb/d) Report (lb/d) Report Report | Monthly Average Daily Max Monthly Average Daily Max | Existing M&R requirement |
| BOD ₅ Influent (IMP/Outfall 101) | Report lbs/day Report lbs/day Report Report | Monthly average Daily Max Monthly average Daily Max | Existing M&R requirement |
| TSS Influent (IMP/Outfall 101) | Report lbs/day Report lbs/day Report | Monthly average Daily Max Monthly average | Existing M&R requirement |

| | Report | Daily Max | |
|-----------------|--------|-------------------------|--|
| CBOD5 Reduction | 85% | Minimum monthly average | Existing POTW requirement. The Department accepts an <u>effluent</u> 1.2 BOD5 to 1.0 CBOD5 ratio in the absence of better information. |
| TSS Reduction | 85% | Minimum monthly average | Existing POTW requirement. |

Comments:

New Ammonia-N Limits: Updated WQM Model 7.1.1 Water Quality Modeling (applying the revised 2020 Ammonia-N WQ criteria) resulted in more stringent Ammonia-N limits. However, Application data and EDMR data indicates the facility complies with the new limits, therefore the more stringent limits will apply on Permit Effective Date:

WQM 7.0 Effluent Limits

| SWP Basin 05B | Stream Code 28231 | Stream Name BIG WAPWALOPEN CREEK | | | | | |
|------------------|----------------------|-------------------------------------|-----------------------|------------------|--------------------------------------|----------------------------------|----------------------------------|
| | | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 0.710 | MAJSA POTW | PA0045985 | 4.160 | CBOD5 | 10 | | |
| | | | | NH3-N | 1.93 | 3.86 | |
| | | | | Dissolved Oxygen | | | 6 |

MAJSAWQModel.p
dfReasonable Potential Analysis:

- Dropped Monitoring Requirements: Previous monitoring for Total Cadmium, Total Lead, Total Nickel, Total Silver, and TTO (organics) determined to be unnecessary by the updated Reasonable Potential Analysis.
- Zinc TRE Report:
 - Used June 2023 through June 2024 Copper and Zinc data (from TRE) to calculate LTAMEC and daily COV for use in the TMS via TOXCONC. In sensitive ND Total Copper values potentially biasing the LTAMEC calculation.
 - The (revised) TRE Zinc Metal Translator calculated a Zinc Metal translator of 0.9289.

| | | Reviewer/Permit Engineer: | Berger |
|---------------------|--|----------------------------------|--------------|
| Facility: | Mountaintop Area Joint Sewer Authority | | |
| NPDES #: | PA0045985 | | |
| Outfall No: | 001 | | |
| n (Samples/Month): | 4 | | |
| Parameter | Distribution Applied | Coefficient of Variation (daily) | Avg. Monthly |
| Total Zinc (mg/L) | Lognormal | 0.1993827 | 0.0444365 |
| Total Copper (mg/L) | Delta-Lognormal | 0.9264331 | 0.0080842 |

- Influent Sampling Data:
 - The Influent sample showed elevated Aluminum, Copper, Free Cyanide, Total Iron, Manganese, Nickel, and Zinc concentrations from either AMD I&I and/or commercial/Industrial sources. Spiking was noted for Copper, Nickel, and Zinc.
 - Chloroform and several other organics detected in influent sampling.
- Total Hardness Application Data:
 - Discharge Hardness ranged from 84 mg/l to 125 mg/l per Application. Low value used in analysis to be conservative (some metals being more toxic at lower Total Hardness values). Previous 2020 TRE data discarded as not reflecting current conditions.
 - Upstream sample at 49.4 mg/l per Application. Calculated Total Hardness value used in Reasonable Potential Analysis.
- Application listed-Industrial users are subject to:
 - 40 CFR 467 Subpart C (Aluminum Forming PSC - Extrusion): Pretreatment ELG constituents include Chromium, Cyanide, Zinc, TTO, Oil & Grease (with Aluminum, TSS, and pH ELGs for direct dischargers).
 - 40 CFR 469 Subpart A (Electrical and Electronic Components (semiconductors) PSC): Pretreatment ELG constituents include TTO (with Fluoride and pH ELGs for direct dischargers).
 - Other Industrial Users per IU permits (attached to application):
 - SIC Code# 2086 (Bot & Can Soft Drink and Carb Water): No ELG
 - SIC Code# 2099 (Food Preparation, NEC): No ELG
 - SIC Code# 3069 (Rubber Category per IU permit): 40 CFR 428. Unclear what subpart might apply.
 - No SIC Code, NAICS# 332231 per IU permit, but Metal Finisher category per IU Permit form table: Unclear what ELG applies, but presumably metal finishing. Unclear if NAICS code is correct.
 - No SIC Code or NAICS#, but dairy product processing plus Soap & detergents per IU Permit:
- TMS Output:
 - New limits (effective in three years):
 - Hexachlorobutadiene: Sampling results (original 3 samples and 3 resamples) had an insensitive ND concentration above DEP TQL. Per the EPA Sufficiently Sensitive Rule, the Department must treat the constituent being present at the insensitive ND concentration. In practical terms, monitoring samples (meeting TQLs) may allow for deletion of the limits per the Part C condition.
 - Total Copper: EDMR showed spiking above the proposed new WQBEL. The calculated LTAMEC value was biased due to Sampling results (June 2023 – June 2024) results with insensitive ND Levels. Per the EPA Sufficiently Sensitive Rule, the Department must treat the constituent being present at the insensitive ND concentration.
 - Existing Zinc Limits: The Antibacksliding prohibition prevents any relief from the existing Zinc limits.
 - New Monitoring Requirements: Aluminum, Hexavalent Chromium, Manganese per the Reasonable Potential Analysis.
 - Deleted Monitoring Requirements: The updated Reasonable Potential Analysis allowed for dropping of previous Cadmium, Total Chromium, Nickel, Silver, and TTO monitoring requirements as unneeded.

NPDES Permit Fact Sheet
Mountaintop Area Joint Sanitary Authority POTW

NPDES Permit No. PA0045985

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|---------------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Aluminum | Report | Report | Report | Report | Report | µg/L | 750 | AFC | Discharge Conc > 10% WQBEL (no RP) |
| Hexavalent Chromium | Report | Report | Report | Report | Report | µg/L | 12.8 | CFC | Discharge Conc > 10% WQBEL (no RP) |
| Total Copper | 0.32 | 0.58 | 9.2 | 16.6 | 23.0 | µg/L | 9.2 | CFC | Discharge Conc ≥ 50% WQBEL (RP) |
| Total Manganese | Report | Report | Report | Report | Report | µg/L | 1,228 | THH | Discharge Conc > 10% WQBEL (no RP) |
| Total Zinc | Report | Report | Report | Report | Report | µg/L | 101 | AFC | Discharge Conc > 10% WQBEL (no RP) |
| Hexachlorobutadiene | 0.0009 | 0.001 | 0.026 | 0.041 | 0.065 | µg/L | 0.026 | CRL | Discharge Conc ≥ 50% WQBEL (RP) |



MAJSATMSPDF.pdf

TRC Spreadsheet: Updated TRC Spreadsheet indicates slightly more stringent TRC limits apply (when chlorine is used in a manner that would result in its present in the discharge for this UV disinfection facility):

| TRC EVALUATION | | MAJSA POTW | |
|---|--------------------------------|-------------------------------|--------------------------------------|
| Input appropriate values in A3:A9 and D3:D9 | | MAJSA POTW | |
| 1.47 | = Q stream (cfs) | 0.5 | = CV Daily |
| 4.16 | = Q discharge (MGD) | 0.5 | = CV Hourly |
| 4 | = no. samples | 1 | = AFC_Partial Mix Factor |
| 0.3 | = Chlorine Demand of Stream | 1 | = CFC_Partial Mix Factor |
| 0 | = Chlorine Demand of Discharge | 15 | = AFC_Criteria Compliance Time (min) |
| 0.5 | = BAT/BPJ Value | 720 | = CFC_Criteria Compliance Time (min) |
| 0 | = % Factor of Safety (FOS) | =Decay Coefficient (K) | |
| Source | Reference | AFC Calculations | Reference |
| TRC | 1.3.2.iii | WLA_afc = 0.092 | 1.3.2.iii |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | 5.1c |
| PENTOXSD TRG | 5.1b | LTA_afc= 0.034 | 5.1d |
| Effluent Limit Calculations | | CFC Calculations | |
| PENTOXSD TRG | 5.1f | AML MULT = 1.720 | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.059 | AFC |
| | | INST MAX LIMIT (mg/l) = 0.138 | |

Development of Effluent Limitations

Outfall No. 002 and 003
41° 6' 55.54" (002)
Latitude 41° 6' 50.49" (003)
Wastewater Description: Stormwater

Design Flow (MGD) 0 (stormwater only)
-75° 57' 36.44" (002)
Longitude -75° 57' 37.31" (003)

Permit Limits and/or Monitoring: Changes bolded

| Parameter | Limit (mg/l unless otherwise specified) | SBC | Basis |
|-------------------------------------|--|-------------|---|
| Total Suspended Solids (TSS) | 100.0 | IMAX | Existing monitoring requirement with 100 mg/l Statewide PAG-03 Best Professional Judgment (BPJ) benchmark value incorporated. Antibacksliding prohibits relief. |
| Total Kjehldahl Nitrogen (TKN) | Report | IMAX | Existing monitoring requirement |
| Total Iron | Report | IMAX | Existing monitoring requirement |
| pH | 6.0 SU – 9.0 SU | IMIN – IMAX | Existing Chapter 95.2 regulatory requirement |
| Oil & Grease | 30.0 | IMAX | Existing Chapter 95.2 regulatory requirement |
| Chemical Oxygen Demand (COD) | Report | IMAX | New PAG-03 Appendix J (Miscellaneous) parameter being added in this permit term. Benchmark of 120 mg/l. |
| Total Nitrogen | Report | IMAX | New PAG-03 Appendix J (Miscellaneous) parameter being added in this permit term. |
| Total Phosphorus | Report | IMAX | New PAG-03 Appendix J (Miscellaneous) parameter being added in this permit term. |

Comments:

Outfall Description: Discharges to UNT to Big Wapwallopen Creek, with UNT also receiving I-81 runoff.

- Outfall #002 (a.k.a. North Stormwater Swale) on North side of WWTP: ~4,550 SF (~1500 SF impervious). Roof drains have strainers.
- Outfall #003 (a.k.a. South Stormwater Swale discharge) on I81 side of WWTP: ~18,036 SF (~3926 SF impervious). Drainage culverts have silt socks. The application drawing indicates that the stormwater from the main plant area appears to flow to this outfall.

Application-identified Stormwater BMPs:

- Vehicles are not washed in locations that drain to catch basins. However, no stormwater BMPs were noted for the vehicle washing locations.
- No chemical storage outside.
- Silt socks are installed in drainage culverts.
- Cleaning leaf litter from outfalls, annual stormwater basin cleaning, and annual cleanup of garbage and debris around outfall No. 003 drainage area to where it discharges to Big Wapwallopen Creek.

Whole Effluent Toxicity (WET)

For Outfall 001, **Chronic** WET Testing was completed:

For the permit renewal application (4 Annual WET tests).

The dilution series used for the tests was: 100%, 90%, 80%, 40%, and 20%. The Target Instream Waste Concentration (TIWC) to be used for analysis of the results is: 80%.

Summary of Four Most Recent Test Results

NOEC/LC50 Data Analysis

| Test Date | Ceriodaphnia Results (% Effluent) | | | Pimephales Results (% Effluent) | | | Pass? * |
|-----------|-----------------------------------|-------------------|-------|---------------------------------|-------------|-------|---------|
| | NOEC Survival | NOEC Reproduction | LC50 | NOEC Survival | NOEC Growth | LC50 | |
| 1/28/2020 | 100% | 100% | >100% | 100% | 100% | >100% | PASS |
| 4/28/2020 | 100% | 100% | >100% | 100% | 100% | >100% | PASS |
| 4/27/2021 | 100% | 100% | >100% | 100% | 100% | >100% | PASS |
| 7/19/2022 | 100% | 100% | >100% | 100% | 100% | >100% | PASS |
| 8/23/2023 | 100% | 100% | >100% | 100% | 100% | >100% | PASS |

* A "passing" result is that which is greater than or equal to the TIWC value.

TST Data Analysis

| Test Date | Ceriodaphnia Results (Pass/Fail) | | Pimephales Results (Pass/Fail) | |
|---------------|----------------------------------|--------------|--------------------------------|--------|
| | Survival | Reproduction | Survival | Growth |
| 7/15, 16/2019 | Pass | Pass | Pass | Pass |
| 11/4, 5/2019 | Pass | Pass | Pass | Pass |
| 2/4/2020 | Pass | Pass | Pass | Pass |
| 5/4, 5/2020 | Pass | Pass | Pass | Pass |
| 5/4/2021 | Pass | Pass | Pass | Pass |
| 7/25, 26/2022 | Pass | Pass | Pass | Pass |
| 9/5/2023 | Pass | Pass | Pass | Pass |

* A "passing" result is that in which the replicate data for the TIWC is not statistically significant from the control condition. This is exhibited when the calculated t value ("T-Test Result") is greater than the critical t value. A "failing" result is exhibited when the calculated t value ("T-Test Result") is less than the critical t value.

Is there reasonable potential for an excursion above water quality standards based on the results of these tests? **NO**

Comments: Previous TUC EDMR reporting is no longer required, given lack of Reasonable Potential.

Evaluation of Test Type, IWC and Dilution Series for Renewed Permit

Acute Partial Mix Factor (PMFa): 1

Chronic Partial Mix Factor (PMFc): 1

1. Determine IWC – Acute (IWCA):

$$(Q_d \times 1.547) / ((Q_{7-10} \times PMFa) + (Q_d \times 1.547))$$

| Approve | Deny | Signatures | Date |
|---------|------|--|----------------|
| X | | James D. Berger (signed) James D. Berger, P.E. / Environmental Engineer | March 21, 2025 |
| X | | Edward Dudick, P.E. / Environmental Engineer Manager | March 21, 2025 |

$$[(4.16 \text{ MGD} \times 1.547) / ((1.47 \text{ cfs} \times 1) + (4.16 \text{ MGD} \times 1.547))] \times 100 = \text{IWCa\%} = 81.4\% \text{ (rounded to 82\%)}$$

Is IWCa < 1%? NO

If the discharge is to the tidal portion of the Delaware River, indicate how the type of test was determined: NA

Type of Test for Permit Renewal: Chronic

2a. Determine Target IWCa (If Acute Tests Required): NA

2b. Determine Target IWCc (If Chronic Tests Required)

$$(Q_d \times 1.547) / (Q_{7-10} \times PMFc) + (Q_d \times 1.547)$$
$$[(4.16 \text{ MGD} \times 1.547) / (1.47 \text{ cfs} \times 1) + (4.16 \text{ MGD} \times 1.547)] \times 100 = \text{TIWCC\%} = 81.4\% \text{ (rounded to 82\%)}$$

3. Determine Dilution Series

Dilution Series = 100%, 91%, 82%, 41%, and 21%.

WET Limits

Has reasonable potential been determined? NO.

Will WET limits be established in the permit? NO. Dropping TUC reporting as not needed due to updated WET

If WET limits will be established, identify the species and the limit values for the permit (TU). NA

If WET limits will not be established, but reasonable potential was determined, indicate the rationale for not establishing WET limits: NA

Communication Log:

- **11/21/2023:** On-Base No. **130449** (original submittal). Application was due 12/3/2023. Assigned 12/6/2023.
- **12/14/2023:** Initial Incompleteness Letter issued (missing GIF, etc.).
- **1/3/2024:** On-Base No. **104010** – partial/incomplete response (supplemental analytical data promised, etc.).
- **1/16/2024:** On-Base No. **201565** (revised application)
- **3/5/2024:** MAJSA (Jayce Temperine) Phone Call/E-mail regarding response to DEP Incompleteness Letter. MAJSA indicated it had submitted something on 1/16/2024 via On-Base. It was subsequently located. Jayce Temperine also identified himself as an alternate site contact for MAJSA. Told him I was going to issue an Admin Extension letter (permit not automatically extended).
- **3/5/2024:** Administrative Extension Letter issued.
- **6/26/2024:** DEP Technical Deficiency Letter issued.
- **6/27/2024:** MAJSA (Temperine) E-mail asking for DEP TOXCONC Spreadsheet.
- **6/27/2024:** DEP (Berger) E-mail with requested blank TOXCONC Spreadsheet, and some general guidance on it.
- **7/15/2024: Public Upload #245577** (received 7/15/2024) – MAJSA Pre-Draft Survey for Toxic Pollutants response (indicating MAJSA will perform additional sampling as noted on the survey form).
- **8/15/2024: Public Upload# 253053** (received 8/15/2024) – incomplete revised NPDES Application (missing new sampling data and any related updating)
- **10/21/2024: MAJSA (Temperine) E-mail** asking how to submit new sampling data (meeting DEP TQLs)
- **10/21/2024: DEP (Berger) E-mail** directing that new sampling data be submitted via Public upload (with e-mail to notify this reviewer of Public Upload#).

- **11/12/2024: Public Upload# 270436** (revised analytical data from Predraft Survey) table with labsheets: Max value bolded for resampled constituents (or one sample if all results the same).

| Date | Parameter | <> | Result ug/l | PA DEP TQL ug/L | <> | Loading Lbs/day | MDL Used as result? |
|-----------|----------------------|----|-------------|-----------------|----|-----------------|---------------------|
| 8/13/2024 | Dissolved Iron | < | 10 | 20 | < | 0.2385 | No |
| 8/20/2024 | Dissolved Iron | | 15 | 20 | | 0.3303 | No |
| 8/27/2024 | Dissolved Iron | | 11 | 20 | | 0.2037 | No |
| 8/13/2024 | Free Cyanide | < | 0.5 | 1 | < | 0.0119 | Yes |
| 8/20/2024 | Free Cyanide | < | 1 | 1 | < | 0.0220 | J- qualified |
| 8/27/2024 | Free Cyanide | < | 0.5 | 1 | < | 0.0093 | Yes |
| 8/13/2024 | Hex Chromium | < | 2 | 1 | < | 0.0477 | Yes |
| 8/20/2024 | Hex Chromium | < | 2 | 1 | < | 0.0440 | Yes |
| 8/27/2024 | Hex Chromium | | 3 | 1 | | 0.0555 | J- qualified |
| 8/13/2024 | Total Silver | < | 0.2 | 0.4 | < | 0.0048 | Yes |
| 8/20/2024 | Total Silver | < | 0.2 | 0.4 | < | 0.0044 | Yes |
| 8/27/2024 | Total Silver | < | 0.2 | 0.4 | < | 0.0037 | Yes |
| 8/13/2024 | Total Aluminum | | 94 | 10 | | 2.2421 | J- qualified |
| 8/20/2024 | Total Aluminum | | 48 | 10 | | 1.0568 | J- qualified |
| 8/27/2024 | Total Aluminum | | 78 | 10 | | 1.4442 | J- qualified |
| 8/13/2024 | Total Cadmium | < | 0.1 | 0.2 | < | 0.0024 | Yes |
| 8/20/2024 | Total Cadmium | < | 0.1 | 0.2 | < | 0.0022 | Yes |
| 8/27/2024 | Total Cadmium | < | 0.1 | 0.2 | < | 0.0019 | Yes |
| 8/13/2024 | Total Copper | | 2.0 | 4 | | 0.0477 | No |
| 8/20/2024 | Total Copper | < | 2.0 | 4 | < | 0.0440 | No |
| 8/27/2024 | Total Copper | | 2.0 | 4 | | 0.0370 | No |
| 8/13/2024 | Total Zinc | | 19 | 5 | | 0.4532 | No |
| 8/20/2024 | Total Zinc | | 21 | 5 | | 0.4624 | No |
| 8/27/2024 | Total Zinc | | 20 | 5 | | 0.3703 | No |
| 8/13/2024 | Acrolein | < | 1.0 | 2 | < | 0.0239 | No |
| 8/20/2024 | Acrolein | < | 1.0 | 2 | < | 0.0220 | No |
| 8/27/2024 | Acrolein | < | 1.0 | 2 | < | 0.0185 | No |
| 8/13/2024 | Bromodichloromethane | < | 0.5 | 0.5 | < | 0.0119 | No |
| 8/20/2024 | Bromodichloromethane | < | 0.5 | 0.5 | < | 0.0110 | No |
| 8/27/2024 | Bromodichloromethane | < | 0.5 | 0.5 | < | 0.0093 | No |
| 8/13/2024 | 1,2-Dichloropropane | < | 0.5 | 0.5 | < | 0.0119 | No |
| 8/20/2024 | 1,2-Dichloropropane | < | 0.5 | 0.5 | < | 0.0110 | No |
| 8/27/2024 | 1,2-Dichloropropane | < | 0.5 | 0.5 | < | 0.0093 | No |
| 8/13/2024 | 1,3-Dichlorobenzene | < | 0.5 | 0.5 | < | 0.0119 | No |
| 8/20/2024 | 1,3-Dichlorobenzene | < | 0.5 | 0.5 | < | 0.0110 | No |
| 8/27/2024 | 1,3-Dichlorobenzene | < | 0.5 | 0.5 | < | 0.0093 | No |
| 8/13/2024 | 2,4-Dinitrophenol | < | 2.86 | 10 | < | 0.0682 | No |
| 8/20/2024 | 2,4-Dinitrophenol | < | 2.86 | 10 | < | 0.0630 | No |

| | | | | | | | |
|------------------|----------------------------|-------------|--------------|------------|-------------|---------------|-----------|
| 8/27/2024 | 2,4-Dinitrophenol | < | 2.86 | 10 | < | 0.0530 | No |
| 8/13/2024 | 2,4-Dinitrotoluene | < | 0.952 | 5 | < | 0.0227 | No |
| 8/20/2024 | 2,4-Dinitrotoluene | < | 0.952 | 5 | < | 0.0210 | No |
| 8/27/2024 | 2,4-Dinitrotoluene | < | 0.952 | 5 | < | 0.0176 | No |
| 8/13/2024 | 2-methyl-4,6-dinitrophenol | < | 2.86 | 10 | < | 0.0682 | No |
| 8/20/2024 | 2-methyl-4,6-dinitrophenol | < | 2.86 | 10 | < | 0.0630 | No |
| 8/27/2024 | 2-methyl-4,6-dinitrophenol | < | 2.86 | 10 | < | 0.0530 | No |
| 8/13/2024 | 3,3'-Dichlorobenzidine | < | 0.952 | 5 | < | 0.0227 | No |
| 8/20/2024 | 3,3'-Dichlorobenzidine | < | 0.952 | 5 | < | 0.0210 | No |
| 8/27/2024 | 3,3'-Dichlorobenzidine | < | 0.952 | 5 | < | 0.0176 | No |
| 8/13/2024 | Benzo(a)anthracene | < | 0.952 | 2.5 | < | 0.0227 | No |
| 8/20/2024 | Benzo(a)anthracene | < | 0.952 | 2.5 | < | 0.0210 | No |
| 8/27/2024 | Benzo(a)anthracene | < | 0.952 | 2.5 | < | 0.0176 | No |
| 8/13/2024 | Benzo(a)pyrene | < | 0.952 | 2.5 | < | 0.0227 | No |
| 8/20/2024 | Benzo(a)pyrene | < | 0.952 | 2.5 | < | 0.0210 | No |
| 8/27/2024 | Benzo(a)pyrene | < | 0.952 | 2.5 | < | 0.0176 | No |
| 8/13/2024 | Benzo(b)fluoranthene | < | 0.952 | 2.5 | < | 0.0227 | No |
| 8/20/2024 | Benzo(b)fluoranthene | < | 0.952 | 2.5 | < | 0.0210 | No |
| 8/27/2024 | Benzo(b)fluoranthene | < | 0.952 | 2.5 | < | 0.0176 | No |
| 8/13/2024 | Benzo(k)fluoranthene | < | 0.952 | 2.5 | < | 0.0227 | No |
| 8/20/2024 | Benzo(k)fluoranthene | < | 0.952 | 2.5 | < | 0.0210 | No |
| 8/27/2024 | Benzo(k)fluoranthene | < | 0.952 | 2.5 | < | 0.0176 | No |
| 8/13/2024 | Chrysene | < | 0.952 | 2.5 | < | 0.0227 | No |
| 8/20/2024 | Chrysene | < | 0.952 | 2.5 | < | 0.0210 | No |
| 8/27/2024 | Chrysene | < | 0.952 | 2.5 | < | 0.0176 | No |
| 8/13/2024 | Dibenzo(a,h)anthracene | < | 0.952 | 2.5 | < | 0.0227 | No |
| 8/20/2024 | Dibenzo(a,h)anthracene | < | 0.952 | 2.5 | < | 0.0210 | No |
| 8/27/2024 | Dibenzo(a,h)anthracene | < | 0.952 | 2.5 | < | 0.0176 | No |
| 8/13/2024 | Hexachlorobutadiene | < | 0.952 | 0.5 | < | 0.0227 | No |
| 8/20/2024 | Hexachlorobutadiene | < | 0.952 | 0.5 | < | 0.0210 | No |
| 8/27/2024 | Hexachlorobutadiene | < | 0.952 | 0.5 | < | 0.0176 | No |
| 8/13/2024 | Hexachlorocyclopentadiene | < | 0.952 | 5 | < | 0.0227 | No |
| 8/20/2024 | Hexachlorocyclopentadiene | < | 0.952 | 5 | < | 0.0210 | No |
| 8/27/2024 | Hexachlorocyclopentadiene | < | 0.952 | 5 | < | 0.0176 | No |
| 8/13/2024 | Indeno(1,2,3-cd)pyrene | < | 0.952 | 2.5 | < | 0.0227 | No |
| 8/20/2024 | Indeno(1,2,3-cd)pyrene | < | 0.952 | 2.5 | < | 0.0210 | No |
| 8/27/2024 | Indeno(1,2,3-cd)pyrene | < | 0.952 | 2.5 | < | 0.0176 | No |
| 8/13/2024 | Pentachlorophenol | < | 0.952 | 10 | < | 0.0227 | No |
| 8/20/2024 | Pentachlorophenol | < | 0.952 | 10 | < | 0.0210 | No |
| 8/27/2024 | Pentachlorophenol | < | 0.952 | 10 | < | 0.0176 | No |
| 8/13/2024 | Phenathrene | < | 0.952 | 2.5 | < | 0.0227 | No |
| 8/20/2024 | Phenathrene | < | 0.952 | 2.5 | < | 0.0210 | No |

| | | | | | | | |
|-----------|-------------|---|-------|-----|---|--------|----|
| 8/27/2024 | Phenathrene | < | 0.952 | 2.5 | < | 0.0176 | No |
| 8/13/2024 | Toxaphene | < | 0.48 | 0.5 | < | 0.0114 | No |
| 9/24/2024 | Toxaphene | < | 0.48 | 0.5 | < | 0.0087 | No |
| 10/1/2024 | Toxaphene | < | 0.48 | 0.5 | < | 0.0082 | No |
| 10/8/2024 | Toxaphene | < | 0.48 | 0.5 | < | 0.0081 | No |