

Application Type Renewal
Facility Type Stormwater
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0051896
APS ID 957092
Authorization ID 1260298

Applicant and Facility Information

Applicant Name	<u>Georgia-Pacific Consumer Operations LLC</u>	Facility Name	<u>Georgia-Pacific – Dixie Leigh Valley</u>
Applicant Address	<u>605 Kuebler Road Easton, PA 18040-9281</u>	Facility Address	<u>605 Kuebler Road Easton, PA 18042-9282</u>
Applicant Contact	<u>Raymond A. Stofko, EHS Manager</u>	Facility Contact	<u>Raymond A. Stofko, EHS Manager</u>
Applicant Phone	<u>(610) 250-1436</u>	Facility Phone	<u>(610) 250-1463</u>
Client ID	<u>339950</u>	Site ID	<u>252126</u>
SIC Code	<u>2656,3089</u>	Municipality	<u>Forks Township</u>
SIC Description	<u>Manufacturing - Plastics Products, Nec, Manufacturing - Sanitary Food Containers</u>	County	<u>Northampton</u>
Date Application Received	<u>January 30, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>February 4, 2019</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of NPDES permit to discharge industrial stormwater.</u>		

Summary of Review

The applicant is requesting a renewal of their NPDES permit to discharge stormwater associated with industrial activity to Bushkill Creek, a HQ-CWF, MF (High Quality-Cold Water Fishes, Migratory Fishes) designated receiving stream in state water plan basin 1-F (Delaware River). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use.

The facility is categorized by SIC code 2656 (Manufacturing – Sanitary Food Containers) and SIC code 3089 (Plastic Products) and falls under Appendices E and S monitoring requirements of the PAG-03 General Permit.

Appendix E of the latest PAG-03 General Permit includes benchmark values for Total Suspended Solids (TSS) and Chemical Oxygen Demand (COD). All industries classified under Appendix E should be within the following values: 100 mg/L for TSS and 120 mg/L for COD.

Appendix S of the latest PAG-03 General Permit includes benchmark values for Total Suspended Solids (TSS). All industries classified under Appendix S should be within 100 mg/L for TSS.

These values are included as IMAX limitations and should be sampled semi-annually. Semi-annual monitoring and reporting for pH and Total Zinc are also required under this permit. Monitoring and reporting requirements for Total Kjeldahl Nitrogen and Total Iron are removed from the permit as per updated requirements under Appendices E and S.

PPC Plan implementation and completion of an annual inspection and compliance evaluation are required under the permit.

A Water Management System Inspection query was performed and indicated on January 25, 2017 a Compliance Evaluation was performed.

Approve	Deny	Signatures	Date
X		Allison Seyfried / Environmental Engineering Specialist	August 8, 2019
X		Amy M. Bellanca, P.E. / Environmental Engineer Manager	August 8, 2019

Summary of Review

The previously issued permit expired on July 31, 2019 and the renewal application was received on time.

There are no open violations for this client that would warrant withholding the issuance of this permit.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

