

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0052647
APS ID 1064325
Authorization ID 1397802

Applicant and Facility Information

Applicant Name	<u>Pottstown Borough Authority</u>	Facility Name	<u>Pottstown Borough Water Treatment Plant</u>
Applicant Address	<u>100 East High Street</u> <u>Pottstown, PA 19464</u>	Facility Address	<u>668 Old Reading Pike</u> <u>Stowe, PA 19464</u>
Applicant Contact	<u>Brent Wagner</u>	Facility Contact	<u>Brent Wagner</u>
Applicant Phone	<u>(610) 970-6530</u>	Facility Phone	<u>(610) 970-6530</u>
Client ID	<u>52334</u>	Site ID	<u>481617</u>
SIC Code	<u>4941</u>	Municipality	<u>Pottstown Borough</u>
SIC Description	<u>Trans. & Utilities - Water Supply</u>	County	<u>Montgomery</u>
Date Application Received	<u>May 26, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 2, 2022</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review


The PA Department of Environmental Protection (PADEP/Department) received an NPDES permit renewal application from Herbert, Rowland & Grubic, Inc. (consultant) on behalf of Pottstown Borough Authority (permittee/authority) on May 26, 2022 for permittee's Pottstown Borough Water Treatment Plant (facility). The facility is in Pottstown Borough, Montgomery County. The treated effluent is discharged through Outfall 001 and 002 into Schuylkill River in State Watershed 3-D, classified as WWF/MF. The facility is a minor industrial waste facility without ELG (MIIW1). The current permit will expire on November 30, 2022. The terms and conditions of the permit will be automatically extended since the renewal application was received at least 180 days prior to the expiration date. Renewal NPDES permit applications under Clean Water program are not covered by PADEP's PDG per 021-2100-001.

This fact sheet is developed in accordance with 40 CFR §124.56.

Changes in this renewal: Mass limits recalculated, TRC average monthly limit for outfall 002 revised.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
√		Reza H. Chowdhury, E.I.T. / Project Manager 	June 21, 2022
X		Pravin Patel Pravin C. Patel, P.E. / Environmental Engineer Manager	06/21/2022

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.22
Latitude	40° 14' 28"	Longitude	-75° 41' 46.00"
Quad Name	Pottstown	Quad Code	1740
Wastewater Description: <u>Water Treatment Effluent</u>			
Receiving Waters	Schuylkill River (WWF, MF)	Stream Code	00833
NHD Com ID	25990574	RMI	57.04
Drainage Area	1,050 mi ²	Yield (cfs/mi ²)	0.26
Q ₇₋₁₀ Flow (cfs)	273	Q ₇₋₁₀ Basis	Please see below
Elevation (ft)	124.79	Slope (ft/ft)	
Watershed No.	3-D	Chapter 93 Class.	WWF, MF
Existing Use	WWF	Existing Use Qualifier	Ch. 93
Exceptions to Use	None	Exceptions to Criteria	N/A
Assessment Status	Impaired		
Cause(s) of Impairment	POLYCHLORINATED BIPHENYLS (PCBS)		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status	Final	Name	Schuylkill River PCB TMDL
Background/Ambient Data		Data Source	
pH (SU)	7.3		WQN0111, median July-Sep, 1999-2019
Temperature (°C)	22.87		WQN0111, median July-Sep, 1999-2019
Hardness (mg/L)	149		WQN0111, median July-Sep, 1999-2019
Other:			
Nearest Downstream Public Water Supply Intake	PA American Royersford in Phoenixville, Chester County		
PWS Waters	Schuylkill River	Flow at Intake (cfs)	
PWS RMI	46.5	Distance from Outfall (mi)	10.54

Other Comments: Changes Since Last Permit Issuance: None

Drainage Area:

The drainage area upstream of the point of discharge is 1,050 mi² according to USGS PA StreamStats, accessible at <https://streamstats.usgs.gov/ss/>

Stream Flow:

Streamflow data was collected from the nearest downstream USGS stream gage 01472000 located in Schuylkill River at Pottstown, PA. Q₇₋₁₀, Q₁₋₁₀, and Q₃₀₋₁₀ values at this gage are 301 cfs, 276 cfs, and 349 cfs respectively for the reporting years of 1980-2008. The drainage area was found to be 1,147 mi². These values were obtained from the latest USGS streamflow report ⁽¹⁾. The drainage area at the discharge point was found to be 1,050 mi² from USGS StreamStats Version 3.0 Flow Statistics Ungaged Site Report on June 16, 2022.

$$\begin{aligned}
 Q_{7-10} \text{ runoff rate} &= 301 \text{ cfs}/1147 \text{ mi}^2 = 0.26 \text{ cfs}/\text{mi}^2 \\
 Q_{7-10} \text{ at Outfall 001} &= 0.26 \text{ cfs}/\text{mi}^2 * 1050 \text{ mi}^2 = 273 \text{ cfs} \\
 Q_{1-10}/Q_{7-10} &= 276 \text{ cfs}/301 \text{ cfs} = 0.917 \\
 Q_{30-10}/Q_{7-10} &= 349 \text{ cfs}/301 \text{ cfs} = 1.159
 \end{aligned}$$

(1) Stuckey, M.H., Roland, M.A., 2011, Selected streamflow statistics for streamgage locations in and near Pennsylvania: U.S. Geological Survey Scientific Investigations Report 2011-1070, 10p, 22p.

PWS Intake:

The nearby PWS intake is PA American Water Royersford in Phoenixville, Chester County, PA, on Schuylkill River at approximate RMI 46.5. The intake is approximately 10.54 miles downstream of the Outfall 001. Due to the distance, dilution of the Schuylkill River, and effluent limitations, the discharge is not expected to impact the PWS intake.

Wastewater Characteristics:

The median pH of 7.38 was calculated from daily eDMR for the months of July-September 2021. Default discharge temperature of 20°C and maximum hardness of 123 mg/l out of 3 samples from application data will be used for modeling, if needed.

Background/Ambient Stream Data:

The nearby WQN station is WQN0111, on SR 4038 Hanover St. Br. The station provided a historical (1999-2019) low flow (July-September) median pH of 7.3, temperature of 22.87°C, and hardness of 149 mg/l, which will be used for modeling, if needed.

Schuylkill River PCB TMDL:

On April 7, 2007, The U.S. EPA Region III established a Total Maximum Daily Load (TMDL) for Polychlorinated Biphenyl (PCB) for the Schuylkill River, which was listed on Pennsylvania's 1996 303(d) list of impaired streams as impaired due to the presence of elevated PCB concentrations found in fish tissue. PCBs are a group of synthetic chemicals that consist of 209 individual compounds (known as Congeners). This facility withdraws the water from Schuylkill River and not adding any PCBs prior to discharge. The facility doesn't have any WLA in the TMDL.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>002</u>	Design Flow (MGD)	<u>0.0098</u>
Latitude	<u>40° 14' 28"</u>	Longitude	<u>75° 41' 53"</u>
Quad Name	<u>Pottstown</u>	Quad Code	<u>1740</u>
Wastewater Description:	<u>Water Treatment Effluent</u>		
Receiving Waters	<u>Unnamed Tributary to Schuylkill River (WWF, MF)</u>	Stream Code	<u>01710</u>
NHD Com ID	<u>25990228</u>	RMI	<u>0.19</u>
Drainage Area	<u>0.96 mi²</u>	Yield (cfs/mi ²)	<u>0.26</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.25</u>	Q ₇₋₁₀ Basis	<u></u>
Watershed No.	<u>3-D</u>	Chapter 93 Class.	<u>WWF, MF</u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Nearest Downstream Public Water Supply Intake	<u>PA American Royersford in Phoenixville, Chester County</u>		
PWS Waters	<u>Schuylkill River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u>46.5</u>	Distance from Outfall (mi)	<u>10.73</u>

Treatment Facility Summary				
Treatment Facility Name: Pottstown Borough Water Filtration Plant				
WQM Permit No.		Issuance Date		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial	Biological (Industrial Waste)	Holding or Detention Pond	No Disinfection	0.22
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
		Not Overloaded	Drying	Landfill


Changes Since Last Permit Issuance: None

Other Comments:

Pottstown Borough Authority owns and operates a Water Treatment Plant. The facility is a potable water treatment plant currently permitted for 8 MGD, serving Pottstown Borough, and Lower Pottsgrove, Upper Pottsgrove, West Pottsgrove, Douglass and North Coventry Townships. Raw water is withdrawn from the Schuylkill River and dosed with potassium permanganate at the mechanical screen chamber. Chlorine is added seasonally for algae control. Alum, carbon, caustic soda and other chemicals are added, as needed, in the flash-mixing chamber. The water then goes to flocculation basins and then to sedimentation basins. The supernatant goes to mixed media for filtration. The filtered water then goes to a clear well where it is treated with chlorine, caustic soda, fluoride, and poly phosphates prior to the distribution system.

There are three sedimentation basins that are cleaned twice per year, during spring and fall. Settled materials drawn from sedimentation basins during cleaning, and filter backwash water are sent to two on-site 245,000-gallon lagoons, where solids are removed before discharge into the Schuylkill River through outfall 001.

In addition, the intake screen is continuously washed during use with clear well water and wastewater is discharged through Outfall 002 to an unnamed tributary to Schuylkill River.



Existing Limits

Outfall 001:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instant. Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	1.0	1.2	Daily when Discharging	Grab
Total Suspended Solids	55	110	XXX	30	60	75	2/month	8-Hr Composite
Aluminum, Total	7.4	14.8	XXX	4.0	8.0	10	2/month	8-Hr Composite
Iron, Total	3.7	7.4	XXX	2.0	4.0	5	2/month	8-Hr Composite
Manganese, Total	1.8	3.6	XXX	1.0	2.0	2.5	2/month	8-Hr Composite

Outfall 002:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Instant. Minimum	Average Monthly	Maximum	Instant. Maximum		
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.4	XXX	1.0	1/week	Grab

Compliance History

DMR Data for Outfall 001 (from May 1, 2021 to April 30, 2022)

Parameter	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21
Flow (MGD) Average Monthly	0.146	0.130	0.137	0.113	0.151	0.137	0.128	0.140	0.085	0.101	0.108	0.086
Flow (MGD) Daily Maximum	0.272	0.201	0.245	0.197	0.288	0.292	0.248	0.240	0.281	0.183	0.179	0.155
pH (S.U.) Instantaneous Minimum	6.74	6.54	6.62	6.53	6.74	7.1	6.95	6.91	7.24	6.57	6.74	6.62
pH (S.U.) Instantaneous Maximum	7.48	7.40	6.81	7.39	7.60	7.37	7.83	7.61	7.79	8.34	7.87	7.43
TRC (mg/L) Average Monthly	0.14	0.12	0.15	0.21	0.14	0.16	0.15	0.23	0.22	0.14	0.13	0.09
TRC (mg/L) Instantaneous Maximum	0.25	0.40	0.59	0.76	0.48	0.46	0.63	0.75	0.47	0.44	0.96	0.47
TSS (lbs/day) Average Monthly	3.6	2.8	3.6	1.19	5.2	9.53	2.8	3.2	1.1	0.74	3.32	0.57
TSS (lbs/day) Daily Maximum	5.5	3.2	4.9	1.58	6.5	10.73	4.6	3.4	1.6	0.74	4.20	0.62
TSS (mg/L) Average Monthly	5.0	4.0	5.0	1	7.0	6	3	3.5	2.0	1.0	5.0	1.0
TSS (mg/L) Daily Maximum	8.0	4.0	6.0	1	8.0	11	5	4.0	2.0	1.0	6.0	1.0
Total Aluminum (lbs/day) Average Monthly	0.32	0.12	0.25	0.38	0.42	0.36	0.25	0.22	0.17	0.11	0.38	0.20
Total Aluminum (lbs/day) Daily Maximum	0.38	0.14	0.30	0.52	0.44	0.43	0.31	0.29	0.25	0.12	0.53	0.27
Total Aluminum (mg/L) Average Monthly	0.43	0.15	0.31	0.31	0.53	0.40	0.26	0.23	0.23	0.15	0.57	0.37
Total Aluminum (mg/L) Daily Maximum	0.55	0.15	0.37	0.33	0.55	0.44	0.31	0.26	0.31	0.16	0.76	0.54
Total Iron (lbs/day) Average Monthly	0.02	0.02	0.03	0.036	0.03	0.03	0.02	0.03	0.02	0.015	0.03	0.02
Total Iron (lbs/day) Daily Maximum	0.02	0.02	0.03	0.047	0.03	0.03	0.02	0.04	0.02	0.015	0.04	0.02

**NPDES Permit Fact Sheet
Pottstown Borough Public Water System**

NPDES Permit No. PA0052647

Total Iron (mg/L) Average Monthly	0.03	0.02	0.03	0.03	0.04	0.03	0.02	0.03	0.03	0.02	0.05	0.04
Total Iron (mg/L) Daily Maximum	0.03	0.02	0.37	0.03	0.04	0.03	0.02	0.04	0.03	0.02	0.06	0.04
Total Manganese (lbs/day) Average Monthly	0.33	0.13	0.21	0.305	0.17	0.57	0.17	0.20	0.14	0.10	0.22	0.20
Total Manganese (lbs/day) Daily Maximum	0.48	0.15	0.23	0.467	0.19	0.96	0.19	0.22	0.21	0.11	0.28	0.22
Total Manganese (mg/L) Average Monthly	0.46	0.16	0.27	0.238	0.20	0.603	0.172	0.223	0.19	0.131	0.33	0.35
Total Manganese (mg/L) Daily Maximum	0.71	0.18	0.28	0.296	0.229	0.987	0.192	0.247	0.26	0.149	0.40	0.43

DMR Data for Outfall 002 (from May 1, 2021 to April 30, 2022)

Parameter	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21
pH (S.U.) Instantaneous Minimum	6.71	6.73	6.73	6.82	6.87	6.79	6.94	6.87	6.87	6.69	6.73	6.57
pH (S.U.) Instantaneous Maximum	6.87	6.95	6.81	6.91	7.60	6.94	6.98	6.92	6.97	6.94	6.94	6.78
TRC (mg/L) Average Monthly	0.04	0.04	0.03	0.038	0.03	0.02	0.03	0.06	0.03	0.03	0.03	0.03
TRC (mg/L) Instantaneous Maximum	0.06	0.07	0.04	0.06	0.04	0.03	0.04	0.08	0.06	0.03	0.03	0.04

Compliance History

No eDMR violation noted.

03/11/2022: FUJ conducted for a TRC IMAX violation on December 17, 2021. The permittee provided a response and corrective action. An NOV was issued on December 23, 2021.

12/17/2021: CEI conducted. TRC IMAX violation noted.

11/16/2020: CEI conducted. No violation noted. Recommended that staged PACL totes should be contained to avoid any possible compliance issues.

12/16/2019: CEI conducted. No violation noted. Recommended that the pipe in the lagoon splitter box should be investigated.

01/17/2019: CEI conducted. No violation noted.

Node 2: At the confluence with Manatawny Creek at Schuylkill RMI 54.61
 Elevation: 119.82 ft (USGS TNM 2.0 viewer, 06/15/2022)
 Drainage Area: 1150 mi² (StreamStat Version 3.0, 06/15/2022)
 River Mile Index: 54.61 (PA DEP eMapPA)
 Low Flow Yield: 0.26 cfs/mi²
 Discharge Flow: 0.00 MGD

Total Residual Chlorine

25 Pa Code §92a.48(b) regulates TRC. DEP’s TRC_CALC worksheet was utilized to determine if existing TBELs are still appropriate at discharge flow of 0.14 MGD. The spreadsheet indicated an average monthly and IMAX limit of 0.5 mg/l and 1.6 mg/l. The BPT IMAX limit is 1.0 mg/l which is more stringent compared to WQBEL. The existing limits are still protective and will be carried over.

Toxics

Based on the available data, PADEP utilizes Toxics Management Spreadsheet (TMS) to (1) evaluate reasonable potential for toxic pollutants to cause or contribute to an excursion above the water quality standards and (2) develop WQBELs for those such toxic pollutants (i.e., 40 CFR § 122.44(d)(1)(i)). It is noteworthy that some of these pollutants that may be reported as “non-detect”, but still exceeded the criteria, were determined to be candidates for modeling because the method detection levels used to analyze those pollutants were higher than target QLs and/or the most stringent Chapter 93 criteria. The model then recommended the appropriate action for the Pollutants of Concerns based on the following logic:

1. In general, establish limits in the draft permit where the effluent concentration determined in B.1 or B.2 equals or exceeds 50% of the WQBEL (i.e., RP is demonstrated). Use the average monthly, maximum daily and instantaneous maximum (IMAX) limits for the permit as recommended by the TMS (or, if appropriate, use a multiplier of 2 times the average monthly limit for the maximum daily limit and 2.5 times the average monthly limit for IMAX).
2. For non-conservative pollutants, in general, establish monitoring requirements where the effluent concentration determined in B.1 or B.2 is between 25% - 50% of the WQBEL.
3. For conservative pollutants, in general, establish monitoring requirements where the effluent concentration determined in B.1 or B.2 is between 10% - 50% of the WQBEL.

NOTE 4 – If the effluent concentration determined in B.1 or B.2 is “non-detect” at or below the target quantitation limit (TQL) for the pollutant as specified in the TMS and permit application, the pollutant may be eliminated as a candidate for WQBELs or monitoring requirements unless 1) a more sensitive analytical method is available for the pollutant under 40 CFR Part 136 where the quantitation limit for the method is less than the applicable water quality criterion and 2) a detection at the more sensitive method may lead to a determination that an effluent limitation is necessary, considering available dilution at design conditions.

NOTE 5 – If the effluent concentration determined in B.1 or B.2 is a detection below the TQL but above or equal to the applicable water quality criterion, WQBELs or monitoring may be established for the pollutant.

4. Application managers may, on a site- and pollutant-specific basis, deviate from these guidelines where there is specific rationale that is documented in the fact sheet.

TMS model was utilized and output file recommended no limits or monitoring requirements for the analyzed parameters. Model output screenshot is provided below:

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits			Units	Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX				

Therefore, no new toxic parameters will be introduced during this renewal. The BPT based TBEL for Total Aluminum, Total Iron, and Total Manganese will prevail.

Additional Considerations

Flow Monitoring

Flow monitoring will remain in the permit and is required by 40 CFR § 122.44(i)(1)(ii).

pH:

The TBEL for pH is above 6.0 and below 9.0 S.U. (40 CFR §133.102(c) and Pa Code 25 § 95.2(1)) which are existing limits and will be carried over.

Total Suspended Solids (TSS):

There is no water quality criterion for TSS. The existing limits of 30 mg/L average monthly, 60 mg/l daily max, and 70 mg/L instantaneous maximum will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment, 25 Pa. Code § 92a.47 and 40CFR 133.102(b). The current permit has these mass loads as 55 lbs./day and 110 lbs./day which were based on an approved average annual design flow of 0.22 MGD. The current limits will be carried over.

Anti-Degradation requirements

The effluent limits for this discharge have been developed to ensure the existing in-stream uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality stream is impacted by this discharge. No Exceptional-Value stream is impacted by this discharge.

Anti-Backsliding Requirements

Unless stated otherwise in this fact sheet, all proposed effluent limits have developed for this permit renewal are at least as stringent as effluent limits developed for the previous permit renewal. Therefore, anti-backsliding provision is not applicable.

Mass-based limit calculation:

The mass-based limits, where applicable, were calculated by the following formula:

$$\text{Mass limit (lbs./day)} = \text{Concentration (mg/l)} * 8.34 * \text{Flow (mgd)}$$

The flow used in the calculations was the 90th percentile flow, or 0.2 MGD. Please note that the mass limits may change in next renewal depending on the appropriate flow number for the renewal.

Development of Effluent Limitations

Outfall No.	<u>002</u>	Design Flow (MGD)	<u>.0098</u>
Latitude	<u>40° 14' 28.00"</u>	Longitude	<u>-75° 41' 53.00"</u>
Wastewater Description:	<u>Water Treatment Effluent</u>		

The source of wastewater from this outfall is the continuous washing operation of the influent screen with finished water. Since the finished water has TRC, the generated wastewater is treated with Sodium Bisulfite prior to discharging at Outfall 002. pH limit will be continued per Pa Code 25 §95.2 and DRBC 4.30.5.C. TRC limits will be revised to reflect the BAT requirement as stated in Pa Code 25 § 92(a)48(b)(2).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Daily when Discharging	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.0	Daily when Discharging	Grab
TSS	50	100	XXX	30	60	75	2/month	8-Hr Composite
Total Aluminum	6.67	13.34	XXX	4.0	8.0	10	2/month	8-Hr Composite
Total Iron	3.34	6.67	XXX	2.0	4.0	5	2/month	8-Hr Composite
Total Manganese	1.67	3.34	XXX	1.0	2.0	2.5	2/month	8-Hr Composite

Compliance Sampling Location: At Outfall 001

Other Comments: See Part C.II. Sedimentation Basin Cleaning for additional requirements

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.


Outfall 002, Effective Period: **Permit Effective Date** through **Permit Expiration Date**.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.0	1/week	Grab

Compliance Sampling Location: At Outfall 002

Other Comments: None

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]



OUTFALL 002:
 LAT: 40° 14' 28"
 LON: 75° 41' 53"


OUTFALL 001:
 LAT: 40° 14' 28"
 LON: 75° 41' 46"

PLANT INTAKE:
 LAT: 40° 14' 16"
 LON: 75° 41' 42"



LOCATION MAP

USGS QUADRANGLES:
 BOYERTOWN & POTTSTOWN



File name: P:\2017\20170101_0185\Plan View\2017\20170101_0185_LOC.mxd Layer: PFP File: 2017-01-31.mxd

HRG
 Engineering & Related Services
 AN EMPLOYEE-OWNED COMPANY

200 West Park Drive
 Harrisburg, PA 17111
 (717) 664-1187
 Fax: (717) 664-1188
 hrghrg.com
 www.hrghrg.com

LOCATION MAP
 FOR
PBA WTP NPDES RENEWAL PROJECT

WEST POTTS GROVE TOWNSHIP MONTGOMERY COUNTY PENNSYLVANIA

PROJ. MGR. - JTF
DESIGN - MNR
CADD - KRB
CHECKED -
SCALE - 1" = 3000'
DATE - FEB. 2022

DRAWING NO.
LOC
SHEET NO.
1 OF 1
PROJECT: 20170101_0185


PA0052647 at Outfall 001

Region ID: PA

Workspace ID: PA20220616122320862000

Clicked Point (Latitude, Longitude): 40.24116, -75.69602

Time: 2022-06-16 08:23:42 -0400



 Collapse All

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	6.5303	degrees
CARBON	Percentage of area of carbonate rock	18.38	percent
DRNAREA	Area that drains to a point on a stream	1050	square miles
PRECIP	Mean Annual Precipitation	47	inches
ROCKDEP	Depth to rock	4.4	feet

Parameter Code	Parameter Description	Value	Unit
STRDEN	Stream Density -- total length of streams divided by drainage area	1.36	miles per square mile
URBAN	Percentage of basin with urban development	6.5759	percent

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [13.8 Percent (145 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1050	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	6.5303	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.4	feet	4.13	5.21
URBAN	Percent Urban	6.5759	percent	0	89

Low-Flow Statistics Parameters [86.2 Percent (905 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1050	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	47	inches	35	50.4
STRDEN	Stream Density	1.36	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.4	feet	3.32	5.65
CARBON	Percent Carbonate	18.38	percent	0	99

Low-Flow Statistics Disclaimers [13.8 Percent (145 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [13.8 Percent (145 square miles) Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	271	ft ³ /s
30 Day 2 Year Low Flow	328	ft ³ /s
7 Day 10 Year Low Flow	168	ft ³ /s
30 Day 10 Year Low Flow	200	ft ³ /s
90 Day 10 Year Low Flow	254	ft ³ /s

Low-Flow Statistics Flow Report [86.2 Percent (905 square miles) Low Flow Region 2]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	451	ft ³ /s	38	38
30 Day 2 Year Low Flow	529	ft ³ /s	33	33
7 Day 10 Year Low Flow	292	ft ³ /s	51	51
30 Day 10 Year Low Flow	345	ft ³ /s	46	46
90 Day 10 Year Low Flow	419	ft ³ /s	36	36

Low-Flow Statistics Flow Report [Area-Averaged]

Statistic	Value	Unit
7 Day 2 Year Low Flow	426	ft ³ /s
30 Day 2 Year Low Flow	501	ft ³ /s
7 Day 10 Year Low Flow	275	ft ³ /s
30 Day 10 Year Low Flow	325	ft ³ /s
90 Day 10 Year Low Flow	396	ft ³ /s

Low-Flow Statistics Citations


PA0052647 at node 2

Region ID: PA

Workspace ID: PA20220616122850455000

Clicked Point (Latitude, Longitude): 40.24193, -75.65868

Time: 2022-06-16 08:29:12 -0400



 Collapse All

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	6.4976	degrees
CARBON	Percentage of area of carbonate rock	18.83	percent
DRNAREA	Area that drains to a point on a stream	1150	square miles
PRECIP	Mean Annual Precipitation	47	inches
ROCKDEP	Depth to rock	4.4	feet

Parameter Code	Parameter Description	Value	Unit
STRDEN	Stream Density -- total length of streams divided by drainage area	1.38	miles per square mile
URBAN	Percentage of basin with urban development	6.5198	percent

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [21.1 Percent (242 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1150	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	6.4976	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.4	feet	4.13	5.21
URBAN	Percent Urban	6.5198	percent	0	89

Low-Flow Statistics Parameters [78.9 Percent (905 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1150	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	47	inches	35	50.4
STRDEN	Stream Density	1.38	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.4	feet	3.32	5.65
CARBON	Percent Carbonate	18.83	percent	0	99

Low-Flow Statistics Disclaimers [21.1 Percent (242 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [21.1 Percent (242 square miles) Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	294	ft ³ /s
30 Day 2 Year Low Flow	357	ft ³ /s
7 Day 10 Year Low Flow	184	ft ³ /s
30 Day 10 Year Low Flow	218	ft ³ /s
90 Day 10 Year Low Flow	278	ft ³ /s

Low-Flow Statistics Flow Report [78.9 Percent (905 square miles) Low Flow Region 2]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	494	ft ³ /s	38	38
30 Day 2 Year Low Flow	579	ft ³ /s	33	33
7 Day 10 Year Low Flow	322	ft ³ /s	51	51
30 Day 10 Year Low Flow	379	ft ³ /s	46	46
90 Day 10 Year Low Flow	459	ft ³ /s	36	36

Low-Flow Statistics Flow Report [Area-Averaged]

Statistic	Value	Unit
7 Day 2 Year Low Flow	452	ft ³ /s
30 Day 2 Year Low Flow	532	ft ³ /s
7 Day 10 Year Low Flow	293	ft ³ /s
30 Day 10 Year Low Flow	345	ft ³ /s
90 Day 10 Year Low Flow	421	ft ³ /s

Low-Flow Statistics Citations

TRC_CALC

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
273	= Q stream (cfs)		0.5	= CV Daily	
0.2	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 281.490		1.3.2.iii	WLA_cfc = 274.423
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 104.890		5.1d	LTA_cfc = 159.537
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots$ $\dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)]^k (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5^k \cdot LN(cvh^2 + 1)) - 2.326^k \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots$ $\dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)]^k (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5^k \cdot LN(cvd^2 / no_samples + 1)) - 2.326^k \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326^k \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5^k \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				



Discharge Information

Instructions Discharge Stream

Facility: Pottstown Boro PWS NPDES Permit No.: PA0052647 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Filter backwash/basin cleaning

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.2	123	7.38						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	270								
	Chloride (PWS)	mg/L	47.9								
	Bromide	mg/L	< 0.2								
	Sulfate (PWS)	mg/L	61								
	Fluoride (PWS)	mg/L	< 0.13								
Group 2	Total Aluminum	µg/L	390								
	Total Antimony	µg/L	0.4								
	Total Arsenic	µg/L	< 1								
	Total Barium	µg/L	36								
	Total Beryllium	µg/L	< 0.1								
	Total Boron	µg/L	< 200								
	Total Cadmium	µg/L	< 0.1								
	Total Chromium (III)	µg/L									
	Hexavalent Chromium	µg/L	0.27								
	Total Cobalt	µg/L	< 0.3								
	Total Copper	µg/L	< 1								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L	< 4								
	Dissolved Iron	µg/L	< 20								
	Total Iron	µg/L	60								
	Total Lead	µg/L	< 0.6								
	Total Manganese	µg/L	2550								
	Total Mercury	µg/L	< 0.09								
	Total Nickel	µg/L	1.7								
	Total Phenols (Phenolics) (PWS)	µg/L	2								
	Total Selenium	µg/L	< 1								
	Total Silver	µg/L	< 0.3								
Total Thallium	µg/L	< 0.2									
Total Zinc	µg/L	< 5									
Total Molybdenum	µg/L	< 3									
Acrolein	µg/L	<									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	<									
Benzene	µg/L	<									
Bromoform	µg/L	<									

Group 3	Carbon Tetrachloride	µg/L	<																	
	Chlorobenzene	µg/L	<																	
	Chlorodibromomethane	µg/L	<																	
	Chloroethane	µg/L	<																	
	2-Chloroethyl Vinyl Ether	µg/L	<																	
	Chloroform	µg/L	<																	
	Dichlorobromomethane	µg/L	<																	
	1,1-Dichloroethane	µg/L	<																	
	1,2-Dichloroethane	µg/L	<																	
	1,1-Dichloroethylene	µg/L	<																	
	1,2-Dichloropropane	µg/L	<																	
	1,3-Dichloropropylene	µg/L	<																	
	1,4-Dioxane	µg/L	<																	
	Ethylbenzene	µg/L	<																	
	Methyl Bromide	µg/L	<																	
	Methyl Chloride	µg/L	<																	
	Methylene Chloride	µg/L	<																	
	1,1,2,2-Tetrachloroethane	µg/L	<																	
	Tetrachloroethylene	µg/L	<																	
	Toluene	µg/L	<																	
1,2-trans-Dichloroethylene	µg/L	<																		
1,1,1-Trichloroethane	µg/L	<																		
1,1,2-Trichloroethane	µg/L	<																		
Trichloroethylene	µg/L	<																		
Vinyl Chloride	µg/L	<																		
Group 4	2-Chlorophenol	µg/L	<																	
	2,4-Dichlorophenol	µg/L	<																	
	2,4-Dimethylphenol	µg/L	<																	
	4,6-Dinitro-o-Cresol	µg/L	<																	
	2,4-Dinitrophenol	µg/L	<																	
	2-Nitrophenol	µg/L	<																	
	4-Nitrophenol	µg/L	<																	
	p-Chloro-m-Cresol	µg/L	<																	
	Pentachlorophenol	µg/L	<																	
	Phenol	µg/L	<																	
2,4,6-Trichlorophenol	µg/L	<																		
Group 5	Acenaphthene	µg/L	<																	
	Acenaphthylene	µg/L	<																	
	Anthracene	µg/L	<																	
	Benzidine	µg/L	<																	
	Benzo(a)Anthracene	µg/L	<																	
	Benzo(a)Pyrene	µg/L	<																	
	3,4-Benzofluoranthene	µg/L	<																	
	Benzo(ghi)Perylene	µg/L	<																	
	Benzo(k)Fluoranthene	µg/L	<																	
	Bis(2-Chloroethoxy)Methane	µg/L	<																	
	Bis(2-Chloroethyl)Ether	µg/L	<																	
	Bis(2-Chloroisopropyl)Ether	µg/L	<																	
	Bis(2-Ethylhexyl)Phthalate	µg/L	<																	
	4-Bromophenyl Phenyl Ether	µg/L	<																	
	Butyl Benzyl Phthalate	µg/L	<																	
	2-Chloronaphthalene	µg/L	<																	
	4-Chlorophenyl Phenyl Ether	µg/L	<																	
	Chrysene	µg/L	<																	
	Dibenzo(a,h)Anthracene	µg/L	<																	
	1,2-Dichlorobenzene	µg/L	<																	
1,3-Dichlorobenzene	µg/L	<																		
1,4-Dichlorobenzene	µg/L	<																		
3,3-Dichlorobenzidine	µg/L	<																		
Diethyl Phthalate	µg/L	<																		
Dimethyl Phthalate	µg/L	<																		
Di-n-Butyl Phthalate	µg/L	<																		
2,4-Dinitrotoluene	µg/L	<																		



Stream / Surface Water Information

Pottstown Boro PWS, NPDES Permit No. PA0052647, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: Schuylkill River No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	000833	57.04	124.79	1050			Yes
End of Reach 1	000833	54.61	119.82	1150			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	57.04	0.26										149	7.3		
End of Reach 1	54.61	0.26										149	7.3		

Q_n

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	57.04														
End of Reach 1	54.61														



Model Results

Pottstown Boro PWS, NPDES Permit No. PA0052647, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	39,521	
Total Antimony	0	0		0	1,100	1,100	57,963	
Total Arsenic	0	0		0	340	340	17,916	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	1,106,575	
Total Boron	0	0		0	8,100	8,100	426,822	
Total Cadmium	0	0		0	2,957	3.19	168	Chem Translator of 0.927 applied
Hexavalent Chromium	0	0		0	16	16.3	859	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	5,006	
Total Copper	0	0		0	19,507	20.3	1,071	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	99,058	135	7,117	Chem Translator of 0.733 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1,400	1.65	86.8	Chem Translator of 0.85 applied
Total Nickel	0	0		0	654,277	656	34,546	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	6,351	7.47	394	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	3,425	
Total Zinc	0	0		0	163,823	168	8,827	Chem Translator of 0.978 applied

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	79,012	
Total Arsenic	0	0		0	150	150	53,872	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	1,472,502	
Total Boron	0	0		0	1,600	1,600	574,635	
Total Cadmium	0	0		0	0.324	0.36	131	Chem Translator of 0.892 applied
Hexavalent Chromium	0	0		0	10	10.4	3,733	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	6,824	
Total Copper	0	0		0	12.587	13.1	4,709	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	1,325,029	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	3.872	5.28	1,897	Chem Translator of 0.733 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	325	Chem Translator of 0.85 applied
Total Nickel	0	0		0	72.844	73.1	26,240	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4.600	4.99	1,792	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	4,669	
Total Zinc	0	0		0	165.560	168	60,305	Chem Translator of 0.986 applied

THH CCT (min): 720 PMF: 0.406 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	2,011	
Total Arsenic	0	0		0	10	10.0	3,591	
Total Barium	0	0		0	2,400	2,400	861,962	
Total Boron	0	0		0	3,100	3,100	1,113,355	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	

Dissolved Iron	0	0		0	300	300	107,744	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	359,147	
Total Mercury	0	0		0	0.050	0.05	18.0	
Total Nickel	0	0		0	610	610	219,080	
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	0.24	0.24	86.2	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	N/A	N/A	N/A	
Total Nickel	0	0		0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	Discharge Conc < TQL
Total Aluminum	25,331	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	2,011	µg/L	Discharge Conc ≤ 10% WQBEL
Total Arsenic	N/A	N/A	Discharge Conc < TQL
Total Barium	709,270	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	273,575	µg/L	Discharge Conc < TQL
Total Cadmium	108	µg/L	Discharge Conc < TQL
Hexavalent Chromium	550	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cobalt	3,209	µg/L	Discharge Conc < TQL
Total Copper	686	µg/L	Discharge Conc < TQL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	107,744	µg/L	Discharge Conc < TQL
Total Iron	1,325,029	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	1,897	µg/L	Discharge Conc < TQL
Total Manganese	359,147	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	18.0	µg/L	Discharge Conc < TQL
Total Nickel	22,142	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	PWS Not Applicable
Total Selenium	1,792	µg/L	Discharge Conc < TQL
Total Silver	252	µg/L	Discharge Conc < TQL
Total Thallium	86.2	µg/L	Discharge Conc < TQL
Total Zinc	5,658	µg/L	Discharge Conc < TQL
Total Molybdenum	N/A	N/A	No WQS