



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0053082

APS ID

1120366

Authorization ID

1496760

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

Applicant Name	Mendenhall Inn	Facility Name	Mendenhall Inn STP
Applicant Address	P. O. Box 607	Facility Address	PO Box 607
	Concordville, PA 19331		Concordville, PA 19331
Applicant Contact	Alexander Hionis	Facility Contact	Alexander Hionis
Applicant Phone	(610) 506-8979	Facility Phone	(610) 506-8979
Client ID	2468	Site ID	452232
Ch 94 Load Status	Not Overloaded	Municipality	Kennett Township
Connection Status		County	Chester
Date Application Received	July 26, 2024	EPA Waived?	No
Date Application Accepted		If No, Reason	Christina TMDL
Purpose of Application	NPDES permit renewal.		

Summary of Review

The Pa Department of Environmental Protection (PADEP/Department) received an NPDES permit renewal application from Clean Water, Inc. (consultant) on behalf of Mendenhall Inn (permittee) on July 26, 2024 for Permittee's Mendenhall Inn STP (facility). This is a minor sewage facility with a design flow of 0.0206 MGD that discharges into Craigs Mill Run (WWF, MF) in state watershed 3-H. The current permit will expire on January 31, 2025. The terms and conditions of the current permit is automatically extended since the renewal application was received at least 180 days prior to expiration date. Renewal NPDES permit application under Clean Water Program are not covered by PADEP's PDG per 021-2100-001. This fact sheet is developed in accordance with 40 CFR §124.56.

Changes to existing permit: Added: E. Coli.

Sludge use and disposal description and location(s): Digested sludge are hauled-off by licensed hauler.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		Reza H. Chowdhury, E.I.T. / Project Manager 	November 20, 2024
X		Pravin Patel Pravin C. Patel, P.E. / Environmental Engineer Manager	11/25/2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.0206
Latitude	39° 51' 17.36"	Longitude	-75° 38' 20.94"
Quad Name	Kennett Square	Quad Code	2040
Wastewater Description:	Sewage Effluent		
Receiving Waters	Craigs Mill Run (WWF, MF)	Stream Code	00023
NHD Com ID	26092224	RMI	2.5
Drainage Area	0.11 mi ²	Yield (cfs/mi ²)	0.21
Q ₇₋₁₀ Flow (cfs)	0.023	Q ₇₋₁₀ Basis	Previous permit
Elevation (ft)	320	Slope (ft/ft)	
Watershed No.	3-H	Chapter 93 Class.	WWF, MF
Existing Use		Existing Use Qualifier	
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Impaired		
Cause(s) of Impairment	SILTATION, SILTATION		
Source(s) of Impairment	AGRICULTURE, HABITAT MODIFICATION - OTHER THAN HYDROMODIFICATION		
TMDL Status	Final	Name	Christina River Basin
Background/Ambient Data		Data Source	
pH (SU)	7.0	Default	
Temperature (°C)	20	Default	
Hardness (mg/L)	100	Default	
Other:			
Nearest Downstream Public Water Supply Intake	None before PA-DE border		

Changes Since Last Permit Issuance: None

Other Comments: Stream data were copied from previous permit's fact sheet. The yield and drainage area at the outfall 001 used in the previous permit was 0.21 cfs/mi² and 0.11 mi², respectively, which resulted in a Q₇₋₁₀ of 0.023 cfs. The previous permit utilized WQM 7.0 modeling to calculate WQBELs for conventional pollutants. The assumptions in that modeling efforts are still valid, therefore, no new WQM 7.0 modeling is conducted for this renewal. A copy of previous modeling is attached with this fact sheet.

Default discharge pH of 7.0, temperature of 25°C, and hardness of 100 mg/l will be used in modeling, as appropriate.

Treatment Facility Summary				
Treatment Facility Name: Mendenhall Inn STP				
WQM Permit No.	Issuance Date			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration	Hypochlorite	0.0206
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0206		Not Overloaded		

Changes Since Last Permit Issuance: None

Other Comments: The treatment facility consists of Grease Traps, Aerated Flow Equalization, Extended Aeration, Clarifier, Backwash Style Filter, Chlorine Contact Chamber, and Flow Meter.

Existing limits

The following effluent limits are currently applied at Outfall 001 for the period 02/01/2020 through 01/31/2025:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.2	XXX	0.5	1/day	Grab
CBOD5 Nov 1 - Apr 30	3.42	XXX	XXX	20	XXX	40	2/month	24-Hr Composite
CBOD5 May 1 - Oct 31	1.71	XXX	XXX	10	XXX	20	2/month	24-Hr Composite
Total Suspended Solids	1.71	XXX	XXX	10	XXX	20	2/month	24-Hr Composite
Fecal Coliform (CFU/100 ml)	XXX	XXX	XXX	200	XXX	1000*	2/month	Grab
Total Nitrogen	3.436	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	1.54	XXX	XXX	9.0	XXX	18	2/month	24-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	0.51	XXX	XXX	3.0	XXX	6	2/month	24-Hr Composite
Total Phosphorus	0.17	XXX	XXX	1.0	XXX	2	2/month	24-Hr Composite

*Not greater than 1,000/100 milliliters of fecal coliform organisms in more than 10 percent of the samples tested.

Compliance History

DMR Data for Outfall 001 (from October 1, 2023 to September 30, 2024)

Parameter	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23
Flow (MGD) Average Monthly	0.00873	0.00964	0.00977	0.00925	0.00863	0.00911	0.00739	0.00554	0.00782	0.0087	0.00955	0.00955
Flow (MGD) Daily Maximum	0.01870	0.01880	0.01650	0.01660	0.01610	0.01500	0.01020	0.00810	0.01650	0.01770	0.01750	0.01550
pH (S.U.) IMIN	7.13	7.15	7.06	7.13	7.04	7.04	7.03	7.04	7.03	7.09	7.13	7.10
pH (S.U.) IMAX	7.39	7.39	7.90	7.36	7.33	7.31	7.38	7.28	7.31	7.26	7.27	7.29
DO (mg/L) IMIN	7.0	7.0	6.8	6.8	7.0	7.0	7.0	7.0	7.0	6.5	7.0	7.0
TRC (mg/L) Average Monthly	0.021	0.025	0.021	0.033	0.018	0.022	0.015	0.019	0.013	0.015	0.017	0.016
TRC (mg/L) IMAX	0.07	0.06	0.05	0.12	0.04	0.08	0.05	0.04	0.04	0.04	0.04	0.04
CBOD5 (lbs/day) Average Monthly	< 0.098	< 0.118	< 0.103	< 0.126	< 0.151	< 0.149	< 0.114	< 0.047	0.164	< 0.142	0.121	< 0.141
CBOD5 (mg/L) Average Monthly	< 2	< 2	< 2	< 2	< 2.7	< 2.6	< 2	< 2	2.7	< 2	2.767	< 2.7
TSS (lbs/day) Average Monthly	0.202	0.587	0.103	0.279	0.241	0.231	0.124	0.073	< 0.128	0.473	0.183	0.149
TSS (mg/L) Average Monthly	4	10	2	4	4.5	5	3	3	< 3	6.5	4	3
Fecal Coliform (CFU/100 ml) Average Monthly	< 2	< 2	< 2	< 2	4732.9	< 4	< 2	< 2	< 2	< 2	< 2.3	< 3.7
Fecal Coliform (CFU/100 ml) IMAX	< 2	< 2	< 2	< 2	7000	8	< 2	< 2	< 2	< 2	3	7
Total Nitrogen (lbs/day) Average Monthly	< 1.255	< 1.772	< 0.707	< 1.873	< 1.291	< 1.810	< 1.207	< 0.769	< 1.453	< 1.443	< 1.206	< 0.607
Total Nitrogen (mg/L) Average Monthly	< 25.2	< 29.95	< 12.9	29.65	< 23	< 29.05	< 21.2	< 22.75	< 24.82	< 20.39	< 24.3	< 13.4
Ammonia (lbs/day) Average Monthly	0.0232	0.003	0.013	< 0.0032	0.0139	0.014	< 0.002	< 0.0007	0.0052	0.1072	0.0024	< 0.0016
Ammonia (mg/L) Average Monthly	0.545	0.05	0.21	< 0.045	0.275	0.215	< 0.03	< 0.03	0.085	1.415	0.053	< 0.035
Total Phosphorus (lbs/day) Average Monthly	0.019	0.015	0.01	0.015	0.012	0.016	0.006	0.004	0.015	0.018	0.011	0.017
Total Phosphorus (mg/L) Average Monthly	0.385	0.245	0.15	0.225	0.21	0.28	0.105	0.155	0.255	0.26	0.29	0.365

Compliance History

Effluent Violations for Outfall 001, from: November 1, 2023 To: September 30, 2024

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	05/31/24	Avg Mo	4732.9	CFU/100 ml	200	CFU/100 ml
Fecal Coliform	05/31/24	IMAX	7000	CFU/100 ml	1000	CFU/100 ml

Summary of Inspections:

02/09/2022: CEI conducted. No violations noted. The inspector couldn't access the site, outfall was assessed, and the effluent was clear.

04/22/2020: Admin review conducted. No violations noted. Due to COVID-19, the restaurant was shut down which reduced the flow to an average of 200-300 GPD.

Other Comments: None

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	.0206	
Latitude	39° 51' 17.45"	Longitude	-75° 38' 20.81"	
Wastewater Description:	Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above technology-based limitations were evaluated and compared against other criteria for this permit renewal. Other criteria which were more stringent, were retained or added to this permit renewal. The pH will remain 6.0 to 9.0 as shown in the above table. The fecal coliform limit is retained from the existing permit and is an effluent concentration not greater than 200/100 milliliters of fecal coliform organisms as a geometric mean value and not greater than 1,000/100 milliliters of fecal coliform organisms in more than 10 percent of the samples tested.

As stated in page 2 of this report, no WQM modeling was conducted for CBOD₅, NH₃-N and DO. The previous model data is attached.

The Christina River Basin TMDL of Nutrients and Dissolved Oxygen Under Low-Flow Condition was issued by the Environmental Protection Agency (EPA) on January 19, 2001 and subsequently revised in October 2002 and April 2006. Subsequently, DEP prepared, and EPA acknowledged, an Alternative Reduction Scenario for the Christina River Basin for Low Flow TMDL dated June 27, 2012 which reassigned some of the allocations within the discharges but kept the total load to the basin the same. Mendenhall Inn STP is part of an Alternative Reduction Scenario TMDL (Summary Table 15) for parameters: CBOD₅, NH₃N, Dissolved Oxygen, Total Nitrogen (TN), and Total Phosphorus (TP). The loadings are 1.719 (10), 0.516 (3), 0.860 (5), 3.436 (10), and 0.344 (2) lb/d (mg/l), respectively. Besides TN (discussed below), the current permit meets these limitations or is more stringent than the Waste Load Allocations (WLA).

The Christina River Basin also has approved High-Flow TMDLs for Bacteria and Sediment (dated September 2006) for Fecal Coliform, enterococci, and TSS, and for Nutrients and Dissolved Oxygen (dated September 2006) loads for phosphorus, ammonia-N, and CBOD₅. The limits for Total Suspended Solids (10 mg/l) and Fecal Coliform (200 No./100ml) will continue in this permit renewal and it is consistent with the High Flow TMDL for Bacteria and Sediment. Seasonal limitations are also consistent with the TMDLs. The high flow TMDL allocations were not adjusted at the time when low flow TMDL allocations were adjusted under the "Alternative Reduction Scenario". Since, the Christina River Low-Flow TMDL is the driver for the Christina River High-Flow TMDL, especially for nutrients, it is assumed that compliance with the low flow TMDL, satisfies the compliance of the high flow TMDL.

TP was set to 1 mg/l, which is lower than the standard practices and the TMDL WLA, and is retained in this permit. The limit was set several permit renewals ago due to stream impairment. The permittee is meeting the limit.

In order to comply with the Low Flow TMDL Alternative Reduction Scenario, a loading limit of 3.436 lb/d as a monthly average was applied in previous permit cycle and will be carried over. Existing concentration-based monitoring will also carried over.

Pa Code 25 § 92a. 61 requires monitoring of E. Coli. DEP's SOP titled "Establishing Effluent Limitations for Individual Sewage Permits (BCW-PMT-033, revised March 24, 2021) recommends annual E. Coli monitoring for facilities with design flow between 2,000 GPD to 50,000 GPD. This requirement will be applied from this permit term.

Total Nitrogen monitoring frequency is changed from 2/month to 1/month.

Sampling frequencies are retained from the existing permit. While the sampling frequencies are lower than those in Table 6-3 in DEP's Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001), per standard practice the frequencies can be retained if the permittee is meeting the limits (SOP New and Reissuance Sewage Individual NPDES Permit Applications).

Best Professional Judgment (BPJ) Limitations

Comments: No comment

Anti-Backsliding

Anti-backsliding prohibition is justified in sections where an exception is justified for the affected pollutant(s). For remaining pollutants, this prohibition isn't applicable since the proposed limits are at least as stringent as were in current permit.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.2	XXX	0.5	1/day	Grab
CBOD5 Nov 1 - Apr 30	3.42	XXX	XXX	20	XXX	40	2/month	24-Hr Composite
CBOD5 May 1 - Oct 31	1.71	XXX	XXX	10	XXX	20	2/month	24-Hr Composite
TSS	1.71	XXX	XXX	10	XXX	20	2/month	24-Hr Composite
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	1000*	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	3.436	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
Ammonia Nov 1 - Apr 30	1.54	XXX	XXX	9.0	XXX	18	2/month	24-Hr Composite
Ammonia May 1 - Oct 31	0.51	XXX	XXX	3.0	XXX	6	2/month	24-Hr Composite
Total Phosphorus	0.17	XXX	XXX	1.0	XXX	2	2/month	24-Hr Composite

*Not greater than 1,000/100 milliliters of fecal coliform organisms in more than 10 percent of the samples tested.

Compliance Sampling Location: At Outfall 001

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
03H		23 Trib 00023 to Brandywine Creek	2.500	320.00	0.11	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.02	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)			
Mendenhall Inn	PA0053082	0.0206	0.0206	0.0206	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc	Trib Conc	Stream Conc	Fate Coef		
		(mg/L)	(mg/L)	(mg/L)	(1/days)		
CBOD5		10.00	2.00	0.00	1.50		
Dissolved Oxygen		5.00	8.24	0.00	0.00		
NH3-N		3.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
03H		23 Trib 00023 to Brandywine Creek			0.200	160.00	0.58	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.100	0.11	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
Discharge Data										
	Name	Permit Number		Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
				0.0000	0.0000	0.0000	0.000	25.00	7.00	
Parameter Data										
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef				
	CBOD5		25.00	2.00	0.00	1.50				
	Dissolved Oxygen		3.00	8.24	0.00	0.00				
	NH3-N		25.00	0.00	0.00	0.70				

WQM 7.0 Hydrodynamic Outputs

SWP Basin			Stream Code		Stream Name								
03H			23		Trib 00023 to Brandywine Creek								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
Q7-10 Flow													
2.500	0.02	0.00	0.02	.0319	0.01318	.34	2.16	6.36	0.07	1.992	23.07	7.00	
Q1-10 Flow													
2.500	0.01	0.00	0.01	.0319	0.01318	NA	NA	NA	0.06	2.166	23.57	7.00	
Q30-10 Flow													
2.500	0.03	0.00	0.03	.0319	0.01318	NA	NA	NA	0.08	1.852	22.70	7.00	

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input checked="" type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

SWP Basin		Stream Code		Stream Name															
03H		23		Trib 00023 to Brandywine Creek															
NH3-N Acute Allocations																			
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction												
2.500	Mendenhall Inn	7.48	6	7.48	6	0	0												
NH3-N Chronic Allocations																			
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction												
2.500	Mendenhall Inn	1.58	2.93	1.58	2.93	0	0												
Dissolved Oxygen Allocations																			
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction										
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)												
2.50	Mendenhall Inn	10	10	2.93	2.93	5	5	0	0										

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
03H	23	Trib 00023 to Brandywine Creek		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.500	0.021	23.072	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
2.163	0.340	6.364	0.071	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
6.92	0.541	1.80	0.887	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.250	29.092	Owens	6	
<u>Reach Travel Time (days)</u>		<u>Subreach Results</u>		
1.992	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.199	6.11	1.51	7.80
	0.398	5.40	1.26	7.80
	0.598	4.77	1.06	7.80
	0.797	4.21	0.89	7.80
	0.996	3.72	0.74	7.80
	1.195	3.29	0.62	7.80
	1.394	2.90	0.52	7.80
	1.594	2.56	0.44	7.80
	1.793	2.26	0.37	7.80
	1.992	2.00	0.31	7.80

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>				
03H	23	Trib 00023 to Brandywine Creek				
<u>RMI</u>	<u>Name</u>	<u>Permit Number</u>	<u>Disc Flow (mgd)</u>	<u>Parameter</u>	<u>Eff. Limit 30-day Ave. (mg/L)</u>	<u>Eff. Limit Maximum (mg/L)</u>
2.500	Mendenhall Inn	PA0053082	0.021	CBOD5	10	
				NH3-N	2.93	5.86
				Dissolved Oxygen		5

Copy of TRC_CALC

TRC EVALUATION									
Input appropriate values in A3:A9 and D3:D9									
0.0226 = Q stream (cfs)			0.5 = CV Daily						
0.0206 = Q discharge (MGD)			0.5 = CV Hourly						
30 = no. samples			1 = AFC_Partial Mix Factor						
0.3 = Chlorine Demand of Stream			1 = CFC_Partial Mix Factor						
0 = Chlorine Demand of Discharge			15 = AFC_Criteria Compliance Time (min)						
0.5 = BAT/BPJ Value			720 = CFC_Criteria Compliance Time (min)						
0 = % Factor of Safety (FOS)			=Decay Coefficient (K)						
Source	Reference	AFC Calculations		Reference	CFC Calculations				
TRC	1.3.2.iii	WLA_afc = 0.245		1.3.2.iii	WLA_cfc = 0.232				
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581				
PENTOXSD TRG	5.1b	LTA_afc = 0.091		5.1d	LTA_cfc = 0.135				
Effluent Limit Calculations									
PENTOXSD TRG	5.1f	AML MULT = 1.231							
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.112		AFC					
		INST MAX LIMIT (mg/l) = 0.368							
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
LTAMULT_afc	$\text{EXP}((0.5^*\text{LN}(cvh^2+1))-2.326^*\text{LN}(cvh^2+1)^{0.5})$								
LTA_afc	wla_afc*LTAMULT_afc								
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
LTAMULT_cfc	$\text{EXP}((0.5^*\text{LN}(cvd^2/no_samples+1))-2.326^*\text{LN}(cvd^2/no_samples+1)^{0.5})$								
LTA_cfc	wla_cfc*LTAMULT_cfc								
AML MULT	$\text{EXP}(2.326^*\text{LN}((cvd^2/no_samples+1)^{0.5})-0.5^*\text{LN}(cvd^2/no_samples+1))$								
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)								
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)								

Mendenhall Inn Wastewater Treatment Plant

Treatment Plant Schematic

