

Application Type Renewal
Facility Type Sewage
Major / Minor Major

**NPDES PERMIT FACT SHEET
ADDENDUM**

Application No. PA0053147
APS ID 832443
Authorization ID 1327056


Applicant and Facility Information

Applicant Name	<u>Upper Saucon Sewage Treatment Authority</u>	Facility Name	<u>Upper Saucon Township WWTP</u>
Applicant Address	<u>5500 Camp Meeting Road</u> <u>Center Valley, PA 18034-9444</u>	Facility Address	<u>4774 Saucon Creek Road</u> <u>Center Valley, PA 18034</u>
Applicant Contact	<u>Patrick Lambert</u>	Facility Contact	<u>Patrick Lambert</u>
Applicant Phone	<u>(610) 282-1171</u>	Facility Phone	<u>(610) 282-1171</u>
Client ID	<u>309424</u>	Site ID	<u>270952</u>
SIC Code	<u>4952</u>	Municipality	<u>Upper Saucon Township</u>
SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>	County	<u>Lehigh</u>
Date Published in PA Bulletin	<u>January 18, 2025</u>	EPA Waived?	<u>No</u>
Comment Period End Date	<u>February 17, 2025</u>	If No, Reason	<u>Major Facility</u>
Purpose of Application	<u>Renewal of NPDES permit.</u>		

Internal Review and Recommendations

Public notification of draft permit issuance was published in the PA Bulletin on January 18, 2025. No comments were received during the 30-day public comment period. NERO's Clean Water Monitoring & Compliance section pointed out a typographical error on the previous fact sheet where the facility was referred to as the Upper Saucon Township "WWWP" instead of the Upper Saucon Township "WWTP". The error is noted, and this fact sheet addendum correctly refers to the facility as a "WWTP".

Current DEP guidance requires monthly E. Coli monitoring/reporting at this facility. The requirement is added to the permit and another draft permit must be issued due to the changes made.

Approve	Return	Deny	Signatures	Date
X			 Brian Burden, E.I.T. / Project Manager	February 19, 2025
X			 Edward Dudick, P.E. / Environmental Engineer Manager	February 19, 2025