

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0053279
 APS ID 1004242
 Authorization ID 1292888

Applicant and Facility Information

Applicant Name	<u>The Mckee Group</u>	Facility Name	<u>Buckingham Springs STP</u>
Applicant Address	<u>1490 Durham Road</u> <u>New Hope, PA 18938</u>	Facility Address	<u>Village Of Buckingham Springs, 2490</u> <u>Durham Road</u> <u>New Hope, PA 18938</u>
Applicant Contact	<u>Kent Jagers</u>	Facility Contact	<u>Kent Jagers</u>
Applicant Phone	<u>(215) 598-7600</u>	Facility Phone	<u>(215) 598-7600</u>
Client ID	<u>62996</u>	Site ID	<u>240632</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Buckingham Township</u>
Connection Status		County	<u>Bucks</u>
Date Application Received	<u>October 15, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>Permit Renewal.</u>		

Summary of Review

The applicant requests renewal of an NPDES permit to discharge treated sewage from Buckingham Springs STP that serves a residential community known as Buckingham Springs Village.

Sewage enters the plant via gravity, passing through a bar screen and influent metering before entering the EQ tank. Sewage is pumped into one of two SBR trains for treatment. Ferric chloride is added to the SBRs. Treated effluent decants to a post EQ tank. From post EQ the effluent is disinfected, dechlorinated, and filtered before discharging to the effluent pump station. Effluent sampling is conducted at the filter.

Sludge from the sludge holding tank is sent to Reed Beds (4) and ultimately hauled away by contractors.

Based on the review of the DMRs, the discharge is in compliance with most of the times.

There are no changes in the flow, treatment units, influent characteristics, stream designation etc., the current permit limits are recommended for the new permit. The only new parameter is TDS. Reported TDS concentration (978 mg/l) is more than the criterion.

Review shows that the discharge is to an unnamed, intermittent tributary to Mill Creek approximately 1000 ft prior to the confluence with perennial stream.

DRBC docket No. D-2009-040 CP-3 was approved on March 13, 2019 for this project. Permittee had issues with the elevated TDS concentrations in the effluent. DRBC determined that the information submitted by the permittee, supported their claim that the elevated TDS levels in the effluent are not caused by the plant operations/processes and may be a result of elevated hardness in the public water supply and water softeners regeneration backwash. A request from the permittee for

Approve	Deny	Signatures	Date
		Sara Reji Abraham, E.I.T. / Project Manager	
		Pravin C. Patel, P.E. / Environmental Engineer Manager	

Summary of Review

the TDS variance was granted and included an average monthly TDS effluent limit of 1500 mg/l in this docket.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Act 14 Notification:

Buckingham Township - September 30, 2019
Bucks County - September 30, 2019

Permits Conditions:

- A. No Stormwater
- B. Acquire Necessary Property Rights
- C. Proper Sludge Disposal
- D. Abandon STP when Municipal Sewers Available
- E. Chlorine Optimization
- F. Operator Notification
- G. Fecal Coliform Requirement
- H. Small Stream Discharge
- I. Solids Management

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.1</u>
Latitude	<u>40° 18' 1.36"</u>	Longitude	<u>-75° 2' 31.05"</u>
Quad Name	<u>Buckingham</u>	Quad Code	<u>1645</u>
Wastewater Description: <u>Treated Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Mill Creek (WWF, MF)</u>	Stream Code	<u>02623</u>
NHD Com ID	<u>25475538</u>	RMI	<u>0.25</u>
Drainage Area	<u>0.24 mi²</u>	Yield (cfs/mi ²)	<u>0.07</u>
Q ₇₋₁₀ Flow (cfs)	<u><0.1</u>	Q ₇₋₁₀ Basis	<u>Previous fact sheet</u>
Watershed No.	<u>2-F</u>	Chapter 93 Class.	<u>WWF, MF</u>
Assessment Status	<u>Attaining Use(s)</u>		
TMDL Status	<u>Final, 04/09/2003</u>	Name	<u>Neshaminy Creek</u>
Nearest Downstream Public Water Supply Intake	<u>Aqua PA – Trevoise, PA</u>		
PWS Waters	<u>Neshaminy Creek</u>		

* Neshaminy Creek TMDL was issued in April 2003 for nutrients and sediment. Neshaminy Creek nutrient TMDL was subsequently withdrawn and will be revised in the future. Neshaminy Creek sediment TMDL is still in effect, but the sediment TMDL does not apply to sewage treatment plants.

At the confluence of the unnamed tributary, Mill Creek has a drainage area of 12.3 mi² and a Q₇₋₁₀ of 0.87 cfs.

Treatment Facility Summary				
Treatment Facility Name: Buckingham Springs STP				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Sequencing Batch Reactor W/Sol Removal	Hypochlorite	0.1
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.1	184	Not Overloaded	Holding Tank	Reed Beds and Hauling Out

Compliance History

DMR Data for Outfall 001 (from November 1, 2018 to October 31, 2019)

Parameter	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18	NOV-18
Flow (MGD) Average Monthly	0.0404	0.0398	0.0421	0.0446	0.0436	0.0467	0.0398	0.0406	0.0397	0.0436	0.0469	0.0514
pH (S.U.) Instantaneous Minimum	6.8	6.8	6.8	7.0	6.8	6.7	7.1	7.1	7.2	7.1	7.2	7.0
pH (S.U.) Instantaneous Maximum	7.4	7.4	7.4	7.4	7.5	7.6	7.6	7.6	7.6	7.6	7.8	7.6
DO (mg/L) Minimum	6.5	6.3	6.4	6.2	6.6	6.6	7.0	8.0	8.2	8.4	8.3	7.4
TRC (mg/L) Average Monthly	0.02	0.02	0.03	0.02	0.04	0.02	0.04	0.05	0.03	0.02	0.02	0.02
TRC (mg/L) Instantaneous Maximum	0.06	0.07	0.08	0.12	0.15	0.09	0.15	0.09	0.08	0.02	0.03	0.04
CBOD5 (lbs/day) Average Monthly	< 1.0	0.9	0.8	1.0	0.8	1.2	0.9	1.3	0.9	1.1	< 0.8	< 1.2
CBOD5 (mg/L) Average Monthly	< 3.0	3	3	3.0	3	3	3	4	3	< 3	< 3	< 3
TSS (lbs/day) Average Monthly	< 2	4	3	3	2	6	6	7	5	6	3	8
TSS (mg/L) Average Monthly	< 5	12	8	8	7	13	18	22	17	17	9	16
Fecal Coliform (CFU/100 ml) Geometric Mean	< 12	11	< 21	159	36	7	< 12	< 5	15	15	15	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	88	64	600	700	88	16	32	48	32	48	33	< 1
Nitrate-Nitrite (lbs/day) Average Monthly	< 0.9	0.9	1.2	< 0.9	1	0.3	0.4	< 0.6	2	2.5	2	3
Nitrate-Nitrite (mg/L) Average Monthly	< 2.8	2.9	3.4	< 2.6	3	0.7	1.2	< 1.7	6.4	7.2	6.67	6.27

**NPDES Permit Fact Sheet
Buckingham Springs STP**

NPDES Permit No. PA0053279

Total Nitrogen (lbs/day) Average Monthly	1	1	2	1	1	1	1.0	1	2	3	5	5
Total Nitrogen (mg/L) Average Monthly	4.42	4.61	5.02	4.14	4.59	2.65	4.2	3.4	7.62	8.4	17.42	7.71
Ammonia (lbs/day) Average Monthly	< 0.1	< 0.04	< 0.1	< 0.06	< 0.06	< 0.04	< 0.1	< 0.03	< 0.03	< 0.04	< 1.2	< 0.3
Ammonia (mg/L) Average Monthly	< 0.3	< 0.1	< 0.4	< 0.2	< 0.2	< 0.1	< 0.3	< 0.1	< 0.1	< 0.1	< 4.2	< 0.8
Total Phosphorus (lbs/day) Average Monthly	0.1	0.2	0.2	0.2	1.0	0.2	0.1	0.1	0.1	0.2	0.1	0.2
Total Phosphorus (mg/L) Average Monthly	0.4	0.5	0.5	0.5	4.59	0.4	0.4	0.3	0.4	0.6	0.3	0.4

Compliance History

Effluent Violations for Outfall 001, from: December 1, 2018 To: October 31, 2019

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Total Phosphorus	06/30/19	Avg Mo	4.59	mg/L	1.5	mg/L

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) .1
 Latitude 40° 18' 0.64" Longitude -75° 2' 30.86"
 Wastewater Description: Treated Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

Parameter	Limit (mg/l)	SBC	Basis
CBOD ₅ (May 1-Oct 31)	10	Average Monthly	WQM 6.3
CBOD ₅ (Nov 1- Apr 30)	15	Average Monthly	seasonal
Total Suspended Solids	30	Average Monthly	DRBC
Total Dissolved Solids	1,500	Average Monthly	DRBC
NH ₃ -N (May 1- Oct 31)	3.0	Average Monthly	WQM 6.3
NH ₃ -N (Nov 1 – Apr 30)	7.0	Average Monthly	seasonal
DO	5.0	Inst.Min.	WQM 6.3
pH	6.0 to 9.0 std at all times		Ch. 93
Fecal Coliform	200/1000	Geo.mean/Imax	Ch.93 and DRBC
TRC*	0.06	Average Monthly	existing
Total Phosphorus (April 1 – Oct 31)	1.5	Average Monthly	Previous calculation/existing*
Total Phosphorus (Nov 1 – Mar 31)	2.0	Average Monthly	
Total Nitrogen	Report	Average Monthly	Data Collection/SOP
Nitrate-Nitrite as N (July 1 – Oct 31)	8.0	Average Monthly	Neshaminy Creek Basin requirement**
Nitrate-Nitrite as N (Nov 1 – Jun 30)	Report	Average Monthly	

All limits are existing except TDS.

* Phosphorus limit was developed based on the existing loading at the 2009 permit renewal.

** Neshaminy Creek has a policy to limit ammonia + nitrate + nitrite concentration to a maximum of 11 mg/l to protect an existing public water supply use. Therefore, the permit includes numerical limits for nitrite/nitrate of 8.0 mg/l during a four-month seasonal period.

*** The discharge from this facility was modeled in 1994 using WQM 6.3. Since there have been no substantial changes the effluent limits are still valid.

Anti-Backsliding

N/A

Proposed Effluent Limitations and Monitoring Requirements

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max.	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.06	XXX	0.19	1/day	Grab
CBOD5 Nov 1 - Apr 30	13	XXX	XXX	15	XXX	30	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	8.3	XXX	XXX	10	XXX	20	1/week	8-Hr Composite
TSS	25	XXX	XXX	30	XXX	60	1/week	8-Hr Composite
Total Dissolved Solids	1251	XXX	XXX	1,500	XXX	XXX	1/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	200 Geo Mean	1000 90%SAMPLES	XXX	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Nitrate-Nitrite Nov 1 - Jun 30	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Nitrate-Nitrite Jul 1 - Oct 31	6.7	XXX	XXX	8.0	XXX	16	1/week	8-Hr Composite
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Ammonia Nov 1 - Apr 30	5.8	XXX	XXX	7.0	XXX	14	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	2.5	XXX	XXX	3.0	XXX	6	1/week	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Phosphorus Nov 1 - Mar 31	1.7	XXX	XXX	2.0	XXX	4	1/week	8-Hr Composite
Total Phosphorus Apr 1 - Oct 31	1.1	XXX	XXX	1.5	XXX	3	1/week	8-Hr Composite