

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0054526
APS ID 1093477
Authorization ID 1448488

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|---|
| Applicant Name | <u>UniTech Services Group, Inc.</u> | Facility Name | <u>UniTech Service Group</u> |
| Applicant Address | <u>401 North 3rd Avenue</u> <u>Royersford, PA 19468-1950</u> | Facility Address | <u>401 N 3rd Avenue</u> <u>Royersford, PA 19468-1950</u> |
| Applicant Contact | <u>Glenn Roberts</u> | Facility Contact | <u>Glenn Roberts</u> |
| Applicant Phone | <u>(410) 382-7350</u> | Facility Phone | <u>(410) 382-7350</u> |
| Client ID | <u>33398</u> | Site ID | <u>452791</u> |
| SIC Code | <u>7218</u> | Municipality | <u>Royersford Borough</u> |
| SIC Description | <u>Services - Industrial Launderers</u> | County | <u>Montgomery</u> |
| Date Application Received | <u>June 16, 2023</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>September 14, 2023</u> | If No, Reason | <u></u> |
| Purpose of Application | <u>NPDES permit renewal.</u> | | |


Summary of Review

The Pa DEP received an NPDES permit renewal application from Keystone Engineering Group (consultant) on June 16, 2023 on behalf of UniTech Services Group, Inc. (permittee) for permittee's Royersford Facility (facility). It's a minor industrial waste facility without ELG that discharges into Schuylkill River (WWF, MF) in state watershed 3-D. The current permit will expire on December 31, 2023. The terms and conditions of the current permit is automatically extended since the renewal application is received at least 180 days prior to expiration date. Renewal NPDES permit application under Clean Water Program are not covered by PADEP's PDG per 021-2100-001. This fact sheet is developed in accordance with 40 CFR §124.56.

Changes in this permit: Color limits removed, and Total Copper limits will be applied.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date |
|---------|------|--|------------------|
| √ | | Reza H. Chowdhury, E.I.T. / Project Manager  | October 23, 2023 |
| X | | Pravin Patel Pravin C. Patel, P.E. / Environmental Engineer Manager | 10/24/2023 |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|-----------------------------------|-------------------|------------------------|
| Outfall No. | <u>002</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 11' 22.00"</u> | Longitude | <u>-75° 32' 47.00"</u> |
| Quad Name | <u>Phoenixville</u> | Quad Code | <u>1741</u> |
| Wastewater Description: <u>Stormwater</u> | | | |
| Receiving Waters | <u>Schuylkill River (WWF, MF)</u> | Stream Code | <u>00833</u> |
| NHD Com ID | <u>133228812</u> | RMI | <u>43.12</u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|--|------------------------------|----------------------------------|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>.1</u> |
| Latitude | <u>40° 11' 22.00"</u> | Longitude | <u>-75° 32' 47.00"</u> |
| Quad Name | <u>Phoenixville</u> | Quad Code | <u>1741</u> |
| Wastewater Description: <u>IW Process Effluent without ELG</u> | | | |
| Receiving Waters | <u>Schuylkill River</u> | Stream Code | <u>00833</u> |
| NHD Com ID | <u>133228812</u> | RMI | <u>43.22</u> |
| Drainage Area | <u>1,190 mi²</u> | Yield (cfs/mi ²) | <u>0.23</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>275</u> | Q ₇₋₁₀ Basis | <u>USGS StreamStats</u> |
| Elevation (ft) | <u>93.01</u> | Slope (ft/ft) | <u></u> |
| Watershed No. | <u>3-D</u> | Chapter 93 Class. | <u></u> |
| Existing Use | <u>WWF, MF</u> | Existing Use Qualifier | <u>Ch. 93</u> |
| Exceptions to Use | <u></u> | Exceptions to Criteria | <u></u> |
| Assessment Status | <u>Impaired</u> | | |
| Cause(s) of Impairment | <u>POLYCHLORINATED BIPHENYLS (PCBS)</u> | | |
| Source(s) of Impairment | <u>SOURCE UNKNOWN</u> | | |
| TMDL Status | <u>Final</u> | Name | <u>Schuylkill River PCB TMDL</u> |
| Background/Ambient Data | | Data Source | |
| pH (SU) | <u>7.0</u> | Default | <u></u> |
| Temperature (°C) | <u>25</u> | Default | <u></u> |
| Hardness (mg/L) | <u>100</u> | Default | <u></u> |
| Other: | <u></u> | | <u></u> |
| Nearest Downstream Public Water Supply Intake | <u>Phoenixville Water Department, Phoenixville Boro, ChestCo</u> | | |
| PWS Waters | <u>Schuylkill River</u> | Flow at Intake (cfs) | <u></u> |
| PWS RMI | <u>40.36 mile</u> | Distance from Outfall (mi) | <u>2.86</u> |

Changes Since Last Permit Issuance: Membrane Ultrafiltration (UF) Unit was added with existing treatment system to increase the cBOD5 removal efficiency. A pilot testing is ongoing to determine the efficiency of UF unit.

Streamflow:

USGS's web based watershed delineation tool StreamStats (accessible at <https://streamstats.usgs.gov/ss/>, accessed on October 12, 2023) was utilized to determine the drainage area at discharge point. The StreamStats report shows the drainage area at the discharge point is 1,190 mi². Data from the StreamStats shows Q₇₋₁₀ and Q₃₀₋₁₀ to be 275 cfs and 326 cfs, respectively.

Q₇₋₁₀ runoff rate (low flow yield): 275 cfs/1190 mi² or 0.23 cfs/mi²
 Q₃₀₋₁₀:Q₇₋₁₀: 326/275 or 1.19
 Default Q₁₋₁₀:Q₇₋₁₀: 0.64
 Q₁₋₁₀: 0.64*275 or 176 cfs

PWS Intake:

The nearest downstream public water supply is Phoenixville Water Department’s intake on Schuylkill River at RMI 40.36, in Phoenixville Borough, Chester County. Its approximately 2.86 miles downstream of Outfall 001. The permit will be crafted in a way that the discharge from this facility may not impact the PWS intake.

Wastewater Characteristics:

The 90th percentile pH of 7.1 was calculated from daily DMR during dry months July through September for the year 2022-2023. The application data indicated the maximum Total Hardness of 74.3 mg/l out of 3 samples and average temperature of 74°F (23.63°C).

Background data:

There’s no nearby (within 10 miles) WQN station to collect site-specific stream data. In absence of site-specific data, default temperature of 25°C, stream hardness of 105 mg/l, and stream pH of 7.0 will be used for modeling, if needed.

Impairment Status of receiving stream (CWA Section 303(d)):

The receiving stream, Schuylkill River, is Fish Consumption impaired from PCBs. It is also Aquatic Life impaired from Urban Runoff/Storm sewers (cause unknown), Municipal Point Source Discharges (cause unknown), and Agriculture (cause unknown). A TMDL is finalized for Schuylkill River which is discussed in below section. The limits and permit terms and conditions will be developed in a way that the facility doesn’t contribute to the existing impairment.

Schuylkill River Polychlorinated Biphenyls (PCBs) Total Maximum Daily Load (TMDL):

The receiving stream, Schuylkill River, is impaired for PCBs and has an EPA approved TMDL. This facility is listed in Segment E Subsegment 21 of the TMDL. Table B-1 assigned a Wasteload Allocation (WLA) of 1.33e⁻⁵ gram/day of PCB for this facility. The surface water quality criteria for PCBs in Schuylkill River is 0.044 ng/l or 44 pg/l, which is also EPA’s TMDL target. The facility collected two PCB samples in the past and submitted the results to PADEP and Delaware River Basin Commission (DRBC). The sample results were higher than the surface water quality criteria which triggered annual dry weather PCBs monitoring requirement for Outfall 001 and annual wet weather PCBs monitoring for Outfall 002. The facility was collecting annual samples from both outfalls. These sample results will be analyzed and either continued monitoring will be carried over or numeric limits will be placed in the permit. It’ll be addressed in more details on Development of Effluent Limits section of this report.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The receiving stream is designated as Warm-Water Fishes (WWF) and Migratory Fishes (MF.) No High-Quality watershed is impacted by this discharge. No Exceptional-value watershed is impacted by this discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

| Treatment Facility Summary | | | | |
|---|----------------------------|---------------------|---------------------|------------------------------|
| Treatment Facility Name: Unitech Services Group | | | | |
| WQM Permit No. | Issuance Date | | | |
| 4615201 A-3 | 2/16/23 | | | |
| 4615201 A-2 | 8/27/21 | | | |
| 4615201 A-1 | 12/6/18 | | | |
| 4615201 | 8/3/15 | | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |

| | | | | |
|---------------------------------|--|--------------------|----------------------------|-------------------------------|
| Industrial | Biological (Industrial Waste), Physical (Industrial Waste) | Filtration | Ultraviolet | 0.08 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.12 | | Not Overloaded | Drying | Landfill |

Treatment Plant Description

UniTech Services Group, Inc. (UniTech/permittee) owns and operates a licensed nuclear laundry facility in Royersford, PA. The facility launders and decontaminates clothing and personal protective equipment received from customers. Equipment employed by UniTech includes washer extractors, dryers, sorting tables, lint collectors, and a liquid wastewater treatment system.

Process wastewater gravity flows to an influent wet well and has a continuous recirculation system to provide adequate mixing within the wet well. Level actuated sump pumps transfer the process wastewater from the wet well to a 50-micron mesh vibrating shaker screen where coarse particles, primarily composed of lint, are separated. The shaker screen filtrate is then pumped to equalization tanks where further mixing and pH adjustment are provided. Next, the process wastewater is transferred to a fixed film bioreactor system which consists of three reactors operating in series. Draft tubes provide air to the biomass within the reactors. Aerobic bacteria attach to the fixed film and provide a high rate of biological treatment of organics. Chemical feed pumps deliver urea and carbon source solutions to maintain required nutrients level to sustain a healthy biomass. Scour aeration is used to prevent the biomass from clogging the fixed film media. Chemical feed equipment provides coagulant and flocculant, as needed, to aid settling of the discharge from the fixed film bioreactors. The process wastewater then gravity flows into two final clarifiers, which are operated in parallel. The final clarifiers remove biological solids. A RAS pump returns biomass to the first bioreactor on an as needed basis.

Clarified water then passes through a buffer tank where it is processed through a variable-flow pressurized filter system. This flow from the aerated bioreactors is diverted to the new UF system for solids removal purposes. After filtration the wastewater is then disinfected via an UV system and pumped to two final holdup tanks. Mixers within the holdup tanks keep the contents well mixed. Prior to final discharge to the stream outfall, a representative sample from both holdup tanks is collected.

Solids treatment consists of a sludge holding tank and an aerobic digester with settling capability. A decant pump inside the aerobic digester removes supernatant fluid prior to solids processing. Solids are processed using a plate-and-frame press for dewatering. After pressing, the filter cake is dropped into an electric drying oven for further reduction of moisture. The dry waste is then packaged, labeled, and then transported by a qualified low-level radiation waste (LLRW) processor who properly disposes of the waste solids.

The following chemicals are used for treatment of wastewater:

4. Identify all chemicals that have been used for wastewater treatment over the past two years.

| Chemical Name | Purpose | Max Usage Rate | Units | Acrylamide? |
|-----------------------|----------------------|----------------|---------|--------------------------|
| Muriatic Acid | pH Neutralizer | 10 | lbs/day | <input type="checkbox"/> |
| Aluminum Sulfate | Coagulant/Flocculant | 25 | lbs/day | <input type="checkbox"/> |
| Polyaluminum Chloride | Coagulant/Flocculant | 8 | lbs/day | <input type="checkbox"/> |

Stormwater Outfall:

There are two stormwater-only outfalls, Outfall 002 and 003, associated with this facility. Outfall 002 is representative of Outfall 003. Outfall 002 has monitoring requirements in current permit which will be carried over in this renewal.

Compliance History

DMR Data for Outfall 001 (from August 1, 2022 to July 31, 2023)

| Parameter | JUL-23 | JUN-23 | MAY-23 | APR-23 | MAR-23 | FEB-23 | JAN-23 | DEC-22 | NOV-22 | OCT-22 | SEP-22 | AUG-22 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.01 | 0.03 | 0.04 | 0.04 | 0.05 | 0.04 | 0.03 | 0.03 | 0.04 | 0.05 | 0.04 | 0.03 |
| Flow (MGD) Daily Maximum | 0.04 | 0.06 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.07 | 0.09 | 0.08 | 0.07 | 0.06 |
| pH (S.U.) Instantaneous Minimum | 6.15 | 6.17 | 6.44 | 6.45 | 6.55 | 6.3 | 6.15 | 6.1 | 6.34 | 6.52 | 6.58 | 6.7 |
| pH (S.U.) IMAX | 7.81 | 7.08 | 7.01 | 7.03 | 7.99 | 6.96 | 6.87 | 7.37 | 7.01 | 8.4 | 8.5 | 7.7 |
| Color (Pt-Co Units) Average Monthly | 15 | 15 | 15 | 15 | 25.0 | 17.5 | 13.75 | 10 | 12.5 | 10 | 10 | 12.5 |
| Color (Pt-Co Units) Daily Maximum | 15 | 15 | 15 | 15 | 35.0 | 25.0 | 15.0 | 10 | 15.0 | 10 | 10 | 15.0 |
| CBOD5 (lbs/day) Average Monthly | 0.87 | < 1 | 0.41 | 1.49 | 0.82 | 2.85 | 1.92 | 1.69 | 1.03 | 2.87 | 3.14 | 1.83 |
| CBOD5 (lbs/day) Industrial Influent Average Monthly | 6.23 | 7.07 | 13.1 | 14.7 | 19.3 | 12.7 | 12.9 | 13.8 | 17.1 | 21.5 | 12.2 | 9.4 |
| CBOD5 (lbs/day) Daily Maximum | 1.74 | < 1 | 0.82 | 1.79 | 0.87 | 6.93 | 3.02 | 2.57 | 1.64 | 8.5 | 7.71 | 3.18 |
| CBOD5 (lbs/day) Industrial Influent Daily Maximum | 6.92 | 7.1 | 15.7 | 17.0 | 24.2 | 15.4 | 21.1 | 25.7 | 25.2 | 29.4 | 15.5 | 18.5 |
| CBOD5 (mg/L) Average Monthly | 3.06 | < 1.0 | 0.82 | 2.81 | 1.72 | 5.85 | 4.25 | 4.06 | 1.97 | 5.31 | 7.98 | 5.77 |
| CBOD5 (mg/L) Industrial Influent Average Monthly | 21.95 | 18.35 | 22.85 | 27.8 | 38.45 | 26.2 | 31.4 | 32.9 | 33.7 | 39.6 | 29.6 | 29.6 |
| CBOD5 (mg/L) Daily Maximum | 6.12 | < 1.0 | 1.64 | 3.2 | 2.07 | 14.0 | 6.28 | 6.04 | 3.38 | 14.9 | 17.9 | 7.7 |
| CBOD5 (mg/L) Industrial Influent Daily Maximum | 24.4 | 20.1 | 24.6 | 30.4 | 42.9 | 28.3 | 37.2 | 49.8 | 44.2 | 58.8 | 37.2 | 43.9 |
| CBOD5 % Removal (%) Minimum Monthly Average | 85 | 85 | 85 | 85 | 85 | 85 | 85 | 85 | 85 | 85 | 85 | 85 |
| TSS (lbs/day) Average Monthly | 1.85 | 2.05 | 0.89 | 1.02 | 0.78 | 11.3 | 4.09 | 2.84 | 0.82 | 1.14 | 0.76 | 0.18 |

**NPDES Permit Fact Sheet
UniTech Services Group**

NPDES Permit No. PA0054526

| | | | | | | | | | | | | |
|--|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| TSS (lbs/day) Daily Maximum | 3.41 | 3.39 | 1.27 | 1.48 | 1.13 | 39.5 | 8.89 | 4.27 | 1.15 | 1.72 | 1.08 | 0.22 |
| TSS (mg/L) Average Monthly | 6.5 | 5.0 | 1.5 | 2.0 | 1.5 | 24.1 | 8.75 | 8.0 | 1.5 | 2.0 | 2.0 | 1.0 |
| TSS (mg/L) Daily Maximum | 12.0 | 8.0 | 2.0 | 3.0 | 2.0 | 80.0 | 14.0 | 12.0 | 2.0 | 3.0 | 3.0 | 1.0 |
| Total Dissolved Solids (lbs/day) Average Monthly | 217.1 | 150 | 206 | 177.6 | 171 | 165.8 | 149.1 | 76.2 | 195.4 | 175 | 117.4 | 90.9 |
| Total Dissolved Solids (lbs/day) Daily Maximum | 283.3 | 156 | 236 | 183.5 | 175 | 179.0 | 228.6 | 85.5 | 224.5 | 207 | 181.5 | 122.6 |
| Total Dissolved Solids (mg/L) Average Monthly | 764.5 | 389.0 | 362.0 | 337.5 | 355.0 | 313.8 | 414.0 | 215.0 | 362.5 | 307.0 | 285.0 | 490.5 |
| Total Dissolved Solids (mg/L) Daily Maximum | 997.0 | 410.0 | 370.0 | 347.0 | 416.0 | 354.0 | 556.0 | 242.0 | 392.0 | 362.0 | 422.0 | 568.0 |
| Oil and Grease (lbs/day) Average Monthly | < 5.0 | < 5.0 | < 5.0 | 2.64 | < 5.0 | 2.65 | 2.02 | 1.77 | 2.7 | < 5.0 | 1.97 | 0.89 |
| Oil and Grease (mg/L) Average Monthly | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 | < 5.0 |
| Ammonia (lbs/day) Average Monthly | 1.86 | 0.77 | 0.78 | 0.47 | 0.29 | 0.09 | 0.17 | 0.04 | 0.04 | 0.1 | 0.19 | 0.39 |
| Ammonia (mg/L) Average Monthly | 6.56 | 1.91 | 1.28 | 0.9 | 0.56 | 0.16 | 0.56 | 0.115 | 0.08 | 0.18 | 0.47 | 1.89 |
| Total Phosphorus (lbs/day) Average Monthly | 0.24 | 0.5 | 0.65 | 0.39 | 0.33 | 0.35 | 0.29 | 0.156 | 0.11 | 0.29 | 0.44 | 0.16 |
| Total Phosphorus (mg/L) Average Monthly | 0.83 | 1.38 | 1.08 | 0.75 | 0.7 | 0.67 | 0.69 | 0.44 | 0.19 | 0.3 | 1.14 | 0.825 |
| Total Copper (lbs/day) Average Quarterly | | 0.278 | | | 0.29 | | | 0.3 | | | 0.099 | |
| Total Copper (lbs/day) Daily Maximum | | 0.278 | | | 0.29 | | | 0.3 | | | 0.099 | |
| Total Copper (mg/L) Average Quarterly | | 0.559 | | | 0.59 | | | 0.596 | | | 0.691 | |
| Total Copper (mg/L) Daily Maximum | | 0.559 | | | 0.59 | | | 0.596 | | | 0.691 | |
| PCBs (Dry Weather) (pg/L) Daily Maximum | | | | | | | | 890 | | | | |

| | | | | | | | | | | | | |
|---|--|----|--|--|----|--|--|------|--|--|----|--|
| Acute WET - Ceriodaphnia Survival (TUa) Daily Maximum | | GG | | | GG | | | 50.0 | | | GG | |
| Acute WET - Pimephales Survival (TUa) Daily Maximum | | GG | | | GG | | | 50.0 | | | GG | |

Compliance History

Effluent Violations for Outfall 001, from: September 1, 2022 To: July 31, 2023

| Parameter | Date | SBC | DMR Value | Units | Limit Value | Units |
|-----------|----------|-----------|-----------|---------|-------------|----------|
| TSS | 02/28/23 | Daily Max | 39.5 | lbs/day | 24.8 | Lbs./day |
| TSS | 02/28/23 | Daily Max | 80.0 | mg/L | 45 | mg/L |

Summary of Inspections:

12/3/2021: CEI conducted. No violation noted. The facility showed continued compliance with the permit.

Other Comments: None.

Existing Limits

For Outfall 001:

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--|-------------------------------------|---------------|-----------------------|-----------------|---------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Recorded |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| Color (Pt-Co Units) | XXX | XXX | XXX | 100 | 200 | 250 | 2/month | 24-Hr Composite |
| Carbonaceous Biochemical Oxygen Demand (CBOD5) | Report | Report | XXX | Report | Report | XXX | 2/month | 24-Hr Composite |
| Carbonaceous Biochemical Oxygen Demand (CBOD5) Industrial Influent | Report | Report | XXX | Report | Report | XXX | 2/month | 24-Hr Composite |

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------|-----------------------|---------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| CBOD5 Minimum % Removal (%) | 85 Min Mo Avg | XXX | XXX | XXX | XXX | XXX | 2/month | Calculation |
| Total Suspended Solids | 13.8 | 24.8 | XXX | 25 | 45 | 50 | 2/month | 24-Hr Composite |
| Total Dissolved Solids | 834 | 1668 | XXX | 1000.0 | 2000.0 | 2500 | 2/month | 24-Hr Composite |
| Oil and Grease | 12.5 | XXX | XXX | 15.0 | XXX | 30 | 2/month | Grab |
| Ammonia-Nitrogen | 8.3 | XXX | XXX | 10.0 | XXX | 20 | 2/month | 24-Hr Composite |
| Total Phosphorus | 1.7 | XXX | XXX | 2.0 | XXX | 4 | 2/month | 24-Hr Composite |
| Copper, Total | Report Avg Qrtly | Report | XXX | Report Avg Qrtly | Report | XXX | 1/quarter | 24-Hr Composite |
| PCBs Dry Weather Analysis (pg/L) | XXX | XXX | XXX | XXX | Report | XXX | 1/year | 24-Hr Composite |
| Toxicity, Acute - Ceriodaphnia Survival (TUa) | XXX | XXX | XXX | XXX | Report | XXX | * | 24-Hr Composite |
| Toxicity, Acute - Pimephales Survival (TUa) | XXX | XXX | XXX | XXX | Report | XXX | * | 24-Hr Composite |

For Outfall 002:

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------------------------|-------------------------------------|-------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Chemical Oxygen Demand (COD) | XXX | XXX | XXX | XXX | Report | XXX | 1/6 months | Grab |
| Total Suspended Solids | XXX | XXX | XXX | XXX | Report | XXX | 1/6 months | Grab |
| Oil and Grease | XXX | XXX | XXX | XXX | Report | XXX | 1/6 months | Grab |
| PCBs Wet Weather Analysis (pg/L) | XXX | XXX | XXX | XXX | Report | XXX | 1/year | Grab |

Development of Effluent Limitations

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Parameter | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|---------------------|----------------------|-----------------|-----------------------|------------------|
| CBOD ₅ * | 85% reduction (Min.) | Average Monthly | 40 CFR 133.102 (a)(4) | |
| Oil and Grease | 15 | Average Monthly | | Chapter 95.2 |
| pH | 6.0 to 9.0 STD | Min-Max | 40 CFR 133.102 (c) | Chapter 95.2 |
| TSS | 30 | Average Monthly | 40 CFR 133.102 (b) | |

*The 85% CBOD₅ reduction is a requirement of the existing permit and carried over to the renewal. This is a DRBC basin wide percentage reduction requirement. The special condition to deviate the percentage reduction requirement when influent CBOD₅ is less than 100 mg/l in the existing permit is also carried over to the new permit.

Mass-Based Limits

The federal regulation at 40 CFR 122.45(f) requires that effluent limits be expressed in terms of mass, if possible. The regulation at 40 CFR 122.45(b) requires that effluent limitations for POTWs be calculated based on the design flow of the facility. The mass-based limits are expressed in pounds per day and are calculated as follows:

$$\text{Mass based limit (lb./day)} = \text{concentration limit (mg/L)} \times \text{design flow (MGD)} \times 8.34$$

Model input data

The following data will be used for modeling, as needed:

- Discharge pH 7.1 (90th percentile, July-Sep 2022-23, daily eDMR data)
- Discharge Temperature 23.63°C (Application data)
- Discharge Hardness 74.3 mg/l (Application data)
- Stream pH 7.0 (Default)
- Stream Temperature 25°C (Default)
- Stream Hardness 105 mg/l (Application data)

The following three nodes were used in modeling:

Node 1: At the outfall 001 on Schuylkill River (00833)
 Elevation: 93.01 ft (National Map-Advanced Viewer, 10/12/2023)
 Drainage Area: 1,190 mi² (StreamStats Version 3.0, 10/12/2023)
 River Mile Index: 43.12 (PA DEP eMapPA)
 Low Flow Yield: 0.23 cfs/mi²
 Q₇₋₁₀: 275 cfs
 Discharge Flow: 0.1 MGD

Node 2: At confluence with Mingo Creek (01609)
 Elevation: 87.83 ft (National Map-Advanced Viewer, 10/12/2023)
 Drainage Area: 1,200 mi² (StreamStats Version 3.0, 10/12/2023)
 River Mile Index: 41.3 (PA DEP eMapPA)
 Low Flow Yield: 0.23 cfs/mi²
 Discharge Flow: 0.0 MGD

WQM 7.0 Model

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate effluent limits for CBOD₅, NH₃-N and DO. The model simulates two basic processes. In the NH₃-N module, the model simulates the mixing and degradation of NH₃-N in the stream and compares calculated instream NH₃-N concentrations to NH₃-N water quality criteria. In the D.O. module, the model simulates the mixing and consumption of D.O. in the stream due to the degradation of CBOD₅ and NH₃N and compares calculated instream D.O. concentrations to D.O. water quality criteria. The model was utilized for this permit renewal by using Q₇₋₁₀ and current background water quality levels of the stream.

NH₃-N

WQM 7.0 suggested existing limits are still protective. Current limits will be carried over.

CBOD5

WQM 7.0 suggests 25 mg/l (which is model input value) as average monthly limit to protect the water quality. Per SOP, if 25 mg/l limit is suggested by the model, a year-round monitoring will be sufficient. Current permit has monitoring requirements which will be carried over.

General Discussion on Toxics Management Spreadsheet (TMS)

Based on the available data, PADEP utilizes Toxics Management Spreadsheet (TMS) to (1) evaluate reasonable potential for toxic pollutants to cause or contribute to an excursion above the water quality standards and (2) develop WQBELs for those such toxic pollutants (i.e., 40 CFR § 122.44(d)(1)(i)). It is noteworthy that some of these pollutants that may be reported as “non-detect”, but still exceeded the criteria, were determined to be candidates for modeling because the method detection levels used to analyze those pollutants were higher than target QLs and/or the most stringent Chapter 93 criteria. The model then recommended the appropriate action for the Pollutants of Concerns based on the following logic as stated in PADEP’s SOP titled “Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants in NPDES Permits for Existing Dischargers (DEP SOP No.: BCW-PMT-037, Revised May 20, 2021)”:

1. In general, establish limits in the draft permit where the effluent concentration determined in B.1 or B.2 equals or exceeds 50% of the WQBEL (i.e., RP is demonstrated). Use the average monthly, maximum daily and instantaneous maximum (IMAX) limits for the permit as recommended by the TMS (or, if appropriate, use a multiplier of 2 times the average monthly limit for the maximum daily limit and 2.5 times the average monthly limit for IMAX).

2. For non-conservative pollutants, in general, establish monitoring requirements where the effluent concentration determined in B.1 or B.2 is between 25% - 50% of the WQBEL.

3. For conservative pollutants, in general, establish monitoring requirements where the effluent concentration determined in B.1 or B.2 is between 10% - 50% of the WQBEL.

NOTE – If the effluent concentration determined in B.1 or B.2 is “non-detect” at or below the target quantitation limit (TQL) for the pollutant as specified in the TMS and permit application, the pollutant may be eliminated as a candidate for WQBELs or monitoring requirements unless 1) a more sensitive analytical method is available for the pollutant under 40 CFR Part 136 where the quantitation limit for the method is less than the applicable water quality criterion and 2) a detection at the more sensitive method may lead to a determination that an effluent limitation is necessary, considering available dilution at design conditions.

NOTE – If the effluent concentration determined in B.1 or B.2 is a detection below the TQL but above or equal to the applicable water quality criterion, WQBELs or monitoring may be established for the pollutant.

4. Application managers may, on a site- and pollutant-specific basis, deviate from these guidelines where there is specific rationale that is documented in the fact sheet.

The statistical methodologies used in this spreadsheet are taken from EPA’s TSD for Water Quality-based Toxics Control, Appendix E and are consistent with PADEP’s technical guidance 391-2000-024. The pollutants are modeled through TMS and output from the TMS is provided below:

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: **4**

| Pollutants | Mass Limits | | Concentration Limits | | | Units | Governing WQBEL | WQBEL Basis | Comments |
|--------------|---------------|---------------|----------------------|------|------|-------|-----------------|-------------|---------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | | | | |
| Total Copper | 0.77 | 1.1 | 0.92 | 1.32 | 2.31 | mg/L | 0.92 | AFC | Discharge Conc ≥ 50% WQBEL (RP) |

Total Copper:

A Reasonable Potential (RP) was demonstrated for Total Copper. The model input value was 1.04 mg/l as AMEC and 0.365 as daily CoV based on quarterly data collected between January 2019 to June 2023. The model suggested 0.92 mg/l as Average Monthly Limit (AML), 1.32 mg/l Maximum Daily Limit (MDL) and 2.31 mg/l as Instantaneous Maximum (IMAX). The current permit has quarterly monitoring requirements. A review of the eDMR data from 2019 to June 2023

indicated that the facility will be meeting the limit approximately 90% of the time. A schedule may not be needed to meet the final WQBEL. The minimum monitoring frequency will be changed to 1/month to be consistent with other IW facilities with similar flows.

Total Dissolved Solids (TDS):

Historically PADEP utilized the following logics to determine limits/monitoring requirements for these special monitoring parameters:

- Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs./day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.
- Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.

PADEP has determined that they have sufficient data over the past 7 years of implementing the special monitoring logic for these parameters and it is no longer needed. DRBC's basin-wide criteria of 1,000 mg/l is the current limit and will be continued in this NPDES permit for consistency purpose.

Color:

The current permit has 100 pt-co unit average monthly limit in the permit. The color was modeled through the TMS with a model input value of 18.7 unit as AMEC and 0.351 as daily CoV from a dataset collected between February 2019 and September 2023. The model doesn't recommend limits or monitoring requirement since the discharge concentration is less than 10% of WQBEL (governing WQBEL is 58,294). Color is a concern if there is nearby PWS intake and the discharge is believed to affect the intake in terms of color. The nearby PWS intake is approximately 3 miles downstream and discharge is into much larger Schuylkill River with lots of dilution (as reflected in WQBEL). The facility indicated that they don't do any re-dyeing of clothes at this facility. If any cloth needs re-dyeing, they ship it to other states. Therefore, it is believed that the color discharge from this facility is not a concern for the aesthetic of the receiving stream or HHC at PWS intake. The current limits will be removed. This is backsliding but is justified by anti-backsliding prohibition exception as stated in CWA § 402(O)(2)(B)(i).

pH:

The TBEL for pH is above 6.0 and below 9.0 S.U. (40 CFR §133.102(c) and Pa Code 25 §§ 95.2(1), 92a.47) which are existing limits and will be carried over.

Total Suspended Solids (TSS):

Current concentration-based AML, MDL, and IMAX limit of 25 mg/l, 45 mg/l, and 50 mg/l are based on radiological sediment concern in the receiving stream. The mass-based limits were calculated from long-term average discharge of 0.066 MGD. A review of flow data from January 2022 through September 2023 indicated 90th percentile flow of 0.068 MGD which is very close to the flow that was used few permits cycle back and still applicable. Therefore, current limits will be carried over.

Oil & Grease:

Pa Code 25 §§ 95.2(2) and 92a.41(c) has average monthly and daily max limit for Oil & Grease, or otherwise regulates their discharge in the receiving stream, which are the current limits and will be carried over.

Total Phosphorus:

The concern of Total Phosphorus is from the use of detergents in the laundering process. The current limits are based on Pa Code 25 § 96.5(c) which are still applicable and will be carried over.

Monitoring Frequency and Sample Types:

Otherwise specified above, the monitoring frequency and sample type of compliance monitoring for existing parameters are recommended by DEP's SOP and Permit Writers Manual and/or on a case-by-case basis using best professional judgment (BPJ).

Flow, Influent cBOD₅ and 85% cBOD₅ reduction Requirement:

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii). DRBC's basin-wide 85% cBOD₅ reduction criteria was applied in previous permits. To comply with 85% cBOD₅ reduction, influent

cBOD5 was also added in previous permits. Current limits will be carried over. The special condition to deviate from the percentage reduction requirement when influent cBOD5 is less than 100 mg/l in the existing permit is also carried over in this renewal.

Schuylkill River PCB:

A review of the PCB data submitted from 2019 through 2022 indicated an average dry weather (outfall 001) PCB concentration of 10,014 pg/l and wet weather (outfall 002) PCB concentration of 833.3 pg/l. The maximum concentration of 18,100 pg/l was modeled through the TMS and no RP was demonstrated. However, since the discharge concentration is higher than Schuylkill River Water Quality Criteria for PCB of 44 pg/l, current monitoring will be continued.

Anti-Backsliding

Anti-backsliding prohibition is justified in sections where an exception is justified for the affected pollutant(s). For remaining pollutants, this prohibition isn't applicable since the proposed limits are at least as stringent as were in current permit.

Whole Effluent Toxicity (WET)

For Outfall 001, **Acute** **Chronic** WET Testing was completed:

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other: **Annual**

The dilution series used for the tests was: 100%, 60%, 30%, 2%, and 1%. The Target Instream Waste Concentration (TIWC) to be used for analysis of the results is: 2%.

Summary of Four Most Recent Test Results

TST Data Analysis

(NOTE – In lieu of recording information below, the application manager may attach the DEP WET Analysis Spreadsheet).

| Test Date | Ceriodaphnia Results (Pass/Fail) | | Pimephales Results (Pass/Fail) | |
|-----------|----------------------------------|--------------|--------------------------------|--------|
| | Survival | Reproduction | Survival | Growth |
| 5/18/19 | Pass | | Pass | |
| 9/13/20 | Pass | | Pass | |
| 7/31/21 | Pass | | Pass | |
| 9/28/22 | Pass | | Pass | |

* A “passing” result is that in which the replicate data for the TIWC is not statistically significant from the control condition. This is exhibited when the calculated t value (“T-Test Result”) is greater than the critical t value. A “failing” result is exhibited when the calculated t value (“T-Test Result”) is less than the critical t value.

Is there reasonable potential for an excursion above water quality standards based on the results of these tests? (NOTE – In general, reasonable potential is determined anytime there is at least one test failure in the previous four tests).

- YES NO

Comments:

Evaluation of Test Type, IWC and Dilution Series for Renewed Permit

Acute Partial Mix Factor (PMFa): **0.063**

Chronic Partial Mix Factor (PMFc): **0.439**

1. Determine IWC – Acute (IWCa):

$$(Q_d \times 1.547) / ((Q_{7-10} \times PMFa) + (Q_d \times 1.547))$$

$$[(0.1 \text{ MGD} \times 1.547) / ((275 \text{ cfs} \times 0.063) + (0.1 \text{ MGD} \times 1.547))] \times 100 = \mathbf{0.89\%}$$

Is IWCa < 1%? YES NO **(YES - Acute Tests Required OR NO - Chronic Tests Required)**

If the discharge is to the tidal portion of the Delaware River, indicate how the type of test was determined:

Type of Test for Permit Renewal: Acute

2a. Determine Target IWCa (If Acute Tests Required)

$$TIWCa = 0.89 / 0.3 = 2.98\%$$

2b. Determine Target IWCa (If Chronic Tests Required)

$$(Q_d \times 1.547) / (Q_{7-10} \times PMF_c) + (Q_d \times 1.547)$$

$$[(\text{Design Flow MGD} \times 1.547) / ((Q_{7-10} \text{ cfs} \times PMF_c) + (\text{Design Flow MGD} \times 1.547))] \times 100 = \text{TIWCc}\%$$

3. Determine Dilution Series

(NOTE – check Attachment C of WET SOP for dilution series based on TIWCa or TIWCc, whichever applies).

Dilution Series = 100%, 60%, 30%, 3%, and 1%.

WET Limits

Has reasonable potential been determined? YES NO

Will WET limits be established in the permit? YES NO

If WET limits will be established, identify the species and the limit values for the permit (TU).

If WET limits will not be established, but reasonable potential was determined, indicate the rationale for not establishing WET limits:

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|---------------|-----------------------|---------------------|---------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Recorded |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| CBOD5 Industrial Influent | Report | Report | XXX | Report | Report | XXX | 2/month | 24-Hr Composite |
| CBOD5 | Report | Report | XXX | Report | Report | XXX | 2/month | 24-Hr Composite |
| CBOD5 % Removal (%) | 85 Min Mo Avg | XXX | XXX | XXX | XXX | XXX | 2/month | Calculation |
| TSS | 13.8 | 24.8 | XXX | 25 | 45 | 50 | 2/month | 24-Hr Composite |
| Total Dissolved Solids | 834 | 1668 | XXX | 1000.0 | 2000.0 | 2500 | 2/month | 24-Hr Composite |
| Oil and Grease | 12.5 | XXX | XXX | 15.0 | XXX | 30 | 2/month | Grab |
| Ammonia | 8.3 | XXX | XXX | 10.0 | XXX | 20 | 2/month | 24-Hr Composite |
| Total Phosphorus | 1.7 | XXX | XXX | 2.0 | XXX | 4 | 2/month | 24-Hr Composite |
| Total Copper | 0.77 | 1.1 | XXX | 0.92 | 1.32 | 2.31 | 1/month | 24-Hr Composite |
| PCBs (Dry Weather) (pg/L) | XXX | XXX | XXX | XXX | Report | XXX | 1/year | 24-Hr Composite |
| Acute WET - Ceriodaphnia Survival (TUa) | XXX | XXX | XXX | Report Daily Max | XXX | XXX | See Permit | 24-Hr Composite |
| Acute WET - Pimephales Survival (TUa) | XXX | XXX | XXX | Report Daily Max | XXX | XXX | See Permit | 24-Hr Composite |

Compliance Sampling Location: At Outfall 001
Other Comments: None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

Outfall 002, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---------------------------|-------------------------------------|----------------|-----------------------|-----------------|---------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| COD | XXX | XXX | XXX | XXX | Report | XXX | 1/6 months | Grab |
| TSS | XXX | XXX | XXX | XXX | Report | XXX | 1/6 months | Grab |
| Oil and Grease | XXX | XXX | XXX | XXX | Report | XXX | 1/6 months | Grab |
| PCBs (Wet Weather) (pg/L) | XXX | XXX | XXX | XXX | Report | XXX | 1/year | Grab |

Compliance Sampling Location: At Outfall 002

Other Comments: None

| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment [redacted]) |
| <input checked="" type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | TRC Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 386-2000-002, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 386-2000-007, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 386-2000-003, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: [redacted] |
| <input type="checkbox"/> | Other: [redacted] |




U.S. DEPARTMENT OF THE INTERIOR
 U.S. GEOLOGICAL SURVEY



PHOENIXVILLE QUADRANGLE
 PENNSYLVANIA
 7.5-MINUTE SERIES



Produced by the United States Geological Survey
 Date: December 2010
 Scale: 1:24,000
 Projection: UTM
 Datum: NAD 83
 Contour Interval: 5 feet
 Elevation: 100 feet
 Contour Interval: 5 feet
 Elevation: 100 feet
 Contour Interval: 5 feet
 Elevation: 100 feet



EDUCATIONAL PURPOSES
 NOT FOR CONSTRUCTION
 This map is provided for educational purposes only. It is not intended for use in any legal proceeding or for any other purpose. The user assumes all responsibility for any use of this map.



| | | |
|---|---|---|
| 1 | 2 | 3 |
| 4 | 5 | 6 |
| 7 | 8 | 9 |

- ROAD CLASSIFICATION**
- Expressway
 - Secondary Road
 - Local Road
 - Interstate
 - US Route
 - State Route

PHOENIXVILLE, PA
 2019

7643016391714

PA0054526 at Outfall 001

Region ID:
Workarea ID:
Clicked Point (Latitude, Longitude):
Time:

PA
PA302161212245277923
49.16677, -75.54624
2023/10/12 07:21:13 -0400



Collapses All

Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|--------|-----------------------|
| BSLOPO | Mean basin slope measured in degrees | 6.3922 | degrees |
| CARBON | Percentage of area of carbonate rock | 18.1 | percent |
| DRNAREA | Area that drains to a point on a stream | 1190 | square miles |
| PRECIP | Mean Annual Precipitation | 46 | inches |
| ROCKDEP | Depth to rock | 4.4 | feet |
| STRDEN | Stream Density -- total length of streams divided by drainage area | 1.39 | miles per square mile |
| URBAN | Percentage of basin with urban development | 6.957 | percent |

Low Flow Statistics

Low Flow Statistics Parameters [34.2 Percent (288 square miles) Low Flow Region 1]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|--------------------------|--------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 1190 | square miles | 4.78 | 1190 |
| BSLOPO | Mean Basin Slope degrees | 6.3922 | degrees | 1.7 | 6.4 |
| ROCKDEP | Depth to Rock | 4.4 | feet | 4.15 | 5.21 |
| URBAN | Percent Urban | 6.957 | percent | 0 | 89 |

Low Flow Statistics Parameters [75.8 Percent (905 square miles) Low Flow Region 2]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| DRNAREA | Drainage Area | 1190 | square miles | 4.93 | 1280 |
| PRECIP | Mean Annual Precipitation | 46 | inches | 35 | 60.4 |
| STRDEN | Stream Density | 1.39 | miles per square mile | 0.51 | 3.1 |
| ROCKDEP | Depth to Rock | 4.4 | feet | 3.32 | 5.44 |
| CARBON | Percent Carbonate | 18.1 | percent | 0 | 99 |

Low Flow Statistics Disclaimers [34.2 Percent (288 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range, estimates were extrapolated with unknown error.

Low Flow Statistics Flow Report [34.2 Percent (288 square miles) Low Flow Region 1]

| Statistic | Value | Unit |
|-------------------------|-------|--------------------|
| 7 Day 2 Year Low Flow | 301 | ft ³ /s |
| 30 Day 2 Year Low Flow | 366 | ft ³ /s |
| 7 Day 10 Year Low Flow | 187 | ft ³ /s |
| 30 Day 10 Year Low Flow | 223 | ft ³ /s |
| 90 Day 10 Year Low Flow | 285 | ft ³ /s |

Low Flow Statistics Flow Report [75.8 Percent (905 square miles) Low Flow Region 2]

| Statistic | Value | Unit | PE: Prediction Interval Lower, PI: Prediction Interval Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (either -- see report) | |
|-------------------------|-------|--------------------|---|------|
| | | | 95 | ASCP |
| 7 Day 2 Year Low Flow | 466 | ft ³ /s | 38 | 35 |
| 30 Day 2 Year Low Flow | 549 | ft ³ /s | 33 | 33 |
| 7 Day 10 Year Low Flow | 323 | ft ³ /s | 31 | 31 |
| 30 Day 10 Year Low Flow | 353 | ft ³ /s | 45 | 45 |
| 90 Day 10 Year Low Flow | 440 | ft ³ /s | 36 | 36 |

Low Flow Statistics Flow Report [Area Averaged]

| Statistic | Value | Unit |
|-------------------------|-------|--------------------|
| 7 Day 2 Year Low Flow | 425 | ft ³ /s |
| 30 Day 2 Year Low Flow | 505 | ft ³ /s |
| 7 Day 10 Year Low Flow | 275 | ft ³ /s |
| 30 Day 10 Year Low Flow | 325 | ft ³ /s |
| 90 Day 10 Year Low Flow | 403 | ft ³ /s |

Unauthorized or unapproved use.

Low Flow Statistics Citation

USGS Software (2006) is the property of the U.S. Geological Survey and is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Aggett, M., et al., 2005. Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-0139, 84 p. (<http://pubs.usgs.gov/sir/2006/0139/>)


StreamStats Services Version: 1.2.23

USGS Software Disclaimer: This software is provided as a service to the public. All data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty is expressed or implied in making regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the use of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material (not that) the fact of release constitutes any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its

At node 2

Region ID: PA
 Workforce ID: PA20231005174550990000
 Clicked Point (Latitude, Longitude): 40.16717, 476.52352
 Time: 2023-12-05 13:46:21 +0000



Collapsable

Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|-------|-----------------------|
| BSLOPD | Mean basin slope measured in degrees | 5.362 | degrees |
| CARBON | Percentage of area of carbonate rock | 17.95 | percent |
| DNAREA | Area that drains to a point on a stream | 1200 | square miles |
| PRECIP | Mean Annual Precipitation | 46 | inches |
| ROCKDEP | Depth to rock | 4.4 | feet |
| STRDEN | Stream Density -- total length of streams divided by drainage area | 1.39 | miles per square mile |
| URBAN | Percentage of basin with urban development | 7.069 | percent |

Low Flow Statistics

Low Flow Statistics Parameters [24.8 Percent (299 square miles) Low Flow Region 1]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|--------------------------|-------|--------------|-----------|-----------|
| DNAREA | Drainage Area | 1200 | square miles | 4.78 | 1188 |
| BSLOPD | Mean Basin Slope degrees | 5.362 | degrees | 1.7 | 6.4 |
| ROCKDEP | Depth to Rock | 4.4 | feet | 4.13 | 5.21 |
| URBAN | Percent Urban | 7.069 | percent | 0 | 89 |

Low Flow Statistics Parameters [75.2 Percent (906 square miles) Low Flow Region 2]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| DNAREA | Drainage Area | 1200 | square miles | 4.95 | 1280 |
| PRECIP | Mean Annual Precipitation | 46 | inches | 35 | 50.4 |
| STRDEN | Stream Density | 1.39 | miles per square mile | 0.51 | 8.1 |
| ROCKDEP | Depth to Rock | 4.4 | feet | 3.32 | 5.65 |
| CARBON | Percent Carbonate | 17.95 | percent | 0 | 99 |

Low Flow Statistics Discrepancy [24.8 Percent (299 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low Flow Statistics Flow Report [24.8 Percent (299 square miles) Low Flow Region 1]

| Statistic | Value | Unit |
|-------------------------|-------|--------------------|
| 7 Day 2 Year Low Flow | 303 | ft ³ /s |
| 30 Day 2 Year Low Flow | 368 | ft ³ /s |
| 7 Day 10 Year Low Flow | 186 | ft ³ /s |
| 30 Day 10 Year Low Flow | 225 | ft ³ /s |
| 90 Day 10 Year Low Flow | 288 | ft ³ /s |

Low Flow Statistics Flow Report [75.2 Percent (906 square miles) Low Flow Region 2]

PE: Prediction [Interval-Lower], PU: Prediction [Interval-Upper], ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

| Statistic | Value | Unit | SE | ASEp |
|-------------------------|-------|--------------------|----|------|
| 7 Day 2 Year Low Flow | 469 | ft ³ /s | 38 | 38 |
| 30 Day 2 Year Low Flow | 553 | ft ³ /s | 33 | 33 |
| 7 Day 10 Year Low Flow | 335 | ft ³ /s | 51 | 51 |
| 30 Day 10 Year Low Flow | 381 | ft ³ /s | 46 | 46 |
| 90 Day 10 Year Low Flow | 443 | ft ³ /s | 35 | 35 |

Low Flow Statistics Flow Report [Area-Averaged]

| Statistic | Value | Unit |
|-------------------------|-------|--------------------|
| 7 Day 2 Year Low Flow | 438 | ft ³ /s |
| 30 Day 2 Year Low Flow | 507 | ft ³ /s |
| 7 Day 10 Year Low Flow | 276 | ft ³ /s |
| 30 Day 10 Year Low Flow | 327 | ft ³ /s |
| 90 Day 10 Year Low Flow | 408 | ft ³ /s |

USGS Product Name Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Low Flow Statistics Database Application Version: 4.1.3

Flow Data (Flow, 2008): USGS Low, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5136, 64 p. (<http://pubs.usgs.gov/wi/2006/5136/>)
 NGS Services Version: 2.2.1

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on a condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|------------------|--------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 03F | 833 | SCHUYLKILL RIVER | 43.120 | 93.01 | 1190.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.230 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|---------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| UniTech | PA0054526 | 0.1000 | 0.1000 | 0.1000 | 0.000 | 24.00 | 7.10 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 10.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|------------------|--------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 03F | 833 | SCHUYLKILL RIVER | 41.300 | 87.83 | 1200.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfs) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | pH | Stream Temp (°C) | pH |
|--------------|-----------|-----------------|-------------------|----------------------|--------------------|----------|----------------|----------------|---------------------|------|------------------|------|
| Q7-10 | 0.230 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|------------------|------------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |
| Parameter Data | | | | | | | |
| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | | |
| CBO5 | 25.00 | 2.00 | 0.00 | 1.50 | | | |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 | | | |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 | | | |

WQM 7.0 Hydrodynamic Outputs

| SWP Basin | Stream Code | Stream Name | | | | | | | | | | |
|--------------------|-------------------|------------------|-----------------------|--------------------------|---------------------|------------|------------|-----------|----------------|------------------------|--------------------|-------------|
| 03F | 833 | SCHUYLKILL RIVER | | | | | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
| Q7-10 Flow | | | | | | | | | | | | |
| 43.120 | 273.70 | 0.00 | 273.70 | .1547 | 0.00054 | 1.151 | 279.83 | 243.16 | 0.85 | 0.131 | 25.00 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 43.120 | 175.17 | 0.00 | 175.17 | .1547 | 0.00054 | NA | NA | NA | 0.66 | 0.168 | 25.00 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 43.120 | 325.70 | 0.00 | 325.70 | .1547 | 0.00054 | NA | NA | NA | 0.94 | 0.119 | 25.00 | 7.00 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.19 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 5 | | |

WQM 7.0 Wasteload Allocations

| SWP Basin | Stream Code | Stream Name |
|-----------|-------------|------------------|
| 03F | 833 | SCHUYLKILL RIVER |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 43.120 | UniTech | 11.07 | 20 | 11.07 | 20 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 43.120 | UniTech | 1.37 | 10 | 1.37 | 10 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | CBOD5 | | NH3-N | | Dissolved Oxygen | | Critical Reach | Percent Reduction |
|-------|----------------|-----------------|-----------------|-----------------|-----------------|------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 43.12 | UniTech | 25 | 25 | 10 | 10 | 3 | 3 | 0 | 0 |

WQM 7.0 D.O.Simulation

| SWP Basin | Stream Code | Stream Name |
|-----------|-------------|------------------|
| 03F | 833 | SCHUYLKILL RIVER |

| RMI | Total Discharge Flow (mgd) | Analysis Temperature (°C) | Analysis pH |
|---------------------------------|----------------------------|---------------------------|-----------------------------|
| 43.120 | 0.100 | 24.999 | 7.000 |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> |
| 279.826 | 1.151 | 243.156 | 0.850 |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> |
| 2.01 | 0.009 | 0.01 | 1.028 |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> |
| 8.240 | 2.407 | Tsvoglou | 5 |
| <u>Reach Travel Time (days)</u> | <u>Subreach Results</u> | | |
| 0.131 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> |
| | | | <u>D.O. (mg/L)</u> |
| | 0.013 | 2.01 | 0.01 |
| | 0.026 | 2.01 | 0.01 |
| | 0.039 | 2.01 | 0.01 |
| | 0.052 | 2.01 | 0.01 |
| | 0.065 | 2.01 | 0.01 |
| | 0.078 | 2.01 | 0.01 |
| | 0.092 | 2.01 | 0.01 |
| | 0.105 | 2.01 | 0.01 |
| | 0.118 | 2.01 | 0.01 |
| | 0.131 | 2.01 | 0.00 |

WQM 7.0 Effluent Limits

| SWP Basin | Stream Code | Stream Name |
|-----------|-------------|------------------|
| 03F | 833 | SCHUYLKILL RIVER |

| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Eff. Limit 30-day Ave. (mg/L) | Eff. Limit Maximum (mg/L) | Eff. Limit Minimum (mg/L) |
|--------|---------|---------------|-----------------|------------------|-------------------------------|---------------------------|---------------------------|
| 43.120 | UniTech | PA0054526 | 0.100 | CBOD5 | 25 | | |
| | | | | NH3-N | 10 | 20 | |
| | | | | Dissolved Oxygen | | | 3 |



Discharge Information

Instructions **Discharge** Stream

Facility: UniTech Services Group NPDES Permit No.: PA0054526 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Treated IW

| Discharge Characteristics | | | | | | | | |
|---------------------------|------------------|----------|----------------------------|-----|-----|-----|--------------------------|----------------|
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | | Complete Mix Times (min) | |
| | | | AFC | CFC | THH | CRL | Q ₇₋₁₀ | Q _h |
| 0.1 | 74.3 | 7.1 | | | | | | |

| Discharge Pollutant | Units | Max Discharge Conc | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | | 1 if left blank | |
|---------------------------------|-------|--------------------|-----------------|-------------|-------------------|-----------|-----------------|------------|-----|-----------------|-------------|
| | | | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | Criteria Mod | Chem Transl |
| Group 1 | | | | | | | | | | | |
| Total Dissolved Solids (PWS) | mg/L | | | | | | | | | | |
| Chloride (PWS) | mg/L | | | | | | | | | | |
| Bromide | mg/L | | | | | | | | | | |
| Sulfate (PWS) | mg/L | | | | | | | | | | |
| Fluoride (PWS) | mg/L | | | | | | | | | | |
| Group 2 | | | | | | | | | | | |
| Total Aluminum | µg/L | 30 | | | | | | | | | |
| Total Antimony | µg/L | 24 | | | | | | | | | |
| Total Arsenic | µg/L | 5 | | | | | | | | | |
| Total Barium | µg/L | 30 | | | | | | | | | |
| Total Beryllium | µg/L | < 1 | | | | | | | | | |
| Total Boron | µg/L | < 200 | | | | | | | | | |
| Total Cadmium | µg/L | < 0.2 | | | | | | | | | |
| Total Chromium (III) | µg/L | | | | | | | | | | |
| Hexavalent Chromium | µg/L | < 0.29 | | | | | | | | | |
| Total Cobalt | µg/L | 0.3 | | | | | | | | | |
| Total Copper | mg/L | 1.04 | | | 0.365 | | | | | | |
| Free Cyanide | µg/L | | | | | | | | | | |
| Total Cyanide | µg/L | 9 | | | | | | | | | |
| Dissolved Iron | µg/L | 0.1 | | | | | | | | | |
| Total Iron | µg/L | 130 | | | | | | | | | |
| Total Lead | µg/L | 2 | | | | | | | | | |
| Total Manganese | µg/L | 13 | | | | | | | | | |
| Total Mercury | µg/L | < 0.02 | | | | | | | | | |
| Total Nickel | µg/L | 10.7 | | | | | | | | | |
| Total Phenols (Phenolics) (PWS) | µg/L | < 2 | | | | | | | | | |
| Total Selenium | µg/L | < 1 | | | | | | | | | |
| Total Silver | µg/L | < 0.3 | | | | | | | | | |
| Total Thallium | µg/L | < 3 | | | | | | | | | |
| Total Zinc | µg/L | 422 | | | | | | | | | |
| Total Molybdenum | µg/L | < 3 | | | | | | | | | |
| Acrolein | µg/L | < | | | | | | | | | |
| Acrylamide | µg/L | < | | | | | | | | | |
| Acrylonitrile | µg/L | < | | | | | | | | | |
| Benzene | µg/L | < | | | | | | | | | |
| Bromoform | µg/L | < | | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | | |
|----------------------------|-----------------------------|------|---|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| Group 3 | Carbon Tetrachloride | µg/L | < | | | | | | | | | | | | | | | | | |
| | Chlorobenzene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Chlorodibromomethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | Chloroethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2-Chloroethyl Vinyl Ether | µg/L | < | | | | | | | | | | | | | | | | | |
| | Chloroform | µg/L | < | | | | | | | | | | | | | | | | | |
| | Dichlorobromomethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,1-Dichloroethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,2-Dichloroethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,1-Dichloroethylene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,2-Dichloropropane | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,3-Dichloropropylene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,4-Dioxane | µg/L | < | | | | | | | | | | | | | | | | | |
| | Ethylbenzene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Methyl Bromide | µg/L | < | | | | | | | | | | | | | | | | | |
| | Methyl Chloride | µg/L | < | | | | | | | | | | | | | | | | | |
| | Methylene Chloride | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,1,1,2-Tetrachloroethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | Tetrachloroethylene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Toluene | µg/L | < | | | | | | | | | | | | | | | | | |
| 1,2-trans-Dichloroethylene | µg/L | < | | | | | | | | | | | | | | | | | | |
| 1,1,1-Trichloroethane | µg/L | < | | | | | | | | | | | | | | | | | | |
| 1,1,2-Trichloroethane | µg/L | < | | | | | | | | | | | | | | | | | | |
| Trichloroethylene | µg/L | < | | | | | | | | | | | | | | | | | | |
| Vinyl Chloride | µg/L | < | | | | | | | | | | | | | | | | | | |
| Group 4 | 2-Chlorophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2,4-Dichlorophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2,4-Dimethylphenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 4,6-Dinitro-o-Cresol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2,4-Dinitrophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2-Nitrophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 4-Nitrophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | p-Chloro-m-Cresol | µg/L | < | | | | | | | | | | | | | | | | | |
| | Pentachlorophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | Phenol | µg/L | < | | | | | | | | | | | | | | | | | |
| 2,4,6-Trichlorophenol | µg/L | < | | | | | | | | | | | | | | | | | | |
| Group 5 | Acenaphthene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Acenaphthylene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Anthracene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Benzidine | µg/L | < | | | | | | | | | | | | | | | | | |
| | Benzo(a)Anthracene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Benzo(a)Pyrene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 3,4-Benzofluoranthene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Benzo(ghi)Perylene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Benzo(k)Fluoranthene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroethoxy)Methane | µg/L | < | | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroethyl)Ether | µg/L | < | | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroisopropyl)Ether | µg/L | < | | | | | | | | | | | | | | | | | |
| | Bis(2-Ethylhexyl)Phthalate | µg/L | < | | | | | | | | | | | | | | | | | |
| | 4-Bromophenyl Phenyl Ether | µg/L | < | | | | | | | | | | | | | | | | | |
| | Butyl Benzyl Phthalate | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2-Chloronaphthalene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 4-Chlorophenyl Phenyl Ether | µg/L | < | | | | | | | | | | | | | | | | | |
| | Chrysene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Dibenzo(a,h)Anthracene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,2-Dichlorobenzene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,3-Dichlorobenzene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,4-Dichlorobenzene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 3,3-Dichlorobenzidine | µg/L | < | | | | | | | | | | | | | | | | | |
| | Diethyl Phthalate | µg/L | < | | | | | | | | | | | | | | | | | |
| | Dimethyl Phthalate | µg/L | < | | | | | | | | | | | | | | | | | |
| Di-n-Butyl Phthalate | µg/L | < | | | | | | | | | | | | | | | | | | |
| 2,4-Dinitrotoluene | µg/L | < | | | | | | | | | | | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | |
|--------------|---------------------------|--------|---------|--|--|--|--|--|--|-------|--|--|--|--|--|--|--|--|--|
| | 2,6-Dinitrotoluene | µg/L | < | | | | | | | | | | | | | | | | |
| | Di-n-Octyl Phthalate | µg/L | < | | | | | | | | | | | | | | | | |
| | 1,2-Diphenylhydrazine | µg/L | < | | | | | | | | | | | | | | | | |
| | Fluoranthene | µg/L | < | | | | | | | | | | | | | | | | |
| | Fluorene | µg/L | < | | | | | | | | | | | | | | | | |
| | Hexachlorobenzene | µg/L | < | | | | | | | | | | | | | | | | |
| | Hexachlorobutadiene | µg/L | < | | | | | | | | | | | | | | | | |
| | Hexachlorocyclopentadiene | µg/L | < | | | | | | | | | | | | | | | | |
| | Hexachloroethane | µg/L | < | | | | | | | | | | | | | | | | |
| | Indeno(1,2,3-cd)Pyrene | µg/L | < | | | | | | | | | | | | | | | | |
| | Isophorone | µg/L | < | | | | | | | | | | | | | | | | |
| | Naphthalene | µg/L | < | | | | | | | | | | | | | | | | |
| | Nitrobenzene | µg/L | < | | | | | | | | | | | | | | | | |
| | n-Nitrosodimethylamine | µg/L | < | | | | | | | | | | | | | | | | |
| | n-Nitrosodi-n-Propylamine | µg/L | < | | | | | | | | | | | | | | | | |
| | n-Nitrosodiphenylamine | µg/L | < | | | | | | | | | | | | | | | | |
| | Phenanthrene | µg/L | < | | | | | | | | | | | | | | | | |
| | Pyrene | µg/L | < | | | | | | | | | | | | | | | | |
| | 1,2,4-Trichlorobenzene | µg/L | < | | | | | | | | | | | | | | | | |
| Group 6 | Aldrin | µg/L | < | | | | | | | | | | | | | | | | |
| | alpha-BHC | µg/L | < | | | | | | | | | | | | | | | | |
| | beta-BHC | µg/L | < | | | | | | | | | | | | | | | | |
| | gamma-BHC | µg/L | < | | | | | | | | | | | | | | | | |
| | delta BHC | µg/L | < | | | | | | | | | | | | | | | | |
| | Chlordane | µg/L | < | | | | | | | | | | | | | | | | |
| | 4,4-DDT | µg/L | < | | | | | | | | | | | | | | | | |
| | 4,4-DDE | µg/L | < | | | | | | | | | | | | | | | | |
| | 4,4-DDD | µg/L | < | | | | | | | | | | | | | | | | |
| | Dieldrin | µg/L | < | | | | | | | | | | | | | | | | |
| | alpha-Endosulfan | µg/L | < | | | | | | | | | | | | | | | | |
| | beta-Endosulfan | µg/L | < | | | | | | | | | | | | | | | | |
| | Endosulfan Sulfate | µg/L | < | | | | | | | | | | | | | | | | |
| | Endrin | µg/L | < | | | | | | | | | | | | | | | | |
| | Endrin Aldehyde | µg/L | < | | | | | | | | | | | | | | | | |
| | Heptachlor | µg/L | < | | | | | | | | | | | | | | | | |
| | Heptachlor Epoxide | µg/L | < | | | | | | | | | | | | | | | | |
| | PCB-1016 | µg/L | < | | | | | | | | | | | | | | | | |
| | PCB-1221 | µg/L | < | | | | | | | | | | | | | | | | |
| | PCB-1232 | µg/L | < | | | | | | | | | | | | | | | | |
| | PCB-1242 | µg/L | < | | | | | | | | | | | | | | | | |
| PCB-1248 | µg/L | < | | | | | | | | | | | | | | | | | |
| PCB-1254 | µg/L | < | | | | | | | | | | | | | | | | | |
| PCB-1260 | µg/L | < | | | | | | | | | | | | | | | | | |
| PCBs, Total | µg/L | < | 0.00181 | | | | | | | | | | | | | | | | |
| Toxaphene | µg/L | < | | | | | | | | | | | | | | | | | |
| 2,3,7,8-TCDD | ng/L | < | | | | | | | | | | | | | | | | | |
| Group 7 | Gross Alpha | pCi/L | | | | | | | | | | | | | | | | | |
| | Total Beta | pCi/L | < | | | | | | | | | | | | | | | | |
| | Radium 226/228 | pCi/L | < | | | | | | | | | | | | | | | | |
| | Total Strontium | µg/L | < | | | | | | | | | | | | | | | | |
| | Total Uranium | µg/L | < | | | | | | | | | | | | | | | | |
| | Osmotic Pressure | mOs/kg | | | | | | | | | | | | | | | | | |
| Color | Pt-Co | | 18.7 | | | | | | | 0.351 | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |

Receiving Surface Water Name: _____

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|-------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 000833 | 43.12 | 93.01 | 1190 | | | Yes |
| End of Reach 1 | 000833 | 41.3 | 87.83 | 1200 | | | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|-------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 43.12 | 0.23 | | | | | | | | | | 105 | 7 | | |
| End of Reach 1 | 41.3 | 0.23 | | | | | | | | | | | | | |

Q_n

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|-------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|----------|----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness | pH | Hardness | pH |
| Point of Discharge | 43.12 | | | | | | | | | | | | | | |
| End of Reach 1 | 41.3 | | | | | | | | | | | | | | |

Hydrodynamics

Wasteload Allocations

AFC

CCT (min): 15

PMF: 0.063

Analysis Hardness (mg/l): 104.73

Analysis pH: 7.00

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Aluminum | 0 | 0 | | 0 | 750 | 750 | 84,782 | |
| Total Antimony | 0 | 0 | | 0 | 1,100 | 1,100 | 124,347 | |
| Total Arsenic | 0 | 0 | | 0 | 340 | 340 | 38,434 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 21,000 | 21,000 | 2,373,892 | |
| Total Boron | 0 | 0 | | 0 | 8,100 | 8,100 | 915,644 | |
| Total Cadmium | 0 | 0 | | 0 | 2,106 | 2.24 | 253 | Chem Translator of 0.942 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 16 | 16.3 | 1,842 | Chem Translator of 0.982 applied |
| Total Cobalt | 0 | 0 | | 0 | 95 | 95.0 | 10,739 | |
| Total Copper | 0 | 0 | | 0 | 14.037 | 14.6 | 1,653 | Chem Translator of 0.96 applied |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | 67.911 | 86.6 | 9,788 | Chem Translator of 0.784 applied |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 1.400 | 1.65 | 186 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 486.899 | 488 | 55,151 | Chem Translator of 0.998 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | 3.483 | 4.1 | 463 | Chem Translator of 0.85 applied |
| Total Thallium | 0 | 0 | | 0 | 65 | 65.0 | 7,348 | |
| Total Zinc | 0 | 0 | | 0 | 121.859 | 125 | 14,085 | Chem Translator of 0.978 applied |
| PCBs, Total | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Color | 0 | 0 | | 0 | N/A | N/A | N/A | |

CFC

CCT (min): 720

PMF: 0.439

Analysis Hardness (mg/l): 104.96

Analysis pH: 7.00

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 220 | 220 | 170,996 | |
| Total Arsenic | 0 | 0 | | 0 | 150 | 150 | 116,588 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 4,100 | 4,100 | 3,186,738 | |
| Total Boron | 0 | 0 | | 0 | 1,600 | 1,600 | 1,243,605 | |
| Total Cadmium | 0 | 0 | | 0 | 0.254 | 0.28 | 218 | Chem Translator of 0.907 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 10 | 10.4 | 8,080 | Chem Translator of 0.962 applied |
| Total Cobalt | 0 | 0 | | 0 | 19 | 19.0 | 14,768 | |
| Total Copper | 0 | 0 | | 0 | 9.334 | 9.72 | 7,557 | Chem Translator of 0.96 applied |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | 1,500 | 1,500 | 2,655,346 | WQC = 30 day average; PMF = 1 |
| Total Lead | 0 | 0 | | 0 | 2.653 | 3.38 | 2,630 | Chem Translator of 0.784 applied |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 0.770 | 0.91 | 704 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 54.181 | 54.3 | 42,239 | Chem Translator of 0.997 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | 4.600 | 4.99 | 3,878 | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 1 applied |
| Total Thallium | 0 | 0 | | 0 | 13 | 13.0 | 10,104 | |
| Total Zinc | 0 | 0 | | 0 | 123.086 | 125 | 97,027 | Chem Translator of 0.986 applied |
| PCBs, Total | 0 | 0 | | 0 | 0.014 | 0.014 | 10.9 | |
| Color | 0 | 0 | | 0 | N/A | N/A | N/A | |

THH CCT (min): 720 PMF: 0.439 Analysis Hardness (mg/l): N/A Analysis pH: N/A

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 5.6 | 5.6 | 4,353 | |
| Total Arsenic | 0 | 0 | | 0 | 10 | 10.0 | 7,773 | |
| Total Barium | 0 | 0 | | 0 | 2,400 | 2,400 | 1,865,408 | |
| Total Boron | 0 | 0 | | 0 | 3,100 | 3,100 | 2,409,485 | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | 300 | 300 | 233,176 | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | 1,000 | 1,000 | 777,253 | |
| Total Mercury | 0 | 0 | | 0 | 0.050 | 0.05 | 38.9 | |
| Total Nickel | 0 | 0 | | 0 | 610 | 610 | 474,124 | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | 5 | 5.0 | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Thallium | 0 | 0 | | 0 | 0.24 | 0.24 | 187 | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |
| PCBs, Total | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Color | 0 | 0 | | 0 | 75 | 75.0 | 58,294 | |

CRL CCT (min): 720 PMF: 0.673 Analysis Hardness (mg/l): N/A Analysis pH: N/A

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Arsenic | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Barium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Boron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Nickel | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Thallium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |
| PCBs, Total | 0 | 0 | | 0 | 0.000064 | 0.00006 | 0.28 | |
| Color | 0 | 0 | | 0 | N/A | N/A | N/A | |

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|--------------|---------------|---------------|----------------------|------|------|-------|-----------------|-------------|---------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Copper | 0.77 | 1.1 | 0.92 | 1.32 | 2.31 | mg/L | 0.92 | AFC | Discharge Conc ≥ 50% WQBEL (RP) |

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge

concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|---------------------------------|-----------------|-------|----------------------------|
| Total Aluminum | 54,342 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Antimony | 4,353 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Arsenic | 7,773 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Barium | 1,521,569 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Beryllium | N/A | N/A | No WQS |
| Total Boron | N/A | N/A | Discharge Conc < TQL |
| Total Cadmium | N/A | N/A | Discharge Conc < TQL |
| Hexavalent Chromium | N/A | N/A | Discharge Conc < TQL |
| Total Cobalt | 6,883 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cyanide | N/A | N/A | No WQS |
| Dissolved Iron | 233,176 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Iron | 2,655,346 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Lead | 2,630 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Manganese | 777,253 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Mercury | 38.9 | µg/L | Discharge Conc < TQL |
| Total Nickel | 35,349 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Phenols (Phenolics) (PWS) | | µg/L | Discharge Conc < TQL |
| Total Selenium | 3,878 | µg/L | Discharge Conc < TQL |
| Total Silver | 297 | µg/L | Discharge Conc < TQL |
| Total Thallium | 187 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Zinc | 9,028 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Molybdenum | N/A | N/A | No WQS |
| PCBs, Total | 0.28 | µg/L | Discharge Conc < TQL |
| Color | 58,294 | Pt-Co | Discharge Conc ≤ 10% WQBEL |

| DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet | | | | |
|--|------------|--|---------------|--|
| Type of Test | Acute | | Facility Name | |
| Species Tested | Pimephales | | UniTech | |
| Endpoint | Survival | | Permit No. | |
| TIWC (decimal) | 0.02 | | PA0054562 | |
| No. Per Replicate | 10 | | | |
| TST b value | 0.8 | | | |
| TST alpha value | 0.1 | | | |

| Test Completion Date | | | Test Completion Date | | |
|----------------------|---------|------|----------------------|---------|------|
| 5/18/2019 | | | 9/13/2020 | | |
| Replicate No. | Control | TIWC | Replicate No. | Control | TIWC |
| 1 | 10 | 10 | 1 | 10 | 10 |
| 2 | 10 | 10 | 2 | 10 | 10 |
| 3 | 10 | 10 | 3 | 10 | 10 |
| 4 | 9 | 10 | 4 | 9 | 10 |
| 5 | | | 5 | | |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|-------|--------|--------------|-------|--------|
| Mean | 9.750 | 10.000 | Mean | 9.750 | 10.000 |
| Std Dev. | 0.500 | 0.000 | Std Dev. | 0.500 | 0.000 |
| # Replicates | 4 | 4 | # Replicates | 4 | 4 |

| | | | |
|------------------|--------|------------------|--------|
| T-Test Result | 9.6643 | T-Test Result | 9.6643 |
| Deg. of Freedom | 3 | Deg. of Freedom | 3 |
| Critical T Value | 1.6377 | Critical T Value | 1.6377 |
| Pass or Fail | PASS | Pass or Fail | PASS |

| Test Completion Date | | | Test Completion Date | | |
|----------------------|---------|------|----------------------|---------|------|
| 7/31/2021 | | | 9/28/2022 | | |
| Replicate No. | Control | TIWC | Replicate No. | Control | TIWC |
| 1 | 10 | 10 | 1 | 8 | 9 |
| 2 | 10 | 10 | 2 | 9 | 9 |
| 3 | 10 | 10 | 3 | 9 | 8 |
| 4 | 10 | 10 | 4 | 9 | 8 |
| 5 | | | 5 | | |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|--------|--------|--------------|-------|-------|
| Mean | 10.000 | 10.000 | Mean | 8.750 | 8.500 |
| Std Dev. | 0.000 | 0.000 | Std Dev. | 0.500 | 0.577 |
| # Replicates | 4 | 4 | # Replicates | 4 | 4 |

| | | | |
|------------------|--------|------------------|--------|
| T-Test Result | 4.1587 | T-Test Result | 4.1587 |
| Deg. of Freedom | 5 | Deg. of Freedom | 5 |
| Critical T Value | 1.4759 | Critical T Value | 1.4759 |
| Pass or Fail | PASS | Pass or Fail | PASS |

| DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet | | | | |
|--|--------------|--|---------------|--|
| Type of Test | Acute | | Facility Name | |
| Species Tested | Ceriodaphnia | | UniTech | |
| Endpoint | Survival | | Permit No. | |
| TIWC (decimal) | 0.02 | | PA0054526 | |
| No. Per Replicate | 10 | | | |
| TST b value | 0.8 | | | |
| TST alpha value | 0.1 | | | |

| Test Completion Date | | | Test Completion Date | | |
|----------------------|---------|------|----------------------|---------|------|
| 5/18/2019 | | | 9/11/2020 | | |
| Replicate No. | Control | TIWC | Replicate No. | Control | TIWC |
| 1 | 10 | 10 | 1 | 10 | 10 |
| 2 | 10 | 10 | 2 | 10 | 10 |
| 3 | 10 | 10 | 3 | 10 | 10 |
| 4 | 10 | 10 | 4 | 10 | 10 |
| 5 | 10 | 10 | 5 | 10 | 10 |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|--------|--------|--------------|--------|--------|
| Mean | 10.000 | 10.000 | Mean | 10.000 | 10.000 |
| Std Dev. | 0.000 | 0.000 | Std Dev. | 0.000 | 0.000 |
| # Replicates | 5 | 5 | # Replicates | 5 | 5 |

| | | | |
|------------------|------|------------------|------|
| T-Test Result | PASS | T-Test Result | PASS |
| Deg. of Freedom | | Deg. of Freedom | |
| Critical T Value | | Critical T Value | |
| Pass or Fail | PASS | Pass or Fail | PASS |

| Test Completion Date | | | Test Completion Date | | |
|----------------------|---------|------|----------------------|---------|------|
| 7/29/2021 | | | 9/28/2022 | | |
| Replicate No. | Control | TIWC | Replicate No. | Control | TIWC |
| 1 | 10 | 10 | 1 | 10 | 10 |
| 2 | 10 | 10 | 2 | 10 | 10 |
| 3 | 10 | 10 | 3 | 10 | 10 |
| 4 | 10 | 10 | 4 | 10 | 10 |
| 5 | 10 | 10 | 5 | 10 | 10 |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|--------|--------|--------------|--------|--------|
| Mean | 10.000 | 10.000 | Mean | 10.000 | 10.000 |
| Std Dev. | 0.000 | 0.000 | Std Dev. | 0.000 | 0.000 |
| # Replicates | 5 | 5 | # Replicates | 5 | 5 |

| | | | |
|------------------|------|------------------|------|
| T-Test Result | PASS | T-Test Result | PASS |
| Deg. of Freedom | | Deg. of Freedom | |
| Critical T Value | | Critical T Value | |
| Pass or Fail | PASS | Pass or Fail | PASS |

| WET Summary and Evaluation | | | | | |
|-------------------------------|------------------------------|--------------------------|-----------|-----------|-----------|
| Facility Name | UniTech | | | | |
| Permit No. | PA0054562 | | | | |
| Design Flow (MGD) | 0.1 | | | | |
| Q ₇₋₁₀ Flow (cfs) | 275 | | | | |
| PMF _a | 0.063 | | | | |
| PMF _c | 0.439 | | | | |
| Species | Endpoint | Test Results (Pass/Fail) | | | |
| | | Test Date | Test Date | Test Date | Test Date |
| Pimephales | Survival | PASS | PASS | PASS | PASS |
| Species | Endpoint | Test Results (Pass/Fail) | | | |
| | | Test Date | Test Date | Test Date | Test Date |
| Ceriodaphnia | Survival | PASS | PASS | PASS | PASS |
| Species | Endpoint | Test Results (Pass/Fail) | | | |
| | | Test Date | Test Date | Test Date | Test Date |
| | | | | | |
| Species | Endpoint | Test Results (Pass/Fail) | | | |
| | | Test Date | Test Date | Test Date | Test Date |
| | | | | | |
| Reasonable Potential? | | NO | | | |
| Permit Recommendations | | | | | |
| Test Type | Acute | | | | |
| TIWC | 3 % Effluent | | | | |
| Dilution Series | 1, 3, 30, 60, 100 % Effluent | | | | |
| Permit Limit | None | | | | |
| Permit Limit Species | | | | | |