

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0055352  
 APS ID 471551  
 Authorization ID 1274364

**Applicant and Facility Information**

Applicant Name	<u>Berks Properties Inc.</u>	Facility Name	<u>Woodland MHP</u>
Applicant Address	<u>3613 Seisholtzville Road PO Box 185</u> <u>Hereford, PA 18056-1542</u>	Facility Address	<u>Dale Road</u> <u>Barto, PA 19504</u>
Applicant Contact	<u>Jim Groff</u>	Facility Contact	<u>Jim Groff</u>
Applicant Phone	<u>(267) 446-0017</u>	Facility Phone	<u>(267) 446-0017</u>
Client ID	<u>180156</u>	Site ID	<u>246037</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Hereford Township</u>
Connection Status		County	<u>Berks</u>
Date Application Received	<u>May 3, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 4, 2019</u>	If No, Reason	
Purpose of Application	<u>NPDES permit Renewal.</u>		

**Summary of Review**

Berks Properties, Inc. has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The permit was issued on October 17, 2014 and became effective on November 1, 2014. The permit authorized discharge of treated sewage from the existing wastewater treatment plant (WWTP) located in Hereford Township, Berks County to West Branch Perkiomen Creek to Perkiomen Creek. The existing permit expiration date was October 31, 2019, and the permit has been administratively extended since that time.

The discharge design flow is 0.014 MGD. This facility received domestic sewage from the Woodland Mobile Home Park which is approximately 30 mobile homes. This discharge to an Exceptional Value (EV) waters re-designation is justified, since the outfall pre-dates the EV classification of the stream.

The WQM No. 0687428 99-1 amendment was issued on April 13, 1999.

Changes from the previous permit: Unit of Fecal Coliform changed from CFU/100 ml to No./100 ml.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		/s/ Hilary H. Le / Environmental Engineering Specialist	January 31, 2020
X		/s/ Daniel W. Martin, P.E. / Environmental Engineer Manager	March 26, 2020
X		/s/ Maria D. Bebenek, P.E. / Clean Water Program Manager	April 7, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.014
Latitude	40° 26' 18.20"	Longitude	-75° 37' 28.06"
Quad Name	East Greenville	Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	West Branch Perkiomen Creek (EV)	Stream Code	01439
NHD Com ID	25971444	RMI	12.0 miles
Drainage Area	4.92 mi. <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	See comments below
Q <sub>7-10</sub> Flow (cfs)	See comments below	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	675.28	Slope (ft/ft)	
Watershed No.	3-E	Chapter 93 Class.	EV
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	AQUA PA, Inc., Montgomery County		
PWS Waters	Perkiomen Creek	Flow at Intake (cfs)	
PWS RMI	1.1 miles	Distance from Outfall (mi)	Approximate 34 miles

Changes Since Last Permit Issuance:

*Drainage Area*

The discharge is to West Branch Perkiomen Creek at RMI 12.0 miles. A drainage area upstream of the discharge is estimated to be 4.92 mi.<sup>2</sup>, according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

*Stream Flow*

There are no nearby stream gages with low flow data that have extensive or recent periods of record. Since USGS PA StreamStats estimated the drainage area that is below the minimum value allowed by USGS's regression equations, the USGS gage station (No. 01472199) on West Branch Perkiomen Creek at Hillegass, PA will be used to calculate the Q<sub>7-10</sub> at the point of discharge using a low flow yield method. The Q<sub>7-10</sub> here is 3.08 cfs and the drainage area is 23.4 mi.<sup>2</sup> which results in a Q<sub>7-10</sub> low flow yield of 0.13 cfs/mi.<sup>2</sup>. This information is used to obtain a chronic or 30-day (Q<sub>30-10</sub>), and an acute or 1-day (Q<sub>1-10</sub>) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned} \text{Low Flow Yield} &= Q_{7-10\text{gage}} / \text{Drainage Area}_{\text{gage}} = 3.08 \text{ cfs} / 23.4 \text{ mi.}^2 = 0.13 \text{ cfs/mi.}^2 \\ Q_{7-10\text{discharge}} &= 0.13 \text{ cfs/mi.}^2 * \text{Drainage Area}_{\text{discharge}} = 0.13 \text{ cfs/mi.}^2 * 4.92 \text{ mi.}^2 = 0.64 \text{ cfs} \\ Q_{30-10} &= 1.36 * Q_{7-10\text{discharge}} = 1.36 * 0.64 \text{ cfs} = 0.87 \text{ cfs} \\ Q_{1-10} &= 0.64 * Q_{7-10\text{discharge}} = 0.64 * 0.64 \text{ cfs} = 0.41 \text{ cfs} \end{aligned}$$

*West Branch Perkiomen Creek*

25 Pa. Code § 93.9f classifies West Branch Perkiomen Creek as Exceptional Value (EV) waters re-designation and migratory fishes (MF). Based on the 2018 Integrated Report, Perkiomen Creek, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

*Potable Water Supply Intake*

The nearest downstream public water supply intake is the AQUA PA, Inc. intake on the Perkiomen Creek, in Montgomery County, approximately 35 miles from the point of discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Woodland MHP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
0687428 99-1		4/13/1999		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary		Gas Chlorine	0.014
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.014		Not Overloaded	N/A	Other WWTP

Changes Since Last Permit Issuance: none

Other Comments: The WWTP is a 14,000 GPD system with the following treatment units:

- Influent Bar Screen
- Equalization Tank
- Influent Distribution Box
- Aeration Tank
- Clarifier
- Chlorine Contact Tank
- Sludge Holding Tank

Compliance History	
<b>Summary of DMRs:</b>	See DMR reported from December 1, 2018 to November 30, 2019 Table below (Page 4).
<b>Summary of Inspections:</b>	<p>1/02/2019: Mr. Buss, DEP WQS, conducted compliance evaluation inspection. There were some recommendations such as submit biosolids production and disposal supplemental spreadsheet each month, and record all sample results on bench sheet. The field test results were within permitted limits. There were no violations noted during inspection.</p> <p>5/2/2017: Mr. Buss, DEP WQS, conducted compliance evaluation inspection. There were some recommendations such as completing MLSS testing at least monthly. The field test results were within permitted limits. There were no violations noted during inspection.</p>
<b>Other Comments:</b>	There are currently no open violations associated with the permittee or the facility.

Other Comments: DMRs for the past 12 months indicate three instances of non-compliance (two exceedances for Fecal Coliform average monthly, and one exceedance for Fecal Coliform IMAX). The facility appears to be operating satisfactorily.

Compliance History

DMR Data for Outfall 001 (from December 1, 2018 to November 30, 2019)

Parameter	NOV-19	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18
Flow (MGD) Average Monthly	0.0006	0.0018	0.0019	0.0017	0.0044	0.0033	0.0038	0.004	0.0088	0.0068	0.0026	0.0021
Flow (MGD) Daily Maximum	0.0017	0.0133	0.0088	0.0054	0.0165	0.0144	0.0096	0.0113	0.0223	0.0111	0.0157	0.013
pH (S.U.) Minimum	6.1	6.4	6.9	6.1	6.1	6.0	6.1	6.4	6.4	6.0	6.2	6.2
pH (S.U.) Maximum	8.0	8.1	8.1	8.2	7.8	8.0	8.1	7.9	7.5	7.8	8.1	8.2
DO (mg/L) Minimum	6.1	6.2	5.5	5.0	5.1	5.3	5.4	5.1	6.1	7.4	7.6	7.2
TRC (mg/L) Average Monthly	0.04	0.1	0.1	0.1	0.03	0.03	0.02	0.02	0.04	0.04	0.1	0.05
TRC (mg/L) Instantaneous Maximum	0.14	0.24	0.16	0.17	0.14	0.12	0.08	0.21	0.14	0.19	0.17	0.22
CBOD <sub>5</sub> (mg/L) Average Monthly	7.5	6.5	4	2	7	4	12.5	6.5	7	5.5	10	7
TSS (mg/L) Average Monthly	13.5	5.5	17	8.5	14	6.5	22.5	6	4	9.5	27	6
Fecal Coliform (CFU/100 ml) Geometric Mean	3	35	800	25	10	251	< 1	< 1	< 1	< 1	17	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	80	1200	1600	40	100	450	< 1	< 1	< 1	< 1	300	< 1
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	3.7	< 0.1	< 0.1	< 0.1	7.5	< 0.10
Total Phosphorus (lbs/day) Average Monthly	0.001	0.001	0.002	0.001	0.004	0.005	0.010	0.003	0.007	0.011	0.006	0.0073
Total Phosphorus (mg/L) Average Monthly	0.1	0.04	0.1	0.1	0.1	0.18	0.3	0.1	0.1	0.2	0.3	0.4

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.014</u>
<b>Latitude</b> <u>40° 26' 18.20"</u>	<b>Longitude</b> <u>-75° 37' 27.72"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

*Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>):*

The attached computer printout of the WQM 7.0 stream model indicates that a monthly average limit of 25 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing limits of 25 mg/L average monthly (AML), and 50 mg/L instantaneous maximum will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

*Ammonia (NH<sub>3</sub>-N):*

NH<sub>3</sub>-N calculations were first based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH<sub>3</sub>-N criteria used in the attached computer model of the stream:

Discharge pH	=	7.0	(Default)
Discharge Temperature	=	20°C	(Default)
Stream pH	=	7.0	(Default)
Stream Temperature	=	20°C	(Default for CWF)
Background NH <sub>3</sub> -N	=	0	(Default)

The model input data and results are attached. The printout of the WQM 7.0 output indicates that at a discharge of 0.014 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 25.0 mg/L NH<sub>3</sub>-N as a monthly average and 50.0 mg/L NH<sub>3</sub>-N instantaneous maximum are necessary to protect the aquatic life from toxicity effects. Additionally, past DMRs and inspection reports show that the facility has been consistently achieving concentrations under these limits. These limits will remain in the proposed permit.

*Total Suspended Solids (TSS):*

The existing limits of 30 mg/L average monthly and 60 mg/L instantaneous maximum will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Past DMRs and inspection reports show that the facility has been consistently achieving concentrations under these limits.

*pH:*  
The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa. Code § 95.2(2).

*Dissolved Oxygen (D.O.):*

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

*Fecal Coliform:*

The recent coliform guidance in 25 Pa. Code § 92a.47(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean (average monthly) and not greater than 1,000/100 ml (IMAX) and 25 Pa. Code § 92a.47(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean (average monthly) and not greater than 10,000/100 ml (IMAX), respectively.

*Total Residual Chlorine (TRC):*

Based on the attached TRC Excel Spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), indicated monthly average limit of 0.5 mg/L and an instantaneous maximum limit of 1.64 mg/L. Based on the DMRs from the past year, the facility has been consistently achieving these limits. Therefore, these limits will remain in the proposed permit.

*Stormwater:*

There is no known stormwater outfall associated with this facility.

*Chesapeake Bay Strategy:*

Since the WWTP does not discharge to the Chesapeake Bay, the Chesapeake Bay requirements do not apply.

*Toxic:*

This is a minor sewage facility receiving domestic wastewater only and the current application does not require sampling of toxic pollutants (or heavy metals) for those facilities with design flows less than 0.1 MGD. Therefore, no reasonable potential analysis for toxic pollutants has been performed for this permit renewal.

*Green Lane Reservoir TMDL (Total Phosphorus):*

EPA has approved a TMDL for Green Lane reservoir on March 13, 2003. Green Lane is located downstream of the Woodland MHP discharge. The TMDL requires all dischargers to achieve a 0.5 mg/L phosphorus limit and an average monthly load of 0.059 pounds per day and a cumulative monthly load of 1.75 lbs./day waste load allocation (WLA) for the Woodland MHP discharge (Table 4-5, Individual Wasteload allocations of total phosphorus for Green Lane reservoir, page 4-12, March 2003). However, the existing limits of 0.5 mg/L and 1.0 mg/L will remain in the proposed permit due to anti-backsliding requirements. Additionally, past DMRs and inspection reports show that the facility has been consistently achieving concentrations under these limits.

*Biosolids Management:*

Approximately, 1,300 gallons of activated sludge is wasted from the biological treatment process on a monthly basis to a sludge holding tank. Following storage in the sludge holding tank, the biosolids are disposed of at Hereford Estates Mobile Home Park in Hereford Township, PA (DEP Permit No. 0041505) or at the Pottstown Borough WWTP in Pottstown, PA (DEP Permit No. 0026786).

*Antidegradation (93.4):*

A Protection Report from 2003 indicates that the receiving stream is classified as a Cold-Water Fishery; however, the current classification is Exceptional Value (EV). The current discharge limits do not reflect Exceptional Value discharge criteria, due to the WWTP being "grandfathered" as an existing discharge. The discharge to an EV stream is justified, since the outfall pre-dates the EV classification of the stream.

*Class A Wild Trout Fisheries:*

No Class A Wild Trout Fisheries are impacted by this discharge.

*303d Listed Streams:*

The discharge is not located on a 303d listed stream segment.

**Anti-Backsliding**

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as existing permit requirements in accordance with 40 CFR §122.44(l)(1).

**WQM 7.0 model inputs**

Node 1: Discharge point at West Branch Perkiomen Creek  
Elevation: 675.28 ft (USGS National Map Viewer)  
Drainage Area: 4.92 mi.<sup>2</sup> (USGS PA StreamStats)  
River Mile Index: 12.0 miles (PA DEP eMapPA)  
Low Flow Yield: 0.13 cfs/mi.<sup>2</sup>  
Discharge Flow: 0.014 MGD (NPDES PA0055352)

Node 2: Just before Trib. 01455 to West Branch Perkiomen Creek  
Elevation: 613.77 ft (USGS National Map Viewer)  
Drainage Area: 5.29 mi.<sup>2</sup> (USGS PA StreamStats)  
River Mile Index: 11.4 miles (PA DEP eMapPA)  
Low Flow Yield: 0.13 cfs/mi.<sup>2</sup>  
Discharge Flow: 0.00 MGD

WQM 7.0 data is attachment.



Berks Properties  
WQM Data.pdf

TRC results

<b>TRC EVALUATION</b>				
Input appropriate values in A3:A9 and D3:D9				
0.64	= Q stream (cfs)	0.5	= CV Daily	
0.014	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 9.446		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 3.520		5.1d
				WLA_cfc = 9.201
				LTAMULT_cfc = 0.581
				LTA_cfc = 5.349
Source	Reference	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635		
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)			



**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly		Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	XXX	1.64	1/day	Grab
CBOD <sub>5</sub>	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	20	XXX	40	2/month	8-Hr Composite
Total Phosphorus	0.059	XXX	XXX	0.5	XXX	1.0	2/month	8-Hr Composite

<b>Proposed Effluent Limitations and Monitoring Requirements</b>
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.64	1/day	Grab
CBOD <sub>5</sub>	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Ammonia	XXX	XXX	XXX	20.0	XXX	40.0	2/month	8-Hr Composite
Total Phosphorus	0.059	XXX	XXX	0.5	XXX	1.0	2/month	8-Hr Composite

Compliance Sampling Location:

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]