



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

**PA0058572**

APS ID

**1110915**

Authorization ID

**1479508**

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

|                           |   |                  |                              |
|---------------------------|---|------------------|------------------------------|
| Applicant Name            | <u>Aqua Pennsylvania Wastewater, Inc.</u> | Facility Name    | <u>Penn Township WWTP</u>    |
| Applicant Address         | <u>762 W Lancaster Avenue</u>             | Facility Address | <u>1017 W Baltimore Pike</u> |
|                           | <u>Bryn Mawr, PA 19010-3402</u>           |                  | <u>West Grove, PA 19390</u>  |
| Applicant Contact         | <u>Todd Duerr</u>                         | Facility Contact | <u>Kyle Roberts</u>          |
| Applicant Phone           | <u>(610) 645-4204</u>                     | Facility Phone   | <u>(610) 520-6384</u>        |
| Client ID                 | <u>62614</u>                              | Site ID          | <u>543466</u>                |
| Ch 94 Load Status         | <u>Not Overloaded</u>                     | Municipality     | <u>Penn Township</u>         |
| Connection Status         | <u>No Limitations</u>                     | County           | <u>Chester</u>               |
| Date Application Received | <u>April 2, 2024</u>                      | EPA Waived?      | <u>Yes</u>                   |
| Date Application Accepted | <u>May 8, 2024</u>                        | If No, Reason    |                              |
| Purpose of Application    | <u>NPDES permit renewal application.</u>  |                  |                              |

**Summary of Review**

The Pa Department of Environmental Protection (PADEP/Department) received an NPDES permit renewal application from Aqua Pennsylvania Wastewater, Inc. (permittee) on April 2, 2024 for Permittee's Penn Township STP (facility). This is a minor sewage facility with a design flow of 0.35 MGD that discharges into an UNT to E. Br. Big Elk Creek (HQ-TSF, MF) in state watershed 7-K. The current permit expired on September 30, 2024. The terms and conditions of the current permit is automatically extended since the renewal application was received at least 180 days prior to expiration date. Renewal NPDES permit application under Clean Water Program are not covered by PADEP's PDG per 021-2100-001. This fact sheet is developed in accordance with 40 CFR §124.56.

Changes to existing permit: Added: Total Zinc, E. Coli.

Sludge use and disposal description and location(s): Digested sludge are hauled-off by licensed hauler.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures   | Date              |
|---------|------|--|-------------------|
| ✓       |      | Reza H. Chowdhury, E.I.T. / Project Manager                            | November 19, 2024 |
| X       |      | Pravin Patel<br>Pravin C. Patel, P.E. / Environmental Engineer Manager | 11/19/2024        |

| Discharge, Receiving Waters and Water Supply Information |  |   |                 |
|--|--|---|-----------------|
| Outfall No.  | 001  | Design Flow (MGD)   | .39             |
| Latitude   | 39° 49' 37.35"   | Longitude   | -75° 53' 21.46" |
| Quad Name  | Oxford   | Quad Code   | 2038            |
| Wastewater Description:                                  | Sewage Effluent  |   |                 |
| Receiving Waters   | Unnamed Tributary of East Branch<br>Big Elk Creek (HQ-TSF, MF)   | Stream Code   | 06751           |
| NHD Com ID   | 112188662  | RMI   | 0.62            |
| Drainage Area  | 0.51 mi <sup>2</sup>   | Yield (cfs/mi <sup>2</sup> )  | 0.1             |
| Q <sub>7-10</sub> Flow (cfs)                             | 0.051  | Q <sub>7-10</sub> Basis   | StreamStats     |
| Elevation (ft)   | 458.99   | Slope (ft/ft)   |                 |
| Watershed No.  | 7-K  | Chapter 93 Class.   | HQ-TSF, MF      |
| Existing Use   |  | Existing Use Qualifier  |                 |
| Exceptions to Use  |  | Exceptions to Criteria  |                 |
| Assessment Status  | Impaired   | ORGANIC ENRICHMENT, ORGANIC ENRICHMENT, ORGANIC ENRICHMENT,<br>ORGANIC ENRICHMENT |                 |
| Cause(s) of Impairment                                   | GRAZING IN RIPARIAN OR SHORELINE ZONES, GRAZING IN RIPARIAN OR<br>SHORELINE ZONES, GRAZING IN RIPARIAN OR SHORELINE ZONES, GRAZING IN<br>RIPARIAN OR SHORELINE ZONES |   |                 |
| Source(s) of Impairment                                  |  |   |                 |
| TMDL Status  | Name _____   |   |                 |
| Background/Ambient Data                                  |  | Data Source   |                 |
| pH (SU)  | 7.0  | Default   |                 |
| Temperature (°C)   | 20   | Default   |                 |
| Hardness (mg/L)  | 100  | Default   |                 |
| Other:   |  |   |                 |
| Nearest Downstream Public Water Supply Intake            | None before PA-MD border   |   |                 |

Changes Since Last Permit Issuance: WQM permit 1501401 was amended on March 21, 2022 to approve installation of 2 final clarifiers and associated sludge pumping facilities at the facility's BESS system. This was a part of first phase of modifications at the facility.

**Other Comments:**

**Streamflow:**

The USGS's web based watershed delineation tool StreamStats (accessible at <https://streamstats.usgs.gov/ss/>, accessed on November 13, 2024) was utilized to determine the drainage area at discharge point. The drainage area at Outfall 001 was found to be 0.51 mi<sup>2</sup>. A default yield of 0.1 cfs/mi<sup>2</sup> will be utilized to calculate the Q<sub>7-10</sub> at the outfall 001.

Q<sub>7-10</sub> at Outfall 001: 0.51\*0.1 or 0.051 cfs.

Default Q<sub>1-10</sub>:Q<sub>30-10</sub> of 0.64 and default Q<sub>30-10</sub>:Q<sub>7-10</sub> of 1.36 (per 391-2000-007) will be used for modeling.

**PWS Intake:**

There's no downstream PWS intake before PA-MD border.

**Wastewater Characteristics:**

Default pH of 7.0, default discharge temperature of 25°C, and default hardness of 100 mg/l will be used for modeling.

**Background data:**

Default pH of 7.0, default temperature of 20°C, and default hardness of 100 mg/l will be used for modeling, as appropriate.

**Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The receiving streams are designated as High-Quality Trout Stocking (HQ-TSF) and Migratory Fishes (MF.) The ABACT limits was considered during the development of final effluent limits.

**Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.

| Treatment Facility Summary                         |   |                                 |                            |                               |
|--|---|---------------------------------|----------------------------|-------------------------------|
| <b>Treatment Facility Name:</b> Penn Township WWTP |   |                                 |                            |                               |
| <b>WQM Permit No.</b>                              | <b>Issuance Date</b>                    |                                 |                            |                               |
| 1501401 A-1  | 3/21/2022                               |                                 |                            |                               |
| 1501401  | 01/07/2020                              |                                 |                            |                               |
| <b>Waste Type</b>                                  | <b>Degree of Treatment</b>              | <b>Process Type</b>             | <b>Disinfection</b>        | <b>Avg Annual Flow (MGD)</b>  |
| Sewage   | Secondary With Total Nitrogen Reduction | Sequencing Batch Reactor, BESTT | Ultraviolet                | 0.35                          |
| <b>Hydraulic Capacity (MGD)</b>                    | <b>Organic Capacity (lbs/day)</b>       | <b>Load Status</b>              | <b>Biosolids Treatment</b> | <b>Biosolids Use/Disposal</b> |
| 0.429  | 976                                     | Not Overloaded                  | Aerobic Digestion          | Other WWTP                    |

**Treatment Plant Description**

The wastewater treatment facility (WWTF), as currently constructed, incorporates two different biologic wastewater treatment processes; Sequencing Batch Reactor (SBR) and Biologically Engineered Single Sludge Treatment (BESST®). Both treatment processes are products of Purestream®, Walton, KY.

The treatment processes consists of: two prefabricated steel sequencing batch reactor (SBR) each having a rated capacity of 0.125 MGD, two cast-in-place concrete Biologically Engineered Single Sludge Treatment (BESST®) each having a rated capacity of 0.175 MGD, a Lakeside Rotomat® screen with parallel by-pass bar screen, a variable speed BESSAT® system effluent pump station, a decant equalization/re-aeration tank, two alternating ultraviolet (UV) disinfection units, an effluent pump station with a meter to measure the total flow from the wastewater treatment plant, and immediately downstream for the effluent pump station is a flow diversion valve pit employed to direct treated effluent to either the four (4) existing RIBs or to the Conard-Pyle storage pond.

There are two (2) prefabricated steel SBRs, each having a rated capacity of 0.125 MGD, which operate in parallel and two (2) cast-in-place concrete BESST® systems, each having a rated capacity of 0.175 MGD, set back to back which also operate in parallel. The total treatment capacity associated with these four (4) treatment units is therefore 0.600 MGD.


The current permit limits overall system capacity to 0.390 MGD to be treated at the facility, however, the discharge flow to the stream is limited to 0.35 MGD. The current WQM Permit provides for up to 0.390 MGD of reclamation capacity. However, Aqua has the option of directing the entire amount to the Conard-Pyle facility or some to the Conrad-Pyle and some to the existing Rapid Infiltration Basins (RIBs). The permitted maximum organic load is 976 lbs./day. Due to various operational considerations, both the BESST® system (both treatment units) and SBRs (one of the two systems) have been used throughout the year. Use of both systems and three of the four treatment trains ensures that all components are functioning properly and exercised routinely.

In addition to the biological treatment units, the WWTF includes: a Lakeside Rotomat® screen with parallel by-pass bar screen; a variable speed BESSAT® system, effluent pump station; a decant equalization/re-aeration tank; two (2) alternating ultraviolet (UV) disinfection units; and an effluent pump station with a meter to measure the total flow from the WWTF.

Immediately downstream of the effluent pump station is a flow diversion valve pit. This valve is employed to direct treated effluent to either the four (4) existing RIBs or to the 12.7 MG treated effluent storage pond on the Conard-Pyle property; the effective storage capacity is 9.1 MG. Currently all flow is directed to Conard-Pyle where it is used to irrigate potted plants.

The storage pond will overflow via an outlet structure to a smaller on-stream pond that was used by Conard-Pyle for irrigation. This discharge from the pond is to an unnamed tributary of East Branch Big Elk Creek, a HQ-TSF stream in the Chesapeake Bay watershed.

Process flow diagram



The agreement to discharge into Conard-Pyle property will expire on October 19, 2026 and the permittee was issued a PTR on April 23, 2024 with limits developed to discharge all of the treated effluent to the UNT to East Branch Big Elk Creek. The receiving stream is special protection water for being HQ and a Chesapeake Bay watershed. The PTR provided limits that were developed to maintain the existing stream quality and non-degrading. The discharge flow is below CB's significant discharger cutoff of 0.4 MGD and no Cap loads were assigned to this facility. However, TN and TP mass limits were proposed in the PTR as a non-degrading measure. The permittee will be required to amend the NPDES permit in the future if they plan to discharge the treated effluent directly to the stream.

The facility uses the following wastewater treatment chemicals:

| Wastewater Treatment Chemical | Purpose                          | Maximum Usage Rate | Units    |
|-------------------------------|----------------------------------|--------------------|----------|
| Polyaluminum Chloride         | Coagulant - Phosphorus Reduction | 48                 | gal/day  |
| Sodium Bicarbonate            | Alkalinity Adjustment            | 200                | lbs/week |
| Sodium Hypochlorite           | Cleaning                         | 32                 | oz/week  |

**Biosolids management:**

The digested biosolids are hauled-off site by HydroTech Environmental, LLC for further processing and disposal.

Compliance History

DMR Data for Outfall 001 (from October 1, 2023 to September 30, 2024)

| Parameter           | SEP-24  | AUG-24 | JUL-24 | JUN-24 | MAY-24 | APR-24 | MAR-24 | FEB-24 | JAN-24 | DEC-23 | NOV-23 | OCT-23 |
|---------------------|---------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD)          |         |        |        |        |        |        |        |        |        |        |        |        |
| Average Monthly     | 0.1833  | 0.2003 | 0.1893 | 0.1952 | 0.2115 | 0.2449 | 0.2353 | 0.2173 | 0.2303 | 0.2213 | 0.1935 | 0.1660 |
| pH (S.U.) IMIN      | 7.3     | 7.2    | 7.3    | 7.2    | 7.2    | 7.2    | 7.1    | 7.2    | 7.1    | 7.1    | 7.3    | 7.1    |
| pH (S.U.) IMAX      | 8.0     | 8.0    | 7.8    | 8.0    | 7.7    | 7.7    | 8.0    | 8.0    | 7.7    | 7.8    | 7.9    | 7.9    |
| DO (mg/L) IMIN      | 7.2     | 7.0    | 6.6    | 7.0    | 7.6    | 8.9    | 7.5    | 8.4    | 8.2    | 9.0    | 8.5    | 7.6    |
| CBOD5 (lbs/day)     |         |        |        |        |        |        |        |        |        |        |        |        |
| Average Monthly     | < 3.4   | < 4    | < 3.3  | < 3.3  | < 3.8  | < 4.4  | < 4.0  | < 3.7  | < 4.7  | < 4.4  | < 4.1  | < 3.0  |
| CBOD5 (lbs/day)     |         |        |        |        |        |        |        |        |        |        |        |        |
| Raw Sewage Influent |         |        |        |        |        |        |        |        |        |        |        |        |
| Average Monthly     | 694.87  | 589    | 508    | 763    | 690    | 652    | 536    | 604    | 561    | 552    | 375    | 316    |
| CBOD5 (lbs/day)     |         |        |        |        |        |        |        |        |        |        |        |        |
| Raw Sewage Influent |         |        |        |        |        |        |        |        |        |        |        |        |
| Daily Maximum       | 907.47  | 787    | 588    | 974    | 1255   | 1087   | 613    | 910    | 734    | 634    | 573    | 400    |
| CBOD5 (mg/L)        |         |        |        |        |        |        |        |        |        |        |        |        |
| Average Monthly     | < 2     | < 2    | < 2    | < 2    | < 2    | < 2    | < 2    | < 2    | < 2    | < 2.28 | < 3    | < 2    |
| CBOD5 (mg/L)        |         |        |        |        |        |        |        |        |        |        |        |        |
| Raw Sewage Influent |         |        |        |        |        |        |        |        |        |        |        |        |
| Average Monthly     | 311.25  | 237    | 235    | 342    | 266    | 204    | 192    | 241    | 254    | 258    | 261    | 198    |
| BOD5 (lbs/day)      |         |        |        |        |        |        |        |        |        |        |        |        |
| Raw Sewage Influent |         |        |        |        |        |        |        |        |        |        |        |        |
| Average Monthly     | 862.99  | 762    | 586    | 841    | 742    | 906    | 924    | 768    | 678    | 697    | 409    | 389    |
| BOD5 (lbs/day)      |         |        |        |        |        |        |        |        |        |        |        |        |
| Raw Sewage Influent |         |        |        |        |        |        |        |        |        |        |        |        |
| Daily Maximum       | 1001.96 | 902    | 607    | 1111   | 1257   | 1307   | 1352   | 938    | 1192   | 914    | 591    | 413    |
| BOD5 (mg/L)         |         |        |        |        |        |        |        |        |        |        |        |        |
| Raw Sewage Influent |         |        |        |        |        |        |        |        |        |        |        |        |
| Average Monthly     | 382.50  | 315    | 273    | 376    | 287    | 291    | 327    | 305    | 319    | 313    | 281    | 244    |
| TSS (lbs/day)       |         |        |        |        |        |        |        |        |        |        |        |        |
| Average Monthly     | 4.0     | < 2    | < 2.6  | < 2.6  | 3.5    | < 2.2  | < 2.2  | < 2.0  | 2.9    | < 1.2  | 2.9    | < 1.6  |
| TSS (lbs/day)       |         |        |        |        |        |        |        |        |        |        |        |        |
| Raw Sewage Influent |         |        |        |        |        |        |        |        |        |        |        |        |
| Average Monthly     | 787.12  | 735    | 501    | 473    | 591    | 745    | 968    | 577    | 509    | 576    | 382    | 457    |
| TSS (lbs/day)       |         |        |        |        |        |        |        |        |        |        |        |        |
| Raw Sewage Influent |         |        |        |        |        |        |        |        |        |        |        |        |
| Daily Maximum       | 1058.54 | 1060   | 682    | 529    | 736    | 863    | 1398   | 1053   | 769    | 884    | 646    | 570    |
| TSS (mg/L)          |         |        |        |        |        |        |        |        |        |        |        |        |
| Average Monthly     | 2       | < 1    | < 2    | < 2    | 2      | < 1    | < 1    | < 1.1  | 1.28   | < 1    | 2      | < 1    |

NPDES Permit Fact Sheet  
Penn Township WWTP

NPDES Permit No. PA0058572

|  |          |        |         |          |          |          |         |          |          |          |          |          |
|--|----------|--------|---------|----------|----------|----------|---------|----------|----------|----------|----------|----------|
| TSS (mg/L)<br>Raw Sewage Influent<br>Average Monthly | 341.00   | 298    | 232     | 210      | 230      | 248      | 344     | 223      | 247      | 258      | 279      | 285      |
| Fecal Coliform<br>(CFU/100 ml)<br>Geometric Mean     | < 5      | < 1    | < 2     | < 1      | < 1      | < 1      | < 4     | 12       | < 6      | < 5      | 5        | 3        |
| Fecal Coliform<br>(CFU/100 ml) IMAX                  | 58       | 3      | 10      | 1        | < 1      | 1        | 41      | 75       | 24       | 76       | 96       | 13       |
| UV Transmittance (%)<br>Minimum                      | 73.5     | 77.0   | 75.3    | 71.7     | 73.9     | 73.4     | 75.4    | 78.0     | 78.5     | 76.8     | 74.5     | 71.8     |
| Nitrate-Nitrite (mg/L)<br>Average Monthly            | 8.41     | < 4.52 | < 4.26  | < 4.87   | < 4.17   | < 5.63   | 4.71    | < 4.76   | 5.42     | < 6.48   | < 7.14   | < 6.68   |
| Nitrate-Nitrite (lbs)<br>Total Monthly               | 426      | < 255  | 218.34  | < 237.84 | < 240.56 | < 362.11 | 289.82  | < 258.65 | 410.48   | < 390.52 | 349.07   | < 304.72 |
| Total Nitrogen (mg/L)<br>Average Monthly             | < 9.27   | < 5.44 | < 5.02  | < 5.79   | < 5.04   | < 6.75   | 6.06    | < 6.38   | < 6.42   | < 7.44   | < 8.15   | < 7.44   |
| Total Nitrogen (lbs)<br>Total Monthly                | < 469.45 | < 307  | 258.24  | < 282.93 | < 290.96 | < 434.73 | 377.5   | < 345.22 | < 473.84 | < 449.56 | < 398.79 | < 339.70 |
| Ammonia (lbs/day)<br>Average Monthly                 | < 0.8    | < 0.9  | < 0.8   | < 0.8    | < 0.9    | < 1.1    | < 1.7   | < 1.0    | < 1.1    | < 1.0    | < 0.8    | < 0.7    |
| Ammonia (mg/L)<br>Average Monthly                    | < 0.5    | < 0.5  | < 0.5   | < 0.5    | < 0.5    | < 0.5    | < 0.8   | < 0.6    | < 0.5    | < 0.5    | < 0.5    | < 0.5    |
| Ammonia (lbs)<br>Total Monthly                       | < 25.27  | < 28   | < 25.65 | < 24.42  | < 29.07  | < 33.17  | < 51.88 | < 30.30  | < 34.92  | < 30.54  | < 24.4   | < 22.82  |
| TKN (mg/L)<br>Average Monthly                        | 0.86     | 0.93   | < 0.76  | < 0.92   | < 0.88   | 1.12     | 1.36    | 1.62     | 1.00     | 0.97     | 1.01     | 0.76     |
| TKN (lbs)<br>Total Monthly                           | 43       | 52     | < 39.9  | < 45.08  | < 50.71  | 72.62    | 87.68   | 86.57    | 63.36    | 59.04    | 49.72    | 34.98    |
| Total Phosphorus<br>(lbs./day)<br>Average Monthly    | 1.0      | 0.4    | 0.4     | 0.5      | 0.7      | 0.5      | 0.2     | 0.2      | 0.3      | 0.2      | 0.1      | < 0.1    |
| Total Phosphorus<br>(mg/L)<br>Average Monthly        | 0.6      | 0.2    | 0.2     | 0.3      | 0.4      | 0.3      | 0.1     | 0.1      | 0.1      | 0.1      | 0.1      | < 0.1    |
| Total Phosphorus<br>(lbs.)<br>Total Monthly          | 29.96    | 12     | 11.84   | 15.57    | 21.45    | 15.21    | 6.06    | 6.01     | 8.55     | 4.94     | 4.28     | < 2.52   |

**Facility inspection summary:**

04/25/2024: CEI conducted. No violation noted.  
05/31/2023: CEI conducted. No violation noted.  
06/15/2022: CEI conducted. No violation noted.

Existing Limits

The following limits were applied for Outfall 001 for the permit term October 1, 2019 through September 30, 2024:

| Parameter   | Effluent Limitations                |               |                       |                 |         |                  | Monitoring Requirements                         |                      |
|---|-------------------------------------|---------------|-----------------------|-----------------|---------|------------------|---|----------------------|
|   | Mass Units (lbs/day) <sup>(1)</sup> |               | Concentrations (mg/L) |                 |         |                  | Minimum <sup>(2)</sup><br>Measurement Frequency | Required Sample Type |
|   | Average Monthly                     | Daily Maximum | Minimum               | Average Monthly | Maximum | Instant. Maximum |   |                      |
| Flow (MGD)  | Report                              | XXX           | XXX                   | XXX             | XXX     | XXX              | Continuous                                      | Recorded             |
| pH (S.U.)   | XXX                                 | XXX           | 6.0<br>Inst Min       | XXX             | XXX     | 9.0              | 1/day   | Grab                 |
| Dissolved Oxygen  | XXX                                 | XXX           | 6.0<br>Inst Min       | XXX             | XXX     | XXX              | 1/day   | Grab                 |
| Carbonaceous Biochemical Oxygen Demand (CBOD5)<br>Raw Sewage Influent | Report                              | Report        | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |
| Carbonaceous Biochemical Oxygen Demand (CBOD5)                        | 29.2                                | XXX           | XXX                   | 10              | XXX     | 20               | 1/week  | 24-Hr Composite      |
| Biochemical Oxygen Demand (BOD5)<br>Raw Sewage Influent               | Report                              | Report        | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |
| Total Suspended Solids  | 29.2                                | XXX           | XXX                   | 10              | XXX     | 20               | 1/week  | 24-Hr Composite      |
| Total Suspended Solids<br>Raw Sewage Influent                         | Report                              | Report        | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |
| Fecal Coliform (CFU/100 ml)   | XXX                                 | XXX           | XXX                   | 200<br>Geo Mean | XXX     | 1000             | 1/week  | Grab                 |
| Ultraviolet light transmittance (%)                                   | XXX                                 | XXX           | Report                | XXX             | XXX     | XXX              | 1/day   | Measured             |
| Ammonia-Nitrogen<br>Nov 1 - Apr 30                                    | 13.1                                | XXX           | XXX                   | 4.5             | XXX     | 9                | 1/week  | 24-Hr Composite      |
| Ammonia-Nitrogen<br>May 1 - Oct 31                                    | 4.4                                 | XXX           | XXX                   | 1.5             | XXX     | 3                | 1/week  | 24-Hr Composite      |
| Total Phosphorus  | 2.9                                 | XXX           | XXX                   | 1.0             | XXX     | 2                | 1/week  | 24-Hr Composite      |

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 39° 49' 38.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .35  
Longitude -75° 53' 21.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant                    | Limit (mg/l)    | SBC             | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD <sub>5</sub>            | 25              | Average Monthly | 133.102(a)(4)(i)   | 92a.47(a)(1)     |
|                              | 40              | Average Weekly  | 133.102(a)(4)(ii)  | 92a.47(a)(2)     |
| Total Suspended Solids       | 30              | Average Monthly | 133.102(b)(1)      | 92a.47(a)(1)     |
|                              | 45              | Average Weekly  | 133.102(b)(2)      | 92a.47(a)(2)     |
| pH                           | 6.0 – 9.0 S.U.  | Min – Max       | 133.102(c)         | 95.2(1)          |
| Fecal Coliform (5/1 – 9/30)  | 200 / 100 ml    | Geo Mean        | -                  | 92a.47(a)(4)     |
| Fecal Coliform (5/1 – 9/30)  | 1,000 / 100 ml  | IMAX            | -                  | 92a.47(a)(4)     |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml  | Geo Mean        | -                  | 92a.47(a)(5)     |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX            | -                  | 92a.47(a)(5)     |
| Total Residual Chlorine      | 0.5             | Average Monthly | -                  | 92a.48(b)(2)     |

**ABACT Limitations**

Since the receiving stream is a special protection water, ABACT limits were considered. The following table summarizes the ABACT limitations:

| Parameter                             | Treatment Process Performance Expectations (mg/l)   |     |     |
|---------------------------------------|---|-----|-----|
|                                       | <u>2,000 to</u><br><u>&lt;2,000      50,000 gpd      &gt;50,000</u>   |     |     |
| CBOD <sub>5</sub> (May 1, - Oct. 31)  | 10  | 10  | 10  |
| CBOD <sub>5</sub> (Nov. 1, - Apr. 30) | 20  | 20  | 10  |
| Suspended Solids                      | 20  | 10  | 10  |
| NH <sub>3</sub> -N (May 1 - Oct. 31)  | 5.0   | 3.0 | 1.5 |
| NH <sub>3</sub> -N (Nov. 1 - Apr. 30) | 15.0  | 9.0 | 4.5 |
| Effective Disinfection                | - - - See footnote below - - - *  |     |     |
| Other Parameters as needed            | - - - Determined by the size and characteristics<br>of the proposed discharge, may include -<br>NO <sub>2</sub> /NO <sub>3</sub> -N, Total Phosphorus, Copper, Lead, Zinc - - - |     |     |

\* Disinfection should be accomplished using a method that leaves no detectable residual. Disinfection using ultra-violet light or other non-chlorine based systems is encouraged and must be considered.

**1997 Dry Stream Limits:**

The Q7-10 at the discharge point is 0.051 cfs and the average annual design flow is 0.35 MGD or 0.54 cfs. The Q7-10:discharge ratio is 0.051:0.54 or 0.094:1, much lower than threshold 3:1. Therefore, the discharge is considered into a dry stream. Since the facility was permitted in 2001 and constructed in 2002, the 1997 dry stream guidance (391-2000-

014) limits were applicable, not the updated 2008 dry stream guidance. The 2008 guidance may be applicable if the facility wants to expand in the future. The 1997 limits are as follows:

b. The ‘minimum treatment’ requirements for a discharge into this type of a drainage ditch are:

|               |  |
|---------------|--|
| BOD and TSS - | 10 mg/l as a monthly average<br>20 mg/l as an instantaneous maximum  |
| NH3 - N -     | 3 mg/l as a monthly average number   |
| D.O. -        | 3 mg/l or greater, as a monthly average  |
| Bacteria -    | (1) For the summertime, provide effective disinfection as described in Sections 95.2 and 95.7 in the Rules and Regulations<br><br>(2) For the remainder of the year, provide effective wintertime disinfection in the ditch at the point of discharge in accordance with $Bac_1$ , in Section 93.7 in the Rules and Regulations. |

### **Mass-Based Limits**

The federal regulation at 40 CFR 122.45(f) requires that effluent limits be expressed in terms of mass, if possible. The regulation at 40 CFR 122.45(b) requires that effluent limitations for POTWs be calculated based on the design flow of the facility. The mass-based limits are expressed in pounds per day and are calculated as follows:

Mass based limit (lb/day) = concentration limit (mg/L)  $\times$  design flow (mgd)  $\times$  8.34

### **Water Quality-Based Limitations**

#### **Model input data**

The following data will be used for modeling, as needed:

|                         |          |           |
|-------------------------|----------|-----------|
| • Discharge pH          | 7.0      | (Default) |
| • Discharge Temperature | 25°C     | (Default) |
| • Discharge Hardness    | 100 mg/l | (Default) |
| • Stream pH             | 7.0      | (Default) |
| • Stream Temperature    | 20.0°C   | (Default) |
| • Stream Hardness       | 100 mg/l | (Default) |

The following two nodes were used in modeling:

Node 1: At the outfall 001 on UNT to East Branch Big Elk Creek (06751)  
Elevation: 458.99 ft (National Map-Advanced Viewer, 11/13/2024)  
Drainage Area: 0.51 mi<sup>2</sup> (StreamStat Version 3.0, 11/13/2024)  
River Mile Index: 0.62 (PA DEP eMapPA)  
Low Flow Yield: 0.1 cfs/mi<sup>2</sup>  
Q<sub>7-10</sub>: 0.051 cfs  
Discharge Flow: 0.35 MGD

Node 2: At confluence with UNT 06750  
Elevation: 422.9 ft (National Map-Advanced Viewer, 11/13/2024)  
Drainage Area: 2.47 mi<sup>2</sup> (StreamStat Version 3.0, 11/13/2024)  
River Mile Index: 0.0 (PA DEP eMapPA)  
Low Flow Yield: 0.1 cfs/mi<sup>2</sup>  
Discharge Flow: 0.0 MGD

### **WQM 7.0 Model**

WQM 7.0 version 1.11 is a water quality model designed to assist DEP to determine appropriate effluent limits for CBOD<sub>5</sub>, NH<sub>3</sub>-N and DO. The model simulates two basic processes. In the NH<sub>3</sub>-N module, the model simulates the mixing and degradation of NH<sub>3</sub>-N in the stream and compares calculated instream NH<sub>3</sub>-N concentrations to NH<sub>3</sub>-N water

quality criteria. In the D.O. module, the model simulates the mixing and consumption of D.O. in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>N and compares calculated instream D.O. concentrations to D.O. water quality criteria. The model was utilized for this permit renewal by using Q<sub>7-10</sub> and current background water quality levels of the stream.

**NH<sub>3</sub>-N**

WQM 7.0 suggested NH<sub>3</sub>-N limit of 1.5 mg/l as monthly average and 3.0 mg/l as IMAX limit during summer to protect water quality standards. The limits are the same as existing permit and will be carried over.

**CBOD5**

WQM 7.0 suggests CBOD5 limit of 10.0 mg/l as AML which is the same as existing limit. Existing AML, MDL, and IMAX will be carried over, along with their respective mass limits.

**DO**

WQM 7.0 suggests minimum DO of 6.0 mg/l which is the model input and same as existing limit. Existing limit will be carried over.

**General Discussion on Toxics Management Spreadsheet (TMS)**

Based on the available data, PADEP utilizes Toxics Management Spreadsheet (TMS) to (1) evaluate reasonable potential for toxic pollutants to cause or contribute to an excursion above the water quality standards and (2) develop WQBELs for those such toxic pollutants (i.e., 40 CFR § 122.44(d)(1)(i)). It is noteworthy that some of these pollutants that may be reported as “non-detect”, but still exceeded the criteria, were determined to be candidates for modeling because the method detection levels used to analyze those pollutants were higher than target QLs and/or the most stringent Chapter 93 criteria. The model then recommended the appropriate action for the Pollutants of Concerns based on the following logic as stated in PADEP’s SOP titled *“Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants in NPDES Permits for Existing Dischargers (DEP SOP No.: BCW-PMT-037, Revised May 20, 2021”*:

1. In general, establish limits in the draft permit where the effluent concentration determined in B.1 or B.2 equals or exceeds 50% of the WQBEL (i.e., RP is demonstrated). Use the average monthly, maximum daily and instantaneous maximum (IMAX) limits for the permit as recommended by the TMS (or, if appropriate, use a multiplier of 2 times the average monthly limit for the maximum daily limit and 2.5 times the average monthly limit for IMAX).
2. For non-conservative pollutants, in general, establish monitoring requirements where the effluent concentration determined in B.1 or B.2 is between 25% - 50% of the WQBEL.
3. For conservative pollutants, in general, establish monitoring requirements where the effluent concentration determined in B.1 or B.2 is between 10% - 50% of the WQBEL.

**NOTE 4** – If the effluent concentration determined in B.1 or B.2 is “non-detect” at or below the target quantitation limit (TQL) for the pollutant as specified in the TMS and permit application, the pollutant may be eliminated as a candidate for WQBELs or monitoring requirements unless 1) a more sensitive analytical method is available for the pollutant under 40 CFR Part 136 where the quantitation limit for the method is less than the applicable water quality criterion and 2) a detection at the more sensitive method may lead to a determination that an effluent limitation is necessary, considering available dilution at design conditions.

**NOTE 5** – If the effluent concentration determined in B.1 or B.2 is a detection below the TQL but above or equal to the applicable water quality criterion, WQBELs or monitoring may be established for the pollutant.

4. Application managers may, on a site- and pollutant-specific basis, deviate from these guidelines where there is specific rationale that is documented in the fact sheet.

Major sewage facilities are required to sample for pollutants group 1-5, at a minimum, and 6 and/or 7, if applicable. TMDL parameters, as applicable, are also required to be sampled if they aren’t covered in any pollutant groups or by Part A of the permit. Pollutants groups 2-7 are modeled through TMS. The facility is required to provide at least three sample results of the effluent from outfall(s) discharging processed wastewater. The permittee submitted at least three sample results of all pollutants in groups 1-5. Maximum sample results of a given pollutant is the input of the model if the sample size is less than 10. For pollutants with sample size  $\geq 10$ , PADEP utilizes TOXCONC to calculate Average Monthly Effluent Concentration (AMEC) and Coefficient of Variation (CoV) to refine the model input. The statistical methodologies used in this spreadsheet are taken from EPA’s *TSD for Water Quality-based Toxics Control, Appendix E* and are

consistent with PADEP's technical guidance 391-2000-024. The pollutants are modeled through TMS and output from the TMS is provided below:

**Recommended WQBELs & Monitoring Requirements**

No. Samples/Month: 4

| Pollutants | Mass Limits   |               | Concentration Limits |        |        |       | Governing WQBEL | WQBEL Basis | Comments                           |
|------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
|            | AML (lbs/day) | MDL (lbs/day) | AML                  | MDL    | IMAX   | Units |                 |             |                                    |
| Total Zinc | Report        | Report        | Report               | Report | Report | mg/L  | 0.12            | AFC         | Discharge Conc > 10% WQBEL (no RP) |

**Total Zinc:**

TMS model suggests monitoring requirements for Total Zinc from a model input value of 0.029 mg/l. A quarterly monitoring will be added.

**Total Phosphorus:**

The current permit has a Total Phosphorus limit of 1.0 mg/l as ABACT and will be continued.

**Fecal Coliform:**

The current permit has a year-round Fecal Coliform limit of 200 CFU/100 ml and IMAX limit of 1000 CFU/100 ml which will be carried over.

**E. Coli:**

Pa Code 25 § 92a. 61 requires monitoring of E. Coli. DEP's SOP titled "Establishing Effluent Limitations for Individual Sewage Permits (BCW-PMT-033, revised March 24, 2021) recommends quarterly E. Coli monitoring. This requirement will be applied from this permit term.

**pH:**

The TBEL for pH is above 6.0 and below 9.0 S.U. (40 CFR §133.102(c) and Pa Code 25 §§ 95.2(1), 92a.47) which are existing limits and will be carried over.

**Total Suspended Solids (TSS):**

There is no water quality criterion for TSS. The limits of 30 mg/L average monthly, 45 mg/l average weekly, and 60 mg/L instantaneous maximum are the minimum level of effluent quality attainable by secondary treatment, 25 Pa. Code § 92a.47 and 40CFR 133.102(b). However, ABACT and Dry Stream Guidance limits are more stringent. The current permit reflects the ABACT and Dry Stream Guidance limits which will be carried over.

**UV Disinfection:**

PADEP's SOP BCW-PMT-033 recommends UV parameter monitoring where UV is used as a method of disinfection, with the same frequency as would be if Chlorine is used for disinfection. The current permit has UV Transmittance in % reporting requirement which will be carried over in this renewal.

**Total Nitrogen and its constituents:**

PADEP's SOP BCW-PMT-033 recommends monitoring for Total Nitrogen for facilities with design flow more than 2000-GPD, which is also supported by Pa Code 25 Ch. 92a.61. Current permit has monitoring requirements for TN and its constituents which will be carried over.

**Chesapeake Bay Nutrients Monitoring:**

The facility is considered a non-significant Phase 4 CB discharger, based on its flow of 0.35 MGD. The Phase 3 Watershed Implementation Plan (Phase 3 WIP), dated July 29, 2022, details the nutrients monitoring requirements for non-significant facilities. The current permit has monitoring requirements for CB Nutrients and will be carried over.

**Monitoring Frequency and Sample Types:**

Otherwise specified above, the monitoring frequency and sample type of compliance monitoring for existing parameters are recommended by DEP's SOP and Permit Writers Manual and/or on a case-by-case basis using best professional judgment (BPJ).

**Flow and Influent BOD<sub>5</sub> and TSS Monitoring Requirement:**

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii). Influent BOD<sub>5</sub> and TSS monitoring requirements are established in the permit per the requirements set in Pa Code 25 Chapter 94.

**Anti-Backsliding**

Anti-backsliding prohibition is justified in sections where an exception is justified for the affected pollutant(s). For remaining pollutants, this prohibition isn't applicable since the proposed limits are at least as stringent as were in current permit.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

| Parameter                    | Effluent Limitations                |               |                       |                 |         |                  | Monitoring Requirements                         |                      |
|------------------------------|-------------------------------------|---------------|-----------------------|-----------------|---------|------------------|---|----------------------|
|                              | Mass Units (lbs/day) <sup>(1)</sup> |               | Concentrations (mg/L) |                 |         |                  | Minimum <sup>(2)</sup><br>Measurement Frequency | Required Sample Type |
|                              | Average Monthly                     | Daily Maximum | Daily Minimum         | Average Monthly | Maximum | Instant. Maximum |   |                      |
| Flow (MGD)                   | Report                              | XXX           | XXX                   | XXX             | XXX     | XXX              | Continuous                                      | Recorded             |
| pH (S.U.)                    | XXX                                 | XXX           | 6.0<br>Inst Min       | XXX             | XXX     | 9.0              | 1/day   | Grab                 |
| DO                           | XXX                                 | XXX           | 6.0<br>Inst Min       | XXX             | XXX     | XXX              | 1/day   | Grab                 |
| CBOD5                        | 29.2                                | XXX           | XXX                   | 10              | XXX     | 20               | 1/week  | 24-Hr Composite      |
| CBOD5<br>Raw Sewage Influent | Report                              | Report        | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |
| BOD5<br>Raw Sewage Influent  | Report                              | Report        | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |
| TSS<br>Raw Sewage Influent   | Report                              | Report        | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |
| TSS                          | 29.2                                | XXX           | XXX                   | 10              | XXX     | 20               | 1/week  | 24-Hr Composite      |
| Fecal Coliform (No./100 ml)  | XXX                                 | XXX           | XXX                   | 200<br>Geo Mean | XXX     | 1000             | 1/week  | Grab                 |
| E. Coli (No./100 ml)         | XXX                                 | XXX           | XXX                   | XXX             | XXX     | Report           | 1/quarter                                       | Grab                 |
| UV Transmittance (%)         | XXX                                 | XXX           | Report                | XXX             | XXX     | XXX              | 1/day   | Measured             |
| Nitrate-Nitrite              | XXX                                 | XXX           | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |
| Nitrate-Nitrite (lbs)        | Report<br>Total Mo                  | XXX           | XXX                   | XXX             | XXX     | XXX              | 1/month   | Calculation          |
| Total Nitrogen               | XXX                                 | XXX           | XXX                   | Report          | XXX     | XXX              | 1/month   | Calculation          |

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter              | Effluent Limitations                |               |                       |                 |         |                  | Monitoring Requirements                         |                      |
|------------------------|-------------------------------------|---------------|-----------------------|-----------------|---------|------------------|---|----------------------|
|                        | Mass Units (lbs/day) <sup>(1)</sup> |               | Concentrations (mg/L) |                 |         |                  | Minimum <sup>(2)</sup><br>Measurement Frequency | Required Sample Type |
|                        | Average Monthly                     | Daily Maximum | Daily Minimum         | Average Monthly | Maximum | Instant. Maximum |   |                      |
| Total Nitrogen (lbs)   | Report Total Mo                     | XXX           | XXX                   | XXX             | XXX     | XXX              | 1/month   | Calculation          |
| Ammonia Nov 1 - Apr 30 | 13.1                                | XXX           | XXX                   | 4.5             | XXX     | 9                | 1/week  | 24-Hr Composite      |
| Ammonia May 1 - Oct 31 | 4.4                                 | XXX           | XXX                   | 1.5             | XXX     | 3                | 1/week  | 24-Hr Composite      |
| Ammonia (lbs)          | Report Total Mo                     | XXX           | XXX                   | XXX             | XXX     | XXX              | 1/month   | Calculation          |
| TKN                    | XXX                                 | XXX           | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |
| TKN (lbs)              | Report Total Mo                     | XXX           | XXX                   | XXX             | XXX     | XXX              | 1/month   | Calculation          |
| Total Phosphorus       | 2.9                                 | XXX           | XXX                   | 1.0             | XXX     | 2                | 1/week  | 24-Hr Composite      |
| Total Phosphorus (lbs) | Report Total Mo                     | XXX           | XXX                   | XXX             | XXX     | XXX              | 1/month   | Calculation          |

Compliance Sampling Location: At Outfall 001

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

| Parameter            | Effluent Limitations                |        |                       |                 |         |                  | Monitoring Requirements                         |                      |
|----------------------|-------------------------------------|--------|-----------------------|-----------------|---------|------------------|---|----------------------|
|                      | Mass Units (lbs/day) <sup>(1)</sup> |        | Concentrations (mg/L) |                 |         |                  | Minimum <sup>(2)</sup><br>Measurement Frequency | Required Sample Type |
|                      | Monthly                             | Annual | Monthly               | Monthly Average | Maximum | Instant. Maximum |   |                      |
| Ammonia--N           | Report                              | Report | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |
| Kjeldahl--N          | Report                              | XXX    | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |
| Nitrate-Nitrite as N | Report                              | XXX    | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |
| Total Nitrogen       | Report                              | Report | XXX                   | Report          | XXX     | XXX              | 1/month   | Calculation          |
| Total Phosphorus     | Report                              | Report | XXX                   | Report          | XXX     | XXX              | 1/week  | 24-Hr Composite      |

Compliance Sampling Location: At Outfall 001

| Tools and References Used to Develop Permit |  |
|---|--|
| <input checked="" type="checkbox"/>         | WQM for Windows Model (see Attachment [REDACTED])  |
| <input checked="" type="checkbox"/>         | Toxics Management Spreadsheet (see Attachment [REDACTED])  |
| <input type="checkbox"/>                    | TRC Model Spreadsheet (see Attachment [REDACTED])  |
| <input type="checkbox"/>                    | Temperature Model Spreadsheet (see Attachment [REDACTED])  |
| <input type="checkbox"/>                    | Water Quality Toxics Management Strategy, 361-0100-003, 4/06.  |
| <input type="checkbox"/>                    | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.   |
| <input type="checkbox"/>                    | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.  |
| <input type="checkbox"/>                    | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.  |
| <input type="checkbox"/>                    | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.   |
| <input type="checkbox"/>                    | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.  |
| <input type="checkbox"/>                    | Pennsylvania CSO Policy, 386-2000-002, 9/08.   |
| <input checked="" type="checkbox"/>         | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.  |
| <input type="checkbox"/>                    | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.   |
| <input type="checkbox"/>                    | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.  |
| <input type="checkbox"/>                    | Implementation Guidance Design Conditions, 386-2000-007, 9/97.   |
| <input checked="" type="checkbox"/>         | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.  |
| <input type="checkbox"/>                    | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.   |
| <input type="checkbox"/>                    | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.   |
| <input type="checkbox"/>                    | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.  |
| <input type="checkbox"/>                    | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.  |
| <input type="checkbox"/>                    | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.   |
| <input type="checkbox"/>                    | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.   |
| <input type="checkbox"/>                    | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.  |
| <input type="checkbox"/>                    | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.   |
| <input type="checkbox"/>                    | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.       |
| <input type="checkbox"/>                    | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.   |
| <input type="checkbox"/>                    | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input type="checkbox"/>                    | Design Stream Flows, 386-2000-003, 9/98.   |
| <input type="checkbox"/>                    | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.                                     |
| <input type="checkbox"/>                    | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.   |
| <input checked="" type="checkbox"/>         | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.   |
| <input type="checkbox"/>                    | SOP: [REDACTED]  |
| <input type="checkbox"/>                    | Other: [REDACTED]  |


# NPDES Permit Fact Sheet

## NPDES Permit No. PA0058572 Penn Township Sewer System & STP

### StreamStats at Outfall 001

#### StreamStats Report

Region ID: PA  
Workspace ID: PA20241113151548569000  
Clicked Point (Latitude, Longitude): 39.82716, -75.88926  
Time: 2024-11-13 10:16:11 -0500



[Collapse All](#)

#### Basin Characteristics

| Parameter Code | Parameter Description                      | Value   | Unit         |
|----------------|--|---------|--------------|
| BSLOPD         | Mean basin slope measured in degrees       | 2.4493  | degrees      |
| DRNAREA        | Area that drains to a point on a stream    | 0.51    | square miles |
| ROCKDEP        | Depth to rock                              | 5       | feet         |
| URBAN          | Percentage of basin with urban development | 17.8776 | percent      |

#### Low-Flow Statistics

##### Low-Flow Statistics Parameters [Low Flow Region 1]

| Parameter Code | Parameter Name           | Value   | Units        | Min Limit | Max Limit |
|----------------|--------------------------|---------|--------------|-----------|-----------|
| DRNAREA        | Drainage Area            | 0.51    | square miles | 4.78      | 1150      |
| BSLOPD         | Mean Basin Slope degrees | 2.4493  | degrees      | 1.7       | 6.4       |
| ROCKDEP        | Depth to Rock            | 5       | feet         | 4.13      | 5.21      |
| URBAN          | Percent Urban            | 17.8776 | percent      | 0         | 89        |

##### Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

## NPDES Permit Fact Sheet

### NPDES Permit No. PA0058572 Penn Township Sewer System & STP

#### Low-Flow Statistics Flow Report [Low Flow Region 1]

| Statistic               | Value  | Unit               |
|-------------------------|--------|--------------------|
| 7 Day 2 Year Low Flow   | 0.076  | ft <sup>3</sup> /s |
| 30 Day 2 Year Low Flow  | 0.112  | ft <sup>3</sup> /s |
| 7 Day 10 Year Low Flow  | 0.0279 | ft <sup>3</sup> /s |
| 30 Day 10 Year Low Flow | 0.0435 | ft <sup>3</sup> /s |
| 90 Day 10 Year Low Flow | 0.0915 | ft <sup>3</sup> /s |

#### *Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.24.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

# NPDES Permit Fact Sheet

## NPDES Permit No. PA0058572 Penn Township Sewer System & STP

### StreamStats at node 2


#### StreamStats Report at node 2

Region ID: PA

Workspace ID: PA20241113175347173000

Clicked Point (Latitude, Longitude): 39.82947, -75.89725

Time: 2024-11-13 12:54:09 -0500



[Collapse All](#)

#### Basin Characteristics

| Parameter Code | Parameter Description                      | Value  | Unit         |
|----------------|--|--------|--------------|
| BSLOPD         | Mean basin slope measured in degrees       | 2.7125 | degrees      |
| DRNAREA        | Area that drains to a point on a stream    | 2.47   | square miles |
| ROCKDEP        | Depth to rock                              | 5      | feet         |
| URBAN          | Percentage of basin with urban development | 4.5445 | percent      |

#### Low-Flow Statistics

##### Low-Flow Statistics Parameters [Low Flow Region 1]

| Parameter Code | Parameter Name           | Value  | Units        | Min Limit | Max Limit |
|----------------|--------------------------|--------|--------------|-----------|-----------|
| DRNAREA        | Drainage Area            | 2.47   | square miles | 4.78      | 1150      |
| BSLOPD         | Mean Basin Slope degrees | 2.7125 | degrees      | 1.7       | 6.4       |
| ROCKDEP        | Depth to Rock            | 5      | feet         | 4.13      | 5.21      |
| URBAN          | Percent Urban            | 4.5445 | percent      | 0         | 89        |

##### Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

## NPDES Permit Fact Sheet

### NPDES Permit No. PA0058572 Penn Township Sewer System & STP

#### Low-Flow Statistics Flow Report [Low Flow Region 1]

| Statistic               | Value | Unit   |
|-------------------------|-------|--------|
| 7 Day 2 Year Low Flow   | 0.333 | ft^3/s |
| 30 Day 2 Year Low Flow  | 0.477 | ft^3/s |
| 7 Day 10 Year Low Flow  | 0.128 | ft^3/s |
| 30 Day 10 Year Low Flow | 0.191 | ft^3/s |
| 90 Day 10 Year Low Flow | 0.379 | ft^3/s |

#### *Low-Flow Statistics Citations*

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.24.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

# NPDES Permit Fact Sheet

## NPDES Permit No. PA0058572 Penn Township Sewer System & STP

### WQM 7.0

#### Input Data WQM 7.0

| Design Cond.          | LFY<br>(cfsm) | Trib Flow<br>(cfs) | Stream Flow<br>(cfs) | Rch Trav Time<br>(days)  | Rch Velocity<br>(fps) | WD Ratio                  | Rch Width<br>(ft) | Rch Depth<br>(ft)      | Tributary |                   | Stream Temp<br>(°C)      | Stream pH<br>(°C) |      |                                     |
|-----------------------|---------------|--------------------|----------------------|--------------------------|-----------------------|---------------------------|-------------------|------------------------|-----------|-------------------|--------------------------|-------------------|------|-------------------------------------|
|                       |               |                    |                      |                          |                       |                           |                   |                        | RMI       | Elevation<br>(ft) | Drainage Area<br>(sq mi) | Slope<br>(ft/ft)  |      |                                     |
| 07K                   |               |                    |                      |                          |                       |                           |                   |                        | 0.620     | 458.99            | 0.51                     | 0.00000           | 0.00 | <input checked="" type="checkbox"/> |
| <b>Stream Data</b>    |               |                    |                      |                          |                       |                           |                   |                        |           |                   |                          |                   |      |                                     |
| Q7-10                 | 0.100         | 0.00               | 0.00                 | 0.000                    | 0.000                 | 0.0                       | 0.00              | 0.00                   | 20.00     | 7.00              | 0.00                     | 0.00              |      |                                     |
| Q1-10                 |               | 0.00               | 0.00                 | 0.000                    | 0.000                 |                           |                   |                        |           |                   |                          |                   |      |                                     |
| Q30-10                |               | 0.00               | 0.00                 | 0.000                    | 0.000                 |                           |                   |                        |           |                   |                          |                   |      |                                     |
| <b>Discharge Data</b> |               |                    |                      |                          |                       |                           |                   |                        |           |                   |                          |                   |      |                                     |
|                       |               |                    |                      |                          |                       |                           |                   |                        |           |                   |                          |                   |      |                                     |
| Name                  |               | Permit Number      |                      | Existing Disc Flow (mgd) |                       | Permitted Disc Flow (mgd) |                   | Design Disc Flow (mgd) |           | Reserve Factor    |                          | Disc Temp (°C)    |      |                                     |
| Aqua Penn TWP         |               | PA0058572          |                      | 0.3500                   |                       | 0.3500                    |                   | 0.3500                 |           | 0.000             |                          | 25.00             |      |                                     |
| <b>Parameter Data</b> |               |                    |                      |                          |                       |                           |                   |                        |           |                   |                          |                   |      |                                     |
|                       |               |                    |                      |                          |                       |                           |                   |                        |           |                   |                          |                   |      |                                     |
| Parameter Name        |               | Disc Conc (mg/L)   |                      | Trib Conc (mg/L)         |                       | Stream Conc (mg/L)        |                   | Fate Coef (1/days)     |           |                   |                          |                   |      |                                     |
| CBOD5                 |               | 10.00              |                      | 2.00                     |                       | 0.00                      |                   | 1.50                   |           |                   |                          |                   |      |                                     |
| Dissolved Oxygen      |               | 6.00               |                      | 8.24                     |                       | 0.00                      |                   | 0.00                   |           |                   |                          |                   |      |                                     |
| NH3-N                 |               | 1.50               |                      | 0.00                     |                       | 0.00                      |                   | 0.70                   |           |                   |                          |                   |      |                                     |

#### Input Data WQM 7.0

| Design Cond.          | LFY<br>(cfsm) | Trib Flow<br>(cfs) | Stream Flow<br>(cfs) | Rch Trav Time<br>(days)  | Rch Velocity<br>(fps) | WD Ratio                  | Rch Width<br>(ft) | Rch Depth<br>(ft)      | Tributary |                   | Stream Temp<br>(°C)      | Stream pH<br>(°C) |      |                                     |
|-----------------------|---------------|--------------------|----------------------|--------------------------|-----------------------|---------------------------|-------------------|------------------------|-----------|-------------------|--------------------------|-------------------|------|-------------------------------------|
|                       |               |                    |                      |                          |                       |                           |                   |                        | RMI       | Elevation<br>(ft) | Drainage Area<br>(sq mi) | Slope<br>(ft/ft)  |      |                                     |
| 07K                   | 0.100         | 0.00               | 0.00                 | 0.000                    | 0.000                 | 0.0                       | 0.00              | 0.00                   | 0.000     | 422.90            | 2.47                     | 0.00000           | 0.00 | <input checked="" type="checkbox"/> |
| <b>Stream Data</b>    |               |                    |                      |                          |                       |                           |                   |                        |           |                   |                          |                   |      |                                     |
| Q7-10                 | 0.100         | 0.00               | 0.00                 | 0.000                    | 0.000                 | 0.0                       | 0.00              | 0.00                   | 20.00     | 7.00              | 0.00                     | 0.00              |      |                                     |
| Q1-10                 |               | 0.00               | 0.00                 | 0.000                    | 0.000                 |                           |                   |                        |           |                   |                          |                   |      |                                     |
| Q30-10                |               | 0.00               | 0.00                 | 0.000                    | 0.000                 |                           |                   |                        |           |                   |                          |                   |      |                                     |
| <b>Discharge Data</b> |               |                    |                      |                          |                       |                           |                   |                        |           |                   |                          |                   |      |                                     |
|                       |               |                    |                      |                          |                       |                           |                   |                        |           |                   |                          |                   |      |                                     |
| Name                  |               | Permit Number      |                      | Existing Disc Flow (mgd) |                       | Permitted Disc Flow (mgd) |                   | Design Disc Flow (mgd) |           | Reserve Factor    |                          | Disc Temp (°C)    |      |                                     |
| Aqua Penn TWP         |               | PA0058572          |                      | 0.0000                   |                       | 0.0000                    |                   | 0.0000                 |           | 0.000             |                          | 25.00             |      |                                     |
| <b>Parameter Data</b> |               |                    |                      |                          |                       |                           |                   |                        |           |                   |                          |                   |      |                                     |
|                       |               |                    |                      |                          |                       |                           |                   |                        |           |                   |                          |                   |      |                                     |
| Parameter Name        |               | Disc Conc (mg/L)   |                      | Trib Conc (mg/L)         |                       | Stream Conc (mg/L)        |                   | Fate Coef (1/days)     |           |                   |                          |                   |      |                                     |
| CBOD5                 |               | 25.00              |                      | 2.00                     |                       | 0.00                      |                   | 1.50                   |           |                   |                          |                   |      |                                     |
| Dissolved Oxygen      |               | 3.00               |                      | 8.24                     |                       | 0.00                      |                   | 0.00                   |           |                   |                          |                   |      |                                     |
| NH3-N                 |               | 25.00              |                      | 0.00                     |                       | 0.00                      |                   | 0.70                   |           |                   |                          |                   |      |                                     |

**NPDES Permit Fact Sheet**

**NPDES Permit No. PA0058572**  
**Penn Township Sewer System & STP**

**WQM 7.0 Hydrodynamic Outputs**

| <u>SWP Basin</u>   |             | <u>Stream Code</u> |                 | <u>Stream Name</u>                |             |       |       |           |          |                 |               |             |
|--------------------|-------------|--------------------|-----------------|-----------------------------------|-------------|-------|-------|-----------|----------|-----------------|---------------|-------------|
| 07K                |             | 6751               |                 | Trib 06751 of E Branch Big Elk Cr |             |       |       |           |          |                 |               |             |
| RMI                | Stream Flow | PWS With           | Net Stream Flow | Disc Analysis Flow                | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
|                    | (cfs)       | (cfs)              | (cfs)           | (cfs)                             | (ft/ft)     | (ft)  | (ft)  |           | (fps)    | (days)          | (°C)          |             |
| <b>Q7-10 Flow</b>  |             |                    |                 |                                   |             |       |       |           |          |                 |               |             |
| 0.620              | 0.05        | 0.00               | 0.05            | .5414                             | 0.01102     | .477  | 6.4   | 13.4      | 0.19     | 0.195           | 24.57         | 7.00        |
| <b>Q1-10 Flow</b>  |             |                    |                 |                                   |             |       |       |           |          |                 |               |             |
| 0.620              | 0.03        | 0.00               | 0.03            | .5414                             | 0.01102     | NA    | NA    | NA        | 0.19     | 0.199           | 24.72         | 7.00        |
| <b>Q30-10 Flow</b> |             |                    |                 |                                   |             |       |       |           |          |                 |               |             |
| 0.620              | 0.07        | 0.00               | 0.07            | .5414                             | 0.01102     | NA    | NA    | NA        | 0.20     | 0.192           | 24.43         | 7.00        |

# NPDES Permit Fact Sheet

## NPDES Permit No. PA0058572 Penn Township Sewer System & STP

### WQM 7.0 Modeling Specifications

|                    |        |                                     |                                     |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters         | Both   | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method         | EMPR   | Use Inputted W/D Ratio              | <input type="checkbox"/>            |
| Q1-10/Q7-10 Ratio  | 0.64   | Use Inputted Reach Travel Times     | <input type="checkbox"/>            |
| Q30-10/Q7-10 Ratio | 1.36   | Temperature Adjust Kr               | <input checked="" type="checkbox"/> |
| D.O. Saturation    | 90.00% | Use Balanced Technology             | <input checked="" type="checkbox"/> |
| D.O. Goal          | 6      |                                     |                                     |

### WQM 7.0 Wasteload Allocations

| SWP Basin | Stream Code | Stream Name |      |                                   |  |  |  |
|-----------|-------------|-------------|------|-----------------------------------|--|--|--|
|           |             | 07K         | 6751 | Trib 06751 of E Branch Big Elk Cr |  |  |  |

#### NH3-N Acute Allocations

| RMI   | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 0.620 | Aqua Penn TWP  | 11.34                     | 3                   | 11.34                     | 3                   | 0              | 0                 |

#### NH3-N Chronic Allocations

| RMI   | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 0.620 | Aqua Penn TWP  | 1.42                      | 1.5                 | 1.42                      | 1.5                 | 0              | 0                 |

#### Dissolved Oxygen Allocations

| RMI  | Discharge Name | CBOD5           |                 | NH3-N           |                 | Dissolved Oxygen |                 | Critical Reach | Percent Reduction |
|------|----------------|-----------------|-----------------|-----------------|-----------------|------------------|-----------------|----------------|-------------------|
|      |                | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L)  | Multiple (mg/L) |                |                   |
| 0.62 | Aqua Penn TWP  | 10              | 10              | 1.5             | 1.5             | 6                | 6               | 0              | 0                 |

### WQM 7.0 D.O. Simulation

| SWP Basin                | Stream Code | Stream Name                |              |                                   |             |                      |  |
|--------------------------|-------------|----------------------------|--------------|-----------------------------------|-------------|----------------------|--|
|                          |             | 07K                        | 6751         | Trib 06751 of E Branch Big Elk Cr |             |                      |  |
| RMI                      |             | Total Discharge Flow (mgd) |              | Analysis Temperature (°C)         |             | Analysis pH          |  |
| 0.620                    |             | 0.350                      |              | 24.570                            |             | 7.000                |  |
| Reach Width (ft)         |             | Reach Depth (ft)           |              | Reach WDRatio                     |             | Reach Velocity (fps) |  |
| 6.396                    |             | 0.477                      |              | 13.400                            |             | 0.194                |  |
| Reach CBOD5 (mg/L)       |             | Reach Kc (1/days)          |              | Reach NH3-N (mg/L)                |             | Reach Kn (1/days)    |  |
| 9.31                     |             | 1.467                      |              | 1.37                              |             | 0.995                |  |
| Reach DO (mg/L)          |             | Reach Kr (1/days)          |              | Kr Equation                       |             | Reach DO Goal (mg/L) |  |
| 6.193                    |             | 31.669                     |              | Owens                             |             | 6                    |  |
| Reach Travel Time (days) |             |                            |              | Subreach Results                  |             |                      |  |
| 0.195                    |             | TravTime (days)            | CBOD5 (mg/L) | NH3-N (mg/L)                      | D.O. (mg/L) |                      |  |
|                          |             | 0.020                      | 8.99         | 1.34                              | 6.78        |                      |  |
|                          |             | 0.039                      | 8.68         | 1.32                              | 7.11        |                      |  |
|                          |             | 0.059                      | 8.38         | 1.29                              | 7.30        |                      |  |
|                          |             | 0.078                      | 8.08         | 1.27                              | 7.41        |                      |  |
|                          |             | 0.098                      | 7.80         | 1.24                              | 7.49        |                      |  |
|                          |             | 0.117                      | 7.53         | 1.22                              | 7.54        |                      |  |
|                          |             | 0.137                      | 7.27         | 1.20                              | 7.58        |                      |  |
|                          |             | 0.156                      | 7.02         | 1.17                              | 7.59        |                      |  |
|                          |             | 0.176                      | 6.78         | 1.15                              | 7.59        |                      |  |
|                          |             | 0.195                      | 6.54         | 1.13                              | 7.59        |                      |  |

**NPDES Permit Fact Sheet**

**NPDES Permit No. PA0058572**  
**Penn Township Sewer System & STP**

**WQM 7.0 Effluent Limits**

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u>                |                 |                  |                                |                            |                            |
|------------------|--------------------|-----------------------------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 07K              | 6751               | Trib 06751 of E Branch Big Elk Cr |                 |                  |                                |                            |                            |
| RMI              | Name               | Permit Number                     | Disc Flow (mgd) | Parameter        | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 0.620            | Aqua Penn TWP      | PA0058572                         | 0.350           | CBOD5            | 10                             |                            |                            |
|                  |                    |                                   |                 | NH3-N            | 1.5                            | 3                          |                            |
|                  |                    |                                   |                 | Dissolved Oxygen |                                |                            | 6                          |

**NPDES Permit Fact Sheet**

**NPDES Permit No. PA0058572**  
**Penn Township Sewer System & STP**

TMS

# NPDES Permit Fact Sheet

## NPDES Permit No. PA0058572 Penn Township Sewer System & STP



Toxics Management Spreadsheet  
Version 1.4, May 2023

### Discharge Information

| Instructions              |                                 |          | Discharge                              |           | Stream      |                          |                   |                |            |     |               |             |
|---------------------------|---------------------------------|----------|--|-----------|-------------|--------------------------|-------------------|----------------|------------|-----|---------------|-------------|
| Facility:                 | Aqua Penn Township STP          |          | NPDES Permit No.:                      | PA0058572 |             | Outfall No.:             | 001               |                |            |     |               |             |
| Evaluation Type:          | Major Sewage / Industrial Waste |          | Wastewater Description: Treated Sewage |           |             |                          |                   |                |            |     |               |             |
| Discharge Characteristics |                                 |          |  |           |             |                          |                   |                |            |     |               |             |
| Design Flow (MGD)*        | Hardness (mg/l)*                | pH (SU)* | Partial Mix Factors (PMFs)             |           |             | Complete Mix Times (min) |                   |                |            |     |               |             |
|                           |                                 |          | AFC                                    | CFC       | THH         | CRL                      | Q <sub>7-10</sub> | Q <sub>h</sub> |            |     |               |             |
| 0.35                      | 100                             | 7        |  |           |             |                          |                   |                |            |     |               |             |
| Group 1                   | Discharge Pollutant             | Units    | Max Discharge Conc                     | Trib Conc | Stream Conc | Daily CV                 | Hourly CV         | Stream CV      | Fate Coeff | FOS | Criteri a Mod | Chem Transl |
|                           | Total Dissolved Solids (PWS)    | mg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Chloride (PWS)                  | mg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Bromide                         | mg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Sulfate (PWS)                   | mg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Fluoride (PWS)                  | mg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Aluminum                  | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Antimony                  | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Arsenic                   | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Barium                    | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Beryllium                 | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Boron                     | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Cadmium                   | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Chromium (III)            | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Hexavalent Chromium             | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Cobalt                    | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Copper                    | mg/L     | 0.001                                  |           |             |                          |                   |                |            |     |               |             |
|                           | Free Cyanide                    | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Cyanide                   | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Dissolved Iron                  | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Iron                      | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Lead                      | mg/L     | < 0.001                                |           |             |                          |                   |                |            |     |               |             |
|                           | Total Manganese                 | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Mercury                   | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Nickel                    | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Phenols (Phenolics) (PWS) | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Selenium                  | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
|                           | Total Silver                    | µg/L     |  |           |             |                          |                   |                |            |     |               |             |
| Total Thallium            | µg/L                            |          |  |           |             |                          |                   |                |            |     |               |             |
| Total Zinc                | mg/L                            | 0.029    |  |           |             |                          |                   |                |            |     |               |             |
| Total Molybdenum          | µg/L                            |          |  |           |             |                          |                   |                |            |     |               |             |
| Acrolein                  | µg/L                            | <        |  |           |             |                          |                   |                |            |     |               |             |
| Acrylamide                | µg/L                            | <        |  |           |             |                          |                   |                |            |     |               |             |
| Acrylonitrile             | µg/L                            | <        |  |           |             |                          |                   |                |            |     |               |             |
| Benzene                   | µg/L                            | <        |  |           |             |                          |                   |                |            |     |               |             |
| Bromoform                 | µg/L                            | <        |  |           |             |                          |                   |                |            |     |               |             |
| Carbon Tetrachloride      | µg/L                            | <        |  |           |             |                          |                   |                |            |     |               |             |

Discharge Information

11/19/2024

Page 1

## NPDES Permit Fact Sheet

**NPDES Permit No. PA0058572**  
**Penn Township Sewer System & STP**

## NPDES Permit Fact Sheet

**NPDES Permit No. PA0058572  
Penn Township Sewer System & STP**

## Discharge Information

11/19/2024

Page 3

Instructions      Discharge      Stream

Receiving Surface Water Name: UNT to E Br Big Elk Crk

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

| Location           | Stream Code* | RMI* | Elevation (ft)* | DA (mi <sup>2</sup> )* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 006751       | 0.62 | 458.99          | 0.51                   |               |                      | Yes                  |
| End of Reach 1     | 006751       | 0    | 422.9           | 2.47                   |               |                      | Yes                  |

Q 7-10

| Location           | RML  | LFY<br>(cfs/mi <sup>2</sup> ) <sup>*</sup> | Flow (cfs) |           | W/D<br>Ratio | Width<br>(ft) | Depth<br>(ft) | Veloci-<br>ty (fps) | Travel<br>Time<br>(days) | Tributary |    | Stream    |     | Analysis |    |
|--------------------|------|--|------------|-----------|--------------|---------------|---------------|---------------------|--------------------------|-----------|----|-----------|-----|----------|----|
|                    |      |  | Stream     | Tributary |              |               |               |                     |                          | Hardness  | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 0.62 | 0.1  |            |           |              |               |               |                     |                          |           |    | 100       | 7   |          |    |
| End of Reach 1     | 0    | 0.1  |            |           |              |               |               |                     |                          |           |    | 100       | 7   |          |    |

Q<sub>n</sub>

# NPDES Permit Fact Sheet

## NPDES Permit No. PA0058572 Penn Township Sewer System & STP

0 Inputs 0 Results 0 Limits

**Hydrodynamics**  
 **Wasteload Allocations**

**AFC** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

| Pollutants   | Stream Conc<br>( $\mu\text{g/L}$ ) | Stream CV | Trib Conc<br>( $\mu\text{g/L}$ ) | Fate Coef | WQC<br>( $\mu\text{g/L}$ ) | WQ Obj<br>( $\mu\text{g/L}$ ) | WLA<br>( $\mu\text{g/L}$ ) | Comments                         |
|--------------|------------------------------------|-----------|----------------------------------|-----------|----------------------------|-------------------------------|----------------------------|----------------------------------|
| Total Copper | 0                                  | 0         |                                  | 0         | 13.439                     | 14.0                          | 15.3                       | Chem Translator of 0.96 applied  |
| Total Lead   | 0                                  | 0         |                                  | 0         | 64.581                     | 81.6                          | 89.3                       | Chem Translator of 0.791 applied |
| Total Zinc   | 0                                  | 0         |                                  | 0         | 117.180                    | 120                           | 131                        | Chem Translator of 0.978 applied |

**CFC** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

| Pollutants   | Stream Conc<br>( $\mu\text{g/L}$ ) | Stream CV | Trib Conc<br>( $\mu\text{g/L}$ ) | Fate Coef | WQC<br>( $\mu\text{g/L}$ ) | WQ Obj<br>( $\mu\text{g/L}$ ) | WLA<br>( $\mu\text{g/L}$ ) | Comments                         |
|--------------|------------------------------------|-----------|----------------------------------|-----------|----------------------------|-------------------------------|----------------------------|----------------------------------|
| Total Copper | 0                                  | 0         |                                  | 0         | 8.956                      | 9.33                          | 10.2                       | Chem Translator of 0.96 applied  |
| Total Lead   | 0                                  | 0         |                                  | 0         | 2.517                      | 3.18                          | 3.48                       | Chem Translator of 0.791 applied |
| Total Zinc   | 0                                  | 0         |                                  | 0         | 118.139                    | 120                           | 131                        | Chem Translator of 0.986 applied |

**THH** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

| Pollutants   | Stream Conc<br>( $\mu\text{g/L}$ ) | Stream CV | Trib Conc<br>( $\mu\text{g/L}$ ) | Fate Coef | WQC<br>( $\mu\text{g/L}$ ) | WQ Obj<br>( $\mu\text{g/L}$ ) | WLA<br>( $\mu\text{g/L}$ ) | Comments |
|--------------|------------------------------------|-----------|----------------------------------|-----------|----------------------------|-------------------------------|----------------------------|----------|
| Total Copper | 0                                  | 0         |                                  | 0         | N/A                        | N/A                           | N/A                        |          |
| Total Lead   | 0                                  | 0         |                                  | 0         | N/A                        | N/A                           | N/A                        |          |
| Total Zinc   | 0                                  | 0         |                                  | 0         | N/A                        | N/A                           | N/A                        |          |

**CRL** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

| Pollutants   | Stream Conc<br>( $\mu\text{g/L}$ ) | Stream CV | Trib Conc<br>( $\mu\text{g/L}$ ) | Fate Coef | WQC<br>( $\mu\text{g/L}$ ) | WQ Obj<br>( $\mu\text{g/L}$ ) | WLA<br>( $\mu\text{g/L}$ ) | Comments |
|--------------|------------------------------------|-----------|----------------------------------|-----------|----------------------------|-------------------------------|----------------------------|----------|
| Total Copper | 0                                  | 0         |                                  | 0         | N/A                        | N/A                           | N/A                        |          |
| Total Lead   | 0                                  | 0         |                                  | 0         | N/A                        | N/A                           | N/A                        |          |

|            |   |   |  |   |     |     |     |  |
|------------|---|---|--|---|-----|-----|-----|--|
| Total Zinc | 0 | 0 |  | 0 | N/A | N/A | N/A |  |
|------------|---|---|--|---|-----|-----|-----|--|

**Recommended WQBELs & Monitoring Requirements**

No. Samples/Month:

| Pollutants | Mass Limits      |                  | Concentration Limits |        |        |       | Governing WQBEL | WQBEL Basis | Comments                           |
|------------|------------------|------------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
|            | AML<br>(lbs/day) | MDL<br>(lbs/day) | AML                  | MDL    | IMAX   | Units |                 |             |                                    |
| Total Zinc | Report           | Report           | Report               | Report | Report | mg/L  | 0.12            | AFC         | Discharge Conc > 10% WQBEL (no RP) |

**Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g.,  $\leq$  Target QL).

| Pollutants   | Governing WQBEL | Units | Comments                        |
|--------------|-----------------|-------|---------------------------------|
| Total Copper | 0.01            | mg/L  | Discharge Conc $\leq$ 10% WQBEL |
| Total Lead   | N/A             | N/A   | Discharge Conc < TQL            |
|              |                 |       |                                 |
|              |                 |       |                                 |