



Application Type
Facility Type
Major / Minor

Renewal
Storm Water
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. **PA0058882**
APS ID **1130857**
Authorization ID **1515839**

Applicant and Facility Information

Applicant Name	Trans Fleet Concrete Inc.	Facility Name	Trans-Fleet Concrete Inc.
Applicant Address	PO Box 26483 101 1st Avenue	Facility Address	606 Jeffers Circle
Applicant Contact	Danielle Kellon	Facility Contact	Marc Longacre
Applicant Phone	(610) 489-8884	Facility Phone	(610) 489-8884
Client ID	212368	Site ID	635095
SIC Code	3272	Municipality	West Whiteland Township
SIC Description	Manufacturing - Concrete Products, Nec	County	Chester
Date Application Received	January 29, 2025	EPA Waived?	Yes
Date Application Accepted		If No, Reason	
Purpose of Application	Permit renewal.		

Summary of Review

The Permittee requests approval for renewal of a NPDES permit to discharge stormwater runoff from the site of a ready-mix concrete batch plant located at 606 Jeffers Circle, Exton, PA, to an unnamed tributary to Valley Creek in the Brandywine Creek watershed.

The effluent limits for TSS and pH are continued from the existing permit. Monitoring requirements for Oil and Grease will also continue in the permit renewal. On page 22 of the NPDES permit there is a Part C condition on no. VII regarding "Requirements applicable to instream monitoring for pH." This requirement is for gathering pH data 50 feet upstream and downstream from the point where stormwater discharge enters the unnamed tributary. Sector-specific stormwater monitoring and BMPs requirements based on Appendix N (Glass, Clay, Cement, Concrete and Gypsum Products) of General Permit PAG-03 for discharge of stormwater associated with industrial activities are carried over from current permit. DEP revised sampling frequency from quarterly to semi-annual for all the parameters in minor amendment which is consistent with similar concrete facilities and will be carried over in this permit renewal. The facility is generally in compliance with effluent limits of NPDES permit.

The Trans Fleet Concrete – Exton Batch Plant is a Ready-mix concrete plant. Aggregate materials are stored in bins on southwest side of facility. Trucks are parked along eastern side of the facility. There are two concrete berms located at each entrance drive to divert stormwater to stormwater basin located in front of the facility which captures majority of stormwater from the facility. Trucks are loaded with concrete inside the building. A trench drain located outside of the loading area captures stormwater in this area. The water is pumped to process water tank. The truck wash-out pit is located next to the aggregate piles. The water is diverted to the process water tank. William Collins of Operations Section conducted site inspection on August 7, 2024 and had no concerns with the facility.

EPA issued the TMDL for nutrients and dissolved oxygen under low-flow conditions in the Christina River Basin for point sources, but stormwater runoff discharges were not included under low-flow conditions.

Approve	Deny	Signatures	Date
X		<i>Christian French</i> Christian French / Environmental Engineering Specialist	August 29, 2025
X		<i>Pravin Patel</i> Pravin C. Patel, P.E. / Environmental Engineer Manager	August 29, 2025

Summary of Review

Act 14 Notification – West Whiteland Township and Chester County – January 15, 2025

Draft permit is being issued contingent on completion of stormwater sampling for Total N, Total P, BOD5, and COD prior to Final Permit issuance.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information

Outfall No. 001

Design Flow (MGD) stormwater

Latitude 40° 0' 41.40"

Longitude -75° 39' 14.59"

Quad Name _____

Quad Code _____

Wastewater Description: Stormwater

Receiving Waters Unnamed Tributary to Valley Creek
(CWF, MF)

Stream Code _____

NHD Com ID 26089460

RMI _____

Watershed No. 3-H

Chapter 93 Class. CWF, MF

Assessment Status Impaired

Name Christina River Basin

Cause(s) of Impairment FLOW REGIME MODIFICATION, SILTATION

Source(s) of Impairment URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS

TMDL Status Final

Changes Since Last Permit Issuance: None

Compliance History

DMR Data for Outfall 001 (from June 1, 2024 to May 31, 2025)

Parameter	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24
pH (S.U.) Downstream Monitoring Instantaneous Minimum						7.0						7.7
pH (S.U.) Instantaneous Minimum						7.6						8.0
pH (S.U.) Upstream Monitoring Instantaneous Minimum						7.7						7.7
pH (S.U.) Downstream Monitoring Instantaneous Maximum						7.0						7.7
pH (S.U.) Instantaneous Maximum						7.6						8.0
pH (S.U.) Upstream Monitoring Instantaneous Maximum						7.7						7.7
TSS (mg/L) Semi-Annual Average						27.9						9.2
TSS (mg/L) Instantaneous Maximum						27.9						9.2
Oil and Grease (mg/L) Semi-Annual Average						< 5.0						< 5
Oil and Grease (mg/L) Instantaneous Maximum						< 5.0						< 5

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Semi-Annual Average	Maximum	Instant. Maximum		
pH (S.U.) Upstream Monitoring	XXX	XXX	Report Inst Min	XXX	XXX	Report	1/6 months	Grab
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/6 months	Grab
pH (S.U.) Downstream Monitoring	XXX	XXX	Report Inst Min	XXX	XXX	Report	1/6 months	Grab
TSS	XXX	XXX	XXX	50.0	XXX	100.0	1/6 months	Grab
Oil and Grease	XXX	XXX	XXX	Report	XXX	Report	1/6 months	Grab