

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0060062  
 APS ID 989390  
 Authorization ID 1266669

**Applicant and Facility Information**

Applicant Name	<u>US Department of Labor</u>	Facility Name	<u>Red Rock Job Corps Center</u>
Applicant Address	<u>PO Box 218</u> <u>Lopez, PA 18628-0218</u>	Facility Address	<u>Rt 487 N</u> <u>Lopez, PA 18628-0218</u>
Applicant Contact	<u>Jeannie Kapler, Dir. of Admin.</u>	Facility Contact	<u>Jeannie Kapler, Dir. of Admin.</u>
Applicant Phone	<u>(570) 477-0208</u>	Facility Phone	<u>(570) 477-0208</u>
Client ID	<u>117503</u>	Site ID	<u>3905</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Colley Township</u>
Connection Status	<u>N/A</u>	County	<u>Sullivan</u>
Date Application Received	<u>March 20, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 27, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit</u>		

**Summary of Review**

The subject sewage treatment plant serves the Red Rock Job Corps Center, a federal job training site in Colley Township, Sullivan County. A map of the discharge location is attached.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
<b>X</b>		Keith C. Allison / Project Manager	September 17, 2019
		Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.05</u>
Latitude	<u>41° 21' 31.21"</u>	Longitude	<u>-76° 18' 9.20"</u>
Quad Name	<u>Red Rock, PA</u>	Quad Code	<u>0835</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Mehoopany Creek (HQ-CWF)</u>	Stream Code	<u>29250</u>
NHD Com ID	<u>66411091</u>	RMI	<u>25.3</u>
Drainage Area	<u>1.74 mi<sup>2</sup> (at Mehoopany Creek)</u>	Yield (cfs/mi <sup>2</sup> )	<u></u>
Q <sub>7-10</sub> Flow (cfs)	<u>Undetermined</u>	Q <sub>7-10</sub> Basis	<u></u>
Elevation (ft)	<u>2320</u>	Slope (ft/ft)	<u>0.087</u>
Watershed No.	<u>4-G</u>	Chapter 93 Class.	<u>HQ-CWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>pH</u>		
Source(s) of Impairment	<u>ATMOSPHERIC DEPOSITION</u>		
TMDL Status	<u></u>	Name	<u></u>
Nearest Downstream Public Water Supply Intake	<u>Danville Municipal Water Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>Approx. 100</u>

Changes Since Last Permit Issuance: None

Other Comments:

Discharge is to a dry stream the drains to a wetland and ultimately to Mehoopany Creek.

The discharge is not expected to be contributing to the impairment for pH to Mehoopany Creek. It consistently meets its pH limits which are identical to the instream criteria. Inspections have not identified any noticeable impact at the outfall or in the receiving swale.

No downstream water supply is expected to be affected by this discharge at this time with the limitations and monitoring proposed.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Red Rock Job Corps				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
5789401		3/21/89		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Tertiary	Extended Aeration With Solids Removal	Ultraviolet	0.05
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.05	92	Not Overloaded	Holding Tank	Off Site

Changes Since Last Permit Issuance: None

Other Comments: The treatment, as permitted by WQM Permit No. 5789401, consists of a bar screen, comminutor, two aeration tanks, two clarifiers, chemical addition (soda ash), two rapid sand filters, UV disinfection and sludge holding tank.

Compliance History	
<b>Summary of DMRs:</b>	A review of the facility DMRs for the past year find one violation for Fecal Coliform as listed below.
<b>Summary of Inspections:</b>	The facility has been inspected approximately annually over the past permit term, most recently on August 2, 2019 by Stephen Puzio, WQS. This inspection identified no violations. However, the facility has seen sewage overflows, apparently from I&I issues.

Other Comments: A WMS query found no open violations for US Department of Labor in eFACTS. The Department sent the permittee a Notice of Violation on November 19, 2018 regarding unanticipated discharges of sewage over the previous year.

**Effluent Violations for Outfall 001, from: August 1, 2018 To: July 31, 2019**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	09/30/18	IMAX	> 2420	CFU/100 ml	1000	CFU/100 ml

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.05</u>
<b>Latitude</b> <u>41° 21' 36.52"</u>	<b>Longitude</b> <u>-76° 17' 51.31"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)

Comments: The above limit are included in the existing permit with the exception of more stringent CBOD<sub>5</sub> and TSS limits due to the dry stream discharge.

**Water Quality-Based Limitations**

**Antidegradation**

This discharge to a special protection watershed is existing and therefore, will not receive the Antidegradation Best Available Combination of Technologies (ABACT) limitations of the Department's Antidegradation guidance.

**Dry Stream Discharge**

Due to the discharge to a dry stream the limits for both CBOD<sub>5</sub> and TSS are at 10 mg/L to account for the lack of available assimilative capacity in the dry swale to Mehoopany Creek. These limits are consistent with the advanced treatment requirements in the Department's *Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers* guidance document. The current version of the guidance also includes limitations for Total Nitrogen, Dissolved Oxygen, and Total Phosphorus which are applicable to new discharges and therefore, will not be included.

**CBOD<sub>5</sub>, DO, and NH<sub>3</sub>-N**

The Department typically uses the WQM7.0 model to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. However, WQM7.0 modeling was not performed for the discharge due to the stringent existing CBOD<sub>5</sub> limitations and the degree of treatment already provided by the facility. Ammonia levels have averaged <0.2 mg/L for the annual monitoring included in the existing permit. Consistent with the Department's requirements for wastewater treatment plants and *NPDES Permit Writer's Manual*, the monitoring for ammonia-nitrogen will be twice per month and Dissolved Oxygen monitoring will now be daily.

**Toxics Management**

No further "Reasonable Potential Analysis" was performed to determine additional parameters as candidates for limitations for this 0.05 MGD facility sewage treatment facility receiving no industrial influent.

**Chesapeake Bay/Nutrient Requirements**

According to the Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, this facility is considered a Phase 5 Chesapeake Bay sewage discharger, and as such requires no nutrient loading limits. Per a review of the

facility DMRs over the past permit term the Total Nitrogen has averaged 19.3 mg/L and the Total Phosphorus has averaged 2.8 mg/L. The existing annual monitoring for Total Nitrogen and Total phosphorus will remain.

**Best Professional Judgment (BPJ) Limitations**

No additional BPJ limitations are necessary beyond the water quality and technology-based limits noted above.

**Anti-Backsliding**

No water quality-based or BPJ limits were made less stringent consistent with the anti-backsliding requirements of 40 CFR 122.44(I).

**Biosolids Disposal**

Per the application, the facility's septage is typically disposed at the Greater Hazelton Joint Sewer Authority facility (PA0026921) for further processing.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Instantaneous Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	10	XXX	20	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10	XXX	20	2/month	8-Hr Composite
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Metered
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Ammonia-nitrogen	XXX	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: The above limits and monitoring are unchanged from the existing permit with the exception of the DO monitoring increasing from twice per month to daily and the ammonia-nitrogen monitoring increasing from annually to twice per month as mentioned above.

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits
<input type="checkbox"/>	Other: [redacted]



Facility Location Map