

Application Type Renewal
Facility Type Sewage
Major / Minor Major

**NPDES PERMIT FACT SHEET
ADDENDUM**

Application No. PA0060089
APS ID 822220
Authorization ID 1210492

Applicant and Facility Information

Applicant Name	<u>Middle Smithfield Township</u>	Facility Name	<u>Fernwood WWTP</u>
Applicant Address	<u>147 Municipal Drive</u> <u>East Stroudsburg, PA 18302</u>	Facility Address	<u>Leroys Lane</u> <u>Bushkill, PA 18324</u>
Applicant Contact	<u>Joan Woisin</u>	Facility Contact	<u>Joan Woisin</u>
Applicant Phone	<u>(570) 223-8920</u>	Facility Phone	<u>(570) 223-8920</u>
Client ID	<u>44038</u>	Site ID	<u>240767</u>
SIC Code	<u>4952</u>	Municipality	<u>Middle Smithfield Township</u>
SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>	County	<u>Monroe</u>
Date Published in PA Bulletin	<u>November 13, 2021</u>	EPA Waived?	<u>No</u>
Comment Period End Date	<u>December 13, 2021</u>	If No, Reason	<u>Major Facility</u>
Purpose of Application	<u>Renewal of NPDES permit for discharge of treated sewage.</u>		

Internal Review and Recommendations

Public notification of draft permit issuance was published in the PA Bulletin on November 13, 2021. No comments were received during the 30-day comment period. The permittee chose to resample and reanalyze for several non-detect pollutants that appeared in the previous draft permit using lower quantitation limitations (QLs).

Based on the updated results, monitoring requirements / limitations for the following pollutants are removed from the permit: Total Antimony, Total Lead, 2,4-Dinitrophenol, 1,4-Dichlorobenzene, 1,3-Dichloropropylene, Total Silver, Total Thallium, 2,4-Dinitrotoluene, 2,6-Dinitrotoluene, 3,3-Dichlorobenzidine, 1,2,4-Trichlorobenzene, Butyl Benzyl Phthalate and Hexachloroethane.

The permittee was offered the chance to reanalyze Free Cyanide since the 20µg/L result submitted with the permit renewal application appeared to be an anomaly/outlier. The updated results were all 1 µg/L or less which indicates reasonable potential for violating Chapter 93 water quality standards has not been established, however, quarterly monitoring/reporting is included in the permit to gather additional data on this pollutant.

Part C.III (Water Quality-Based Effluent Limitations for Toxic Pollutants) and Part C.V (WQBELs Below Quantitation Limits) have been removed from the permit since they no longer apply.

Another draft permit must be issued with a new public comment period due to the changes made to this version.

Approve	Return	Deny	Signatures	Date
X			<i>Brian Burden</i> Brian Burden, E.I.T. / Project Manager	June 15, 2022
X			Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Environmental Engineer Manager	7-6-22