

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0060208  
APS ID 1100434  
Authorization ID 1460923

**Applicant and Facility Information**

Applicant Name	<u>Nelson Township Authority Tioga County</u>	Facility Name	<u>Nelson Township Authority Sewer Plant</u>
Applicant Address	<u>PO Box 100 328 Bliss Road Nelson, PA 16940-0100</u>	Facility Address	<u>328 Bliss Road Nelson, PA 16940-0100</u>
Applicant Contact	<u>Vicky Wiles</u>	Facility Contact	<u>Michael Patrick, Operator</u>
Applicant Phone	<u>(814) 302-4112</u>	Facility Phone	<u>(814) 302-4112</u>
Client ID	<u>77763</u>	Site ID	<u>496639</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Nelson Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Tioga</u>
Date Application Received	<u>October 31, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>November 8, 2023</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a minor POTW NPDES Permit</u>		



**Summary of Review**

The subject facility is a publicly owned treatment works serving the area of Nelson Village in Nelson Township, Tioga County. A map indicating the discharge location is attached.

Sludge use and disposal description and location(s): The facility's sludge is disposed by landfill. Per the application 4.97 dry tons were disposed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		 Keith C. Allison / Project Manager	May 1, 2024
✓		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	May 3, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.05</u>
Latitude	<u>41° 58' 41.32"</u>	Longitude	<u>-77° 14' 18.61"</u>
Quad Name	<u>Tioga, PA</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Cowanesque River (WWF)</u>	Stream Code	<u>30995</u>
NHD Com ID	<u>57349839</u>	RMI	<u>7.62</u>
Drainage Area	<u>281</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0159</u>
Q <sub>7-10</sub> Flow (cfs)	<u>4.47</u>	Q <sub>7-10</sub> Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>1069</u>	Slope (ft/ft)	<u>N/A</u>
Watershed No.	<u>4-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Nearest Downstream Public Water Supply Intake	<u>PA-NY border</u>		
PWS Waters	<u>Cowanesque River</u>	Distance from Outfall (mi)	<u>7.62</u>

Changes Since Last Permit Issuance: None. The above stream and drainage characteristics were determined for previous reviews and remain adequate.

Other Comments: This discharge is to the upstream end of the Cowanesque Reservoir.

No downstream water supply is expected to be affected by this discharge at this time with the limitations and monitoring proposed. The Department considers the Pennsylvania-New York Border to serve as the nearest downstream water supply when no nearer water supply exists

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Nelson Township Authority Sewer Plant				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
5903401		10/22/2003		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia And Phosphorus	Activated Sludge	Hypochlorite	0.05
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.075	91.7	Not Overloaded	Aerobic Digestion	Land Application

Changes Since Last Permit Issuance: None

Other Comments: Treatment as permitted under WQM No. 5903401 is an A<sup>2</sup>O process consisting of bar screen, influent pump station, anaerobic zone, anoxic zone, aerobic zone, clarification, chlorination, aerobic digestion, and reed beds.

Compliance History

DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)

Parameter	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23
Flow (MGD) Average Monthly	0.031	0.026	0.041	0.039	0.019	0.018	0.021	0.018	0.017	0.018	0.020	0.024
Flow (MGD) Daily Maximum	0.070	0.044	0.098	0.112	0.028	0.027	0.046	0.100	0.025	0.022	0.032	0.041
pH (S.U.) Instantaneous Minimum	6.9	7.0	6.9	6.9	7.2	7.1	7.1	7.0	7.2	7.1	7.2	7.3
pH (S.U.) Instantaneous Maximum	7.3	7.3	7.2	7.3	7.4	7.4	7.4	7.4	7.4	7.3	7.4	7.5
DO (mg/L) Instantaneous Minimum	5.09	5.01	4.73	4.83	3.92	3.36	3.04	3.01	3.05	3.02	3.75	4.11
TRC (mg/L) Average Monthly	0.40	0.44	0.41	0.39	0.44	0.37	0.26	0.34	0.30	0.33	0.34	0.42
TRC (mg/L) Instantaneous Maximum	0.68	0.67	0.64	1.50	0.61	0.70	0.32	0.56	0.50	0.60	0.60	0.61
CBOD5 (lbs/day) Average Monthly	< 0.92	< 0.63	< 0.701	< 0.62	< 0.42	< 0.42	< 0.42	< 0.49	< 0.43	< 0.58	< 1.03	< 0.58
CBOD5 (lbs/day) Weekly Average	< 1.35	0.67	< 0.776	< 0.65	< 0.48	< 0.43	< 0.43	< 0.55	< 0.43	0.73	1.37	0.75
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.10	< 3.00	< 3.0	< 3.0	< 3.0	< 3.00	< 3.00	< 3.0	< 4.07	< 6.07	< 3.00
CBOD5 (mg/L) Weekly Average	< 3.0	3.10	< 3.00	< 3.0	< 3.0	< 3.0	< 3.00	< 3.00	< 3.0	5.13	9.13	3.00
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	28	25	47	24.11	25	38.56	25	24	31.55	32.68	28.67	39.91
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	37	28	54	33.61	28	47.35	33	30	40.69	40.97	30.62	55.79
BOD5 (mg/L) Raw Sewage Influent Average Monthly	137	124	200	116	188	279	183	156	223	231	157	202
TSS (lbs/day) Average Monthly	7.25	2.69	2.29	4.24	0.90	< 0.66	0.50	1.24	< 0.43	< 3.09	1.65	1.26

**NPDES Permit Fact Sheet  
Nelson Township Authority Sewer Plant**

**NPDES Permit No. PA0060208**

TSS (lbs/day) Raw Sewage Influent Average Monthly	77	18	63	26.38	34	48.39	37	61	35.66	30.49	25	30.43
TSS (lbs/day) Raw Sewage Influent Daily Maximum	122	22	72	31.66	49	84.50	43	112	56.29	39.70	38.28	36.03
TSS (lbs/day) Weekly Average	12.84	3.30	2.59	4.86	0.95	1.13	0.51	1.28	0.62	5.95	1.86	1.40
TSS (mg/L) Average Monthly	19.5	13.0	9.75	27	6.65	< 4.80	3.60	7.70	< 3.00	< 21.8	9.4	7
TSS (mg/L) Raw Sewage Influent Average Monthly	238	88	270	128	286	344	271	343	252	215	124	165
TSS (mg/L) Weekly Average	28.5	15.2	10.0	32	7.30	8.00	3.60	8.40	4.40	42.0	12.4	8.40
Fecal Coliform (No./100 ml) Geometric Mean	< 1.0	< 1.0	< 1.0	6.4	< 1.0	< 1.0	< 1.0	< 1.0	< 8.26	< 1.0	< 1.0	< 2.72
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1.0	1.0	< 1.0	40.4	< 1.0	< 1.0	< 1.0	< 1.0	68.3	< 1.0	< 1.0	7.4
Ammonia (lbs/day) Average Monthly	0.81	0.34	0.82	0.14	0.105	0.055	0.37	0.62	0.09	< 0.39	2.05	4.82
Ammonia (mg/L) Average Monthly	2.365	1.657	0.919	0.687	0.744	< 0.397	2.658	4.16	0.67	< 2.75	9.71	26.90
Total Phosphorus (lbs/day) Average Monthly	0.18	0.14	0.25	0.83	0.04	0.11	0.17	0.21	0.34	0.21	0.53	0.29
Total Phosphorus (mg/L) Average Monthly	0.565	0.668	1.02	4.13	0.308	0.81	1.23	1.27	2.39	1.44	3.19	1.31

**Compliance History, Cont'd**

**Effluent Violations for Outfall 001, from: May 1, 2023 To: March 31, 2024**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Total Phosphorus	01/31/23	Avg Mo	0.995	lbs/day	0.8	lbs/day
Total Phosphorus	07/31/23	Avg Mo	2.39	mg/L	2.0	mg/L
Total Phosphorus	05/31/23	Avg Mo	3.19	mg/L	2.0	mg/L
Total Phosphorus	01/31/23	Avg Mo	2.34	mg/L	2.0	mg/L

**Compliance History, Cont'd**

<b>Compliance History, Cont'd</b>	
<b>Summary of Inspections:</b>	The facility has been inspected periodically by the Department over the past permit term. The most recent inspection on March 23, 2023 identified violations for inoperable blowers and eDMR effluent violations.
<b>Other Comments:</b>	A query in WMS found open violations in eFACTS for the Nelson Township Authority for Failure to Implement a Filter Bed Evaluation Program and Disinfection/Disinfection Byproducts Precursor Removal Violation.

**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	10	16	XXX	25	40	50	2/month	Grab
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	Grab
TSS	12	18	XXX	30	45	60	2/month	Grab
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Ammonia	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Total Phosphorus	0.8	XXX	XXX	2.0	XXX	4	2/month	Grab

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.05</u>
<b>Latitude</b> <u>41° 58' 42.00"</u>	<b>Longitude</b> <u>-77° 14' 19.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limits are applicable and are included in the existing permit.

**Water Quality-Based Limitations**

**DO, CBOD<sub>5</sub> and NH<sub>3</sub>-N**

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. WQM7.0 modeling was performed (see Attachment B) for the discharge to the Cowanesque River and verifies that no limitations are necessary beyond the technology-based secondary treatment limits listed above.

**Total Residual Chlorine**

The attached modeling shows that the technology-based limit of 0.5 mg/L is adequate to protect the receiving waters (See Attachment C).

**Water Quality Toxics Management**

No additional reasonable potential analysis has been performed to determine additional parameters for limitations or monitoring for this minor municipal treatment plant with no industrial users.

**Chesapeake Bay/Nutrient Requirements**

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. The Nelson Township Authority facility is considered a Phase V, non-significant Chesapeake Bay discharger and as such no nutrient cap loadings have been established for the facility pursuant to the Phase II Watershed Implementation Plan. The Total Nitrogen and Total Phosphorus concentrations have averaged 8.4 and 1.0 mg/L, respectively.

The facility has an existing Phosphorus limit of 2.0 mg/L that was based on previous studies of the Cowanesque Reservoir. The limit remains protective and will remain. Annual Total Nitrogen monitoring will also remain.



**Best Professional Judgment (BPJ) Limitations**

Comments: No additional BPJ limits are necessary at this time beyond the water quality and technology-based limits noted above.

**E. Coli**

Annual e. coli monitoring will be required at this time due to changes to Chapter 93 of the Department's regulations and Department policy.

**Anti-Backsliding**

No limitations in this proposed draft permit have been made less stringent consistent with the anti-backsliding requirements of the Clean Water Act and 40 CFR 122.44(l).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	10	16	XXX	25	40	50	2/month	Grab
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	Grab
TSS	12	18	XXX	30	45	60	2/month	Grab
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Total Phosphorus	0.8	XXX	XXX	2.0	XXX	4	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

**NPDES Permit Fact Sheet  
Nelson Township Authority Sewer Plant**

**NPDES Permit No. PA0060208**

Compliance Sampling Location: Outfall 001


Other Comments: E. Coli monitoring is new as mentioned above. Total nitrogen monitoring is now listed as a daily maximum rather than annual average.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment <b>B</b> )
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment <b>  </b> )
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment <b>C</b> )
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment <b>  </b> )
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input checked="" type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: <b>  </b>
<input type="checkbox"/>	Other: <b>  </b>

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. TRC Model







### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	30995	COWANESQUE RIVER	<b>8.310</b>	1069.00	281.00	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
<b>Q7-10</b>	0.016	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Nelson Twp Auth	PA0060208	0.0500	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	30995	COWANESQUE RIVER	<b>7.620</b>	1054.00	290.00	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	pH	(°C)	pH
<b>Q7-10</b>	0.016	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		



## WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
04A		30995				COWANESQUE RIVER						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
8.310	4.50	0.00	4.50	.0773	0.00412	.766	42.63	55.66	0.14	0.301	20.08	7.00
<b>Q1-10 Flow</b>												
8.310	2.88	0.00	2.88	.0773	0.00412	NA	NA	NA	0.11	0.384	20.13	7.00
<b>Q30-10 Flow</b>												
8.310	6.11	0.00	6.11	.0773	0.00412	NA	NA	NA	0.17	0.254	20.06	7.00

## WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
04A	30995	COWANESQUE RIVER			
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
8.310	0.050	20.085		7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
42.627	0.766	55.664		0.140	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
2.39	0.221	0.42		0.705	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
8.154	5.492	Tsivoglou		5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>				
0.301	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>	
	(days)	(mg/L)	(mg/L)	(mg/L)	
	0.030	2.37	0.41	8.23	
	0.060	2.36	0.41	8.23	
	0.090	2.34	0.40	8.23	
	0.120	2.33	0.39	8.23	
	0.150	2.31	0.38	8.23	
	0.181	2.30	0.37	8.23	
	0.211	2.28	0.36	8.23	
	0.241	2.26	0.36	8.23	
	0.271	2.25	0.35	8.23	
	0.301	2.23	0.34	8.23	

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
04A	30995	COWANESQUE RIVER

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
8.310	Nelson Twp Auth	16.58	50	16.58	50	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
8.310	Nelson Twp Auth	1.88	25	1.88	25	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
8.31	Nelson Twp Auth	25	25	25	25	3	3	0	0

## WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
04A		30995	COWANESQUE RIVER				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
8.310	Nelson Twp Auth	PA0060208	0.050	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

<b>TRC EVALUATION</b>					
Input appropriate values in A3:A9 and D3:D9					
4.47	= Q stream (cfs)		0.5	= CV Daily	
0.05	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 18.454		1.3.2.iii	WLA_cfc = 17.983
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 6.876		5.1d	LTA_cfc = 10.455
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				