

Application Type Renewal  
Facility Type Industrial  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL INDUSTRIAL WASTE (IW)  
AND IW STORMWATER**

Application No. PA0060305  
APS ID 1048215  
Authorization ID 1370300

**Applicant and Facility Information**

Applicant Name	<u>PA DCNR</u>	Facility Name	<u>Mt. Pisgah State Park</u>
Applicant Address	<u>28 Entrance Road</u> <u>Troy, PA 16947-8506</u>	Facility Address	<u>28 Entrance Road</u> <u>Troy, PA 16947-8506</u>
Applicant Contact	<u>Layne Nolan (lanolan@pa.gov)</u>	Facility Contact	<u>Derek Parks (dparks@pa.gov)</u>
Applicant Phone	<u>(570) 297-2734</u>	Facility Phone	<u>(570) 297-2734</u>
Client ID	<u>52524</u>	Site ID	<u>245442</u>
SIC Code	<u>4941</u>	Municipality	<u>West Burlington Township</u>
SIC Description	<u>Trans. &amp; Utilities - Water Supply</u>	County	<u>Bradford</u>
Date Application Received	<u>September 20, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 27, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for the renewal of an individual NPDES Permit for industrial waste.</u>		

**Summary of Review**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

This existing NPDES permit (PA0060305) is for the discharge of filter backwash to Mill Creek. The only treatment currently is approved under WQM Permit No. 0880206 and is achieved by a 1000-gallon settling tank. This NPDES permit will be terminated upon the completion of WQM Permit 0880206 A-1. That amendment permits the installation of a filter backwash infiltration system that will utilize components of the existing sewage WWTP to infiltrate the effluent in lieu of discharging.

Approve	Deny	Signatures	Date
X		<i>Jonathan P. Peterman</i> Jonathan P. Peterman / Project Manager	October 13, 2022
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	October 17, 2022

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0002</u>
Latitude	<u>41° 48' 18.94"</u>	Longitude	<u>-76° 40' 16.93"</u>
Quad Name	<u>East Troy</u>	Quad Code	<u>0432</u>
Wastewater Description: <u>IW Process Effluent without ELG</u>			
Receiving Waters	<u>Mill Creek (TSF)</u>	Stream Code	<u>30718</u>
NHD Com ID	<u>66400299</u>	RMI	<u>4.51 (for Mill Creek)</u>
Drainage Area	<u>10.5 mi<sup>2</sup> (@Mill Creek)</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0042</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.0441</u>	Q <sub>7-10</sub> Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>1102</u>	Slope (ft/ft)	<u>Undetermined</u>
Watershed No.	<u>4-C</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	<u>None</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>N/A</u>		
Source(s) of Impairment	<u>N/A</u>		
TMDL Status	<u>N/A</u>	Name	<u>N/A</u>
Nearest Downstream Public Water Supply Intake	<u>Danville Municipal Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>1740</u>
PWS RMI	<u>124</u>	Distance from Outfall (mi)	<u>Approx. 180</u>

Changes Since Last Permit Issuance: None.

Other Comments: The backwash discharge only occurs approximately three times per month for 20 minutes at a time. The discharge is to a vegetative area a few hundred feet from Mill Creek and likely evaporates or infiltrates prior to reaching Mill Creek.

Treatment Facility Summary		
Treatment Facility Name: Mt. Pisgah State Park		
WQM Permit No.	Issuance Date	Comments
0880206	01/14/81	Original permit.
0880206 A-1	6/7/22	A pool filter backwash treatment and infiltration disposal system.

Changes Since Last Permit Issuance: Previously, the treatment of the filter backwash, as approved under WQM Permit No. 0880206 was provided by a 1000-gallon settling tank and discharged. The pool filter backwash will now be infiltrated and an NPDES permit will no longer be required after construction is completed.

Other Comments: None.

**Existing Effluent Limitations and Monitoring Requirements**

Existing Limits – Outfall 001

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.2	1/week	Grab
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	1/month	Grab
Aluminum, Total	XXX	XXX	XXX	4.0	8.0 Daily Max	XXX	1/year	Grab
Iron, Total	XXX	XXX	XXX	2.0	4.0 Daily Max	XXX	1/year	Grab
Manganese, Total	XXX	XXX	XXX	1.0	2.0 Daily Max	XXX	1/year	Grab

\*The existing effluent limits for Outfall 001 were based on a design flow of 0.0002 MGD.

**Development of Effluent Limitations**

Outfall No. 001 Design Flow (MGD) 0.0002  
 Latitude 41° 48' 21.80" Longitude -76° 40' 11.90"  
 Wastewater Description: IW Process Effluent without ELG

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l) (Average Monthly)	Limit (mg/l) (Daily Maximum)	Federal Regulation	State Regulation
pH	6-9 at all times	-	§133.102(c)	§95.2
TRC	0.5	-	-	§92a.48

Parameter	Limit (mg/l) (Average Monthly)	Limit (mg/l) (Daily Maximum)	Basis
TSS	30	60	These limits are derived from Guidance Document (392-2183-003) <i>Technology-Based Control Requirements for Water Treatment Plant.</i>
Iron (Total)	2.0	4.0	
Aluminum (Total)	4.0	8.0	
Manganese (Total)	1.0	2.0	
TRC	0.5	1.0	

**Water Quality-Based Limitations**

To establish whether or not water-quality based effluent limitations (WQBELs) are required, the Department models in-stream conditions. In order to determine limitations for toxics, the Department utilizes the Toxics Management Spreadsheet (TMS). The use of a WQM7.0 or TMS analysis is not required for this discharge.

**Best Professional Judgment (BPJ) Limitations**

Comments: None needed beyond the technology-based limitations noted above.

**Anti-Backsliding**

In accordance with 40 CFR 122.44(l)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

**Chesapeake Bay**

In accordance with the Phase III WIP Chesapeake Bay Strategy this facility has been identified previously by DEP as "insignificant dischargers" by virtue of having gross effluent discharges that do not exceed 75 lbs/day of TN or 25 lbs/day of TP. For these non-significant IW facilities, monitoring and reporting of TN and TP will be required throughout the permit term in renewed or amended permits anytime the facility has the potential to introduce a net TN or TP increase to the load contained within the intake water used in processing. No nutrient monitoring is required for this facility.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

**Proposed Limits - Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.2	1/week	Grab
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	1/month	Grab
Aluminum, Total	XXX	XXX	XXX	4.0	8.0 Daily Max	XXX	1/year	Grab
Iron, Total	XXX	XXX	XXX	2.0	4.0 Daily Max	XXX	1/year	Grab
Manganese, Total	XXX	XXX	XXX	1.0	2.0 Daily Max	XXX	1/year	Grab

\*The proposed effluent limits for Outfall 001 were based on a design flow of 0.0002 MGD.

The existing monitoring frequencies and sample types for the abovementioned parameters are consistent with water treatment plant wastewater discharges and the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001) Table 6-4. The existing requirements will remain.

**Flow**

The existing reporting of average monthly and daily max flows is consistent with similar facilities and will remain.

**pH**

CFR Title 40 §133.102(c) and 25 PA Code §95.2(1) provide the basis of effluent limitations for pH.

**Total Suspended Solids (TSS), Total Aluminum, Total Manganese, and Total Iron**

The existing technology-based effluent limits for these parameters have been implemented in accordance with DEP Guidance Document (392-2183-003) *Technology-Based Control Requirements for Water Treatment Plants* and shall remain.

**Total Residual Chlorine (TRC)**

The Guidance Document (392-2183-003) stipulates that the monthly average limit for TRC should be 0.5 mg/L, but it also stipulates that the technology limit for TRC is required by former Section 93.5 of Title 25 of the Departments Regulations. It also refers to Section 93.5 and the Implementation Guidance for Total Residual Chlorine (TRC) Regulation for details on how to impose TRC limitations. The TRC model evaluation was conducted using the existing technology-based limit of 0.5 mg/l and the results indicate that the existing limit is protective of water quality. The existing TRC effluent limits will remain.

**Compliance History**

**Summary of Inspections** -The last inspection of the facility was conducted on 5/11/21 by the Department which reveals that there were no issues and the facility was operating normally.

**WMS Query Summary** - A WMS Query was run at *Reports - Violations & Enforcements – Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed no open violations for this facility. There were open violations for PA DCNR statewide, but this should not affect the issuance of this particular permit.

Compliance History

DMR Data for Outfall 001 (from September 1, 2021 to August 31, 2022)

Parameter	AUG-22	JUL-22	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21
Flow (MGD) Average Monthly	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002		0.00020 0	0.00020 0	0.00020 0	0.00020 0	0.00020 0
Flow (MGD) Daily Maximum	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002		0.00020 0	0.00020 0	0.00020 0	0.00020 0	0.00020 0
pH (S.U.) Minimum	8.1	8.0	7.9	8.0	8.0	7.8		8.1	8.0	8.0	8.2	7.9
pH (S.U.) Maximum	8.2	8.2	8.1	8.2	8.0	7.8		8.1	8.0	8.0	8.2	8.1
TRC (mg/L) Average Monthly	0.12	0.11	0.09	0.11	0.10	0.09		0.08	0.10	0.09	0.11	0.12
TRC (mg/L) Instantaneous Maximum	0.15	0.13	0.11	0.12	0.10	0.09		0.08	0.10	0.09	0.11	0.16
TSS (mg/L) Average Monthly	< 8	< 8	< 8	< 8	< 8	< 15		< 15	< 15	< 15	6	< 5
TSS (mg/L) Instantaneous Maximum	< 8	< 8	< 8	< 8	< 8	< 15		< 15	< 15	< 15	6	< 5
Total Aluminum (mg/L) Average Monthly									0.30			
Total Aluminum (mg/L) Daily Maximum									0.30			
Total Iron (mg/L) Average Monthly									0.10			
Total Iron (mg/L) Daily Maximum									0.10			
Total Manganese (mg/L) Average Monthly									0.12			
Total Manganese (mg/L) Daily Maximum									0.12			

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input checked="" type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]



