

Application Type Renewal  
Facility Type Sewage  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
ADDENDUM**

Application No. PA0061115  
APS ID 892155  
Authorization ID 1259447

**Applicant and Facility Information**

Applicant Name	<u>SC Stream PA LLC</u>	Facility Name	<u>Paradise Stream Resort Wastewater Treatment Plant</u>
Applicant Address	<u>PO Box 99</u>	Facility Address	<u>6208 Paradise Valley Road</u>
	<u>Mount Pocono, PA 18344-0099</u>		<u>Cresco, PA 18326</u>
Applicant Contact	<u>Patricia Williams, Resort Manager</u>	Facility Contact	<u>David Scholtz, Operator</u>
Applicant Phone	<u>(570) 839-5154</u>	Facility Phone	<u>(570) 839-5154</u>
Client ID	<u>326433</u>	Site ID	<u>250962</u>
SIC Code	<u>4952</u>	Municipality	<u>Paradise Township</u>
SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>	County	<u>Monroe</u>
Date Published in PA Bulletin	<u>February 16, 2019</u>	EPA Waived?	<u>Yes</u>
Comment Period End Date	<u>March 18, 2019</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Application for a renewal of an NPDES permit for discharge of treated sewage.</u>		

**Internal Review and Recommendations**

The first draft of this application appeared in the PA Bulletin on Saturday, February 16, 2019. The final NPDES permit could not be issued due to open violations.

There are still two open violations for the client/facility in the Clean Water Program:

1. 02/15/2023 - Violation ID 985192 – Violation Code 92A.44 – NPDES - Violation of effluent limits in Part A of permit.
2. 02/15/2023 - Violation ID 985193 – Violation Code 92A.61(C) – NPDES - Failure to monitor pollutants as required by the NPDES permit.

A new DRBC Docket has come into effect since the first draft NPDES Permit has been issued. DRBC Docket NO. D-2006-020-4 has an approval date of December 8, 2021 and expiration date of December 2, 2026. This docket requires monthly monitoring/reporting for Nitrate as N or Nitrate + Nitrite as N and also monthly monitoring/reporting for Total Nitrogen or Total Kjeldahl Nitrogen.

Therefore, the annual monitoring and reporting for Nitrate-Nitrite as N, Total Nitrogen, and Total Kjeldahl Nitrogen were replaced with monthly monitoring and reporting. The annual monitoring for Total Phosphorus was removed because there are already limitations required for Total Phosphorus.

Sewage discharges now require monitoring and reporting for E. Coli. A monitoring frequency of 1/month for design flows >= 1 MGD, 1/quarter for design flows >= 0.05 and < 1 MGD, 1/year for design flows of 0.002 – 0.05 MGD will be utilized.

All the permit documents have been updated to the newest format.

Approve	Return	Deny	Signatures	Date
X			/s/ Allison Seyfried Zukosky / Project Manager	April 17, 2025
X			/s/ Edward Dudick, P.E. / Engineer Manager	April 18, 2025