

Application Type Renewal
Wastewater Type Sewage
Facility Type SFTF

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0061506
APS ID 583334
Authorization ID 1410780

Applicant, Facility and Project Information

Applicant Name	<u>Maxson Sandra L</u>	Facility Name	<u>Preston Country Market</u>
Applicant Address	<u>PO Box 2</u>	Facility Address	<u>530 Shehawken Road</u>
Applicant Contact	<u>Sandra Maxson</u>	Facility Contact	<u></u>
Applicant Phone	<u>(570) 789-2871</u>	Facility Phone	<u></u>
Client ID	<u>145332</u>	Site ID	<u>246597</u>
SIC Code	<u>4952</u>	Municipality	<u>Preston Township</u>
SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>	County	<u>Wayne</u>
Date Application Received	<u>September 9, 2022</u>	WQM Required	<u>N/A</u>
Date Application Accepted	<u>September 12, 2022</u>	WQM App. No.	<u></u>
Project Description	<u>RENEWAL OF EXISTING NPDES SEWAGE PERMIT.</u>		

Summary of Review

The applicant is requesting renewal of NPDES Permit No. PA0061506 to discharge up to 0.000535 MGD of treated sewage to an unnamed tributary to Shehawken Creek, a HQ-CWF receiving water. The permit is being renewed with the same effluent limits as the previous permit since conditions have not changed at this small flow treatment facility.

The Fecal Coliform, TRC and pH effluent limitations are BPT based. The limitations for CBOD₅, TSS and NH₃-N are water quality-based.

Annual monitoring for E-coli has been added to this permit.

A compliance check performed on February 1, 2023, did not reveal any unresolved violations.

The EPA waiver is in effect.

Approve	Deny	Signatures	Date
X		Hakim Yesli (signed) Environmental Engineering Specialist	October 1, 2024
X		Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Acting Engineer Manager	10-29-24

DRAFT