

Application Type Renewal  
Wastewater Type Sewage  
Facility Type SRSTP

## NPDES PERMIT FACT SHEET INDIVIDUAL SRSTP

Application No. PA0061808  
APS ID 520625  
Authorization ID 1479671

### Applicant, Facility and Project Information

Applicant Name	<u>Royle Barbara H</u>	Facility Name	<u>Barbara Royle Residence</u>
Applicant Address	<u>113 Salamander HI Hunter Farm Road</u> <u>Henryville, PA 18332-7703</u>	Facility Address	<u>Hunter Farm Road 113 Salamander Hill</u> <u>Henryville, PA 18332</u>
Applicant Contact	<u>Barbara Royle</u>	Facility Contact	<u>Barabara Royle</u>
Applicant Phone	<u>(570) 629-1774</u>	Facility Phone	<u>(570) 629-1774</u>
Client ID	<u>68029</u>	Site ID	<u>240811</u>
SIC Code	<u>8811</u>	Municipality	<u>Paradise Township</u>
SIC Description	<u>Services - Private Households</u>	County	<u>Monroe</u>
Date Application Received	<u>April 4, 2024</u>	WQM Required	<u>N/A</u>
Date Application Accepted	<u>April 12, 2024</u>	WQM App. No.	<u>N/A</u>
Project Description	<u>Renewal of existing NPDES permit to discharge treated sewage effluent.</u>		

### Summary of Review

The applicant is requesting the renewal of an NPDES permit to discharge treated sewage effluent to Tributary 04955 to Swiftwater Creek, a High Quality-Cold Water Fishes receiving water in state water plan basin 1-E (Broadhead Creek). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use.

The system for this facility is as follows: Discharged sewage from a single-family home travels to 2 aerobic tanks, then to a sand filter, and finally disinfected with chlorine tablets. There are no current planned upgrades to this facility and the operator reports great working conditions.

Limitations for this facility are in accordance with the SRSTP standard operating procedure. Part F.3. supplies a table for average yearly/monthly and IMAX values for Flow, COBD<sub>5</sub>, TSS, TRC, and Fecal Coliform. TRC and WQM modeling were not performed for this facility.

The Annual Maintenance Report (AMR) that's to be issued with the final permit shall be used to record the monitoring results. Discharge Monitoring Reports (DMRs) will not be sent will the final permit. EPA wavier is in effect.

The previous permit expired on 9/30/2024 and was administratively extended. The previous inspection at this facility was held on 6/17/2022 and resulted in no NOVs. There are no open violations for this facility. Recommend approval.

### Public Participation

Approve	Deny	Signatures	Date
X		<i>William Hon</i> William Hon / Environmental Engineer Specialist	March 27, 2025
X		<i>Edward Dudick</i> Edward Dudick, P.E. / Environmental Engineer Manager	March 27, 2025

### Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

