

Application Type Renewal  
Facility Type Sewage  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
THIRD DRAFT**

Application No. PA0062596  
APS ID 544690  
Authorization ID 1130619

**Applicant and Facility Information**

Applicant Name	<u>Laceyville Borough Joint Municipal Authority</u>	Facility Name	<u>Laceyville Borough Joint Municipal Authority Wastewater Treatment Plant</u>
Applicant Address	342 Church Street Laceyville, PA 18623-6826	Facility Address	Tannery Street Laceyville, PA 18623
Applicant Contact	Renee Brigham	Facility Contact	<u>Larry Lechleitner, Operator</u>
Applicant Phone	<u>(570) 240-0748</u>	Facility Phone	<u>(570) 833-2547</u>
Client ID	<u>65407</u>	Site ID	<u>257228</u>
SIC Code	<u>4952</u>	Municipality	<u>Laceyville Borough</u>
SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>	County	<u>Wyoming</u>
Date Published in PA Bulletin	<u>January 18, 2020</u>	EPA Waived?	<u>Yes</u>
Comment Period End Date	<u>February 18, 2020</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Application for a renewal of an NPDES permit for discharge of treated Sewage</u>		

**Internal Review and Recommendations**

The first draft of this application appeared in the PA Bulletin on Saturday, January 19, 2019, and the second draft of this application appeared in the PA Bulletin on January 18, 2020. The final NPDES permit could not be issued due to open violations.

There is still one open violation for the client/facility:

1. 01/30/2020 - Violation ID 876794 – Violation Code 92A.41(A)4 – NPDES - Failure to take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of a permit.

A third draft of the NPDES permit is being issued because 6 months (or 180 days) have elapsed since the second draft has been issued.

Re-modeling was not performed. Limitations and monitoring frequencies have been carried over from the second draft.

Sewage discharges now require monitoring and reporting for E. Coli. A monitoring frequency of 1/month for design flows >= 1 MGD, 1/quarter for design flows >= 0.05 and < 1 MGD, 1/year for design flows of 0.002 – 0.05 MGD will be utilized.

All the permit documents have been updated to the newest format. The contact information for the client and facility has also been updated.

Approve	Return	Deny	Signatures	Date
X			/s/ Allison Seyfried Zukosky / Project Manager	January 28, 2025
X			/s/ Amy M. Bellanca, P.E. / Acting Engineer Manager	1-31-25