

Application Type Renewal
Facility Type Sewage
Major / Minor Minor

NPDES PERMIT FACT SHEET ADDENDUM

Application No. PA0062839
APS ID 563086
Authorization ID 1347363

Applicant and Facility Information

<p>Applicant Name <u>Lake Adventure Community Association</u></p> <p>Applicant Address <u>150 Office Way N</u> <u>Milford, PA 18337-4114</u></p> <p>Applicant Contact <u>Cheryl DeStefano, Camp Manager</u></p> <p>Applicant Phone <u>(570) 686-2800</u></p> <p>Client ID <u>39883</u></p> <p>SIC Code <u>7033</u></p> <p>SIC Description <u>Services - Trailer Parks and Campsites</u></p> <p>Date Published in PA Bulletin <u>June 4, 2022</u></p> <p>Comment Period End Date <u>July 4, 2022</u></p> <p>Purpose of Application <u>Renewal of NPDES permit for discharge of treated sewage</u></p>	<p>Facility Name <u>Lake Adventure Community Association WWTF</u></p> <p>Facility Address <u>5000 Lake Adventure Drive</u> <u>Milford, PA 18337-9709</u></p> <p>Facility Contact <u>John Wurst, STP Operator</u></p> <p>Facility Phone <u>(570) 656-6495</u></p> <p>Site ID <u>4275</u></p> <p>Municipality <u>Dingman Township</u></p> <p>County <u>Pike</u></p> <p>EPA Waived? <u>Yes</u></p> <p>If No, Reason <u>-</u></p>
--	---

Internal Review and Recommendations

The first draft of this application appeared in the PA Bulletin on Saturday, June 4, 2022. The final NPDES permit could not be issued at that time due to open violations.

A second draft of the NPDES permit is being issued because 6 months (or 180 days) have elapsed since the first draft has been issued.

There are still 13 open violations for this client and facility; however, new standard operating procedures allow for the issuance of the final permit.

Re-modeling was not performed. Limitations and monitoring frequencies have been carried over from the first draft.

The TRC average monthly effluent limitation has been removed because the facility utilizes Ultraviolet (UV) disinfection as the primary disinfection method. The IMAX TRC limitations from the first draft permit have been carried over. TRC shall still be sampled for in the event the facility uses chlorine for cleaning purposes or as a back-up disinfection option.

Chapter 94 Monitoring/ Reporting requirements have been added for this facility. This includes the addition of influent monitoring/reporting for TSS and BOD₅. A 2/month monitoring frequency has been applied to be consistent with the discharge sampling frequency. A "Sewage Sludge Management Inventory" and Municipal Wasteload Management Report will be required to be submitted annually. Please refer to Part C. II. C. of the draft NPDES permit.

The influent CBOD₅ monitoring/reporting has been maintained due to DRBC requirements.

One comment was received from the Clean Water Operations Section:

Approve	Return	Deny	Signatures	Date
X			/s/ Allison Seyfried Zukosky / Project Manager	July 30, 2025
X			/s/ Amy M. Bellanca, P.E. / Program Manager	7-30-25

Internal Review and Recommendations

Comment – “Part C.I.E.2 lists the NODI code to be used in the event that chlorine was used that month as “GGG”; I believe this should be “GG”.”

Response – The Part C.I.E.2 was updated to accurately state the eDMR NODI Code GG (Conditional Monitoring – Not Required) shall be used for eDMR reporting that chlorine has not been utilized during that time period.