

Application Type Renewal
 Wastewater Type Sewage
 Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0062944
 APS ID 953109
 Authorization ID 1514227

Applicant, Facility and Project Information

Applicant Name	<u>David Randich</u>	Facility Name	<u>618 Quaker Plain Road SRSTP</u>
Applicant Address	<u>618 Quaker Plain Road</u>	Facility Address	<u>618 Quaker Plain Road</u>
	<u>Bangor, PA 18013-5756</u>		<u>Bangor, PA 18013-5756</u>
Applicant Contact	<u>David Randich, Owner</u>	Facility Contact	<u>David Randich</u>
Applicant Phone	<u>(347) 891-1551</u>	Facility Phone	<u>(347) 891-1551</u>
Client ID	<u>317862</u>	Site ID	<u>449318</u>
SIC Code	<u>4952</u>	Municipality	<u>Upper Mount Bethel Township</u>
SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>	County	<u>Northampton</u>
Date Application Received	<u>June 6, 2023</u>	WQM Required	<u>-</u>
Date Application Accepted	<u>June 21, 2023</u>	WQM App. No.	<u>-</u>
Project Description	<u>Existing NPDES Permit Renewal for a Single-Residence Sewage Treatment Plant.</u>		

Summary of Review

The applicant is requesting the renewal of an NPDES permit for a single residence sewage treatment plant (SRSTP) to discharge up to 0.0008 MGD of treated sewage into an Unnamed Tributary to East Fork Martins Creek, a Cold-Water Fishes, Migratory Fish (CWF, MF) receiving stream in State Water Plan Basin 1-F (Jacoby – Bushkill Creeks). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use. This stream segment is not designated as a naturally reproducing trout stream as per PA Fish & Boat Commission. The stream is also not listed as being impaired. This discharge is not expected to affect public water supplies.

The BOD5 monitoring/reporting has been changed to CBOD5 monitoring/reporting to be consistent the updated Standard Operating Procedures for the Department.

The flow, pH, Total Residual Chlorine (TRC), Total Suspended Solids (TSS), and Fecal Coliform monitoring/reporting limitations have been carried over from the previous permit. The monitoring frequencies have also been maintained.

The note under the Part A effluent limitation table requiring at least one sample for Fecal Coliform to be taken between June 1 and August 31 each year has been added.

The Annual Maintenance Report (AMR) that's to be issued with the final permit shall be used to record the monitoring results. Per the Annual Maintenance Report (AMR) condition, the permittee must submit the AMR by June 30th of each year.

The existing permit expired on December 31, 2023, and the renewal application was received on time.

A Water Management System Inspection query indicated that on March 5, 2021 and April 17, 2023 an Administrative/File Review was performed.

Approve	Deny	Signatures	Date
X		/s/ Allison Seyfried Zukosky / Project Manager	March 5, 2025
X		/s/ Edward Dudick, P.E. / Engineer Manager	March 5, 2025

Summary of Review

There are currently no open violations for this client/facility.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

