

Application Type Renewal  
Facility Type Industrial  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
ADDENDUM**

Application No. PA0063142  
APS ID 521956  
Authorization ID 1313549

**Applicant and Facility Information**

Applicant Name	<u>Chrin Brothers, Inc.</u>	Facility Name	<u>Chrin Brothers Sanitary Landfill</u>
Applicant Address	<u>1225 Industrial Drive</u> <u>Easton, PA 18042</u>	Facility Address	<u>1225 Industrial Drive</u> <u>Easton, PA 18042</u>
Applicant Contact	<u>Joseph Klobusicky</u>	Facility Contact	<u>Joseph Klobusicky</u>
Applicant Phone	<u>(610) 258-8737</u>	Facility Phone	<u>(610) 258-8737</u>
Client ID	<u>42952</u>	Site ID	<u>238053</u>
SIC Code	<u>4953</u>	Municipality	<u>Williams Township</u>
SIC Description	<u>Trans. &amp; Utilities - Refuse Systems</u>	County	<u>Northampton</u>
Date Published in PA Bulletin	<u>October 8, 2022</u>	EPA Waived?	<u>Yes</u>
Comment Period End Date	<u>November 7, 2022</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of NPDES permit.</u>		

**Internal Review and Recommendations**

Public notification of draft permit issuance was published in the PA Bulletin on October 8, 2022. No comments were received during the 30-day comment period.

The permittee chose to resample for Total Lead at a lower QL to remove the Total Lead monitoring requirements and limitations from the final permit. The Total Lead analytical results submitted with the permit application were all non-detect, but DEP's TMS recommended new limitations for Total Lead (15 µg/L monthly average) since the QL used in the sampling analysis (20 µg/L) was higher than the governing WQBEL. The sample results submitted to DEP on May 23, 2023 were all non-detect at a laboratory QL of 1 µg/L (also DEP's target QL), therefore, the monitoring requirements and limitations for Total Lead are removed from the permit.

Semiannual monitoring/reporting requirements for Total Nitrogen and Total Phosphorus are added to the permit for stormwater Outfall 002 in accordance with requirements in Appendix C of the most recently issued PAG-03 general permit.

Another draft permit is being issued to reflect the changes to the permit described above.



TMS PA0063142.pdf

Approve	Return	Deny	Signatures	Date
X			<i>Brian Burden</i> Brian Burden, E.I.T. / Project Manager	August 2, 2023
X			Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Acting Environmental Engineering Manager	9-25-23