

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0063444
APS ID 575829
Authorization ID 1134206

Applicant and Facility Information

Applicant Name	<u>Butler Township Municipal Authority</u>	Facility Name	<u>Butler Township Municipal Authority WWTP</u>
Applicant Address	<u>572 Dutchtown Road</u> <u>Ashland, PA 17921</u>	Facility Address	<u>572 Dutchtown Road</u> <u>Ashland, PA 17921</u>
Applicant Contact	<u>Patrick Caulfield (SCMA)</u>	Facility Contact	<u>Stephen Ulceski</u>
Applicant Phone	<u>(570) 622-8240</u>	Facility Phone	<u>(570) 622-8240</u>
Client ID	<u>87646</u>	Site ID	<u>260097</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Butler Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Schuylkill</u>
Date Application Received	<u>October 4, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 4, 2021</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of existing NPDES sewage discharge permit.</u>		

Summary of Review

The applicant is requesting renewal of their NPDES permit to discharge 0.240 MGD of treated sewage to Mahanoy Creek, a WWF/MF designated receiving stream in state water plan basin 06-B (Mahanoy – Shamokin Creeks). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use.

As per the latest Chapter 94 report, BTMA contracted with SCMA for operation and maintenance of the WWTP and collection system beginning on January 1, 2018. SCMA is in the process of acquiring the WWTP/system and transferring the NPDES permit. The report states: "Once an agreement is reached on the amendment of the CO&A, SCMA will submit the Application for NPDES Permit Transfer to formally request the change of ownership by the Department. Also, SCMA is currently in the planning stages of the Gordon WWTP upgrade project. As part of the project, SCMA is evaluating the feasibility of decommissioning the Butler Township WWTP and conveying the Butler sewage to the upgraded Gordon facility, thereby combining the systems. A final determination will not be made until the Act 537 planning process is complete."

The receiving stream is part of the Mahanoy Creek Watershed TMDL, which was approved by the EPA on April 4, 2007. Stream impairments result from high levels of metals, and in some areas depressed pH. All impairments resulted from acid mine drainage from coal mining. The TMDL addresses the three primary metals (Iron, Manganese, and Aluminum) associated with acid mine drainage and depressed pH. There are no TMDL wasteload allocations (WLAs) assigned to this facility. Quarterly monitoring and reporting for Total Iron, Total Manganese, and Total Aluminum was added to the permit in the previous renewal to monitor these pollutants of concern. Modeling results over the previous permit term indicate the WWTP effluent is not a significant source of these metals and the monitoring frequency is updated to 1/year for this permit term. There are no industrial or commercial users in the sewer system.

As per the attached 1995 Pollution Report, previous modeling utilized a Q_{7-10} value obtained by using the low flow yield (LFY) at stream gage 01555250 (Mahanoy Creek @ Dornsife). $LFY = 22 \text{ cfs} / 117 \text{ mi}^2 = 0.18 \text{ cfs/mi}^2$. There is no longer flow data

Approve	Deny	Signatures	Date
X		<i>Brian Burden</i> Brian Burden, E.I.T. / Environmental Engineer	March 29, 2022
X		Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Environmental Engineer Manager	4-5-22

Summary of Review

available for that gage and no current data available for any other gages on Mahanoy Creek. The 0.18 cfs/mi² LFY is carried over from the previous renewals.

The pH, CBOD₅, TSS, Fecal Coliform and TRC limits are technology-based and carried over from the previous permit. Note that a technology-based pH IMAX of 9.0 S.U. is added to eDMR since the limitation was not included on eDMR during the previous permit term. The Dissolved Oxygen and Total Copper limits are water quality-based and carried over from the previous permit. The units for the Total Copper limitations are changed from µg/L to mg/L for this renewal to remain consistent with the units of the other monitored parameters. More stringent limitations were not recommended in WQM 7.0 modeling, the TRC Calculation Spreadsheet or Toxics Management Spreadsheet (all attached). The Toxics Management Spreadsheet recommended monitoring for Total Zinc since the 0.11 mg/L sample result provided with the renewal application is more than 10% of the 0.935 mg/L modeled WQBEL. Annual monitoring/reporting for Total Zinc is added to the permit.

Weekly monitoring and reporting for Ammonia-Nitrogen is carried over from the previous permit. Influent monitoring for BOD₅ and TSS is carried over from the previous permit. Monthly monitoring and reporting for Total Phosphorus and Total Nitrogen (Nitrate+Nitrite-N + TKN) is carried over from the previous permit and in accordance with DEP's Phase 3 Watershed Implementation Plan Wastewater Supplement (Revised, September 13, 2021). There are no Total Phosphorus or Total Nitrogen WLAs assigned to this non-significant Phase 4 Chesapeake Bay discharger.

As per DEP guidance, 1/quarter monitoring and reporting is added to the permit for E. Coli.

The 2021 Chapter 94 Report does not show current or projected hydraulic/organic overloads at the facility. Regarding biosolids treatment and disposal, the report indicates "Wastewater solids generated by the treatment process are pumped onto drying beds that are planted with reeds. These beds are designed to accumulate the solids, where they are then dewatered and further digested by the physical and microbiological activity associated with the reeds. In 2021, there was a total of 225,125 gallons applied to the sludge drying beds. In 2021, 209.87 tons were removed from beds #1 and #2 and properly disposed of at CES Landfill. SCMA did not accept sludge for processing at the Butler Township treatment plant during the year 2021."

DMR results over the previous 2 years shows one effluent limitation exceedance:

- April 2021: Fecal Coliform – 91,000 No./100mL IMAX (limitation was 10,000 No./100mL)

There are no open violations for this client that would warrant withholding the issuance of this permit. EPA waiver is in effect.

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.24</u>
Latitude	<u>40° 45' 46.8"</u>	Longitude	<u>-76° 20' 14.9"</u>
Quad Name	<u>Ashland</u>	Quad Code	<u>1235</u>
Wastewater Description: <u>Sewage Effluent</u>			

Receiving Waters	<u>Mahanoy Creek</u>	Stream Code	<u>17556</u>
NHD Com ID	<u>54962587</u>	RMI	<u>37.9</u>
Drainage Area	<u>43.5</u>	Yield (cfs/mi ²)	<u>0.18</u>
Q ₇₋₁₀ Flow (cfs)	<u>7.83</u>	Q ₇₋₁₀ Basis	<u>Gage 01555250</u>
Elevation (ft)	<u>807</u>	Slope (ft/ft)	<u>0.003</u>
Watershed No.	<u>6-B</u>	Chapter 93 Class.	<u>WWF/MF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>

Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Metals, Water/Flow Variability, pH</u>		
Source(s) of Impairment	<u>Abandoned Mine Drainage</u>		
TMDL Status	<u>Final</u>	Name	<u>Mahanoy Creek</u>

Background/Ambient Data		Data Source
pH (SU)	<u>-</u>	<u>-</u>
Temperature (°F)	<u>-</u>	<u>-</u>
Hardness (mg/L)	<u>-</u>	<u>-</u>
Other:	<u>-</u>	<u>-</u>

Nearest Downstream Public Water Supply Intake	<u>United Water Pennsylvania</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>2,360 (using default LFY of 0.1 cfs/mi²)</u>
PWS RMI	<u>61.6</u>	Distance from Outfall (mi)	<u>~75</u>

Treatment Facility Summary				
Treatment Facility Name: Butler Township Municipal Authority WWTP				
WQM Permit No.		Issuance Date		
5495405		5/2/1996		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Aeration	Sodium Hypochlorite	0.11 (2021)
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.24	480	Not Overloaded	Aerobic Digestion/ Reed Beds	Landfill

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 45' 46.8"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.24
Longitude -76° 20' 14.9"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25.0	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40.0	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
	50.0	IMAX	-	-
Total Suspended Solids	30.0	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45.0	Average Weekly	133.102(b)(2)	92a.47(a)(2)
	60.0	IMAX	-	-
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
	1.1	IMAX	-	-

Water Quality-Based Limitations

A “Reasonable Potential Analysis” (PENTOX attachment) determined the following parameters were candidates for limitations: Total Copper

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Dissolved Oxygen	5.0	Minimum	1995 Pollution Report
Total Copper	0.105 mg/L	Average Monthly	2016 PENTOX
	0.210 mg/L	IMAX	