

Application Type Renewal
Facility Type Sewage
Major / Minor Minor

2nd NPDES PERMIT FACT SHEET

Application No. PA0063690
APS ID 623209
Authorization ID 1210192

Applicant and Facility Information

Applicant Name	<u>Melroes Restaurant</u>	Facility Name	<u>Melroes Restaurant</u>
Applicant Address	<u>832 Salem Boulevard</u> <u>Berwick, PA 18603-6838</u>	Facility Address	<u>832 Salem Boulevard</u> <u>Berwick, PA 18603-6838</u>
Applicant Contact	<u>Melissa Evans mel1522@epix.net</u>	Facility Contact	<u>Melissa Evans</u>
Applicant Phone	<u>570-472-5859</u>	Facility Phone	<u></u>
Client ID	<u>94349</u>	Site ID	<u>463462</u>
SIC Code	<u>4952</u>	Municipality	<u>Salem Township</u>
SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>	County	<u>Luzerne</u>
Date Application Received	<u>December 1, 2017</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 13, 2017</u>	If No, Reason	<u></u>
Purpose of Application	<u>RENEWAL OF EXISTING NPDES PERMIT.</u>		

2nd Summary of Review

This second draft is prepared in order to grant the applicants request for the site to be monitored as a Single Flow Treatment Facility (SFTF) category 2 effluent requirements from a small flow treatment plant category 3. This is agreeable to PaDEP. Historic DMRs show a maximin daily rate of 1,200 GPD rather than the originally permitted 1997 discharge design rate of 0.003 MGD that was never utilized. That is well below the SFTF threshold.

It has the same effluent limits that were originally issued in 1997 and Standard today for an SFTF.

POLLUTION REPORT
(Effect of Discharges on Receiving Waters)

Specific Substance	BPT Secondary Treatment		Requirements to (1) Meet Water Quality Standards	
	Avg. (2)	Inst. Max. (3)	Avg. (2)	Inst. Max. (3)
1. CBOD ₅	25.0	50.0		
2. TSS	30.0	60.0	None	
3. pH	6.0-9.0 at all times		6.0 to 9.0 at all times	
4. TOTAL RESIDUAL CHLORINE	1.2	2.8		
5. Fecal coliform (5-1 to 9-30)			200/100 ml as a geo.avg.	
5. Fecal coliform (10-1 to 4-3)			2,000/100 ml as a geo.avg.	
7. Dissolved Oxygen				
8. Total phosphorous as P				

Approve	Return	Deny	Signatures	Date
X			Bernard Feist (signed) Bernard Feist, P.E. / Environmental Engineer	August 26, 2021
X			Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Environmental Engineer Manager	9-20-21

2nd Summary of Review

This proposed new 2nd draft Permit for an Individual SFTF template is available presently and offered for review. Currently the statewide general permit template is unavailable for an indeterminate future pending EPA approval.

The applicant's first draft was published in the Pa Bulletin on Saturday, October 19, 2019. No further comments were received.



First PA0063690
FACT_SHEET.pdf



First Draft
PA0063690 NPDES_P

The NMS query "Violations – eFACTS – Open Violations for Client" was run. There are currently no open violations.

The EPA Waiver is in effect.