

Application Type Renewal  
Facility Type Sewage  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
ADDENDUM**

Application No. PA0063851  
APS ID 827581  
Authorization ID 1314251

**Applicant and Facility Information**

Applicant Name	<u>Sweet Valley Mobile Home Village</u>	Facility Name	<u>Sweet Valley Mobile Home Village</u>
Applicant Address	<u>100 Swale Brook Lane</u> <u>Milford, PA 18337</u>	Facility Address	<u>First Lane Sweet Valley Mobile Home Village</u> <u>Hunlock Creek, PA 18621-2940</u>
Applicant Contact	<u>Lisa Dalavai</u>	Facility Contact	<u>Carl J. Yorina, WWTP Operator</u>
Applicant Phone	<u>(570) 362-8292</u>	Facility Phone	<u>(570) 362-8292</u>
Client ID	<u>52159</u>	Site ID	<u>1031</u>
SIC Code	<u>4952</u>	Municipality	<u>Ross Township</u>
SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>	County	<u>Luzerne</u>
Date Published in PA Bulletin	<u>January 22, 2022</u>	EPA Waived?	<u>Yes</u>
Comment Period End Date	<u>February 21, 2022</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Application for a renewal of an NPDES permit for discharge of treated sewage.</u>		

**Internal Review and Recommendations**

The first draft of this application appeared in the PA Bulletin on Saturday, January 22, 2022. The final NPDES permit could not be issued due to open violations.

A second draft of the NPDES permit is being issued because 6 months (or 180 days) have elapsed since the first draft has been issued.

Re-modeling was not performed. Limitations and monitoring frequencies have been carried over from the first draft.

All the permit documents have been updated to the newest format.

There are still 12 open violations for this client and facility:

1. 5/11/2020 - Violation ID 887009 – Violation Code 92A.75(A) – NPDES - Failure to submit NPDES renewal application at least 180 days prior to expiration or later approved date.
2. 5/11/2020 - Violation ID 887010 – Violation Code 92A.44 – NPDES - Violation of effluent limits in Part A of permit.
3. 5/11/2020 - Violation ID 887011 – Violation Code 92A.41(A)12B – NPDES - Failure to submit monitoring report(s) or properly complete monitoring reports.
4. 5/11/2020 - Violation ID 887012 – Violation Code 92A.41(A)5 – NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance.

Approve	Return	Deny	Signatures	Date
X			/s/ Allison Seyfried Zukosky / Project Manager	March 25, 2025
X			/s/ Edward Dudick, P.E. / Engineer Manager	March 26, 2025

**Internal Review and Recommendations**

5. 4/25/2022 - Violation ID 952571 – Violation Code 92A.75(A) – NPDES - Failure to submit NPDES renewal application at least 180 days prior to expiration or later approved date.
6. 4/25/2022 - Violation ID 952572 – Violation Code 92A.44 – NPDES - Violation of effluent limits in Part A of permit.
7. 4/25/2022 - Violation ID 952573 – Violation Code 92A.41(A)12B – NPDES - Failure to submit monitoring report(s) or properly complete monitoring reports.
8. 4/25/2022 - Violation ID 952574 – Violation Code 92A.41(A)5 – NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance.
9. 4/25/2022 - Violation ID 952575 – Violation Code 92A.41(A)10B – NPDES - Failure to utilize approved analytical methods.
10. 09/21/2022 - Violation ID 968963 – Violation Code 92A.75(A) – NPDES - Failure to submit NPDES renewal application at least 180 days prior to expiration or later approved date.
11. 09/21/2022 - Violation ID 968964 – Violation Code 92A.44 – NPDES - Violation of effluent limits in Part A of permit.
12. 09/21/2022 - Violation ID 968965 – Violation Code 92A.41(A)8 – NPDES - Violation of effluent limits in Part A of permit.