

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0065102
APS ID 821047
Authorization ID 1232675

Applicant, Facility and Project Information

| | | | |
|---------------------------|---|------------------|---|
| Applicant Name | <u>Sohail & Humaira Anjum</u> | Facility Name | <u>Anjum SRSTP</u> |
| Applicant Address | <u>369 Bossardsville Road</u> <u>Stroudsburg, PA 18360</u> | Facility Address | <u>369 Bossardsville Road</u> <u>Stroudsburg, PA 18360</u> |
| Applicant Contact | <u>Humaira & Sohail Anjum</u> | Facility Contact | <u>Humaira & Sohail Anjum</u> |
| Applicant Phone | <u>(973) 527-4694</u> | Facility Phone | <u>(973) 527-4694</u> |
| Client ID | <u>306790</u> | Site ID | <u>666405</u> |
| SIC Code | <u>8811</u> | Municipality | <u>Hamilton Township</u> |
| SIC Description | <u>Services - Private Households</u> | County | <u>Monroe</u> |
| Date Application Received | <u>June 6, 2018</u> | WQM Required | <u>Issued on 12/16/2013</u> |
| Date Application Accepted | <u>June 20, 2018</u> | WQM Permit No. | <u>4506402T-1</u> |
| Project Description | <u>Renewal of NPDES permit.</u> | | |

Summary of Review

The applicant is requesting renewal of their NPDES permit to discharge treated sewage from a single residence sewage treatment plant (SRSTP) to Tributary 4886 to Lake Creek, a HQ-CWF, MF designated receiving stream in state water plan basin 01-E (Brodhead Creek). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use.

Water quality modeling was not performed during this permit renewal as per DEP guidance for SRSTPs. CBOD₅ and TSS both have annual average limitations of 10.0 mg/L (20.0 mg/L IMAX) and are to be sampled at least once per year. As in the last permit renewal, Fecal Coliform has an annual average limitation of 200 No./100mL and an IMAX limitation of 1,000 No./100mL. The SRSTP utilizes ultraviolet radiation for disinfection. Part C.I.D. of the permit requires the permittee to notify DEP prior to initiating the use of chlorine at the SRSTP (for cleaning or other purposes) and to monitor TRC concentrations in the effluent on each day in which chlorine is used.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date |
|---------|------|--|-----------------|
| X | | <i>Brian Burden</i> Brian Burden, E.I.T. / Project Manager | August 17, 2022 |
| X | | Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Environmental Engineer Manager | 9-22-22 |

